	Power Sector – PEM Noida Technical Pre - Qualification Requirements (For Open/Global Tender) To be read in conjunction with PEM general PQR	Project: 1x500MW UNCHA HAR TPP (BTG) Package: MISC. TANKS-SITE FABRICATED DEPARTMENT: Mechanical Auxiliary Engineering
	Sheet 1 of 2	REV 00

Following technical details are required from bidder to comply technical PQR:

1. Fixed roof tanks with minimum 200 cum storage capacity.
2. Depending upon the maximum capacity of the storage tank being designed by the vendor, suitable technical limit will be applied at the time of registration/evaluation for the bids as below:

Sl no	Min Tank Capacity executed (Cum)	Technical limit on the vendor of maximum capacity of tank qualified (Cum)
1	200	1500
2	1500	5000





Supplier should have designing/manufacturing capability and having testing facility (in house or outsourced).

Tanks should have been successfully in use for at least one year as on Dt. **15.06.14** in power plant or other industries e.g. refinery/steel/process/commercial etc. For this the supplier has to submit either of following supporting documents meeting below mentioned conditions

- i. Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order specifying that the product is running successfully for one (1) year from date of commissioning.
OR
- ii. Minimum one second/repeat purchase order (placed with a minimum gap of one(1) year after commissioning of first order) from same purchaser meeting the minimum pre-qualifying requirement.
OR
- iii. Minimum three purchase orders (placed with minimum gap of one(1) year from previous purchase order) from same purchaser meeting the minimum pre-qualifying requirement

Note:

- 1) Vendor shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- 2) Minimum two (2) nos. Purchase orders shall be submitted which should not be more than ten (10) years old as on date of application for registration/bid submission, for establishing continuity in business.
- 3) Vendor may also qualify based on the credential of principal meeting package specific pre-qualifying requirements having technical valid collaboration/licensing agreement.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
PANKAJ KUMAR		18/7/14	HARISH KUMAR		18/7/14	PRAVEEN KISHORE		
NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE



Power Sector – PEM Noida

**Technical Pre - Qualification
Requirements**

(For Open/Global Tender)

**To be read in conjunction with PEM
general PQR**

Sheet 2 of 2

Project:

Package: MISC. TANKS-SITE FABRICATED




**DEPARTMENT: Mechanical Auxiliary
Engineering**

REV 00

- 4) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.

General:

- 1 PEM registered vendors without technical limit are not required to submit the credentials to meet the PQR in case of open/global tender, however credentials may be required to be submitted for customer approval.
- 2 PEM registered vendors with technical limit are required to check PQR in case of open/global tender and will submit the credentials, if project specific PQR is more stringent than technical limit of registration in PEM. In such case, the bidder will be evaluated based on credentials.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
PANKAJ KUMAR		18/07/14	HARISH KUMAR		18/07/14	PRAVEEN KISHORE		18/07/14
NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE