

Specification No.		9989/Rev-2		
Item No.		SP/MISC/9989/1 TO 8		
Location		BAY-8		
SCOPE :				
SUPPLY INSTALLATION & COMMISSIONING OF SPLIT TOWER / SPLIT WALL MOUNTED TYPE AIR CONDITIONER AS PER SPECIFICIFICATION				
NOTE :	1. VENDOR must submit complete information against clause No. 6.0 (Qualifying condition). The offer meeting would only be processed.			
	2. The " offered" Column and where applicable, the " Deviations" Column of this format shall be filled in by the VI submitted along with the offer. Technical details also submitted with the offer. Inadequate / incomplete, ambiguous unsustainable information against any of the clauses of the specification / requirements shall be treated as non -Compliance			
	3. The offer and all documents enclosed with offer should be in English language only.			
SUPPLY INSTALLATION & COMMISSIONING OF SPLIT TOWER & SPLIT WALL MOUNTED TYPE AIR CONDITIONER AS PER SPECIFICIFICATION				
S.NO.	DESCRIPTION FOR BHEL REQUIREMENT	SPECIFIED /TO BE CONFIRMED BY	OFFERED	DEVIATIONS
1	PURPOSE			
1.1	Split Wall mounted type 02 Ton and Split tower type 02 Ton capacity A/C is required for bay-8 winding	VENDER TO CONFIRM		
2	WORK PIECE MATERIAL			
2.1	supply, installation and commissioning of Split wall mounted type 2 TON capacity air conditioner (rating of A/C should be not less than 3 star) along with stabilizer and mounting bracket (for out door unit). Make - LLOYD/VOLTAS/SAMSUNG/LG /HITACHI/DAIKIN/BLUE STAR/CARRIER/ O'GENERAL/VIDEOCON/VESTAR/GODREJ/ ONIDA/WIRLPOOL/ELECTROLUX ONLY . Quantity - 06 Nos.	VENDER TO CONFIRM		
2.2	supply, installation and commissioning of splitTower type 02 TON capacity air conditioner along with stabilizer and mounting bracket (if req)). Make - LLOYD/VOLTAS/SAMSUNG/LG /HITACHI/DAIKIN/BLUE STAR/CARRIER/ O'GENERAL/VIDEOCON/VESTAR/GODREJ/ ONIDA/WIRLPOOL/ELECTROLUX ONLY . Quantity - 02 Nos.	VENDER TO CONFIRM		
3	TECHNICAL. DETAILS			
3.1	SPLIT WALL MOUNTED A/C- 02 TON			
3.1.1	Tonnage - 2 TR	VENDER TO CONFIRM		
3.1.2	Star rating (not less than 3 star)	VENDER TO SPECIFY & CONFIRM		
3.1.3	Capacity - BTU/Hr	VENDER TO SPECIFY		
3.1.4	Rated current -	VENDER TO SPECIFY		
3.1.5	Rated power -	VENDER TO SPECIFY		
3.1.6	Supply voltage - 230 Volt 50HZ	VENDER TO CONFIRM		
3.1.7	Noise level	VENDER TO SPECIFY		
3.1.8	Compressor type -	VENDER TO SPECIFY		
3.1.9	Make of offered air conditioner	VENDER TO SPECIFY		
3.1.10	Model of offered air conditioner	VENDER TO SPECIFY		
3.1.11	Dimension of Indoor & Outdoor unit in mm	VENDER TO SPECIFY		
3.1.12	Weight of unit (kg.)	VENDER TO SPECIFY		
3.1.13	Capacity of voltage stabilizer-5 KVA	VENDER TO CONFIRM		
3.1.14	Make of voltage stabilizer	VENDER TO SPECIFY		

