

**GSECL**

**1X800MW WANAKBORI TPS UNIT-8**

**VOLUME -IIB**

**TECHNICAL SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS**

**Specification No. : PE-TS-408-100-N001 (REV. 0)**



**BHARAT HEAVY ELECTRICALS LIMITED  
POWER SECTOR  
PROJECT ENGINEERING MANAGEMENT  
PPEI BUILDING, SECTOR 16 A  
NOIDA - 201301**



PREAMBLE

SPECIFICATION  
NO.:

PE-TS-408-100-N001

REV. NO. 0

DATE:

19.12.15

1.0 The tender document contains three (3) volumes. The bidder shall meet the requirements of all the three volumes.

#### 1.1 Volume I - CONDITIONS OF CONTRACT

This consists of four parts as below:

Volume - I A : This part contains instructions to bidders for making bids to BHEL.

Volume - I B : This part contains general commercial conditions of the tender and include provision that vendor shall be responsible for the quality of item supplied by their sub-vendors.

Volume - I C : This part contains special conditions of contract.

Volume - I D : This part contains commercial conditions for erection and commissioning site work, as applicable.

#### 1.2 Volume II - TECHNICAL SPECIFICATIONS

Technical requirements are stipulated in Volume II which comprises of:

Volume - II A : General Technical Conditions

Volume - II B : Technical specification including drawings, if any

##### 1.2.1 Volume - II B :

This volume is sub-divided into following sections:

Section - A : This section outlines the scope of enquiry.

Section - B : This section provides "Project Information"

Section - C : This section indicates technical requirements specific to the contract, not covered in Section-D.

Section - D : This section comprises of technical specifications of equipments complete with data sheet A, B & C.

Data sheet - A specifies data and other requirements pertaining to the equipment.

Data sheet - B specifies data to be filled by the bidder (Data Sheet B is contained in Volume - III)

Data sheet - C indicates data documents to be furnished after the award of contract as per agreed schedule by the vendor (as applicable).

##### 1.2.2 Volume - III TECHNICAL SCHEDULES

This volume contains technical schedules and Data Sheets - B, which are to be duly filled by the bidder and the same shall be furnished with the technical bid as per checklist, sec B7 in vol III.

2.0 The requirements mentioned in Section C/Data Sheets-A of Section-D shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section - D.



TECHNICAL SPECIFICATIONS

SPECIFICATION  
NO.:

PE-TS-408-100-N001

MISCELLANEOUS PUMPS

REV. NO.

0

DATE:

19.12.15

**INDEX****SECTION TITLE**

A SCOPE OF ENQUIRY

B PROJECT INFORMATION

C SPECIFIC TECHNICAL REQUIREMENTS FOR

C1 PUMPS

C2 MOTORS

D STANDARD TECHNICAL SPECIFICATIONS FOR

D1 PUMPS

- STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS- NO. PE-TS-179-06
- DATA SHEETS-A FOR ABOVE PROJECT ALONGWITH LIST OF MANDATORY SPARES & WATER ANALYSIS.
- DATA SHEET - C
- STANDARD QUALITY PLAN FOR PUMPS

D2 MOTORS

- STANDARD TECHNICAL SPECIFICATION FOR MOTORS
- DATA SHEET-A
- STANDARD QUALITY PLAN FOR MOTORS



TECHNICAL SPECIFICATIONS

SPECIFICATION  
NO.:

PE-TS-408-100-N001

MISCELLANEOUS PUMPS

VOLUME:

IIB

SECTION:

A

REV. NO.

0

DATE:

19.12.15

**SECTION A**  
**SCOPE OF ENQUIRY**



TECHNICAL SPECIFICATIONS  MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	SPECIFICATION NO.:	PE-TS-408-100-N001		
	VOLUME:	IIB	SECTION:	A
	REV. NO.	0	DATE:	19.12.15

## 1.0 SCOPE

- 1.1 This enquiry covers the design, manufacture, assembly, inspection and testing at manufacturer's and/or his sub-contractors works, proper packing for delivery and installation checks and replacement of gland packing with Mechanical Seal arrangement (if applicable) at site and PG Test at site for Miscellaneous Pumps along with mandatory spares complete with all accessories as per the requirements specified in this specification etc for following project:

### 1X800 MW WANAKBORI TPS UNIT-8

The above project is referred as '1X800 MW WANAKBORI TPS U-8' elsewhere in the Specification for ease of reference.

- 1.2 The miscellaneous pumps covered under this specification shall be Horizontal Pumps (Group-I).

#### NOTE:-

- a) **The bidder shall include complete supplies for the Project/Group as above in his scope as per NIT. Part supplies offered for the Project/Group shall disqualify the bidder's offer for that Project/Group.**


- 1.3 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning. Replacement of gland packing with Mechanical Seal (If applicable) as per Cl. No. 2.0 of Section C1 & Cl. No. 9.08.04 of section D of this volume. The charges for these shall be included by bidder in his offer.
- 1.4 The miscellaneous pumps and drives covered under this specification for various projects are as per Annexure I. HT drives, wherever applicable and irrespective of motor ratings, shall be issued free of cost by BHEL. The details of pumps with HT drives shall be as per Annexure II.

The Capacity, Head, Materials of construction, Mandatory spares and other particulars of these pumps, are detailed in Data Sheet-A annexed with Section-D of the specification.

- 1.5 For detailed scope of supply & services refer clause 3.00.00 of Standard technical Specification for Horizontal Centrifugal pumps specified under Section-D of this volume.
- 1.6 Electrical scope between BHEL and Vendor for Miscellaneous pumps and drives of this specification shall be as per annexure I of section C-2 of this volume.

## 2.0 GENERAL TECHNICAL INSTRUCTIONS

- 2.1 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.
- 2.2 The omission of specific reference to any component/accessory necessary for the proper performance of Miscellaneous Pumps and drives shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of equipment at quoted prices.
- 2.3 BHEL's / Customer's representative shall be given full access to the shop in which the equipments are being manufactured or tested and all test records shall be made available to him.
- 2.4 The equipments covered under this specification shall not be despatched unless the same have been finally inspected, accepted and shipping release issued by BHEL/Customer.

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001		
	MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	19.12.15

2.5 ***In case of any deviation from this technical specification (Vol.IIB) and General Technical Conditions (Vol.II A), the same shall be indicated in the schedule of deviations enclosed in Vol.III. In the absence of duly filled schedules it will be assumed that the bid strictly conforms to the specification.***

2.6 Unpriced copy of the price bid shall be furnished alongwith the technical bid.



TECHNICAL SPECIFICATIONS

SPECIFICATION  
NO.:

PE-TS-408-100-N001

MISCELLANEOUS PUMPS  
SCOPE OF ENQUIRY

VOLUME:

IIB

SECTION:

A

REV. NO.

0

DATE:

19.12.15

**Annexure I****List of Miscellaneous Pumps and drives for :****A. 1X800 MW WANAKBORI TPS U-8**

Sl. No.	Pump Description	Total Qty.	Type of Pumps
	<b>Horizontal Pumps (Group I)</b>		
1	DMCW TG AUX. PUMPS	3 nos.	Horizontal
2	DMCW SG AUX. PUMPS	2 nos.	Horizontal
3	EMERGENCY HOTWELL MAKE UP PUMPS	2 nos.	Horizontal
4	BOILER FILL PUMPS	2 nos.	Horizontal
5	CW MAKE UP PUMPS	3 nos.	Horizontal
6	SERVICE WATER BOOSTER PUMPS	2 nos.	Horizontal
7	POTABLE WATER PUMPS	2 nos.	Horizontal
8	HVAC PUMPS	2 nos.	Horizontal
9	CLARIFIED WATER TRANSFER PUMPS	2 nos.	Horizontal
10	AHP PUMPS	2 nos.	Horizontal
11	DM MAKE UP PUMPS	3 nos.	Horizontal
12	APH WASH/ ESP WATER WASH PUMPS	2 nos.	Horizontal



TECHNICAL SPECIFICATIONS

SPECIFICATION  
NO.:

PE-TS-408-100-N001

MISCELLANEOUS PUMPS  
SCOPE OF ENQUIRY

VOLUME:

IIB

SECTION:

A

REV. NO.

0

DATE:


19.12.15

**Annexure II**

**Following HT drives for 1X800 MW WANAKBORI TPS U-8, irrespective of Motor ratings shall be issue free, by BHEL:**


**Horizontal Pumps (Group I):**

- 1 DMCW TG AUX. PUMPS
- 2 DMCW SG AUX. PUMPS
- 3 BOILER FILL PUMPS
- 4 APH WASH/ ESP WATER WASH PUMPS

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	B
		REV. NO.	0	DATE:	19.12.15

**SECTION B**  
**PROJECT INFORMATION**

## PROJECT SYNOPSIS AND GENERAL INFORMATION



---

DEVELOPMENT CONSULTANTS  
(K9213R-EPC-SPC-001-Vol-IIA-Sec-1&2)

028



VOLUME : IIA

SECTION-II

PROJECT SYNOPSIS AND GENERAL INFORMATION

1.00.00 INTRODUCTION

The proposed 1x800 MW Supercritical Thermal Power Project would be set up by Gujarat State Electricity Corporation Limited (GSECL) at Kheda district of Gujarat.

The Bidder shall acquaint himself by a visit to the site, if felt necessary, with the conditions prevailing at site before submission of the bid. The information given here in under is for general guidance and shall not be contractually binding on the Owner. All relevant site data /information as may be necessary shall have to be obtained /collected by the Bidder.

2.00.00 APPROACH TO SITE

The proposed site is located in Kheda district about 13 kilometers from the nearest commercial town of Balasinor & 10 kilometers from Sevalia town. The National Highway, NH-08, connecting Dakor – Godhra is about 10 kilometers from the site. The State Highway SH – 59 connecting Balasinor – Sevalia is about 2 Kilometers from the site. Nearest railway station to the existing site is Sevalia, located about 8 kilometers from the site on Anand – Godhara main broad gauge line of Western Railway.



Nearby Air Ports are Ahmedabad at a distance of about 110 kilometers from the site and Vadodara at a distance of about 85 kilometers from the site.

3.00.00 LAND

The proposed extension unit will be developed in the existing Wanakbori Thermal Power Station and will be located north east side of the existing plot in the Kheda District of Gujarat. The land of the proposed plant will be filled in upto a desired level. Existing Ash Pond/ Dyke area will be utilized for the extension unit.

4.00.00 SOURCE OF COAL

Indian coal would be sourced from captive mines Machha Kata in Talcher, State – Orissa which are situated about 1800 Kms from the project site. GSECL will arrange for transportation of the coal required for the extension unit from these captive mines by the existing railway facilities for delivery of coal supply to the Wanakbori power station.




## CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	INTRODUCTION
2.00.00	APPROACH TO SITE
3.00.00	LAND
4.00.00	SOURCE OF COAL
5.00.00	SOURCE OF WATER
6.00.00	ASH DISPOSAL AREA
7.00.00	SALIENT DESIGN DATA



DEVELOPMENT CONSULTANTS  
(K9213R-EPC-SPC-001-Vol-IIA-Sec-1&2)

030



5.00.00 SOURCE OF WATER

The water required for the new unit shall be obtained from River Mahi, flowing by the side of the existing Wanakbori Power Station.

One (1) new jackwell will be installed on Mahi river for supply of water for new plant. In addition, existing Canal Water and Jackwell Water will have interconnection with new plant to cater plant water requirement of new plant.

6.00.00 ASH DISPOSAL AREA



Existing Ash Pond / Dyke area will be utilized for the extension unit. Fly ash silos will be located outside plant boundary wall (but within GSECL land) in the vicinity of the Ash Dyke area.


7.00.00 SALIENT DESIGN DATA

7.01.00 Meteorological data of site is given below:-

Elevation above MSL	:	72 M
Max. daily average temp	:	34 °C
Min. daily average temp	:	11.7 °C
Max. Ambient air temp. (daily)	:	34°C
Max. Ambient air temp. (yearly)	:	30°C
Max. Ambient air temp.	:	42°C
Wet bulb temperature	:	28°C
Relative Humidity	:	RH varies within a range from 50% to 95%.
Average annual rainfall	:	750 mm

[Metrological data of Vadodara is attached for reference].




	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C
		REV. NO.	0	DATE:	19.12.15

## SECTION C

### SPECIFIC TECHNICAL REQUIREMENTS

**C1: SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS**

**C2: SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS**

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C1
		REV. NO.	0	DATE:	19.12.15

## SECTION C1

### SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS

**TECHNICAL SPECIFICATIONS**SPECIFICATION  
NO.:

PE-TS-408-100-N001

**MISCELLANEOUS PUMPS**

VOLUME:

IIB

SECTION:

C1

REV. NO.

0

DATE:

19.12.15

**1.0 SPECIFIC TECHNICAL REQUIREMENTS:****DELIVERY:**

Delivery of miscellaneous pumps shall be as per NIT requirement.

**2.0 Horizontal Pumps:**

- 2.1** Horizontal Pumps with Mechanical seal shall be supplied with gland packing arrangement to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be despatched alongwith main supply for this purpose. Shaft sleeve and any other item required for satisfactory operation of Mechanical seal after replacement at site shall be provided by the pump supplier without any cost implication to BHEL.

**3.0 Additional Dispatch Requirements:**

MDCC after final inspection shall be provided to vendor on the basis of following:-

- 3.1** List of items packed in each box with description & quantity.
- 3.2** Photograph of each box in open & closed condition.
- 3.3** Bidder to include handling instructions in engineering drg/doc and packing to be done in such a way to avoid damage of items in transit and long storage at site and same shall be approved in ontract stage by BHEL/Customer
- 4.0** Inspection and Testing requirements in addition to those specified in section-D of this volume are Annexed as Annexure-A.

# ANNEXURE-A

6.00.00      **INSPECTION AND TESTING**

6.01.00      The Contractor shall carry out the following specific tests and inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.

a)      **Identification and Testing**

i) All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standards and test certificates shall be made available to the Owner.

ii) Tests for each pump included under this section shall include but not be limited to the following :

- The entire surface of the impeller castings shall be subjected to Dye Penetration Test as per ASTM Specification no.: E165-65.
- Shaft shall be subjected to Dye Penetration and Ultrasonic Tests.
- Wearing rings shall be subjected to Dye Penetration Test.
- Verification of material, witnessing of pouring, casting and inspection of finalized fabricated/cast castings.
- Inspection of finished castings for impeller and verification of materials.
- Inspection of pump shaft and verification of material.
- Witnessing of NDT/review of NDT reports.
- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940.
- Complete Inspection of assembled pump.

b)      **Hydrostatic Testing**

The pump casing shall be hydrostatically tested at 150% of the shut-off pressure. Pressure shall be maintained for a period of not less than one (1) hour. While arriving at the above values maximum suction pressure shall be taken into account.


c)      **Performance Test at Shop**

i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard but the tolerances on head discharge and power shall be as specified in HIS, USA.

ii) Performance tests are to be conducted to cover the entire range of operation of the pumps. These shall be carried out to span 130%

of rated capacity up to pump shut-off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexures. After completion of performance test, all pumps shall be stripped down for inspection of internals.

- iii) Tests shall be conducted with actual drive motors being furnished.
- iv) NPSH tests are to be conducted on one pump of each type at 3% head drop conditions, if specified in the pump Annexures.
- v) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.
- vi) Tests shall be conducted at the rated RPM.
- vii) Prior to performance test, the pump supplier shall furnish the procedure and methods of testing to the purchaser for approval.

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: C2
		REV. NO.	0	DATE: 19.12.15

## SECTION C2

### SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS



**ELECTRICAL EQUIPMENT SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS  
1X800MW WANAKBORI STPP**

SPECIFICATION NO.

VOLUME NO. : **II-B**

SECTION : **C**

REV NO. : **00** DATE : 27.10.15

SHEET : 1 OF 1

**1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:**

- a) Services and equipment as per “Electrical Scope between BHEL and Vendor”.
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Erection and Commissioning spares.
- e) Erection & Maintenance tools & tackles.
- f) Electrical load requirement for Miscellaneous Pumps.
- g) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- h) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer /BHEL approval without any commercial and delivery implications to BHEL
- i) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL.

**2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:**

Refer “Electrical Scope between BHEL and Vendor”.

**3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID**

3.1 Bidder shall confirm total compliance to the electrical specification without any deviation from the technical/quality assurance requirements stipulated. In line with this two signed and stamped copies of the following shall be furnished by the bidder as technical offer:

- a) A copy of this sheet “Electrical equipment Specification for Miscellaneous Pumps” and sheet “Electrical Scope between BHEL and Vendor” with bidder’s signature and company stamp.
- b) List of Erection and Commissioning spares.
- c) List of Erection & Maintenance tools & tackles.
- d) Electrical load requirement

3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

## STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS)

PACKAGE: MISCELLANEOUS PUMP

PROJECT: 1X800MW WANAKBORI STPP

<u>S.NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&amp;C</u>	<u>REMARKS</u>
1.	415 V MCC	BHEL	BHEL	415 V AC (3 PHASE 3 WIRE) supply shall be provided by BHEL based on load data provided by vendor at contract stage for all equipment supplied by vendor as part of contract. Any other voltage level (AC/DC) required will be derived by the vendor.
2.	Local Push Button Station ( for motors)	BHEL	BHEL	Located near the motors.
3.	Power cables, control cables and screened control cables	BHEL	BHEL	Incoming cable from BHEL supplied MCC will be informed by BHEL. Screened control cable between DCS & field equipment will also be informed by BHEL. Vendor shall provide lugs & glands accordingly.
4.	Cable trays, accessories & cable trays supporting system	BHEL	BHEL	
5.	Cable glands and lugs for equipments supplied by Vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power and control cables.
6.	Conduit and conduit accessories for cabling between equipments supplied by vendor	BHEL	BHEL	
7.	Equipment grounding & lightning protection	BHEL	BHEL	
8.	Below grade grounding	BHEL	BHEL	
9.	LT Motors with base plate and foundation hardware	Vendor	BHEL	Makes shall be subject to BHEL approval at contract stage.
10.	Mandatory spares	Vendor	-	Vendor to quote as per specification.
11.	Recommended O & M spares	Vendor	-	As per specification
12.	Any other equipment/material/service required for completeness of system but not specified above (to ensure trouble free and efficient operation of the system).	Vendor	BHEL	
13.	Electrical equipment GA drawing	Vendor	-	For necessary interface review.

STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS)

PACKAGE: MISCELLANEOUS PUMP

NOTES:

1. Make of all electrical equipments/items supplied shall be reputed make & shall be subject to approval of BHEL after award of contract.
2. All QPs shall be subject to approval of BHEL after award of contract without any commercial implication.

**VOLUME : IIF/1**

**SECTION-II**

**TECHNICAL SPECIFICATION  
FOR  
A.C. & D.C. MOTORS**

## CONTENT

<b>CLAUSE NO.</b>	<b>DESCRIPTION</b>
1.00.00	SCOPE
2.00.00	STANDARDS
3.00.00	SERVICE CONDITIONS
4.00.00	TYPE AND RATING
5.00.00	PERFORMANCE
6.00.00	SPECIFIC REQUIREMENTS
7.00.00	ACCESSORIES
8.00.00	TESTS
9.00.00	DRAWINGS, DATA & MANUALS

### ATTACHMENT

ANNEXURE-A	DESIGN DATA
------------	-------------

**VOLUME : IIF/1**

**SECTION-II**

**TECHNICAL SPECIFICATION  
FOR  
A.C. & D.C. MOTORS**

**1.00.00 SCOPE**

- 1.01.00 This section covers the general requirements of the drive motors for power station auxiliary equipment.
- 1.02.00 Motors shall be furnished in accordance with both this general specification and the accompanying driven equipment specification.
- 1.03.00 In case of any discrepancy, the driven equipment specification shall govern.

**2.00.00 STANDARDS**

- 2.01.00 All motors shall conform to the latest applicable IS, IEC and CBIP Standards/Publications except when otherwise stated herein or in the driven equipment specification.
- 2.02.00 Major standards, which shall be followed, are listed below other applicable Indian Standards for any component part even if not covered in the listed standards shall also be followed :
- IS-325
- IS-12615
- IEC-34

**3.00.00 SERVICE CONDITIONS**

- 3.01.00 The motors will be installed in hot, humid and tropical atmosphere, highly polluted at places with coal dust and/or fly ash.
- 3.02.00 Unless otherwise noted, electrical equipment/system design shall be based on the service conditions and auxiliary power supply given in the annexure to this specification.
- 3.03.00 For motor installed outdoor and exposed to direct sunrays, the effect of solar heat shall be considered in the determination of the design ambient temperature.

**4.00.00 TYPE AND RATING**

**4.01.00 A.C. Motors**

4.01.01 Motors shall be general purpose, constant speed, squirrel cage, three/single phase, induction type.

4.01.02 All motors shall be rated for continuous duty. They shall also be suitable for long period of inactivity.

4.01.03 The motor name-plate rating at 50°C shall have at least 10% margin over the input power requirement of the driven HT equipment and 15% for LT driven equipment at rated duty point unless stated otherwise in driven equipment specification or in general electrical specification.

4.01.04 The motor characteristics shall match the requirements of the driven equipment so that adequate starting, accelerating, pull up, break down and full load torques are available for the intended service.

4.01.05 All HT & LT motors shall be energy efficient type as per IS. However for HT motors, if the same is not specified in IS, minimum efficiency of all HT motors shall be considered as 90%.

**4.02.00 D.C. Motors**

4.02.01 D.C. motor provided for emergency service shall be shunt/compound wound type. All DC motors shall be energy efficient type with minimum efficiency of 80%.

4.02.02 Motor shall be sized for operation with fixed resistance starter for maximum reliability.

Starter panel complete with all accessories shall be included in the scope of supply.

**5.00.00 PERFORMANCE**

**5.01.00 Running Requirements**

5.01.01 Motor shall run continuously at rated output over the entire range of voltage and frequency variations as given in the annexure

5.01.02 The motor shall be capable of operating satisfactorily at full load for 5 minutes without injurious heating with 75% rated voltage at motor terminals.

5.01.03 The motor shall be designed to withstand momentary overload of 60% of full load torque for 15 second without any damage.

**5.02.00 Starting Requirements**

Motor shall be designed for direct online starting at full voltage. Starting current shall not exceed 6 times full load current for all HT motors except boiler feed pump motor where the starting current shall be limited to 4.5 times. No further tolerances are applicable on starting current specified above

for HT motors. For LT motors, the applicable starting current shall be limited to 7.2 times of full load current including all tolerance.

- 5.02.01 The motor shall be capable of withstanding the stresses imposed if started at 110% rated voltage.
- 5.02.02 Motor shall start with rated load and accelerate to full speed with 80% rated voltage at motor terminal except BFP motor. In case of BFP motor, it shall be 80% rated voltage. Minimum starting requirement for mill motor (double cage) shall be 80% rated voltage at motor terminals. However for mill motors if the minimum starting voltage is more than 80% rated voltage at motor terminal and within 90% rated voltage, bidder shall provide necessary arrangement to keep the motor terminal voltage above that voltage to achieve smooth start of the motor.
- 5.02.03
- a) Motor shall be capable of three equally spread starts per hour, two starts in quick succession from cold condition and one restart from hot condition.
  - b) Cranking motor shall be capable of six equally spread starts per hour, three starts in quick succession from cold condition and one restart from hot condition. The coal conveyor and crusher motors shall be suitable for 3 consecutive hot starts with maximum 20 starts per day.
  - c) Pump motor subject to reverse rotation shall be designed to withstand the stresses encountered when starting with shaft rotating at 125% rated speed in reverse direction.
- 5.02.04 HT pump motors shall be suitable to start with forward rotation.
- 5.02.05 The motors shall be designed to withstand 120% of rated speed for 2 minutes without any mechanical damage
- 5.03.00 **Stress During Bus Transfer**
- 5.03.01 The motor may be subjected to sudden application of 150% rated voltage during bus transfer, due to the phase difference between the incoming voltage and motor residual voltage.
- 5.03.02 The motor shall be designed to withstand any torsional and/or high current stresses, which may result, without experiencing any deterioration in the normal life and performance characteristics.
- 5.04.00 **Locked Rotor Withstand Time**
- 5.04.01 The locked rotor withstand time under hot condition at 110% rated voltage shall be more than motor starting time by at least 2.5 seconds for motors up to 20 seconds starting time and by 5 seconds for motor with more than 20 seconds starting time.
- 5.04.02 Starting time mentioned above is at minimum permissible voltage of 80% rated voltage.
- 5.04.03 Hot thermal withstand curve shall have a margin of at least 10% over the full load current of the motor to permit relay setting utilising motor rated capacity.

6.00.00      **SPECIFIC REQUIREMENTS**

6.01.00      **Enclosure**

6.01.01      All motor enclosures for outdoor, semi-outdoor & indoor application shall conform to the degree of protection IP-55 unless otherwise specified. Motor for outdoor or semi-outdoor service shall be of weather-proof construction with canopy.

6.01.02      Motors for circulating water pumps of large output ratings, located indoor and not directly exposed to coal dust or fly ash, could have screen protected drip proof enclosure conforming to IP-23.

6.01.03      For hazardous area approved type of increased safety enclosure shall be furnished.

6.02.00      **Cooling**

6.02.01      The motor shall be self ventilated type, either totally enclosed fan cooled (TEFC) or closed air circuit air- cooled (CACW) or totally enclosed tube ventilated (TETV) type. Totally enclosed tube ventilated (TETV) type motors shall be acceptable for HT motors only.

6.02.02      For large capacity motors, closed air circuit water cooled (CACW) may be considered for acceptance.

6.03.00      **Winding and Insulation**

6.03.01      All insulated winding shall be of copper.

6.03.02      All motors shall have class F insulation but limited to class B temperature rise.

6.03.03      Windings shall be impregnated to make them non-hygroscopic and oil resistant.

6.04.00      **Tropical Protection**

6.04.01      All motors shall have fungus protection involving special treatment of insulation and metal against fungus, insects and corrosion.

6.04.02      All fittings and hardware shall be corrosion resistant.

6.05.00      **Bearings**

6.05.01      Motor shall be provided with antifriction bearings, unless sleeve bearings are required by the motor application.

6.05.02      Vertical shaft motors shall be provided with thrust and guide bearings. Thrust bearing of tilting pad type is preferred.

6.05.03      Bearings shall be provided with seals to prevent leakage of lubricant or entrance of foreign matters like dirt, water etc. into the bearing area.

6.05.04      Sleeve bearings shall be split type, ring oiled, with permanently aligned, close running shaft sleeves.

- 6.05.05 Grease lubricated bearings shall be prelubricated and shall have provisions for in-service positive lubrication with drains to guard against over lubrication.
- 6.05.06 Oiled bearing shall have an integral self cooled oil reservoir with oil ring inspection ports, oil sight glass with oil level marked for standstill and running conditions and oil fill and drain plugs.
- 6.05.07 Forced lubricated or water cooled bearing shall not be used without prior approval of Owner.
- 6.05.08 Lubricant shall not deteriorate under all service conditions. The lubricant shall be limited to normally available types with IOC equivalent.
- 6.05.09 Bearings shall be insulated as required to prevent shaft current and resultant bearing damage.
- 6.06.00 **Noise & Vibration**
- 6.06.01 The noise level shall not exceed 85db (A) at 1.5 metres from the motor at no load condition.
- 6.06.02 The peak amplitude of the vibration shall be within IS/IEC specified limits.
- 6.07.00 **Motor Terminal Box**
- 6.07.01 HT Motor terminal box (Phase side) shall be Phase Segregated (PSTB) type and LT motor terminal box shall be non-phase segregated type. Both HT & LT motor terminal box shall be located in accordance with Indian Standards clearing the motor base- plate/ foundation.
- 6.07.02 Terminal box shall be capable of being turned 360 Deg. in steps of 180 Deg. for HT motors and 90 Deg. for LT motors unless otherwise approved.
- 6.07.03 The terminal box shall be split type with removable cover with access to connections and shall have the same degree of protection as motor.
- 6.07.04 The terminal box shall have sufficient space inside for termination/connection of XLPE insulated armoured aluminium cables.
- 6.07.05 Motor main terminal box shall be located right hand side of motor body looking from driving end.
- 6.07.06 Terminals shall be stud or lead wire type, substantially constructed and thoroughly insulated from the frame.
- 6.07.07 The terminals shall be clearly identified by phase markings, with corresponding direction of rotation marked on the non-driving end of the motor.
- 6.07.08 The terminal box shall be capable of withstanding maximum system fault current for a duration of 0.25 sec.
- 6.07.09 HT motor phase side terminal box shall be phase-segregated type and HT motor neutral leads shall be brought out in a separate terminal box preferably

opposite side of phase terminal box & may not be necessarily phase segregated type with shorting links for star connection.

6.07.10 Motor terminal box shall be furnished with suitable cable lugs and nickel plated double compression brass glands to match with cable used.

6.07.11 The gland plate for single core cable shall be non-magnetic type.

6.08.00 **Grounding**

6.08.01 The frame of each motor shall be provided with two separate and distinct grounding pads complete with tapped hole, GI bolts and washer.

6.08.02 The grounding connection shall be suitable for accommodation of ground conductors as follows :

HT Motor (11kV, 6.6kV & 3.3 kV ) : 75 X 10 mm GS Flat

LT Motor above 90 KW : 50 x 6 mm GS Flat

Motor above 30 KW up to 90 KW : 35 x 6 mm GS Flat

Motor above 5 KW up to 30 KW : 25 x 3 mm GS Flat

Motor up to 5 KW : 8 SWG GI Wire

6.08.03 The cable terminal box shall have a separate grounding pad.

6.09.00 **Rating Plate**

In addition to the minimum information required by IS, the following information shall be shown on motor rating plate :

- a) Temperature rise in Deg.C under rated condition and method of measurement.
- b) Degree of protection.
- c) Bearing identification no. and recommended lubricant.
- d) Location of insulated bearings.

7.00.00 **ACCESSORIES**

7.01.00 **General**

Accessories shall be furnished, as listed below, or if otherwise required by driven equipment specification or application.

7.02.00 **Space Heater**

7.02.01 Motor of rating 30 KW and above shall be provided with space heaters, suitably located for easy removal or replacement.

- 7.02.02 The space heater shall be rated 240 V, 1 phase 50 Hz and sized to maintain the motor internal temperature above dew point when the motor is idle.
- 7.03.00 **Temperature Detectors**
- 7.03.01 All 11000V, 6600V and 3300V motors shall be provided with twelve (12) nos. simplex type winding temperature detectors, four (4) nos. per phase. Six (6) nos. duplex type winding temperature detectors, two (2) nos. per phase shall only be acceptable for special application motors only subject to approval of owner.
- 7.03.02 11000V, 6600V and 3300V motor bearing shall be provided with duplex type temperature detectors.
- 7.03.03 The temperature detector mentioned above shall be resistance type, 3 wire, platinum wound, 100 Ohms at 0°C.
- 7.03.04 Leads of all simplex type motor winding RTDS and motor bearing RTDS shall be wired up to respective switchgear metering & protection compartment. From which one set of RTDS will be connected to numerical protection relay and another set shall be kept free for DCS connectivity.
- 7.03.05 Five numbers of Temperature detectors / thermisters shall be provided for L.T. motors above 90 KW (3 nos. winding temperatures & 2 nos. bearing temperatures)
- 7.04.00 **Indicator/Switch**
- 7.04.01 Dial type local indicator with alarm contacts shall be provided for the following:
- a) 11000 V, 6600V and 3300V motor bearing temperature.
  - b) Hot and cold air temperature of the closed air circuit for CACA and CACW motor.
- 7.04.02 Flow switches shall be provided for monitoring cooling water flow of CACW motor and oil flow of forced lubrication bearing, if used.
- 7.04.03 Alarm switch contact rating shall be minimum 0.5 A at 220V D.C. and 5A at 240V A.C.
- 7.05.00 **Current Transformer for Differential Protection**
- 7.05.01 Motor 1000 KW and above shall be provided with three differential current transformers mounted over the neutral leads within the enclosure. Loose 3 nos. CT for mounting on switchgear side shall be in bidder's scope.
- 7.05.02 The arrangement shall be such as to permit easy access for C.T. testing and replacement. Current transformer characteristics shall match Owner's requirements to be intimated later.
- 7.06.00 **Accessory Terminal Box**

7.06.01 All accessory equipment such as space heater, temperature detector, current transformers etc., shall be wired to and terminated in terminal boxes, separate from and independent of motor (power) terminal box.

7.06.02 Accessory terminal box shall be complete with double compression brass glands and pressure type terminals to suit cable connections.

7.07.00 **Drain Plug**

Motor shall have drain plugs so located that they will drain the water, resulting from the condensation or other causes from all pockets of the motor casing.

7.08.00 **Lifting Provisions**

Motor weighing 25 Kg. or more shall be provided with eyebolt or other adequate provision of lifting.

7.09.00 **Dowel Pins**

The motor shall be designed to permit easy access for drilling holes through motor feet or mounting flange for installation of dowel pins after assembling the motor and driven equipment.

7.10.00 **Painting**

Motor including fan shall be painted with corrosion proof paints of colour battle ship grey shade 632 of IS-5.

8.00.00 **TESTS**

Routine and Type Tests are to be conducted in presence of customer's representative as per IS:325 and required copies of test certificates are to be furnished for approval. In addition, following tests shall have to be carried out on the motors in presence of OWNER's representative on 3.3kV/6.6kV/11kV motors.

- a. Impulse test by 1.2 / 50 micro sec. On sample coil of Stator winding insulation as type test as per IEC-60034, part -15 test voltages as under :

Voltage rating of motor	Impulse Test Voltage
3.3 kV	18 kV peak
6.6 kV	31 kV peak
11 kV	49 kV peak

- b. Tan delta, charging current and dielectric loss measurements on each phase of motor stator winding as routine test.
- c. Polarization Index Test as per IS:7816 as routine test
- d. Test for suitability of IPW– 55 (Weather proof) as per IS 4691 as type test. Type test certificate for first numeral shall be acceptable in lieu of test, provided the test motor is identical to motor being supplied.

Second numeral test shall be carried out on one motor of each type and rating.

- e. Fault Withstand Test for main terminal box as type test. Type test certificate shall be acceptable, if the test is conducted on exactly identical terminal box.
- f. Test for noise level as routine test.
- g. Test for vibration as routine test.
- h. Tan delta measurement on coils.
- i. Surge withstand test for inter turn insulation.

Tests indicated at (h), (i), shall be carried out during manufacture of the coils and shall be furnished for verification.

Furnished type test certificates of motor shall not be older than five (5) years from the date of Inspection, otherwise type test shall be conducted without any price implication.

**9.00.00 DRAWINGS, DATA & MANUALS**

Drawings, data & manuals for the motors shall be submitted as indicated below:

**9.01.00 Along with the bid**

- a) List of the motors
- b) Individual motor data sheet as per format of the proposal data sheets.
- c) Scheme & write up on forced lubrication system, if any
- d) Type test report

**9.02.00 After Award of the Contract**

- a) Dimensional General Arrangement drawing
- b) Foundation Plan & Loading
- c) Cable end box details
- d) Space requirement for rotor removal
- e) Thermal withstand curves hot & cold
- f) Starting and speed torque characteristics at 80% & 100% voltage
- g) Complete motor data
- h) Erection & Maintenance Manual

- i) Test reports
- j) Data sheets to be enclosed

**ANNEXURE-A  
DESIGN DATA**

1.0 AUXILIARY POWER SUPPLY

Supply	Description	Consumer
H.T. Supply	11000 V, 3Ø, 3W, 50 Hz, non-effectively earthed	Motors above 2000 KW & all mill motors
	Fault level 44 KA symm.	
	3300 V, 3Ø, 3W, 50 Hz, non-effectively earthed	Motors above 160 KW upto and including 2000 KW
	6600 V, 3Ø, 3W, 50 Hz, non-effectively earthed	Motors of CHP system and Water System above 160kW
	Fault level 40 KA symm for 3300V & 6600V	
L.T. Supply	415V, 3Ø, 3W, 50 Hz effectively earthed	Motors upto and including 160KW
	Fault level 50 KA symm.	
	240V, 1Ø, 2W, 50 Hz effectively earthed	Lighting, space hea- ting, A.C. control & protective devices
D.C. Supply	220V, 2W, unearthed	D.C. alarm, control & protective devices
	Fault level 25* KA.	

\* Indicative only, the actual value will be decided by the Bidder, after substantiating the same by calculation.

2.0 RANGE OF VARIATION

A.C. Supply :

Voltage : ± 10% Frequency : ± 5% Combined Volt : 10% (absolute sum)  
+ frequency

During starting of large motor, the voltage may drop to 80% of the rated voltage for a period of 60 seconds. All electrical equipment while running shall successfully ride over such period without affecting system performance.

D.C. Supply :

Voltage : 187 to 242 Volt

**ANNEXURE-B**  
**MODULE SELECTION**

**MOTOR FEEDER**

Type	Motor Rating	MCCB Rating	Contactora	Cable size
AU/AR	0 - 5.5 KW	32A	16A	3/c – 2.5 Sq.mm - Cu
BU/BR	5.6 - 11 KW	63A	32A	3/c - 16 Sq.mm - Al
CU	11.1 - 22 KW	63A	63A	3/c - 35 Sq.mm - Al
DU	22.1 - 50 KW	100A	100A	3/c - 95 Sq.mm - Al
EU	50.1 - 75 KW	200A	160A	3/c - 185 Sq.mm - Al
FU	75.1 - 110 KW	400A	300A	2 x 3/c - 185 Sq.mm - Al


**NOTE :**

1. MCCB with short circuit release, thermal overload relay with SPP feature, Contractor are to be co-ordinate (Type-2) with motor rating by the Contractor.
2. “U” stands for Undirectional and “R” for Reversible drives.

**OUTGOING FEEDER**

Type	MCCB Rating	Cable Size
AF	32A	4/c – 16 Sq.mm - Cu
BF	63A	4/c – 35 Sq.mm - Al
CF	100A	3.1/2 – 95 Sq.mm - Al
DF	200A	3.1/2 – 300 Sq.mm - Al
EF	400A	4 x 1/c – 630 Sq.mm - Al

Note: Cable sizes as indicated above are indicative. However EPC contractor shall submit the sizing calculation of cable and select the cable accordingly.


	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D
		REV. NO.	0	DATE:	19.12.15

## SECTION D

### STANDARD TECHNICAL SPECIFICATIONS

**D1: STANDARD TECHNICAL SPECIFICATIONS FOR PUMPS**

**D2: STANDARD TECHNICAL SPECIFICATIONS FOR MOTORS**

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-408-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D1
		REV. NO.	0	DATE:	19.12.15


## SECTION D1


**STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS NO. PE TS-179-06**


**DATA SHEET A ALONGWITH LIST OF MANDATORY SPARES &  
WATER ANALYSIS**


**DATA SHEET C**

**QUALITY PLAN**

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 1 of 14	
<b>1.00.00</b>	<b>GENERAL INFORMATION</b>		
1.01.00	The general guidelines as illustrated in the subsequent clauses of this section shall be applicable for horizontal centrifugal pumps to be procured under the scope of this package.		
<b>2.00.00</b>	<b>CODES AND STANDARDS</b>		
2.01.00	In addition to the requirements spelt out elsewhere in the specification, the equipment to be provided under this section shall specifically conform to the following codes, standards, specifications and regulations, as applicable, including all the latest amendments subsequent to the year of publication as mentioned below.		
2.01.01	IS-1520/1980:	Horizontal Centrifugal pumps for clear, cold and fresh water.	
2.01.02	IS-5120/1977:	Technical requirements for Rotodynamic special Purpose pumps.	
2.01.03	IS-5639/1970:	Pumps for handling chemicals & corrosive liquids.	
2.01.04	IS-5659/1970:	Pumps for process water.	
2.01.05	IS-6536/1972:	Pumps for handling volatile liquids.	
2.01.06	IS-9137/1978:	Code for acceptance tests for centrifugal, mixed flow and axial flow pumps- Class 'C'.	
2.01.07	ISO 3555/1977: BS 5316/1977 Part 2	Acceptance test for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.	
2.01.08	ISO 2548/1973: BS 5316/1976 Part 1	- Do - Class 'C' tests.	
2.01.09	API-610/1989:	Centrifugal pumps for general refinery services.	
2.01.10	HIS	Hydraulic Institute Standards, USA	
2.01.11	PTC 8.2/1965:	Power Test Codes - Centrifugal pumps.	
2.01.12	ASTM-1-165-55	Standard Methods for Liquid Penetration Inspection.	
2.02.00	In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding on the bidder.		

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 2 of 14	
<b>3.00.00</b>	<b>SCOPE OF SUPPLY &amp; SERVICES:</b>		
3.01.00	The miscellaneous pumps and drives scope shall be as specified in Data Sheet A /Section A.		
3.02.00	The Capacity, Head, Materials of construction and other particulars of pumps are detailed in Data Sheet A of the specification.		
3.03.00	Accessories:		
	All the pumps under this specification shall be complete with following standard/special accessories.		
3.03.01	Standard accessories:		
	a)	LT Electric drives/motors (as applicable) with cable gland and lugs at motor end. (The bare HT drive motors and LT motors not in bidder's scope of supply, wherever required supplied as free issue by BHEL refer CI. 5.08.00).	
	b)	Pump motor coupling along with coupling guard.	
	c)	Common base plate for pumps and motor.	
	d)	Self contained lubrication system along with all internal piping, valves, fittings, specialties etc. as required.	
	e)	Counter flanges for suction/ discharge nozzles along with fixing nuts, bolts and gaskets.	
	f)	Anchor bolts, nuts, seating steel works, shims etc. as necessary for mounting the pump-motor unit on Civil foundations.	
	g)	Suitable vent (with valves)/ lifting/ handling attachments for the pump/ motor/ accessories.	
	h)	Suitable drain connections with isolating valves as applicable.	
	i)	Supply of first fill of lubricants with topping requirements for one year of operation after commissioning and handing over of equipment.	
	j)	Set of "Special" Tools & Tackles for Pumps and motors, if any.	
	k)	Erection and commissioning spares, "on as required" basis.	
	l)	Bidder shall provide various drawings, data, calculations, test reports/ certificates, operation and maintenance manuals, As-built drawings, etc. as specified and as necessary.	

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 3 of 14
<p>m) Mandatory spares as specified in respective Data Sheet-A of this section.</p> <p>3.04.00 Services included in Bidder's Scope:</p> <p>3.04.01 The pumps shall be guaranteed to meet the performance requirements specified vide Data Sheet -A and also for trouble free operation after commissioning. Schedule of performance guarantees (enclosed in Volume-III) duly filled and signed shall be furnished with the bid.</p> <p>3.04.02 Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose.</p> <p>3.04.03 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning.</p> <p>3.04.04 After commissioning of pumps at site, site performance test for Noise, vibration and parallel running of pumps of all pumps for each unit/project will be conducted by BHEL at project site to ensure that the pumps meet the specified requirements. In case of any deficiency, the vendor shall rectify the same at site at no additional cost to BHEL.</p> <p>3.04.05 Performance Guarantees for pumps shall stand valid till the satisfactory completion of performance testing by BHEL and its acceptance by purchaser / customer.</p> <p>3.05.00 Works excluded from Bidder's Scope:</p> <p>a) All HT motors and those LT Motors which are specifically excluded.</p> <p>b) Civil foundation</p> <p>c) Suction/ discharge pipe works</p> <p>d) MCC/ Switchgear/Power supply</p> <p>e) Power and Control Cables, unless specifically specified in Electrical/ Systems portion of the specification.</p> <p>f) Erection of equipments.</p> <p><b>4.00.00 BID EVALUATION CRITERIA &amp; LIQUIDATED DAMAGES FOR SHORTFALL:</b></p> <p>4.01.00 The bids received shall be evaluated for power consumption at inlet to the motors, in respect of pumps specified in Data Sheet-A (working pump only viz. not the standby), for the purpose of price comparisons as briefed below:</p> <p>The bid evaluation shall be done at the rate as specified in Data Sheet A per one (1) KW Power consumption, per working pump as follows.</p> $\text{KW} = \frac{Q \times H \times S}{P \times M \times 367.2}$		

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 4 of 14	

Where Q = Rated capacity M<sup>3</sup>/hr  
H = Rated TDH, MWC  
P = Pump Efficiency  
M = Motor Efficiency.  
S = Specific Gravity of fluid handled

4.02.00 The efficiencies for pumps and motors for arriving at benchmark power for Bid Evaluation shall be as indicated in Data Sheet A for various pumps.

No advantage shall be given to the bidder for Aux. Power quoted lower than the Bench mark values calculated with KW calculation formula at Cl. 4.01.00 above, *considering the bid evaluation efficiencies for pump and motor as indicated in Data Sheet-A.* However the bids shall be evaluated as above if the Aux. Power quoted are higher than Bench mark values.

NOTE:  
1. Efficiencies for HT motors and LT motors not in bidder's scope, for bid evaluation purpose shall be taken based on the maximum value as furnished in Data Sheet A.  
2. During contract stage the Guaranteed power consumption of Pumps with BHEL supplied drives (HT/LT) for successful bidder shall be reworked by BHEL as below:

Revised guarantee power consumption shall be as per KW calculation formula at Cl. 4.01.00 above, *where P = pump efficiency guaranteed by bidder and M = motor efficiency as per approved datasheet of the supplied HT/LT motor.*

4.03.00 Liquidated damages for shortfall in Guaranteed KW

The above guaranteed power consumption shall be demonstrated by the successful bidder during performance testing at works/ site.


For pumps with BHEL supplied drives, the power consumption shall be compared with the reworked guarantee power consumption, defined as per note no. 2 of Cl. 4.02.00 above for the purpose of shortfall.


The liquated damages @ twice the bid evaluation rate as above per KW per working pump shall be levied in the event of failure of bidder to demonstrate the guaranteed power consumption.


**5.00.00 TECHNICAL REQUIREMENTS:**


5.01.00 The pumps shall meet the technical requirements of section "D" as well as Data Sheet - A. Wherever there is contradiction between Section D and Data Sheet-A, the latter shall prevail. In the event of any contradiction of section "D" with Section-C, the Section-C will prevail.


5.02.00 The pumps shall be Electric motor driven.


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 5 of 14	
5.03.00	The Pumps shall conform to HIS. It is bare minimum requirement, however, any other equivalent or stringent standard is also acceptable, if, all the requirements of HIS are also met.		
5.04.00	The horizontal pumps shall be Horizontal split casing type with speeds not exceeding 1500 RPM or as indicated in Data Sheet-A.		
5.05.00	No negative tolerance shall be permitted in rated capacity & TDH.		
5.06.00	No negative tolerance shall be permitted in efficiency at rated capacity.		
5.07.00	<p>The shut off head of pumps shall be more than pump rated TDH and percentage variation may vary depending on the specific speed of the pump as under:</p> <ol style="list-style-type: none"> <li>10-15% for pumps of specific speed up to 1000 US units,</li> <li>15-20% for pumps of specific speed in the range of 1000 to 2000 US units,</li> <li>20-40% for pumps of specific speed in the range of 2000 to 4000 US units,</li> <li>Above 50% for pumps of specific speed in the range of 4000 to 7000 US units.</li> </ol>		
5.08.00	<p>All HT motors and those LT motors which are not in bidder's scope of supply : bare motors only, shall be supplied as free issue by BHEL through BHEL, based on ratings and TS (Torque - Speed) curve selected and furnished by the bidders along with their un-priced bid. The responsibility for satisfactory operation for combined performance of pumps &amp; motors shall rest with the bidder only as if, the drive motors also have been supplied by the bidder.</p> <p>Couplings, base plate, foundation bolts, any other fittings, etc. as required shall be supplied by the bidders only. BHEL shall supply one number of each type of drive motors (where drive motor is not in bidder's scope of supply) for shop testing of pumps with job motors. All other motors shall be dispatched by BHEL directly to project sites.</p>		
5.09.00	<p>For all HT motor driven pumps, BHEL has envisaged vibration-monitoring system in their own scope. The bidder shall make provisions for mounting following on the pump/ pump shaft:</p> <ul style="list-style-type: none"> <li>Purchaser's probes in both DE/NDE bearings of pumps</li> <li>Key slots on pump shaft with dimensions as specified in Data Sheet A.</li> <li>Other components as finalized during detailing.</li> <li>For mounting of above on the HT motors, same shall be taken care by BHEL - Bhopal.</li> </ul>		
5.10.00	The pumps shall be capable of developing the required total head at rated capacity for continuous operation. The pumps shall operate satisfactorily at any point on the Q-H characteristic curve over a range of 0% to 130% capacity and shall be suitable for continuous operation between 30% to 130% capacity.		


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 6 of 14	
5.11.00	Selection of the pumps shall be such that the design point shall be met even with negative manufacturing tolerance.		
5.12.00	The total head capacity curve shall be continuously rising towards the shut off, the pumps shall preferably be non-overloading type and stable.		
5.13.00	<p>The pumps shall be capable of running over the entire range of NPSH conditions required without any noise, vibration or cavitations.</p> <p>The prevailing suction pressures for various pumps are indicated in Data Sheet-A for suitable mechanical design of pumps.</p>		
5.14.00	The pumps shall be of stiff shaft design. The minimum internal clearances should be sufficiently more than the max. static deflection of the shaft. Shaft size selected must take into consideration the critical speed as specified in API-610.		
5.15.00	<p>Pumps and motors shall run smooth without undue noise and vibration.</p> <p>The vibration shall be within vibration norms for testing as per American National Standard for 'Rotodynamics Pump' for Vibration Measurement and allowable values, Doc. ANSI/ HIS 9.6.4-2009. The applicable vibration limits for each pump, shall be indicated in the Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO.</p> <p>The noise level shall be limited to 85 dB at distance of 1.0M.</p>		
5.16.00	Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.		
5.17.00	After installation, the guaranteed values of noise, vibration and parallel operation of pumps shall be tested and verified. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.		
5.18.00	High reliability of the pumps is an essential requirement and therefore it gets weightage over its efficiency. It is therefore essential that the bidder choose a standard proven model from the range of pumps manufactured.		
5.19.00	The offered pumps shall be of proven design meeting the experience-qualifying requirement of their operation at two sites for a minimum period of two years. Any deviation to this criterion shall be suitably highlighted in the deviations schedule.		
5.20.00	The bearings shall be self-water lubricated, no external water supply shall be available. The cooling/ lubrication water for bearings, etc. shall be tapped from the pump discharge and supplied thru' bidder's integral pipe work.		


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 7 of 14
<p>If water handled by pump is dirty/ not suitable for lubrication/ cooling, the bidder shall provide requisite strainer/ filters, tanks, motorized valves, etc. after the tap off for the required service, the arrangement provided shall be subject to Purchaser's approval.</p>		
<b>6.00.00</b>	<b>MANDATORY SPARES:</b>	
6.01.00	Bidder to provide the Mandatory spares listed vide Data Sheet-A. Unit price of mandatory spares shall be furnished in price Schedule.	
6.02.00	Bidder shall include the cost of Mandatory Spares in the base price of the pump, unless specified otherwise in Sec-C of the specification or NIT.	
<b>7.00.00</b>	<b>OTHER REQUIREMENTS:</b>	
7.01.00	The quality of water handled by various pumps shall be as per Data Sheet-A.	
7.02.00	The materials of construction for various components specified are the minimum requirements and materials of construction for other components not specified shall be similarly selected by the bidder for the intended duty.	
7.03.00	The makes of various bought out items of bidder (i.e. motor, bearings, mechanical seal etc.) shall be subject to purchaser's approval in the event of order.	
7.04.00	Painting for Pumps	
	a) The surface of SS, Gun metal, brass, bronze and non-metallic component shall not be applied with any painting.	
	b) The Steel surface to be applied with painting shall be thoroughly cleaned before applying painting by brushing, shop blasting etc. as per the agreed procedure.	
	c) For all the steel surfaces inside the (indoor installation) building, a coat of red oxide primes of min. thickness DFT of 50 microns followed up with under coat of Synthetic Enamel paint of min. thickness DFT of 50 microns shall be applied. The top coat shall consist of two coats each of min. thickness DFT of 50 microns of synthetic enamel paint and thus total DFT shall be min. 200 microns.	
	d) For all the steel surfaces exposed to (outdoor installation) atmosphere, a coat of chlorinated rubber based zinc phosphate primer of min. thickness DFT of 50 microns followed up with under coat of chlorinated rubber paint of min. thickness DFT of 50 microns shall be applied. Then, intermediate coat consisting of one coat of chlorinated rubber based paint pigmented with Titanium di-oxide with min. thickness DFT of 50 microns and top coat shall consist of two coats each of min. thickness DFT of 50	


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 8 of 14
	microns of chlorinated rubber paint shall be provided. Total DFT of paint system shall be min. 200 microns.	
<b>7.05.00</b>	<b>It is mandatory for the bidder to submit along with the bid, the deviations if any – whether major or minor in the schedule of deviations only. In the absence of deviations listed in the “Schedule of deviations, the offer shall be deemed to be full conformity with the specification, “notwithstanding” anything else stated elsewhere in bidder’s offer. The implied/indirect deviations shall not be binding on the purchaser.</b>	
<b>8.00.00</b>	<b>PERFORMANCE REQUIREMENTS</b>	
8.01.00	Performance requirements for the pumps shall be as guided in Data sheet - A enclosed with this section.	
8.02.00	Pump(s) shall preferably be designed to have the best efficiency at flow within $\pm 10\%$ of the specified duty point flow. The pumps shall be suitable for continuous operation at any point within the “Range of Operation” as stipulated in the Data Sheet - A attached with this section.	
8.03.00	Pump(s) shall preferably have a continuously rising head-capacity characteristics from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation.  Under all circumstances, the ‘range of operation’ of the pumps shall exclude any unstable operating zone of the head-capacity curve.	
8.04.00	Wherever specified in the Data Sheet - A attached to this section, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.	
8.05.00	The pump set along with drive motor shall run smooth without undue noise and vibration. Acceptable vibration limits shall be guided by the HIS of USA. Refer clause 5.15.00 above for permissible limits.	
<b>9.00.00</b>	<b>DESIGN AND CONSTRUCTION</b>	
<b>9.01.00</b>	<b>Pump Casing</b>	
9.01.01	Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves. It shall be provided with a connection for suction and discharge pressure gauge as standard feature.	
9.01.02	Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.	


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 9 of 14
9.01.03	In case where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.	
9.02.00	<b>Impeller</b>	
9.02.01	The Impeller assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.	
9.03.00	<b>Wearing Rings</b>	
9.03.01	Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.	
9.04.00	<b>Shaft</b>	
9.04.01	Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall be at least 30% higher than the rated speed.	
9.05.00	<b>Shaft Sleeves</b>	
9.05.01	Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past Shaft and shaft sleeve and that past the seals/glands.	
9.05.02	Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft sleeve assembly should ensure concentric rotation.	
9.06.00	<b>Bearings</b>	
9.06.01	Bearings shall be easily accessible without disturbing the pump assembly. A drain shall be provided at the bottom of each bearing housing.	
9.06.02	Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.	
9.06.03	In case of sleeve type radial, axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.	
9.06.04	Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation. Life of the bearings shall be guided by the design standard of the pump. Antifriction bearings of standard type, if provided, shall be selected for a minimum	

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 10 of 14
	life 20,000 hrs. of continuous operation at maximum axial and radial loads at rated speed. Thrust bearing shall be capable of running continuously at maximum load.	
9.06.05	The bearing shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete with all accessories like pump, filters, piping, fittings, valves, interlocking and supervising instruments etc. as necessary. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.	
9.06.06	Bearings of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.	
9.07.00	<b>Stuffing Boxes</b>	
9.07.01	Stuffing box design shall permit replacement of packing without removing any part other than the gland.	
9.07.02	Stuffing boxes shall be sealed/cooled by the fluid being pumped/external clear water, as specified in the Annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the Annexure shall be included in the scope of supply.	
9.08.00	<b>Mechanical Seals</b>	
9.08.01	Mechanical seals (cartridge type) shall be provided if specified in the Data Sheet-A of this section. The pump supplier shall co-ordinate with the seal maker in establishing the direct circulation rate for maintaining a stable film at the seal in the chamber. The seal piping system shall form an integral part of the pump assembly.	
9.08.02	When handling liquids near boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.	
9.08.03	For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.	
9.08.04	Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. The special tools (if any) required for above shall be arranged by bidder.	
9.08.05	Mechanical seals of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.	
9.09.00	<b>Drive Unit</b>	

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 11 of 14
9.09.01	The pumps shall be driven by electric motor directly coupled as specified in the Data Sheet-A of this section. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit.	
9.09.02	Unless otherwise specified in Data Sheet-A of this section, drive unit power rating shall be the maximum of the following requirements.	
	a) 15% margin over the pump shaft input power at the rated duty point.	
	b) 5% margin over the maximum pump shaft input power required within the 'Range of Operation'.	
	c) Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.	
9.10.00	<b>Coupling for pump &amp; Motor Shaft</b>	
9.10.01	The pump and motor shafts shall be connected with adequately sized flexible coupling of proven design with spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guard shall be provided.	
9.10.02	No. of coupling holes for joining coupling hubs shall be even in number and preferably in multiples of four.	
10.00.00	<b>INSPECTION AND TESTING</b>	
10.01.00	The Quality Plans enclosed in the specification are for bidder's guidance only. The bidder shall comply with these and other minimum requirements specified in the specification and shall furnish his own quality plan in the event of order based on the guidance given as above, for approval by BHEL/Customer.	
10.02.00	The Bidder shall carry out the following specific tests inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.	
	a) <b>Identification and Testing</b>	
	i) All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standard and test certificates shall be made available to the Owner.	
	ii) 100% PMI (Process Material Identification) inspection for material grade of pump casing, shaft and impeller shall be done by vendor & certification shall be submitted for review of BHEL. Further BHEL reserves the right to conduct	

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 12 of 14	
<p>random &amp; independent PMI inspection on pump casing, shaft and impeller to ascertain the grade of material during inspection at vendor works.</p> <p>iii) Tests for each pump included under this section shall include but not be limited to the following:</p> <ul style="list-style-type: none"> <li>- The entire surface of the impeller / casing / diffuser castings shall be subjected to Dye Penetration Test as per ASTM Specification no.:1-165-65.</li> <li>- Shaft coupling &amp; other active components shall be subjected to Dye Penetration and Ultrasonic Tests.</li> <li>- Wearing rings, shaft sleeves shall be subjected to Dye Penetration Test.</li> <li>- Fabricated components of pumps shall be subjected to Dye Penetration test on weld.</li> <li>- Verification of material, witnessing of pouring, casting and inspection of finished fabricated/castings.</li> <li>- Inspection of finished castings for impeller and verification of materials.</li> <li>- Inspection of pump shaft and verification of material.</li> <li>- Witnessing of NDT/review of NDT reports.</li> <li>- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940 to grade 6.3 or better.</li> <li>- Complete Inspection of assembled pump.</li> </ul> <p>b) <b>Hydraulic Testing</b></p> <p>The pump casing shall be hydrostatically tested at maximum of the following:</p> <ol style="list-style-type: none"> <li>i. 2 times the TDH (Total Dynamic Head) at rated capacity (or)</li> <li>ii. 1.5 times the shut-off pressure (or)</li> <li>iii. System Design pressure indicated in Data Sheet-A of this section.</li> </ol> <p>The HT pressure shall be maintained for a period of not less than 30 minutes. During testing there should not be any pressure drop &amp; leakage.</p> <p>c) <b>Performance Test at Shop</b></p> <p>i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute</p>			

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B
		<b>SECTION:</b> D
		<b>REV. NO.</b> 03 <b>DATE:</b> 16.07.2012
		<b>SHEET</b> 13 of 14
	<p>of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard.</p> <p>ii) Performance tests are to be conducted to cover the entire range of operation of the pumps at rated speed. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals.</p> <p>iii) Tests shall be conducted with actual drive motors being furnished.</p> <p>iv) NPSH tests are to be conducted for each type at 3% head drop conditions, if specified in the pump approved QP.</p> <p>v) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.</p> <p>10.03.00 Inspection of Mandatory/ Recommended spares shall be in line with approved QP for main supply.</p> <p><b>11.00.00 DRAWINGS/ DOCUMENTS DISTRIBUTION SCHEDULE</b></p> <p>11.01.00 After award of LOI, the successful bidder shall submit drawings/documents as per Data Sheet-C.</p> <p>11.02.00 The no. of drawings/documents to be submitted shall be as per Annexure to Data Sheet-C.</p> <p>12.00.00 The various Sections-C's &amp; D's along with Data Sheets attached in this specification together with the specification for Miscellaneous Pumps shall be complied with by the bidders.</p> <p>13.00.00 Bidder to submit all drawing/ documents in soft as well as hard copy within 2 weeks from placement of LOI's in the event of order.</p> <p>Within one (1) week of receipt of BHEL comments a technical representative from Bidder's works shall come for meeting with BHEL along with revised documents to resolve all issues and incorporate all comments in the soft copy here only for further submission to customer.</p> <p>Further on receipt of customer's comments on the documents a technical representative from Bidder's works shall come for meeting with Customer to resolve all issues and incorporate all comments in the soft copy here only and further resubmission of same to</p>	

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 14 of 14	
<p>Customer. The representative shall be available here till Category-I approval of all the drawings and documents.</p> <p>14.00.00 Guarantee for all pumps shall at least remain valid for 18 months from the Unit commissioning date or as specified in NIT.</p> <p><b>15.00.00 The following documents only shall be furnished by the bidder with his offer:</b></p> <p>a) Compliance certificate duly signed and stamped (enclosed at Vol. III of specn.).</p> <p>b) GA drawings of pumps and motors with following: (shall be only for reference purpose, same shall not be reviewed/commented by purchaser at this stage and shall be subject to approval only during contract).</p> <ul style="list-style-type: none"> <li>• Civil static &amp; dynamic loads.</li> <li>• Foundation details.</li> </ul> <p>c) Guarantee Schedule duly signed and stamped (enclosed at Vol. III of specn.).</p> <p>d) Technical deviation schedule (if reqd.) (enclosed at Vol. III of specn.).</p> <p>e) Data for drive Motor (HT/LT- which is not in bidder's scope of supply - as applicable): Load torque speed curves of the pumps, selected motor rating, rpm, <math>GD^2</math> of driven equipment.</p> <p><b>Apart from above no other Drgs./Docs./Data sheets etc. are required to be submitted at bid stage and even if furnished shall not be taken cognizance of.</b></p>			



TECHNICAL SPECIFICATIONS  MISCELLANEOUS PUMPS DATA SHEET - C	SPECIFICATION NO.:	PE-TS-408-100-N001		
	VOLUME:	IIB	SECTION:	D1
	REV. NO.	0	DATE:	19.12.15

**Drawings / documents distribution schedule to be followed by successful bidder :**

- 1.0 Drawings/documents submission schedule, shall be as per NIT. The successful bidder shall submit following drawings/ documents.
- 1.1 Fully dimensioned outline general arrangement drawings of the pump and motor assembly. This drawing should include foundation base plate/sole plate details as applicable, civil foundation, anchor bolt details, loading data (Static and Dynamic), points of connections of external piping, cables and mounting of devices furnished by the supplier and details for Gap between Coupling Shafts, Float & details for axial/radial tolerance allowed etc which are required for erecting agency during erection of pump.
- 1.2 Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction with standard applicable codes.
- 1.3 Characteristic curves of pump showing the following:
  - a) Flow Vs Head
  - b) Flow VS Power
  - c) Flow Vs Efficiency
  - d) Flow Vs NPSHR/Min. Submergence
- 1.4 Operation and maintenance manual
- 1.5 Lubrication arrangement drawings for external lubrication (if applicable).
- 2.0 Within the stipulated time period as per vendor's drawings/ documents schedule as per NIT, the O&M Manual comprising of minimum following shall be submitted
  - a) Drawings of components & details as deemed necessary.
  - b) Instruction manual for erection, operation & maintenance.
  - c) Storage instruction.
- 3.0 Before despatch of the equipment the bidder shall furnish the following.
  - a) Material test certificates.
  - b) Shop test reports & certificates.
  - c) Fulfilment of packing instructions as indicated in section C1 of this specification.
- 4.0 Distribution of drawings / documents for all projects:

The no. of drawing/ documents to be submitted by the successful bidder, after the award of the contract shall be intimated after award of contract.

DATA SHEET - A													SPECIFICATION NO.:	PE-TS-408-100-N001
MISCELLANEOUS PUMPS (HORIZONTAL) - GROUP-I													REV. NO.:	00
1X800MW WANAKBORI TPS UNIT-8													DATE:	21/12/2015
Sl. No.	DESCRIPTION	DMCW TG AUX'S PUMPS	DMCW SG AUX'S PUMPS	EMERGENCY HOTWELL MAKE-UP PUMPS	BOILER FILL PUMPS	CW MAKEUP PUMPS	SERVICE WATE BOOSTER PUMPS	POTABLE WATER PUMPS	HVAC PUMPS	CLARIFIED WATER TRANSFER PUMPS	AHP PUMPS	DM MAKEUP PUMPS	APH WASH/ESP WATER WASH PUMPS	
HORIZONTAL PUMPS (GROUP-I)														
1.0	<b>SERVICE</b>													
1.1	Total no. of pumps for Project	3	2	2	2	3	2	2	2	2	2	3	2	
1.2	No. of working & standby pumps	(2W+1S)	(1W+1S)	(1W+1S)	(1W+1S)	(2W+1S)	(1W+1S)	(1W+1S)	(1W+1S)	(1W+1S)	(1W+1S)	(2W+1S)	(1W+1S)	
1.3	Liquid Handled (ref. water analysis enclosed herein)	pH corrected DM Water	pH corrected DM Water	DM Water	DM Water	RAW / Clarified Water	RAW Water	Clarified Water	Clarified Water	Clarified Water	Clarified Water	DM Water	RAW / Clarified Water	
1.4	Location (Indoor / Outdoor)	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	
1.5	Duty	Continuous	Continuous	Intermittent	Intermittent	Continuous	Intermittent	Intermittent	Continuous	Continuous	Continuous	Intermittent	Intermittent	
1.6	No. of pumps working in parallel	2	-	-	-	2	-	-	-	-	-	-	-	
1.7	Specific gravity	1	1	1	1	1	1	1	1	1	1	1	1	
1.8	System design pressure (kg/sqcm), g	10	12	10	25	10	10	10	10	10	10	10	10	
2.0	<b>DESIGN PARAMETERS</b>													
2.1	Design capacity each, M <sup>3</sup> /hr	1065	910	140	200	950	20	20	50	150	80	25	465	
2.2	Total dynamic head (MWC)	38	58	50	170	10	47	65	72	20	44	50	80	
2.3	Suction Pressure(MWC)	35	35	Flooded suction	Flooded suction	Flooded suction	Flooded suction	Flooded suction	Flooded suction	Flooded suction	Flooded suction	Flooded suction	Flooded suction	
2.4	Design Temperature (°C)	60	60	60	60	60	60	60	60	60	60	60	60	
2.5	Maximum permissible speed of pump (RPM)	1500	1500	1500	1500	1500	3000	3000	1500	1500	1500	3000	1500	
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 51.5 Hz	Not to exceed 55 MWC	Not to exceed 76 MWC	Not to exceed 90 MWC	Not to exceed 225 MWC	Not to exceed 90 MWC	Not to exceed 90 MWC	Not to exceed 90 MWC	Not to exceed 90 MWC	Not to exceed 80 MWC	Not to exceed 90 MWC	Not to exceed 90 MWC	Not to exceed 95 MWC	
2.7	Operating range	-----30-130% of design duty point flow-----												
2.8	Motor rating	<p>Motor rating shall be the maximum of the following requirements:</p> <p>a) 15% (for LT motor) or 10% (for HT motor) margin over the pump shaft input power at the rated duty point.</p> <p>b) 5% margin over the maximum pump shaft input power required within the "Range of Operation".</p> <p>c) Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.</p>												
2.9	Permissible tolerance in rated capacity & TDH	-----No negative tolerance-----												
2.10	Permissible tolerance in efficiency at rated capacity(%)	-----No negative tolerance-----												
2.11	Performance/Design Standard	-----HIS / IS-5120 / Equivalent Standard.-----												
3.0	<b>CONSTRUCTION FEATURES</b>													
3.1	Pump type	Horizontal centrifugal type Between Bearing Pump	Horizontal centrifugal type Between Bearing Pump	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	Horizontal centrifugal type	
3.2	Impeller type	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	
3.3	Casing type	Horizontal axial split type	Horizontal axial split type	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	
3.4	Coupling type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	
3.5	Sealing arrangement	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning	Gland packing	Gland packing	Gland packing	Gland packing	Gland packing	Gland packing	Gland packing initially & Mechanical seal finally after commissioning	Gland packing	
3.6	Type of Bearing Lubrication	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	Oil/Grease	
3.7	Pump characteristics	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	
3.8	Drain Plugs, vent with 3-way SS isolating valve, lifting lugs, priming connection	-----Required-----												
4.0	<b>MATERIALS OF CONSTRUCTION</b>													
4.1	Casing	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	ASTM A-743 Gr. CF8M	IS 210 FG 260	
4.2	Impeller	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	ASTM A-743 Gr. CF8M	
4.3	Shaft	AISI- 410	AISI- 410	AISI- 410	AISI- 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	ASTM A-276 Gr. 410	
4.4	Shaft Sleeves	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	SS-316	
4.5	Wearing rings	SS-316	SS-316	SS-316	SS-316	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	ASTM A-743 Gr. C 440	
4.6	Wetted fasteners (Refer note 4)	SS AISI -304	SS AISI -304	SS AISI -304	SS AISI -304	SS AISI 304	SS AISI 304	SS AISI 304	SS AISI 304	SS AISI 304	SS AISI 304	SS AISI 304	SS AISI 304	
4.7	Fasteners (others) (Refer note 4)	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	As per IS 1367 or Equivalent	
4.8	Gland/Seal Cover	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	SS-304	
4.9	Lantern Ring	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	
4.10	Mech. seal	Manufacturer standard	Manufacturer standard	Manufacturer standard	Manufacturer standard	NA	NA	NA	NA	NA	NA	Manufacturer standard	NA	
4.11	Gland Packing	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	
4.12	Base Plate	-----MS fabricated IS-2062 (min. thk. -10 mm) Epoxy Coated-----												
4.13	Stuffing Box	ASTM-A743 Gr. CF8M	ASTM-A743 Gr. CF8M	ASTM-A743 Gr. CF8M	ASTM-A743 Gr. CF8M	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	IS 210 FG 260	ASTM A-743 Gr. CF8M	IS 210 FG 260	
4.14	Coupling	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	SS	
4.15	Connecting Pipe material (for deciding counterflange material)	Piping upto and including 150NB shall be Carbon Steel ERW, IS:1239 (Heavy Grade) and piping above 150 NB shall be Carbon Steel (IS:2062), rolled and welded conforming to IS:3589.		SA 312 TP 304, ERW	SA 312 TP 304, ERW	Piping upto and including 150NB shall be Carbon Steel ERW, IS:1239 (Heavy Grade) and piping above 150 NB shall be Carbon Steel (IS:2062), rolled and welded conforming to IS:3589.						SA 312 TP 304, ERW	Piping upto and including 150NB shall be Carbon Steel ERW, IS:1239 (Heavy Grade) and piping above 150 NB shall be Carbon Steel (IS:2062), rolled and welded conforming to IS:3589.	
5.0	<b>MANDATORY SPARES</b>													
5.1	Shaft	-	-	-	-	1 No.	1 No.	1 No.	1 No.	1 No.	1 No.	-	1 No.	
5.2	Shaft Sleeve	-	-	-	-	2 Nos.	2 Nos.	2 Nos.	2 Nos.	2 Nos.	2 Nos.	-	2 Nos.	
5.3	Impeller	-	-	-	-	1 No.	1 No.	1 No.	1 No.	1 No.	1 No.	-	1 No.	
5.4	Impeller locking nut and bolt	-	-	-	-	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	-	4 Nos.	
5.5	Impeller wear ring	-	-	-	-	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	-	4 Nos.	
5.6	Casing wear ring	-	-	-	-	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	-	4 Nos.	
5.7	Oil Seal	-	-	-	-	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	4 Nos.	-	4 Nos.	
5.8	Oil Deflector	-	-	-	-	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	-	3 Nos.	
5.9	Oil Ring	-	-	-	-	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	-	3 Nos.	
5.10	Gland Packing	-	-	-	-	4 Sets	4 Sets	4 Sets	4 Sets	4 Sets	4 Sets	-	4 Sets	
5.11	Lantern Ring	-	-	-	-	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	-	3 Nos.	
5.12	Oil Level Gauge	-	-	-	-	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	3 Nos.	-	3 Nos.	
5.13	Coupling	-	-	-	-	2 Nos.	2 Nos.	2 Nos.	2 Nos.	2 Nos.	2 Nos.	-	2 Nos.	
5.14	Rubber Bush for Coupling	-	-	-	-	2 Nos.	2 Nos.	2 Nos.	2 Nos.	2 Nos.	2 Nos.	-	2 Nos.	
5.15	O' Rings	-	-	-	-	2 Sets.	2 Sets.	2 Sets.	2 Sets.	2 Sets.	2 Sets.	-	2 Sets.	
5.16	Bearing for Pump Motor	-	-	-	-	2 Sets	2 Sets	2 Sets	2 Sets	2 Sets	2 Sets	-	2 Sets	
5.17	Complete Impeller Assembly	1 Set for each application and ratings of Pumps	1 Set for each application and ratings of Pumps	1Set	1Set	-	-	-	-	-	-	1Set	-	
5.18	Diffuser with guide vanes for 1st Stage	-	-	1Set	1Set	-	-	-	-	-	-	1Set	-	
5.19	Keys for impeller	1 No. for each application and ratings of Pumps	1 No. for each application and ratings of Pumps	1Set	1Set	-	-	-	-	-	-	1Set	-	

DATA SHEET - A												SPECIFICATION NO.:	
MISCELLANEOUS PUMPS (HORIZONTAL) - GROUP-I												REV. NO.: 00	DATE : 21/12/2015
1X800MW WANAKBORI TPS UNIT-8													
Sl. No.	DESCRIPTION	DMCW TG AUX'S PUMPS	DMCW SG AUX'S PUMPS	EMERGENCY HOTWELL MAKE-UP PUMPS	BOILER FILL PUMPS	CW MAKEUP PUMPS	SERVICE WATE BOOSTER PUMPS	POTABLE WATER PUMPS	HVAC PUMPS	CLARIFIED WATER TRANSFER PUMPS	AHP PUMPS	DM MAKEUP PUMPS	APH WASH/ESP WATER WASH PUMPS
5.20	Pump shaft	1 No. for each application and ratings of Pumps	1 No. for each application and ratings of Pumps	1No.	1No.	-	-	-	-	-	-	1No.	-
5.21	Bearings (comprising of Drive & Non-drive end )	1 Set for each application and ratings of Pumps	1 Set for each application and ratings of Pumps	1Set	1Set	-	-	-	-	-	-	1Set	-
5.22	Wear Ring for Shaft & Impeller	1 Set for each application and ratings of Pumps	1 Set for each application and ratings of Pumps	1Set	1Set	-	-	-	-	-	-	1Set	-
5.23	Bearing Housing (comprising of DE & NDE )	-	-	1Set	1Set	-	-	-	-	-	-	1Set	-
5.24	Complete Set of Mechanical seal	-	-	1Set	1Set	-	-	-	-	-	-	1Set	-
5.25	Shaft Sleeves (Suction & Disc Side)	1Set	1Set	1Set	1Set	-	-	-	-	-	-	1Set	-
5.26	Coupling Bolt, Nut & Bush	-	-	1Set	1Set	-	-	-	-	-	-	1Set	-
5.27	Coupling	1 No. for each application and ratings of Pumps	1 No. for each application and ratings of Pumps	1No.	1No.	-	-	-	-	-	-	1No.	-
5.28	Drive Motor	NA	NA	1No.	NA	-	-	-	-	-	-	1No.	-
5.29	Mechanical seal	1 Set for each application and ratings of Pumps	1 Set for each application and ratings of Pumps	1 Set for each application and ratings of Pumps	1 Set for each application and ratings of Pumps	-	-	-	-	-	-	1 Set for each application and ratings of Pumps	-
<b>LT Motors Spares</b>													
5.30	End Shield Cover Driving & Non-Driving End (applicable for motors above 30KW)	-	-	1 Set for each type and rating of Motor	-	1 Set for each type and rating of Motor	-	-	-	-	-	-	-
5.31	Driving End & Non-Driving End Bearing	-	-	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	-	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	1 Set for each type and rating of Motor (for above 30KW) 3 Set for each type and rating of Motor (for upto 30KW)	-
5.32	Cooling Fan	-	-	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	-	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 2 No. for each type and rating of Motor (for upto 30KW)	-
5.33	Motor Space Heater (applicable for motors above 30KW)	-	-	1 No. for each type and rating of Motor	-	1 No. for each type and rating of Motor	-	-	-	-	-	-	-
5.34	Motor Terminal Block	-	-	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	-	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	1 No. for each type and rating of Motor (for above 30KW) 5 No. for each type and rating of Motor (for upto 30KW)	-
5.35	Complete Set of Coupling	-	-	1 Set for each Application	-	1 Set for each Application	1 Set for each Application	1 Set for each Application	1 Set for each Application	1 Set for each Application	1 Set for each Application	1 Set for each Application	-
<b>Mandatory Spare Note:</b> 1. In respect of quantity mentioned as 'Set' means the total quantity of all the components/items used in particular equipment unless otherwise specified.													
6.0	<b>BID EVALUATION RATE</b>												
6.1	Bid evaluation rate	Rs. 2.0 Lacs/KW	Rs. 2.0 Lacs/KW	NA	NA	Rs. 2.0 Lacs/KW	NA	NA	Rs. 2.0 Lacs/KW	Rs. 2.0 Lacs/KW	Rs. 2.0 Lacs/KW	NA	NA
6.2	Maximum permissible efficiency for Bid evaluation												
6.2.1	Pump Efficiency (%)	85	83	-	-	86	-	-	69	84	78	-	-
6.2.2	Motor Efficiency (%)	94	94	-	-	93.3	-	-	91.9	91.3	91.3	-	-
<b>Notes :</b>													
1	Material of construction for other components not specified above shall be similarly selected in line with the above for the duty intended and subject to approval.												
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.												
3	For all HT motor driven pumps (wherever applicable), bidder shall provide flat surface with dimensions 60 MM x60 MM on bearing Housing for mounting vibration measuring block and a key slots of dimensions 30MM (L) X 15 MM (W) X 3 MM (D) on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL for Phase Marker.												
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.												

## CLARIFIED WATER ANALYSIS

Sl no.	Particulars	Units	Value
1	pH	---	8.42
2	TSS	ppm	15 ppm
3	Conductivity	Micro S/cm	440
4	Calcium Hardness	ppm as CaCO <sub>3</sub>	52
5	Magnesium hardness	ppm as CaCO <sub>3</sub>	82
6	Sodium	ppm as CaCO <sub>3</sub>	79
7	Iron in solution	ppm as Fe	Nil
8	Manganese in solution	ppm as CaCO <sub>3</sub>	Nil
9	Total Cations		213
10	Bicarbonate	ppm as CaCO <sub>3</sub>	152
11	Carbonate	ppm as CaCO <sub>3</sub>	2
12	Hydroxide	-----	Nil
13	Sulphate	ppm as CaCO <sub>3</sub>	13
14	Chloride	ppm as CaCO <sub>3</sub>	46.48
15	Nitrate	ppm as NO <sub>3</sub>	Nil
16	Fluoride	ppm as CaCO <sub>3</sub>	Nil
17	Total Anions		213
18	Reactive Silica as SiO <sub>2</sub>	ppm	22
19	Colloidal Silica as SiO <sub>2</sub>	ppm	Nil.

\* Note: Other parameters not indicated above considering as Nil.

## DM WATER ANALYSIS

Water Quality at the outlet of MB Exchanger:	
Total Electrolyte	0.1 ppm, max.
Reactive SiO <sub>2</sub>	Less than 0.01 ppm as SiO <sub>2</sub>
Iron as Fe	Nil
Free CO <sub>2</sub> ppm as CO <sub>2</sub>	Nil
Total Hardness	Nil
pH value at 25°C	6.8 - 7.2
Conductivity, micro mho/cm	< 0.1 at 25 °C

Passivated DM water shall have PH value of 8.5 to 9.5.

TABLE-II

RAW WATER ANALYSIS  
(As Received)

Source : River Mahi (Jack-well/ canal)

Page 1 of 2

(1) Jack-well/Canal Water Parameters

Sl. No.	Parameter	Unit	Result
1	pH	Unit	8.42
2	Turbidity	NTU	2.2
3	Conductivity	µMhos/cm	440
4	Total alkalinity as CaCO <sub>3</sub>	ppm	152
5	Chloride as Cl	ppm	33
6	Total hardness as CaCO <sub>3</sub>	ppm	134
7	Calcium Hardness as CaCO <sub>3</sub>	ppm	52
8	Magnesium Hardness as CaCO <sub>3</sub>	ppm	82
9	Silica as SiO <sub>2</sub>	ppm	20
10	Total Dissolved solids as such	ppm	308.42
11	Sulphate as SO <sub>4</sub>	ppm	12
12	Iron as Fe	ppm	0.031
13	Potassium		Not present
14	TSS	ppm	1-2

*Changed*

(2) Hypothetical Combination of Ions

Page 2 of 2

Sl. No.	Parameter	As	CONTENT ppm
1	Calcium Hardness	CaCO <sub>3</sub>	52
2	Magnesium Hardness	CaCO <sub>3</sub>	82
3	Sodium	CaCO <sub>3</sub>	79
4	Iron in Solution.	Fe	-
5	Manganese in solution	CaCO <sub>3</sub>	-
6	Total Cations	CaCO <sub>3</sub>	213
7	Bicarbonate	CaCO <sub>3</sub>	152
8	Carbonate	CaCO <sub>3</sub>	2
9	Hydroxide	-	-
10	Sulphate	SO <sub>4</sub>	12.5
11	Chloride	CaCO <sub>3</sub>	46.48
12	Nitrate	NO <sub>3</sub>	-
12	Fluoride	-	-
13	Total Anions	-	213



**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

Rev-01

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>	CUSTOMER	PROJECT TITLE
	BIDDER/VENDOR	QUALITY PLAN NUMBER PE-QP-999-100-N004 (For Hor. Pumps) PE-QP-999-100-N004 (For Ver. Pumps)
SHEET 1 OF 6		SYSTEM ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)

S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
1	<b>MATERIALS CONTROL</b>												
1.1	CASINGS (INCLUDING BOWLS, DIFFUSERS, STAGE BODIES, DISCH HEAD (IF CAST)), ETC. - (AS APPLICABLE) AND IMPELLER	MECHANICAL AND CHEMICAL PROPS	CR	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.			2,1	
1.2	STUFFING BOX, SUCTION BELL, WEARING RINGS, NECK RINGS, SHAFT SLEEVES	DO-	MA	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.			2,1	
		HARDNESS DIFFERENCE BETWEEN CASING / IMPELLER AND WEARING RING	MA	LAB. TEST	100%	APPROVED CS DRAWING/DATA SHEET	50 BHN MIN.	LAB. REPORT	3/2.			2,1	
1.3	BARS/FORGINGS FOR SHAFTS, LINE SHAFTS	1. PHYSICAL & CHEMICAL PROPS	CR	1. MECHANICAL & CHEMICAL ANALYSIS.	1/CAST OR 1/BARS	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	MILL T.C. OR LAB. REPORT	3/2.			2,1	CORRELATION REQUIRED, IDENTIFICATION AS PER TC
		2. DIMENSIONS	CR	2. MEASUREMENT	100%	MFR. DRAWING	MFR. DRAWING	INSP. REPORT	3/2.			2,1	
		3. INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS.	CR	3. ULTRA SONIC TEST	100%	ASTMA388 BACK WALL ECHO 100%	DEFECT ECHO MAX 20% OF B.W.E. LOSS OF BACK WALL ECHO 20% MAX	NDT CERTIFICATE	3/2.			2,1	
1.4	STRESS RELIEVING/ HEAT TREATMENT OF CASTING OF ALL ABOVE (IF APPLICABLE) / SOLUTION ANNEALING OF SS CASTING	1. VERIFICATION OF HT CHART	MA	VERIFICATION OF SR/HT CHART	ALL BATCHES	RELEVANT MATERIAL SPECN.	DO-	CORRELATED SR/HT. CHARTS	3/2.			2,1	
		2. IGC TEST FOR SS CASTING	MA	LAB. TEST	ONE SAMPLE/ HT BATCH	ASTM A 262	ASTM A 262 Gr A	LAB. REPORT	3/2.			2,1	
1.5	SHAFT ENCLOSING TUBES, COLUMN PIPES & DISCHARGE ELBOW	1. MECHANICAL & CHEMICAL PROPS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/BATCH 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./MAFG./ APPROVED DOCS	MFR T.C OR LAB. REPORT	3/2.			2,1	

BHEL			PARTICULARS			BIDDER / VENDOR		
NAME								
SIGNATURE								
DATE						BIDDER/VENDOR SEAL		

NAME	Prepared By	Reviewed By	Approved By
SIGN.	AJAY JAIN	ASHWANI KHANNA	I. J. SINGH
DATE	23-07-2012	23-07-2012	23-07-2012



**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT**  
**STANDARD QUALITY PLAN**

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
SHEET 2 OF 6			BIDDER/VENDOR			QUALITY PLAN NUMBER						
SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)									
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECKED	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.6	PLATE FLANGE, C/FLANGE	1. MECHANICAL & CHEMICAL PROS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/CAST 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	CORRELATION REQ. FOR MAT OTHER THAN IS 2082
1.7	SUCTION STRAINER (IF APPLICABLE)	MECHANICAL & CHEMICAL PROS.	MI	MECH. & CHEMICAL TEST	1/HEAT	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	
1.8	MECHANICAL SEAL (IF APPLICABLE)	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET / GA MECH. SEAL	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
1.9	PUMP BEARINGS	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
<b>2.0</b>	<b>IN PROCESS CONTROL</b>											
2.1	ALL COMPONENTS UNDER 1.00 ABOVE	VISUAL DEFECTS, DIMENSIONS	MA	VISUAL EXAM, MEASUREMENT	100%	MFG. DRAWING	MFG. DRAWING	COMPLIANCE TC	3/2.		2,1	
2.2	IMPELLER	CLEANING AND DEBURRING	MA	VISUAL	100%	MFG. DRAWING	MFG. DRAWING		3/2.		2,1	
	IMPELLER	DYNAMIC BALANCING	CR	DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2,1		WITNESSING ONLY FOR SIZE GREATER THAN 10KW
2.3	IMPELLER-ALL ACCESSIBLE SURFACES, DIFFUSERS	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VARIIFICATION BY CUSTOMER
2.4	WERING RING, SHAFT SLEEVES, CASING	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.		2,1	
2.5	SHAFT	DP TEST	MA	DP TEST ON M/CED AREA	100%	ASTM E 165	NO RELEVANT INDICATION ALLOWED	NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VARIIFICATION BY CUSTOMER
2.6	CASINGS/ BOWLS, STAGE BODIES, DISCHARGE HEAD (IF CAST), SUCTION HOUSING, COLUMN PIPE DISCHARGE PIPE ETC	LEAK TIGHTNESS	CR	VISUAL	100%	TECHNICAL DATA SHEET AND NOTE 2	NO LEAKAGE FOR TEST DURATION OF 30 MIN.	HT CERTIFICATE	3/2.	2,1		HAMMERING OF CASTINGS WITH WOODEN/ RUBBER MALLET BEFORE HYDRO TEST
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

NAME  
SIGN.  
DATE

Prepared By  
AJAY JAIN  
*Ajay*  
23-07-2012

Reviewed By  
ASHWANI KHANNA  
*Ashwani*  
23-07-2012

Approved By  
I. J. SINGH  
*I. J. Singh*  
23-07-2012



**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

Rev-01

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>				CUSTOMER			PROJECT TITLE					
SHEET 3 OF 6				BIDDER/VENDOR			QUALITY PLAN NUMBER					
SYSTEM				ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)								
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGOR Y	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7	FABRICATED COMPONENTS											
2.7.1	WELDING PROCEDURE SPECIFICATION	CORRECTNESS	MA	EXAM.	100%	ASME SEC.IX	ASME SEC.IX	QW 482 OF ASME SEC.IX	3/2.		2,1	WELDING PROCEDURE APPROVAL BY BHEL ALT. 3RD PARTY (LLYODS, BVQI OR EQ.) IS ACCEPTABLE.
2.7.2	WELDING PROCEDURE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 483 OF ASME SEC.IX	3/2.		2,1	
2.7.3	WELDER PERFORMANCE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 484 OF ASME SEC.IX	3/2.		2,1	
2.7.4	WELD FIT-UPS	DIMENSION & ALIGNMENT	MA	MEAS.VISUAL EXAM	100%	WPS, MFG . DRAWING	WPS, MFG . DRAWING	IR/LOGBOOK	3/2.			
2.7.5	ROOT RUNS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	NO SURFACE DEFECT	DO.	3/2.		2, 1	
2.7.6	WELDMENTS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	ASME-VIII,DIV I	INSPN REPORT	3/2.		2,1	
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

NAME SIGN. DATE	Prepared By	Reviewed By	Approved By
	AJAY JAIN	ASHWANI KHANNA	I. J. SINGH
	<i>Ajay</i> 23-07-2012	<i>Ashwani</i> 23-07-2012	<i>I. J. Singh</i> 23-07-2012



**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

**Rev-01**

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>				CUSTOMER			PROJECT TITLE					
				BIDDER/VENDOR			QUALITY PLAN NUMBER					
SHEET 4 OF 6				SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)					
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGOR Y	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7.7	BUTT WELDS	INTERNAL DEFECT	MA	UT/RT	100%			IR	3/2.			2.1
2.7.8	DICHARGE HEAD, COLUMN PIPE, DISCHARGE PIPE, ETC.	1. LEAK TIGHTNESS 2. DIMENSION	CR	1. HYDROTEST 2. MEASUREMENT	100%	TECHNICAL SPEC/ DATA SHEET. MFR DRAWING	1. NO LEAKAGE 2. MFR. DRAWING	IR	3/2.	2.1		
<b>3.0</b>	<b>SUB-ASSEMBLY CONTROL</b>											
3.1	ROTOR ASSEMBLY	ECCENTRICITY	MA	MEASUREMENT	100%	MFR.DRAWING	MFR.DRAWING	IR/LOG BOOK	3/2.			1
3.2	ROTOR ASSEMBLY RESIDUAL UNBALACE	STATIC & DYNAMIC	CR	STATIC & DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2.1		WTNESSING ONLY FOR SIZE GREATER THAN 10KW
3.3	COMPLETE PUMP ASSEMBLY	COMPLETENESS, CORRECTNESS, CLEANLINESS, CLEARANCES, FREENESS, ALIGNMENT	MA	VISUAL EXAM MEASUREMENT	100%	APPROVED DRG & MFG STANDARDS	APPROVED DRG & MFG STANDARDS	I.R. & CHECK LISTS	3/2.			2.1
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE								BIDDER/VENDOR SEAL

NAME SIGN. DATE	Prepared By <b>AJAY JAIN</b>  23-07-2012	Reviewed By <b>ASHWANI KHANNA</b>  23-07-2012	Approved By <b>I. J. SINGH</b>  23-07-2012
-----------------------	---	--	---



**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

Rev-01

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>	CUSTOMER	PROJECT TITLE
	BIDDER/VENDOR	QUALITY PLAN NUMBER
SHEET 5 OF 6	SYSTEM	ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)

S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGOR Y	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11

4	FINAL INSPECTION, TESTS & PACKING DESPATCH CONTROL												
4.1	PUMP WITH JOB/SHOP MOTOR ASSEMBLED ON INDIVIDUAL BASE FRAME	1. Q V/S HEAD, 2. Q V/S POWER, 3. Q V/S PUMP EFF. 4. VIBRATION 5. NOISE 6. BEARING TEMP. 7. LEAKAGES	CR	PERFORMANCE TEST	100%	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES FOR VIBRATIONS - AS PER ANSI/HIS 9.6.4-2009 (VALUES AS PER APPROVED DATA SHEET) FOR BEARING TEMP - BEARING HOUSING SHOULD NOT BE UNTOUCHABLY HOT. FOR LEACKAGE - MINOR LEKAGE (DROP BY DROP) IN CASE OF GLAND PACKING ARRANGEMENT.	APPD. G.A DRAWING	APPD. G.A DRAWING	I.R., PERF. TEST RECORD, PLOTED CURVES	3/2.	2,1.		* MINIMUM 7 POINTS FROM SHUT-OFF TO MAX. OPERATING FLOW COVERING ENTIRE OPERATION RANGE OF PUMP SHALL BE TAKEN.
		NPSH/ MIN. SUBMERGENCE REQUIRED	CR	NPSH TEST	1/MODEL	DO.			IR. NPSH/MIN. SUBMERGENCE TEST RECORD, PLOTED CURVES	3/2.	2,1.		IF SPECIFIED or INSISTED BY CUSTOMER.
4.2	STRIP DOWN AFTER PERFORMANCE TEST	1UNDUE WEAR TEAR AND RUBBING	MA	VISUAL EXAM AFTER STRIPPING	1/MODEL	NO UNDUE WEAR TEAR & RUBBING ON IMPELLER & WEAR RING			INSP. REPORT	3/2.	1		WITNESS REQUIRED ONLY WHEN ABNORMAL SOUND OBSERVED DURING PERFORMING TEST.
4.3	COMPLETE PUMP WITH UNIT MOTOR BASE FRAME, COUNTER FLANGES ETC. INCLUDING ALL ACCESSORIES AS PER SECTION C OF SPECN.	COMPLETENESS, CLEANLINES, OVERALL DIMENSIONS ORIENTATION, WORKMANSHIP AND FINISH	MA	VISUAL EXAM MEASURMENT	100%		APPD. G.A DRAWING	APPD. G.A DRAWING	INSP. REPORT	3/2.	1		

BHEL	PARTICULARS	BIDDER / VENDOR
	NAME	
	SIGNATURE	
	DATE	BIDDER/VENDOR SEAL

NAME	Prepared By AJAY JAIN	Reviewed By ASHWANI KHANNA	Approved By I. J. SINGH
SIGN.			
DATE	23-07-2012	23-07-2012	23-07-2012



**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

Rev-01

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>	CUSTOMER	PROJECT TITLE
	BIDDER/VENDOR	QUALITY PLAN NUMBER
SHEET 6 OF 6	SYSTEM	ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)

S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4.4	COMPLETION OF ALL STAGES	1.COMPLETION	MA	VERIFICATION OF IR/T.C.ETC.	100%	MFG. DRG./TECHNICAL DOCS.	APPD. MFG. DRG./TECHNICAL DOCS	IR.	3/2.	2,1		WTNESSING ONLY BY BHEL, CUSTOMER VARIFICATION ONLY BUT CHP
4.5	PAINING	1.SURFACE FINISH, DFT, MARKINGS ETC.	MA	VISUAL EXAM MEASURMENT AESTHETIC	100%	APPD.DRG.	APPD.DOCS	IR.	3/2.		2	
4.6	PACKING, MARKING	SOUNDNESS OF PACKING	MI	VISUAL AESTHETIC	100%	MFG. STANDARD	MFG. STANDARD		3/2.		2	

MTC -Mill Test Certificate, MA-Major, MI-Minor, TC-Test Certificate, CR-Critical, IGC- Inter Granular Corrosion


- AS CAST HEAT MARKS SHALL BE PROVIDED ON CI CASTING LIKE TOP & BOTTOM CASING.
- HYDRO TEST PRESSURE SHALL BE AT LEAST 2(TWO) TIMES THE DUTY POINT (OR) 1.5 TIMES OF SHUT OFF HEAD (OR) SYSTEM DESIGN PRESSURE, WHICHEVER IS HIGHER.
- THIS QAP IS ALSO APPLICABLE FOR SPARES.
- NO WELD REPAIRS PERMISSIBLE ON CI CASTING.
- MATERIAL SHALL BE AS PER APPROVED CROSS SECTION DRG./ DATA SHEET.
- STRIP TEST- INCASE OF ABNORMAL NOISE OBSERVED DURING PERF. TEST, THOSE PUMP WILL BE STRIPPED DOWN FOR VISUAL INSPECTION OF IMPELLER & WEAR SHALL BE OFFERED FOR VISUAL INSPECTION FOR WEAR /RUBBING MARKS.
- PUMPS WITH MECHANICAL SEAL ARRANGEMENT TO BE TESTED AND SUPPLIED WITH GLAND PACKING ARRANGEMENT. HOWEVER MANUFACTURER TO ENSURE DIMENTIONAL MATCHING OF MECHANICAL SEAL WITH PUMP GA DRAWING.

LEGEND : 1- BHEL OR BHEL NOMINATED THIRD PARTY /END CUSTOMER OF BHEL,  
2- VENDOR,  
3-SUB-VENDOR

P- PERFORM, W- WITNESS, V-VERIFICATION

BHEL	PARTICULARS	BIDDER / VENDOR	
	NAME		
	SIGNATURE		
	DATE		BIDDER/VENDOR SEAL

NAME	Prepared By	Reviewed By	Approved By
SIGN.	AJAY JAIN	ASHWANI KHANNA	I. J. SINGH
DATE	23-07-2012	23-07-2012	23-07-2012

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-410-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D2
		REV. NO.	0	DATE:	20.06.15

**SECTION D2**

**STANDARD QUALTY PLAN FOR MOTORS**



**QUALITY PLAN**

SHEET 1 OF 9

CUSTOMER GSECL

PROJECT 1X800 MW WANAKBORI STPP

SPECIFICATION :

NUMBER :

BIDDER/ :

QUALITY PLAN

SPECIFICATION :

VENDOR

NUMBER PED-506-00-Q-007, REV-03

TITLE


SYSTEM


ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)


SECTION

VOLUME III


SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.0	RAW MATERIAL & BOUGHT OUT CONTROL											
1.1	SHEET STEEL, PLATES, SECTION, EYEBOLTS	1.SURFACE CONDITION	MA	VISUAL	100%	-	FREE FROM BLINKS, CRACKS, WAVINESS ETC	LOG BOOK	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	-DO-	3	-	-	
		3.PROOF LOAD TEST (EYE BOLT)	MA	MECH. TEST	-DO-	-DO-	-DO-	INSPEC. REPORT	3	-	2	
1.2	HARDWARES	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, UN-EVENNESS ETC.	-DO-	3	-	-	
		2.PROPERTY CLASS	MA	VISUAL	SAMPLES	MANFR'S DRG./SPEC BOOK	RELEVANT IS/SPEC.	SUPPLIERS TC & LOG	3	-	2	PROPERTY CLASS MARKING SHALL BE CHECKED BY THE VENDOR
1.3	CASTING	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, BLOW HOLES ETC.	LOG BOOK	3	-	2	
		2.CHEM. & PHY. PROP.	MA	CHEM & MECH TEST	1/HEAT NO.	MANFR'S DRG./SPEC	RELEVANT IS/	SUPPLIER'S TC	3	-	2	HEAT NO. SHALL BE VERIFIED
		3.DIMENSIONS	MA	MEASUREMENT	100%	MANFR'S DRG.	MANFR'S DRG.	LOG BOOK	3	-	2	
1.4	PAINT & VARNISH	1.MAKE, SHADE, SHELF LIFE & TYPE	MA	VISUAL	100% CONTINUOUS	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	LOG BOOK	3	-	2	
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN			CUSTOMER GSECL		PROJECT 1X800 MW WANAKBORI STPP		SPECIFICATION :			
					BIDDER/ VENDOR :		TITLE		NUMBER :			
SHEET 2 OF 9		SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION		VOLUME III			
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.5	SHAFT (FORGED OR ROLLED)	1. SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	VENDOR'S APPROVAL IDENTIFICATION SHALL BE MAINTAINED
		2. CHEM. & PHYSICAL PROPERTIES	MA	CHEM. & PHYSICAL TESTS	1/HEAT NO. OR HEAT TREATMENT BATCH NO	MFG. DRG. SPEC.	RELEVANT IS	SUPPLIER'S TC	3	-	2	
		3. DIMENSIONS	MA	MEASUREMENT	100%	-DO-	MANUFR'S DRG.	LOG BOOK	3	-	2	
		4.INTERNAL FLAWS	CR	UT	-DO-	ASTM-A388	MANUFR'S SPEC. BHEL SPEC.	-DO-	3	2	1	
1.6	SPACE HEATERS, CONNECTORS, TERMINAL BLOCKS, CABLES, CABLE LUGS, CARBON BRUSH TEMP. DETECTORS, RTD, BTD'S	1. MAKE & RATING	MA	VISUAL	-DO-	MANUFR'S DRG. SPEC.	MANUFR'S DRG. SPEC.	-DO-	3	-	2	
		2. PHYSICAL COND.	MA	-DO-	-DO-	-	NO PHYS. DAMAGE, NO ELECTRICAL DISCONTINUITY	-DO-	3	-	2	
		3.DIMENSIONS (WHEREVER APPLICABLE)	MA	MEASUREMENT	SAMPLE	MANUFR'S DRG./ SPEC.	MANUFR'S DRG. / SPEC.	-DO-	3	-	2	
		4.PERFORMANCE/ CALIBRATION	MA	TEST	100%	-DO-	-DO-	INSP. REPORT	3	-	2	
BHEL			PARTICULARS		BIDDER/VENDOR							
			NAME									
			SIGNATURE									
			DATE					BIDDER'S/VENDORS COMPANY SEAL				

		<b>QUALITY PLAN</b> SHEET 3 OF 9			CUSTOMER GSECL		PROJECT 1X800 MW WANAKBORI STPP		SPECIFICATION : NUMBER :			
					BIDDER/ VENDOR :		TITLE		SPECIFICATION : TITLE			
		SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION		VOLUME III			
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.7	OTHER INSULATING MATERIALS LIKE SLEEVES, BINDINGS CORDS, PAPERS, PRESS BOARDS ETC.	1. SURFACE COND. ETC.	MA	VISUAL	100%	-	NO VISUAL DEFECTS	INSPT. REPORT	3	-	2	
		2. OTHER CHARACTERISTICS	MA	TEST	SAMPLE	MANUF'S SPEC.	MANUF'S SPEC.	LOG BOOK AND OR SUPPLIER'S TC	3	-	2	
1.8	SHEET STAMPING (PUNCHED)	1. SURFACE COND.	MA	VISUAL	100%	-	NO VISUAL DEFECTS (FREE FROM BURS)	LOG BOOK	3	-	-	
		2.DIMENSIONS INCLUDING BURS HEIGHT	MA	MEASUREMENT	SAMPLE	MANUFR'S DRG. .	MANUFR'S DRG.	-DO-	3	-	2	
		3. ACCEPTANCE TESTS	MA	ELECT. & MECH TESTS	-DO-	MANUF'S SPEC./ RELEVANT IS	RELEVANT IS	SUPPLIER'S TC	3	-	2	
1.9	CONDUCTORS	1. SURFACE FINISH	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	LOG BOOK	3*	-	2*	* MOTOR MANUFACTURER TO CONDUCT VISUAL CHECK FOR SURFACE FINISH ON RANDOM BASIS (10% SAMPLE) AT HIS WORKS AND MAINTAIN RECORD FOR VERIFICATION BY BHEL/CUSTOMER.
		2.ELECT. PROP. & MECH. PROP	MA	ELECT. & MECH.TEST	SAMPLES	RELEVANT IS/ BS OR OTHER STANDARDS	RELEVANT IS/ BS OR OTHER STANDARDS	SUPPLIERS TC & VENDOR'S INSPN. REPORTS	3	-	2	
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN			CUSTOMER GSECL		PROJECT 1X800 MW WANAKBORI STPP		SPECIFICATION :			
					BIDDER/ VENDOR :		TITLE		NUMBER :			
SHEET 4 OF 9		SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION			VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.10	BEARINGS	3.DIMENSIONS	MA	MEASUREMENT	-DO-	-DO-	-DO-	Log Book	3	-	2	
		1.MAKE & TYPE	MA	VISUAL	100%	MANFR'S DRG./ APPROVED DATASHEET	MANFR'S DRG./ APPROVED DATASHEET	-DO-	3	-	2	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	BHEL DATA SHEET	BHEL DATA SHEET BEARING MANUF'S CATALOGUES	-DO-	3	-	2	
1.11	SLIP RING (WHEREVER APPLICABLE)	3.SURFACE FINISH	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	2	
		1.SURFACE COND.	MA	VISUAL	100%	-	-DO-	-DO-	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
		3.TEMP.WITH-STAND CAPACITY	MA	ELECT.TEST	-DO-	MANUF'S SPEC./ BHEL SPEC.	MANUF'S SPEC./ BHEL SPEC.	-DO-	3	-	2	
1.12	OIL SEALS & GASKETS	4.HV/IR	MA	-DO-	100%	-DO-	-DO-	-DO-	3	-	2	
		1.MATERIAL OF GASKET	MA	VISUAL	100%	MANUF'S DRG/SPECS	MANUF'S DRG./ SPECS.	-DO-	3	-	-	
		2.SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	
		3.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			



		QUALITY PLAN			CUSTOMER GSECL		PROJECT 1X800 MW WANAKBORI STPP		SPECIFICATION :				
					BIDDER/ :		TITLE		NUMBER :				
SHEET 5 OF 9		VENDOR			QUALITY PLAN		NUMBER PED-506-00-Q-007, REV-03		SPECIFICATION :				
SYSTEM		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			TITLE		SECTION		VOLUME III				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
2.0	IN PROCESS												
2.1	STATOR FRAME WELDING (IN CASE OF FABRICATED STATOR )	1.WORKMANSHIP & CLEANNES	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	3/2	2	-		
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-		
2.2	MACHINING	1.FINISH	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	2	-	-		
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-		
		3.SHAFT SURFACE FLOWS	MA	PT	-DO-	RELEVANT SPEC./ ASTM-E165	MANUF'S SPEC./ BHEL SPEC./	-DO-	2	-	1		
2.3	PAINTING	1.SURFACE PREPARATION	MA	VISUAL	100%	MANFR'S SPEC/BHEL SPEC./ RELEVANT STAND	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-		
		2.PAINT THICKNESS (BOTH PRIMER & FINISH COAT)	MA	MEASUREMENT BY ELCOMETER	SAMPLE	-DO-	-DO-	-DO-	2	-	-		
		3.SHADE	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-		
		4.ADHESION	MA	CROSS CUTTING & TAPE TEST	-DO-	-DO-	-DO-	Log Book	2	-	-		
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE						BIDDER'S/VENDORS COMPANY SEAL				



**QUALITY PLAN**

SHEET 6 OF 9

CUSTOMER GSECL

PROJECT 1X800 MW WANAKBORI STPP

SPECIFICATION :

BIDDER/ VENDOR :

QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03

NUMBER :

SPECIFICATION : TITLE

SYSTEM

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SECTION

VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
2.4	SHEET STACKING	1.COMPLETENESS	MA	MEASUREMENT	SAMPLE	MANUFR'S SPEC.	MANUFR'S SPEC.	Log Book	2	-	-	(FOR MOTORS OF 2MW AND ABOVE) * ON 10% RANDOM SAMPLE	
		2.COMPRESSION & TIGHTENING	MA	MEASUREMENT	100%	-DO-	-DO-	Log Book	2	-	-		
		3.CORE LOSS & HOTSPOT	MA	ELECT.TEST	-DO-	-DO-	-DO-	Log Book	2	1*	1		
2.5	WINDING	1.COMPLETENESS	CR	VISUAL	100%	MANUFR'S SPEC./BHEL SPEC.	MANUFR'S SPEC./BHEL SPEC.	Log Book	2	-	-		
		2.CLEANLINESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
		3.IR-HV-IR	CR	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2	-	1		
		4.RESISTANCE	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
		5.INTERTURN INSULATION	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
2.6	IMPREGNATION	6.SURGE WITH STAND AND TAN. DELTA TEST	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		FOR MV MOTOR
		1.VISCOSCITY	MA	PHY. TEST	AT STARTING	-DO-	-DO-	Log Book	2	-	-		
		2.TEMP. PRESSURE VACCUM	MA	PROCESS CHECK	CONTINUOUS	-DO-	-DO-	Log Book	2	-	-		
		3.NO. OF DIPS	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1	THREE DIPS TO BE GIVEN	
		<b>BHEL</b>		<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>										
			<b>SIGNATURE</b>										
			<b>DATE</b>						<b>BIDDER'S/VENDORS COMPANY SEAL</b>				



**QUALITY PLAN**

SHEET 7 OF 9

CUSTOMER GSECL

PROJECT 1X800 MW WANAKBORI STPP

SPECIFICATION :

BIDDER/ :  
VENDOR

TITLE  
QUALITY PLAN  
NUMBER PED-506-00-Q-007, REV-03


NUMBER :

SYSTEM

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SPECIFICATION :  
TITLE

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7	COMPLETE STATOR ASSEMBLY	4.DURATION	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1	VERIFICATION FOR MV MOTOR ONLY
2.8	BRAZING/COMPRESSION JOINT	1.COMPACTNESS & CLEANLINESS	MA	VISUAL	100%	-DO-	-DO-	Log Book	2	-	-	
2.9	COMPLETE ROTOR ASSEMBLY	1.COMPLETENESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-	
		2.SOUNDNESS	CR	MALLET TEST & UT	-DO-	-DO-	-DO-	Log Book	2	-	1	
		3.HV	MA	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2	-	1	
2.10	ASSEMBLY	1.RESIDUAL UNBALANCE	CR	DYN. BALANCE	-DO-	MFG SPEC./ ISO 1940	MFG. DWG.	Log Book	2	-	1	
		2.SOUNDNESS OF DIE CASTING	CR	ELECT. (GROWLER TEST)	-DO-	MFG. SPEC.	MFG. SPEC.	Log Book	2	-	1	
2.10	ASSEMBLY	1.ALIGNMENT	MA	MEAS.	-DO-	-DO-	-DO-	Log Book	2	-	-	
		2.WORKMANSHIP	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-	
		3.AXIAL PLAY	MA	MEAS.	-DO-	-DO-	-DO-	Log Book	2	-	1	
		4.DIMENSIONS	MA	-DO-	-DO-	MFG.DRG./ MFG SPEC.	MFG. DRG/ RELEVANT IS	Log Book	2	-	-	
2.10	ASSEMBLY	5.CORRECTNESS, COMPLETENESS TERMINATIONS/ MARKING/ COLOUR CODE	MA	VISUAL	100%	MFG SPEC. RELEVANT IS	MFG SPEC. RELEVANT IS	Log Book	2	-	-	
		6. RTD, BTD & SPACE HEATER MOUNTING.	MA	VISUAL	100%	MFG SPEC. RELEVANT IS	MFG SPEC. RELEVANT IS	Log Book	2	-	1	
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>									
			<b>SIGNATURE</b>									
			<b>DATE</b>						<b>BIDDER'S/VENDORS COMPANY SEAL</b>			

		QUALITY PLAN			CUSTOMER GSECL		PROJECT 1X800 MW WANAKBORI STPP		SPECIFICATION :			
					BIDDER/ VENDOR :		TITLE		NUMBER :			
SHEET 8 OF 9		SYSTEM		REFERENCE DOCUMENT		ACCEPTANCE NORM		FORMAT OF RECORD		SECTION		VOLUME III
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6	7	8	9	10			11
									P	W	V	
3.0	TESTS	1.TYPE TESTS INCLUDING SPECIAL TESTS AS PER BHEL SPEC.	MA	ELECT.TEST	1/TYPE/SIZE	IS-325/ BHEL SPEC./ DATA SHEET	IS-325/ BHEL SPEC./ DATA SHEET	TEST REPORT	2	1*	1	* NOTE - 1
		2.ROUTINE TESTS INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 <sup>§</sup>	1	§ NOTE - 2
		3.VIBRATION & NOISE LEVEL	MA	-DO-	100%	IS-12075 & IS-12065	IS-12075 & IS-12065	-DO-	2	1 <sup>§</sup>	1	§ NOTE - 2
		4.OVERALL DIMENSIONS AND ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPC. REPORT	2	1	-	
		5.DEGREE OF PROTECTION	MA	ELECT. & MECH. TEST	1/TYPE/ SIZE	RELEVANT IS	BHEL SPEC. AND DATA SHEET	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		6. MEASUREMENT OF RESISTANCE OF RTD & BTD	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 <sup>§</sup>	1	§ NOTE - 2
		7. MEASUREMENT OF RESISTANCE, IR OF SPACE HEATER	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 <sup>§</sup>	1	§ NOTE - 2
		8. NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPC. REPORT	2	1 <sup>§</sup>	1	§ NOTE - 2
		9.EXPLOSION FLAME PROOF NESS (IF SPECIFIED)	MA	EXPLOSION FLAME PROOF TEST	1/TYPE	IS-3682 IS-8239 IS-8240	IS-3682 IS-8239 IS-8240	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		10. PAINT SHADE, THICKNESS & FINISH	MA	VISUAL & MEASUREMENT BY ELKOMETER	SAMPLE	BHEL SPEC. & DATA SHEET	BHEL SPEC. & DATA SHEET	TC	2	1 <sup>§</sup>	1	SAMPLING PLAN TO BE DECIDED BY INSPECTION AGENCY § NOTE - 2
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			



**QUALITY PLAN**

SHEET 9 OF 9

CUSTOMER GSECL

PROJECT 1X800 MW WANAKBORI STPP  
TITLE

SPECIFICATION :  
NUMBER :

BIDDER/ VENDOR :

QUALITY PLAN  
NUMBER PED-506-00-Q-007, REV-03

SPECIFICATION :  
TITLE

SYSTEM

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SECTION VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11

NOTES:


- 1 DEPENDING UPON THE SIZE AND CRITICALLY, WITNESSING BY BHEL SHALL BE DECIDED.
- 2 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON.
- 3 IN CASE TEST CERTIFICATES FOR THESE TESTS ON SIMILAR TYPE, SIZE AND DESIGN OF MOTOR FROM INDEPENDENT LABORATORY ARE AVAILABLE, THESE TEST MAY NOT BE REPEATED.
- 4 WHEREVER CUSTOMER IS INVOLVED IN INSPECTION, AGENCY (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.

Legends for Inspection agency

1. BHEL/CUSTOMER
2. VENDOR (MOTOR MANUFACTURER)
3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)

- P. PERFORM  
W. WITNESS  
V. VERIFY

<b>BHEL</b>	<b>PARTICULARS</b>	<b>BIDDER/VENDOR</b>	
	NAME		
	SIGNATURE		
	DATE		
			<b>BIDDER'S/VENDORS COMPANY SEAL</b>

		<b>QUALITY PLAN</b>			CUSTOMER GSECL		PROJECT 1X800 MW WANAKBORI STPP		SPECIFICATION :			
					BIDDER/ VENDOR :		TITLE		NUMBER :			
		SHEET 1 OF 2		SYSTEM			QUALITY PLAN NUMBER PED-506-00-Q-006, REV-01		SPECIFICATION TITLE			
					ITEM AC ELECT. MOTORS BELOW 55KW (LV)		SECTION		VOLUME III			
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.0	ASSEMBLY	1.WORKMANSHIP	MA	VISUAL	100%	MANUF'S SPEC	MANUF'S SPEC	-DO-	2	-	-	
		2.DIMENSIONS	MA	-DO-	-DO-	MFG. DRG./MFG. SPEC.	MFG. DRG./MFG. SPEC.	-DO-	2	-	-	
		3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/COLOUR CODE	MA	VISUAL	100%	MFG.SPEC./RELEVANT IS	MFG.SPEC. RELEVANT IS	-DO-	2	-	-	
2.0	PAINTING	1.SHADE	MA	VISUAL	SAMPLE	MANUFR'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
3.0	TESTS	1.ROUTINE TEST INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	IS-325/BHEL SPEC./DATA SHEET	SAME AS COL.7	TEST REPORT	2	1		NOTE -1 & NOTE-3
		2.OVERALL DIMENSIONS & ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPN. REPORT	2	1	-	NOTE -1 & NOTE-3
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									



**QUALITY PLAN**

CUSTOMER GSECL

PROJECT 1X800 MW WANAKBORI STPP

SPECIFICATION :

BIDDER/ :

TITLE

NUMBER :

VENDOR

QUALITY PLAN  
NUMBER PED-506-00-Q-006, REV-01

SPECIFICATION :

SHEET 2 OF 2

SYSTEM

ITEM AC ELECT. MOTORS BELOW 55KW (LV)

TITLE :  
SECTION VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
		3.NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT	2	1	-	
<p>NOTES:</p> <p>1 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON</p> <p>2 WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.</p> <p>3 FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.</p> <p><u>Legends for Inspection agency</u></p> <p>1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)</p> <p>P. PERFORM W. WITNESS V. VERIFY</p>												
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			