

**NEYVELI LIGNITE CORPORATION LIMITED (NLC LTD)**

**2 X 500 MW NEW NEYVELI TPP (NNTPP)-SG PACKAGE  
2 X 500 MW NEW NEYVELI TPP (NNTPP)-TG PACKAGE**

**VOLUME -IIB**

**TECHNICAL SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS**

**Specification No. : PE-TS-400/402-100-N001 (REV. 0)**



**BHARAT HEAVY ELECTRICALS LIMITED  
POWER SECTOR  
PROJECT ENGINEERING MANAGEMENT  
PPEI BUILDING, SECTOR 16 A  
NOIDA - 201301**



PREAMBLE

SPECIFICATION NO.: PE-TS-400/402-100-N001

2X500 MW NNTPP (SG &amp; TG)

REV. NO. 0

DATE: 25.08.14

1.0 The tender document contains three (3) volumes. The bidder shall meet the requirements of all the three volumes.

#### 1.1 Volume I - CONDITIONS OF CONTRACT

This consists of four parts as below:

Volume - I A : This part contains instructions to bidders for making bids to BHEL.

Volume - I B : This part contains general commercial conditions of the tender and include provision that vendor shall be responsible for the quality of item supplied by their sub-vendors.

Volume - I C : This part contains special conditions of contract.

Volume - I D : This part contains commercial conditions for erection and commissioning site work, as applicable.

#### 1.2 Volume II - TECHNICAL SPECIFICATIONS

Technical requirements are stipulated in Volume II which comprises of:

Volume - II A : General Technical Conditions

Volume - II B : Technical specification including drawings, if any

##### 1.2.1 Volume - II B :

This volume is sub-divided into following sections:

Section - A : This section outlines the scope of enquiry.

Section - B : This section provides "Project Information"

Section - C : This section indicates technical requirements specific to the contract, not covered in Section-D.

Section - D : This section comprises of technical specifications of equipments complete with data sheet A, B & C.

Data sheet - A specifies data and other requirements pertaining to the equipment.

Data sheet - B specifies data to be filled by the bidder (Data Sheet B is contained in Volume - III)

Data sheet - C indicates data documents to be furnished after the award of contract as per agreed schedule by the vendor (as applicable).

##### 1.2.2 Volume - III TECHNICAL SCHEDULES

This volume contains technical schedules and Data Sheets - B, which are to be duly filled by the bidder and the same shall be furnished with the technical bid as per checklist, sec B7 in vol III.

2.0 The requirements mentioned in Section C/Data Sheets-A of Section-D shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section -D.



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS  
2X500 MW NNTPP (SG & TG)

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

REV. NO. 0

DATE: 25.08.14

## INDEX

### SECTION TITLE

A SCOPE OF ENQUIRY

B PROJECT INFORMATION

C SPECIFIC TECHNICAL REQUIREMENTS FOR

C1 PUMPS  
C2 MOTORS

D STANDARD TECHNICAL SPECIFICATIONS FOR

D1 PUMPS

- STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS- NO. PE-TS-179-06
- STANDARD TECHNICAL SPECIFICATIONS FOR VERTICAL PUMPS- NO. PE-TS-179-07
- DATA SHEETS-A FOR ABOVE PROJECT ALONGWITH LIST OF MANDATORY SPARES & WATER ANALYSIS.
- DATA SHEET - C
- STANDARD QUALITY PLAN FOR PUMPS

D2 MOTORS

- STANDARD TECHNICAL SPECIFICATION FOR MOTORS
- DATA SHEET-A
- STANDARD QUALITY PLAN FOR MOTORS



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS

2X500 MW NNTPP (SG & TG)

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

A

REV. NO.


0

DATE:

25.08.14

## SECTION A

### SCOPE OF INQUIRY

	<b>TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS</b> 2X500 MW NNTPP (SG & TG) <b>SCOPE OF ENQUIRY</b>	SPECIFICATION NO.:		PE-TS-400/402-100-N001	
		VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	25.08.14

## 1.0 SCOPE

- 1.1 This enquiry covers the design, manufacture, assembly, inspection and testing at manufacturer's and/or his sub-contractors works, proper packing for delivery and installation checks and replacement of gland packing with Mechanical Seal arrangement (if applicable) at site for Miscellaneous Pumps along with mandatory spares complete with all accessories as per the requirements specified in this specification for following project.

2 X 500 MW NEW NEYVELI TPP (NNTPP)-SG PACKAGE  
 2 X 500 MW NEW NEYVELI TPP (NNTPP)-TG PACKAGE

The bidder's scope shall also include any other services, etc. if called for in the succeeding sections of the specification.

- 1.2 The miscellaneous pumps covered under this specification shall be Horizontal pumps.

### NOTE:-

- a) **The bidder shall include complete supplies for the Project/Group as above in his scope. Part supplies offered for the Project/Group shall disqualify the bidder's offer for that Project/Group.**
- b) **All pumps for above projects (NNTPP-SG & NNTPP-TG) may be combined together for bid evaluation if stated in NIT**

- 1.3 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning. Replacement of gland packing with Mechanical Seal (If applicable) as per Cl. No. 2.0 of Section C1 & Cl. No. 9.08.04 of section D of this volume. The charges for these shall be included by bidder in his base price, itself.

- 1.4 The miscellaneous pumps and drives covered under this specification for various projects are as per Annexure-I. HT drives, wherever applicable and irrespective of motor ratings, shall be issued free of cost by BHEL. The details of pumps with HT drives shall be as per Annexure II.

The Capacity, Head, Materials of construction, Mandatory spares and other particulars of these pumps, are detailed in Data Sheet-A annexed with Section-D of the specification.

- 1.5 For detailed scope of supply & services refer clause 3.00.00 of Standard technical Specification for Horizontal Centrifugal pumps/ Vertical pumps specified under Section-D of this volume.
- 1.6 Electrical scope between BHEL and Vendor for Miscellaneous pumps and drives of this specification shall be as per annexure I of section C-2 of this volume.

## 2.0 GENERAL TECHNICAL INSTRUCTIONS:

- 2.1 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.
- 2.2 The omission of specific reference to any component/accessory necessary for the proper performance of Miscellaneous Pumps and drives shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of equipment at quoted prices.
- 2.3 BHEL's / Customer's representative shall be given full access to the shop in which the equipments are being manufactured or tested and all test records shall be made available to him.
- 2.4 The equipments covered under this specification shall not be despatched unless the same have been finally inspected, accepted and shipping release issued by BHEL/Customer.
- 2.5 ***In case of any deviation from this technical specification (Vol.IIB) and General Technical Conditions (Vol.II A), the same shall be indicated in the schedule of deviations enclosed in Vol.III. In the absence of duly filled schedules it will be assumed that the bid strictly conforms to the specification.***
- 2.6 Unpriced copy of the price bid shall be furnished alongwith the technical bid.



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS  
2X500 MW NNTPP (SG & TG)  
SCOPE OF ENQUIRY

SPECIFICATION NO.: PE-TS-400/402-100-N001

VOLUME: IIB SECTION: A

REV. NO. 0 DATE: 25.08.14

Annexure I

List of Miscellaneous Pumps and drives for :

2 X 500 MW NNTPP-SG PACKAGE

Sl. No.	Pump Description	Total Qty.	Type of Pumps
1	DMCW (SG Aux.) Pumps	4 nos.	Horizontal

2 X 500 MW NNTPP-TG PACKAGE

Sl. No.	Pump Description	Total Qty.	Type of Pumps
1	ACW Pumps	6 nos.	Horizontal
2	DMCW (TG Aux.) Pumps	6 nos.	Horizontal
3	Condensate Transfer Pumps	3 nos.	Horizontal



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS  
2X500 MW NNTPP (SG & TG)  
SCOPE OF ENQUIRY

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

A

REV. NO.

0

DATE:

25.08.14

**Annexure II**

**Following HT drives, irrespective of Motor ratings shall be issue free, by BHEL:**

**2 X 500 MW NNTPP-SG PACKAGE**

- 1 DMCW (SG Aux.) Pumps

**2 X 500 MW NNTPP-TG PACKAGE**

- 1 DMCW (TG Aux.) Pumps



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS

2X500 MW NNTPP (SG & TG)

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

B

REV. NO.

0

DATE:

25.08.14

## SECTION B

### PROJECT INFORMATION



## SECTION - 2

### 2 GENERAL PROJECT INFORMATION

#### 2.1 Introduction

The project site at Neyveli has distinct location advantages, being at pit-head distance from the source of lignite supply from Mines, making it convenient for transportation of lignite by belt conveyor. Water source is readily available from the nearby mines lake. Besides, other infrastructure such as access road, railway connection etc, already exist.

#### 2.2 Power Plant Site

The power plant site is located at Neyveli, opposite to the now defunct Fertilizer and Briquetting & Carbonization Plant, near TPS-1 Expansion and TPS-II.

#### 2.3 Project & Site Information

- |         |                                 |   |  |
|---------|---------------------------------|---|--|
| (i).    | Owner/Purchaser                 | : | Neyveli Lignite Corporation Limited (NLC Ltd), Neyveli, Cuddalore District, Tamil Nadu State, India  |
| (ii).   | Consultant                      | : | Lahmeyer International (India) Pvt. Ltd (LII), Gurgaon, NCR, India.  |
| (iii).  | Project Title                   | : | 2x500 MW Neyveli New Thermal Power Station (NNTPS)   |
| (iv).   | Location                        | : | 200 kms south of Chennai and 50 kms south-west of Cuddalore  |
| (v).    | Latitude                        | : | 11° 34' 00" N to 11° 35' 00" N   |
| (vi).   | Longitude                       | : | 79° 26' 00" E to 79° 27' 00" E   |
| (vii).  | Elevation above MSL             | : | + 67 m   |
| (viii). | Nearest Railway Station         | : | Neyveli,   |
| (ix).   | Nearest Sea Port                | : | Chennai, at a distance of 200 km   |
| (x).    | Nearest Airport                 | : | Chennai, at a distance of 200 km   |
| (xi).   | Road Access/Approach to Site    | : | Connected by Chennai-Thanjavur NH 45C road and state highway connecting Cuddalore – Virudhachalam via Neyveli. Both NH and state high way roads are well connected to NLC township roads. The approach road is approximately 15 kms from Chennai–Thanjavur NH – 45C road |
| (xii).  | <b>Site Meteorological Data</b> |   |  |
|         | • Max ambient temperature       | : | 42.8° C  |

Document Number	Rev No.	Description	Page No.	Date of Issue
LII-GEOE11019-G-00156-002	02	TG, Vol-IA, IFB-NTA2	- 9-	25-Jun-11



- Min Ambient Temperature : 26.9° C
  - Wet bulb temp : 29° C
  - Max. Relative Humidity : 92 % in the month of September
  - Min. Relative Humidity : 23 % in the month of May
  - Rainfall : About 1265.7 mm annually (average)
  - Wind direction : South West to North East direction
  - Wind Speed : 97.2 km/hr (maximum recorded)  
4.3 km/hr (average wind speed)
  - Seismicity : As per IS: 1893 (part 4) (Zone-II)  
Importance factor: 1.75.
- (xiii). Languages spoken in the region : English, Tamil

\* \* \* \* \*

Document Number	Rev No.	Description	Page No.	Date of Issue
LII-GEOE11019-G-00156-002	02	TG, Vol-IA, IFB-NTA2	- 10-	25-Jun-11



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS  
2X500 MW NTPP (SG & TG)

SPECIFICATION  
NO.:  
VOLUME:  
REV. NO.

PE-TS-400/402-100-N001  
IIB  
0  
SECTION: C  
DATE: 25.08.14

**SECTION C**

**SPECIFIC TECHNICAL REQUIREMENTS**

**C1: SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS**

**C2: SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS**



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS

2X500 MW NNTPP (SG & TG)

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

C1

REV. NO.

0

DATE:

25.08.14

## SECTION C1

### SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS

SPECIFICATION NO.: PE-TS-400/402-100-N001

VOLUME: IIB SECTION: C1

2X500 MW NNTPP (SG & TG)

REV. NO. 0 DATE: 25.08.14

**1.0 SPECIFIC TECHNICAL REQUIREMENTS:**

**DELIVERY:**

Delivery of miscellaneous pumps shall be as per NIT requirement.

**2.0 Horizontal Pumps:**

**2.1** Horizontal Pumps with Mechanical seal shall be supplied with gland packing arrangement to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be despatched alongwith main supply for this purpose. Shaft sleeve and any other item required for satisfactory operation of Mechanical seal after replacement at site shall be provided by the pump supplier without any cost implication to BHEL.

**3.0 Important Note:-**

**3.1** MDCC after final inspection shall be provided to vendor on the basis of following:-

**3.1.1** List of items packed in each box with description & quantity.

**3.1.2** Photograph of each box in open & closed condition.

**3.2** Bidder to include handling instructions in engineering drg/doc and packing to be done in such a way to avoid damage of items in transit and long storage at site and same shall be approved in contract stage by BHEL/Customer.



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS

2X500 MW NTPP (SG & TG)

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

C2

REV. NO.

0

DATE:

25.08.14

## SECTION C2

### SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS



TECHNICAL SPECIFICATION FOR  
MISC. PUMPS  
(ELECTRICAL PORTION)

SPECIFICATION NO.  
VOLUME II B  
SECTION-C  
REV DATE 13.05.2014  
PAGE 1 OF 1

SPECIFIC TECHNICAL REQUIREMENTS: ELECTRICAL

1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER/ PURCHASER

- 1.1 Scope for supply, and erection & commissioning of various equipment forming part of electrical system for this package shall be as per Annexure-I to Section – C [Scope of Work (Electrical)].
- 1.2 Make of various equipment/ items in the scope of bidder shall be to approval of owner during detailed engineering stage without any commercial implications.
- 1.3 Bidder shall furnish all AC as well as DC loads required for the system at different voltage levels (eg. 415V AC, 240 V AC, 220 V DC etc.) of all types, such as motor feeders, supply feeders in PEM format along with the offer.
- 1.4 All electrical equipment shall be suitable for the power supplies, fault levels and climatic conditions indicated in project information enclosed with the specification.
- 1.5 All drawings, data sheets, Quality Plan, calculations, test reports, test certificates, etc. shall be submitted during detailed engineering stage as per formats enclosed. The same shall be subject to approval without any commercial implications.
- 1.6 Technical requirements shall be as per specifications listed in Clause 4.1, 4.2 & 4.3 below.

3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID

- 3.1 Bidder shall confirm total compliance to the electrical specification without any deviation from the technical/ quality assurance requirements stipulated. In line with this, the bidder as technical offer shall furnish two signed and stamped copies of the following:
  - a) A copy of this sheet "Electrical Equipment Specification for Misc. Pumps and sheet "Electrical Scope between BHEL and Vendor" with bidder's signature and company stamp.
  - b) List of Erection and Commissioning spares.
  - c) List of Erection & Maintenance tools & tackles.
  - d) Electrical load requirement in the load data format.
- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

4.0 LIST OF ENCLOSURES

- 4.1 Electrical scope between BHEL & vendor (Annexure-I).
- 4.2 Technical specification no. PE-SS-999-506-E101, Data Sheets (A & C) for 415V Electric Motors.
- 4.3 Quality Plan for motors.
- 4.4 Load data format (Annexure-II).

## SPECIFIC ELECTRICAL REQUIREMENT OF MOTORS FOR MISC PUMPS

SL.NO.	PARAMETERS	UNIT	NLC
<b>MOTOR</b>			
1	DESIGN AMBIENT TEMP	DEG. C	50
2	VOLTAGE SUPPLY AND VARIATION	VOLT	415V, $\pm$ 10%
3	FREQUENCY WITH VARIATION	Hz	50 (+) 5% to (-) 3%
4	COMBINED VOLTAGE & FREQUENCY VARIATION		10%
5	MAX ACCEPTABLE RATING OF MOTOR AT 415 V	KW	160 KW & below
6	SYSTEM FAULT LEVEL AND ITS DURATION	KA	50kA, 1sec
7	SUTABILITY OF TERMINAL BOX FOR FAULT LEVEL AND DURATION		50 KA, 0.25 sec
8	CLASS OF INSULATION & TEMP RISE LIMITED TO		Class-F or better and temp rise limited to Class-B
9	MIN. STARTING VOLTAGE		85%
10	MOTOR RATING FOR SINGLE PHASE SUPPLY		0.22 kW & Below
11	MAXIMUM LOCKED ROTOR CURRENT	% OF FLC	As per IS 12615
12	ACCEPTABLE NOISE LEVEL	DB	Noise level for all motors shall be limited to 85dB(A) at 1.5 m (in line with IS 12065)
13	TYPE OF STARTER PROVIDED IN MCC		DOL
14	DOP OF ENCLOSURE		IP-55 FOR OUTDOOR & IP-54 for indoor resp.
15	SPACE HEATER REQUIREMENT	<30kW	30KW & ABOVE
16	PAINT SHADE		DURING DETAIL ENGINEERING.
17	ENERGY EFFICIENT		(I) ENERGY EFFICIENT TYPE IE2 AS PER IS 12615 (II) For LT Motors above 50kW, type test reports for type tests as per IS: 325/ IS: 12615 conducted on equipment similar to those proposed to be supplied and carried out within last five years from the date of bid opening viz. February 2012 shall be submitted. However, if such reports are not available, one motor of each type shall be subjected to type tests for free of cost.

## ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR


**PROJECT: 2 x 500MW NLC**

**PACKAGE: MISC PUMP**

<u>S.NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&amp;C</u>	<u>REMARKS</u>
1	LT MCC	BHEL <sup>\$</sup>	BHEL <sup>\$</sup>	DOL starters for motors and 415V supply feeders will be provided by BHEL. The starters for motors shall be located in MCC. Vendor to furnish the load list.
2	Local push button station (for motors)	BHEL <sup>\$</sup>	BHEL <sup>\$</sup>	Located near the motor
3	Power cables, ordinary control cables and screened control cables between equipments supplied by vendor.	BHEL <sup>\$</sup>	BHEL <sup>\$</sup>	
4.	Power cables, ordinary control cables and screened control cables between equipments supplied by vendor & BHEL <sup>\$</sup> .	BHEL <sup>\$</sup>	BHEL <sup>\$</sup>	
5	Any special type of cable like compensating. Co-axial, prefab, MICC and fibre optical	--	--	
6	Cabling material (cable trays, accessories and cable tray-supporting system, conduits, M Boxes/J Boxes) for cabling between equipments supplied by vendor and BHEL.	BHEL <sup>\$</sup>	BHEL <sup>\$</sup>	
7	Conduits and conduit accessories for cabling between equipments by vendor	BHEL <sup>\$</sup>	BHEL <sup>\$</sup>	
8	Equipment earthing.	BHEL	BHEL	
9	Motors with Base frame and fixing hardware for motors.	Vendor	BHEL	Makes shall be subject to customer/BHEL approval at contract stage.
10	Cable glands and lugs for equipment supplied by vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass /tinned brass glands. 2. Solder less crimping type heavy-duty tinned copper/heavy duty aluminium lugs for power cables. 3. Heavy duty tinned copper lugs for control cables.
11	a) Input cable schedules b) Cable interconnection details. c) Cable block diagram	Vendor Vendor Vendor	- - -	Cable listing for control cables for vendor-supplied equipment (soft copies in the BHEL cable schedule format) shall be furnished during detail engineering by vendor.
12	Equipment layout drawings.	Vendor	-	Layout details between vendor supplied equipment and installation drawings by vendor
13	Any other item for completeness of system.	Vendor	BHEL	Supply of any other item for completeness of electrical work ( although not mentioned specifically but required for trouble free operation of system) shall be deemed to be included in the scope of vendor without any extra charge.

Notes-

1. All QPs shall be subject to approval of BHEL/ Customer after award of contract.
2. Make of all electrical equipments/ items supplied shall be of reputed make & shall be subject to approval of BHEL/ Customer after award of contract.
3. \$: Shall be in customer scope where equipment are supplied by customer.


	<b>TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS</b>  2X500 MW NTPP (SG & TG)	SPECIFICATION NO.: PE-TS-400/402-100-N001			
		VOLUME:	IIB	SECTION:	D
		REV. NO.	0	DATE:	25.08.14

## SECTION D

### STANDARD TECHNICAL SPECIFICATIONS

**D1: STANDARD TECHNICAL SPECIFICATIONS FOR PUMPS**

**D2: STANDARD TECHNICAL SPECIFICATIONS FOR MOTORS**

	<b>TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS</b>  <b>2X500 MW NNTPP (SG &amp; TG)</b>	<b>SPECIFICATION NO.:</b> PE-TS-400/402-100-N001	
		<b>VOLUME:</b> IIB	<b>SECTION:</b> D1
		<b>REV. NO.</b> 0	<b>DATE:</b> 25.08.14

## SECTION D1

**STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS NO. PE TS-179-06**

**DATA SHEET A ALONGWITH LIST OF MANDATORY SPARES & WATER ANALYSIS**

**QUALITY PLAN**

**DATA SHEET C**



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 1 of 14

**1.00.00 GENERAL INFORMATION**

1.01.00 The general guidelines as illustrated in the subsequent clauses of this section shall be applicable for horizontal centrifugal pumps to be procured under the scope of this package.

**2.00.00 CODES AND STANDARDS**

2.01.00 In addition to the requirements spelt out elsewhere in the specification, the equipment to be provided under this section shall specifically conform to the following codes, standards, specifications and regulations, as applicable, including all the latest amendments subsequent to the year of publication as mentioned below.

- |         |  |  |
|---------|--|--|
| 2.01.01 | IS-1520/1980:                            | Horizontal Centrifugal pumps for clear, cold and fresh water.                          |
| 2.01.02 | IS-5120/1977:                            | Technical requirements for Rotodynamic special Purpose pumps.                          |
| 2.01.03 | IS-5639/1970:                            | Pumps for handling chemicals & corrosive liquids.                                      |
| 2.01.04 | IS-5659/1970:                            | Pumps for process water.   |
| 2.01.05 | IS-6536/1972:                            | Pumps for handling volatile liquids.   |
| 2.01.06 | IS-9137/1978:                            | Code for acceptance tests for centrifugal, mixed flow and axial flow pumps- Class 'C'. |
| 2.01.07 | ISO 3555/1977:<br>BS 5316/1977<br>Part 2 | Acceptance test for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.    |
| 2.01.08 | ISO 2548/1973:<br>BS 5316/1976<br>Part 1 | - Do - Class 'C' tests.  |
| 2.01.09 | API-610/1989:                            | Centrifugal pumps for general refinery services.                                       |
| 2.01.10 | HIS                                      | Hydraulic Institute Standards, USA   |
| 2.01.11 | PTC 8.2/1965:                            | Power Test Codes - Centrifugal pumps.  |
| 2.01.12 | ASTM-1-165-55                            | Standard Methods for Liquid Penetration Inspection.                                    |

2.02.00 In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding on the bidder.



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 2 of 14

**3.00.00 SCOPE OF SUPPLY & SERVICES:**

3.01.00 The miscellaneous pumps and drives scope shall be as specified in Data Sheet A /Section A.

3.02.00 The Capacity, Head, Materials of construction and other particulars of pumps are detailed in Data Sheet A of the specification.

3.03.00 Accessories:

All the pumps under this specification shall be complete with following standard/special accessories.

3.03.01 Standard accessories:

- a) LT Electric drives/motors (as applicable) with cable gland and lugs at motor end. (The bare HT drive motors and LT motors not in bidder's scope of supply, wherever required supplied as free issue by BHEL refer Cl. 5.08.00).
- b) Pump motor coupling along with coupling guard.
- c) Common base plate for pumps and motor.
- d) Self contained lubrication system along with all internal piping, valves, fittings, specialties etc. as required.
- e) Counter flanges for suction/ discharge nozzles along with fixing nuts, bolts and gaskets.
- f) Anchor bolts, nuts, seating steel works, shims etc. as necessary for mounting the pump-motor unit on Civil foundations.
- g) Suitable vent (with valves)/ lifting/ handling attachments for the pump/ motor/ accessories.
- h) Suitable drain connections with isolating valves as applicable.
- i) Supply of first fill of lubricants with topping requirements for one year of operation after commissioning and handing over of equipment.
- j) Set of "Special" Tools & Tackles for Pumps and motors, if any.
- k) Erection and commissioning spares, "on as required" basis.
- l) Bidder shall provide various drawings, data, calculations, test reports/ certificates, operation and maintenance manuals, As-built drawings, etc. as specified and as necessary.



<b>TITLE:</b>  <b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>VOLUME:</b> II B	
	<b>SECTION:</b> D	
	<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
	<b>SHEET</b> 3 of 14	

m) Mandatory spares as specified in respective Data Sheet-A of this section.

3.04.00 Services included in Bidder's Scope:

3.04.01 The pumps shall be guaranteed to meet the performance requirements specified vide Data Sheet -A and also for trouble free operation after commissioning. Schedule of performance guarantees (enclosed in Volume-III) duly filled and signed shall be furnished with the bid.

3.04.02 Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose.

3.04.03 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning.

3.04.04 After commissioning of pumps at site, site performance test for Noise, vibration and parallel running of pumps of all pumps for each unit/project will be conducted by BHEL at project site to ensure that the pumps meet the specified requirements. In case of any deficiency, the vendor shall rectify the same at site at no additional cost to BHEL.

3.04.05 Performance Guarantees for pumps shall stand valid till the satisfactory completion of performance testing by BHEL and its acceptance by purchaser / customer.

3.05.00 Works excluded from Bidder's Scope:

- a) All HT motors and those LT Motors which are specifically excluded.
- b) Civil foundation
- c) Suction/ discharge pipe works
- d) MCC/ Switchgear/Power supply
- e) Power and Control Cables, unless specifically specified in Electrical/ Systems portion of the specification.
- f) Erection of equipments.

**4.00.00 BID EVALUATION CRITERIA & LIQUIDATED DAMAGES FOR SHORTFALL:**

4.01.00 The bids received shall be evaluated for power consumption at inlet to the motors, in respect of pumps specified in Data Sheet-A (working pump only viz. not the standby), for the purpose of price comparisons as briefed below:

The bid evaluation shall be done at the rate as specified in Data Sheet A per one (1) KW Power consumption, per working pump as follows.

$$\text{KW} = \frac{Q \times H \times S}{P \times M \times 367.2}$$



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 4 of 14

Where Q = Rated capacity M<sup>3</sup>/hr  
H = Rated TDH, MWC  
P = Pump Efficiency  
M = Motor Efficiency.  
S = Specific Gravity of fluid handled

4.02.00 The efficiencies for pumps and motors for arriving at benchmark power for Bid Evaluation shall be as indicated in Data Sheet A for various pumps.

No advantage shall be given to the bidder for Aux. Power quoted lower than the Bench mark values calculated with KW calculation formula at Cl. 4.01.00 above, considering the bid evaluation efficiencies for pump and motor as indicated in Data Sheet-A. However the bids shall be evaluated as above if the Aux. Power quoted are higher than Bench mark values.

NOTE:

1. Efficiencies for HT motors and LT motors not in bidder's scope, for bid evaluation purpose shall be taken based on the maximum value as furnished in Data Sheet A.
2. During contract stage the Guaranteed power consumption of Pumps with BHEL supplied drives (HT/LT) for successful bidder shall be reworked by BHEL as below:

Revised guarantee power consumption shall be as per KW calculation formula at Cl. 4.01.00 above, where  $P$  = pump efficiency guaranteed by bidder and  $M$  = motor efficiency as per approved datasheet of the supplied HT/LT motor.

4.03.00 Liquidated damages for shortfall in Guaranteed KW

The above guaranteed power consumption shall be demonstrated by the successful bidder during performance testing at works/ site.

For pumps with BHEL supplied drives, the power consumption shall be compared with the reworked guarantee power consumption, defined as per note no. 2 of Cl. 4.02.00 above for the purpose of shortfall.

The liquated damages @ twice the bid evaluation rate as above per KW per working pump shall be levied in the event of failure of bidder to demonstrate the guaranteed power consumption.

**5.00.00 TECHNICAL REQUIREMENTS:**

5.01.00 The pumps shall meet the technical requirements of section "D" as well as Data Sheet - A. Wherever there is contradiction between Section D and Data Sheet-A, the latter shall prevail. In the event of any contradiction of section "D" with Section-C, the Section-C will prevail.

5.02.00 The pumps shall be Electric motor driven.



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B


**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 5 of 14

- 5.03.00 The Pumps shall conform to HIS. It is bare minimum requirement, however, any other equivalent or stringent standard is also acceptable, if, all the requirements of HIS are also met.
- 5.04.00 The horizontal pumps shall be Horizontal split casing type with speeds not exceeding 1500 RPM or as indicated in Data Sheet-A.
- 5.05.00 No negative tolerance shall be permitted in rated capacity & TDH.
- 5.06.00 No negative tolerance shall be permitted in efficiency at rated capacity.
- 5.07.00 The shut off head of pumps shall be more than pump rated TDH and percentage variation may vary depending on the specific speed of the pump as under:
- 10-15% for pumps of specific speed up to 1000 US units,
  - 15-20% for pumps of specific speed in the range of 1000 to 2000 US units,
  - 20-40% for pumps of specific speed in the range of 2000 to 4000 US units,
  - Above 50% for pumps of specific speed in the range of 4000 to 7000 US units.
- 5.08.00 All HT motors and those LT motors which are not in bidder's scope of supply : bare motors only, shall be supplied as free issue by BHEL through BHEL, based on ratings and TS (Torque - Speed) curve selected and furnished by the bidders along with their un-priced bid. The responsibility for satisfactory operation for combined performance of pumps & motors shall rest with the bidder only as if, the drive motors also have been supplied by the bidder.
- Couplings, base plate, foundation bolts, any other fittings, etc. as required shall be supplied by the bidders only. BHEL shall supply one number of each type of drive motors (where drive motor is not in bidder's scope of supply) for shop testing of pumps with job motors. All other motors shall be dispatched by BHEL directly to project sites.
- 5.09.00 For all HT motor driven pumps, BHEL has envisaged vibration-monitoring system in their own scope. The bidder shall make provisions for mounting following on the pump/ pump shaft:
- Purchaser's probes in both DE/NDE bearings of pumps
  - Key slots on pump shaft with dimensions as specified in Data Sheet A.
  - Other components as finalized during detailing.
  - For mounting of above on the HT motors, same shall be taken care by BHEL - Bhopal.
- 5.10.00 The pumps shall be capable of developing the required total head at rated capacity for continuous operation. The pumps shall operate satisfactorily at any point on the Q-H characteristic curve over a range of 0% to 130% capacity and shall be suitable for continuous operation between 30% to 130% capacity.

	<b>TITLE:</b>  <b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS</b>	<b>SPECIFICATION NO.</b> PES-179-06	
		<b>VOLUME:</b> II B	
		<b>SECTION:</b> D	
		<b>REV. NO.</b> 03	<b>DATE:</b> 16.07.2012
		<b>SHEET</b> 6 of 14	
5.11.00	<p>Selection of the pumps shall be such that the design point shall be met even with negative manufacturing tolerance.</p>		
5.12.00	<p>The total head capacity curve shall be continuously rising towards the shut off, the pumps shall preferably be non-overloading type and stable.</p>		
5.13.00	<p>The pumps shall be capable of running over the entire range of NPSH conditions required without any noise, vibration or cavitations.</p> <p>The prevailing suction pressures for various pumps are indicated in Data Sheet-A for suitable mechanical design of pumps.</p>		
5.14.00	<p>The pumps shall be of stiff shaft design. The minimum internal clearances should be sufficiently more than the max. static deflection of the shaft. Shaft size selected must take into consideration the critical speed as specified in API-610.</p>		
5.15.00	<p>Pumps and motors shall run smooth without undue noise and vibration.</p> <p>The vibration shall be within vibration norms for testing as per American National Standard for 'Rotodynamics Pump' for Vibration Measurement and allowable values, Doc. ANSI/ HIS 9.6.4-2009. The applicable vibration limits for each pump, shall be indicated in the Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO.</p> <p>The noise level shall be limited to 85 dB at distance of 1.0M.</p>		
5.16.00	<p>Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.</p>		
5.17.00	<p>After installation, the guaranteed values of noise, vibration and parallel operation of pumps shall be tested and verified. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.</p>		
5.18.00	<p>High reliability of the pumps is an essential requirement and therefore it gets weightage over its efficiency. It is therefore essential that the bidder choose a standard proven model from the range of pumps manufactured.</p>		
5.19.00	<p>The offered pumps shall be of proven design meeting the experience-qualifying requirement of their operation at two sites for a minimum period of two years. Any deviation to this criterion shall be suitably highlighted in the deviations schedule.</p>		
5.20.00	<p>The bearings shall be self-water lubricated, no external water supply shall be available. The cooling/ lubrication water for bearings, etc. shall be tapped from the pump discharge and supplied thru' bidder's integral pipe work.</p>		



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 7 of 14

If water handled by pump is dirty/ not suitable for lubrication/ cooling, the bidder shall provide requisite strainer/ filters, tanks, motorized valves, etc. after the tap off for the required service, the arrangement provided shall be subject to Purchaser's approval.

**6.00.00 MANDATORY SPARES:**

- 6.01.00 Bidder to provide the Mandatory spares listed vide Data Sheet-A. Unit price of mandatory spares shall be furnished in price Schedule.
- 6.02.00 Bidder shall include the cost of Mandatory Spares in the base price of the pump, unless specified otherwise in Sec-C of the specification or NIT.

**7.00.00 OTHER REQUIREMENTS:**

- 7.01.00 The quality of water handled by various pumps shall be as per Data Sheet-A.
- 7.02.00 The materials of construction for various components specified are the minimum requirements and materials of construction for other components not specified shall be similarly selected by the bidder for the intended duty.
- 7.03.00 The makes of various bought out items of bidder (i.e. motor, bearings, mechanical seal etc.) shall be subject to purchaser's approval in the event of order.
- 7.04.00 Painting for Pumps
- The surface of SS, Gun metal, brass, bronze and non-metallic component shall not be applied with any painting.
  - The Steel surface to be applied with painting shall be thoroughly cleaned before applying painting by brushing, shop blasting etc. as per the agreed procedure.
  - For all the steel surfaces inside the (indoor installation) building, a coat of red oxide primes of min. thickness DFT of 50 microns followed up with under coat of Synthetic Enamel paint of min. thickness DFT of 50 microns shall be applied. The top coat shall consist of two coats each of min. thickness DFT of 50 microns of synthetic enamel paint and thus total DFT shall be min. 200 microns.
  - For all the steel surfaces exposed to (outdoor installation) atmosphere, a coat of chlorinated rubber based zinc phosphate primer of min. thickness DFT of 50 microns followed up with under coat of chlorinated rubber paint of min. thickness DFT of 50 microns shall be applied. Then, intermediate coat consisting of one coat of chlorinated rubber based paint pigmented with Titanium di-oxide with min. thickness DFT of 50 microns and top coat shall consist of two coats each of min. thickness DFT of 50



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 8 of 14

microns of chlorinated rubber paint shall be provided. Total DFT of paint system shall be min. 200 microns.

**7.05.00** It is mandatory for the bidder to submit along with the bid, the deviations if any – whether major or minor in the schedule of deviations only. In the absence of deviations listed in the “Schedule of deviations, the offer shall be deemed to be full conformity with the specification, “notwithstanding” anything else stated elsewhere in bidder’s offer. The implied/indirect deviations shall not be binding on the purchaser.

**8.00.00 PERFORMANCE REQUIREMENTS**

8.01.00 Performance requirements for the pumps shall be as guided in Data sheet - A enclosed with this section.

8.02.00 Pump(s) shall preferably be designed to have the best efficiency at flow within  $\pm 10\%$  of the specified duty point flow. The pumps shall be suitable for continuous operation at any point within the “Range of Operation” as stipulated in the Data Sheet - A attached with this section.

8.03.00 Pump(s) shall preferably have a continuously rising head-capacity characteristics from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation.

Under all circumstances, the ‘range of operation’ of the pumps shall exclude any unstable operating zone of the head-capacity curve.

8.04.00 Wherever specified in the Data Sheet - A attached to this section, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.

8.05.00 The pump set along with drive motor shall run smooth without undue noise and vibration. Acceptable vibration limits shall be guided by the HIS of USA. Refer clause 5.15.00 above for permissible limits.

**9.00.00 DESIGN AND CONSTRUCTION**

**9.01.00 Pump Casing**

9.01.01 Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves. It shall be provided with a connection for suction and discharge pressure gauge as standard feature.

9.01.02 Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 9 of 14

- 9.01.03 In case where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.
- 9.02.00 **Impeller**
- 9.02.01 The Impeller assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.
- 9.03.00 **Wearing Rings**
- 9.03.01 Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.
- 9.04.00 **Shaft**
- 9.04.01 Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall be at least 30% higher than the rated speed.
- 9.05.00 **Shaft Sleeves**
- 9.05.01 Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past Shaft and shaft sleeve and that past the seals/glands.
- 9.05.02 Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft sleeve assembly should ensure concentric rotation.
- 9.06.00 **Bearings**
- 9.06.01 Bearings shall be easily accessible without disturbing the pump assembly. A drain shall be provided at the bottom of each bearing housing.
- 9.06.02 Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.
- 9.06.03 In case of sleeve type radial, axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.
- 9.06.04 Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation. Life of the bearings shall be guided by the design standard of the pump. Antifriction bearings of standard type, if provided, shall be selected for a minimum



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 10 of 14

life 20,000 hrs. of continuous operation at maximum axial and radial loads at rated speed. Thrust bearing shall be capable of running continuously at maximum load.

9.06.05 The bearing shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete with all accessories like pump, filters, piping, fittings, valves, interlocking and supervising instruments etc. as necessary. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.

9.06.06 Bearings of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.

9.07.00 **Stuffing Boxes**

9.07.01 Stuffing box design shall permit replacement of packing without removing any part other than the gland.

9.07.02 Stuffing boxes shall be sealed/cooled by the fluid being pumped/external clear water, as specified in the Annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the Annexure shall be included in the scope of supply.

9.08.00 **Mechanical Seals**

9.08.01 Mechanical seals (cartridge type) shall be provided if specified in the Data Sheet-A of this section. The pump supplier shall co-ordinate with the seal maker in establishing the direct circulation rate for maintaining a stable film at the seal in the chamber. The seal piping system shall form an integral part of the pump assembly.

9.08.02 When handling liquids near boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.

9.08.03 For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.

9.08.04 Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. The special tools (if any) required for above shall be arranged by bidder.

9.08.05 Mechanical seals of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.

9.09.00 **Drive Unit**



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 11 of 14

9.09.01 The pumps shall be driven by electric motor directly coupled as specified in the Data Sheet-A of this section. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit.

9.09.02 Unless otherwise specified in Data Sheet-A of this section, drive unit power rating shall be the maximum of the following requirements.

- a) 15% margin over the pump shaft input power at the rated duty point.
- b) 5% margin over the maximum pump shaft input power required within the 'Range of Operation'.
- c) Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.

9.10.00 **Coupling for pump & Motor Shaft**

9.10.01 The pump and motor shafts shall be connected with adequately sized flexible coupling of proven design with spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guard shall be provided.

9.10.02 No. of coupling holes for joining coupling hubs shall be even in number and preferably in multiples of four.

10.00.00 **INSPECTION AND TESTING**

10.01.00 The Quality Plans enclosed in the specification are for bidder's guidance only. The bidder shall comply with these and other minimum requirements specified in the specification and shall furnish his own quality plan in the event of order based on the guidance given as above, for approval by BHEL/Customer.

10.02.00 The Bidder shall carry out the following specific tests inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.

a) **Identification and Testing**

- i) All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standard and test certificates shall be made available to the Owner.
- ii) 100% PMI (Process Material Identification) inspection for material grade of pump casing, shaft and impeller shall be done by vendor & certification shall be submitted for review of BHEL. Further BHEL reserves the right to conduct



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 12 of 14

random & independent PMI inspection on pump casing, shaft and impeller to ascertain the grade of material during inspection at vendor works.

iii) Tests for each pump included under this section shall include but not be limited to the following:

- The entire surface of the impeller / casing / diffuser castings shall be subjected to Dye Penetration Test as per ASTM Specification no.:1-165-65.
- Shaft coupling & other active components shall be subjected to Dye Penetration and Ultrasonic Tests.
- Wearing rings, shaft sleeves shall be subjected to Dye Penetration Test.
- Fabricated components of pumps shall be subjected to Dye Penetration test on weld.
- Verification of material, witnessing of pouring, casting and inspection of finished fabricated/castings.
- Inspection of finished castings for impeller and verification of materials.
- Inspection of pump shaft and verification of material.
- Witnessing of NDT/review of NDT reports.
- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940 to grade 6.3 or better.
- Complete Inspection of assembled pump.

**b) Hydraulic Testing**

The pump casing shall be hydrostatically tested at maximum of the following:

- i. 2 times the TDH (Total Dynamic Head) at rated capacity (or)
- ii. 1.5 times the shut-off pressure (or)
- iii. System Design pressure indicated in Data Sheet-A of this section.

The HT pressure shall be maintained for a period of not less than 30 minutes. During testing there should not be any pressure drop & leakage.

**c) Performance Test at Shop**

i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 13 of 14

of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard.

- ii) Performance tests are to be conducted to cover the entire range of operation of the pumps at rated speed. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals.
- iii) Tests shall be conducted with actual drive motors being furnished.
- iv) NPSH tests are to be conducted for each type at 3% head drop conditions, if specified in the pump approved QP.
- v) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.

10.03.00 Inspection of Mandatory/ Recommended spares shall be in line with approved QP for main supply.

**11.00.00 DRAWINGS/ DOCUMENTS DISTRIBUTION SCHEDULE**

11.01.00 After award of LOI, the successful bidder shall submit drawings/documents as per Data Sheet-C.

11.02.00 The no. of drawings/documents to be submitted shall be as per Annexure to Data Sheet-C.

12.00.00 The various Sections-C's & D's along with Data Sheets attached in this specification together with the specification for Miscellaneous Pumps shall be complied with by the bidders.

13.00.00 Bidder to submit all drawing/ documents in soft as well as hard copy within 2 weeks from placement of LOI's in the event of order.

Within one (1) week of receipt of BHEL comments a technical representative from Bidder's works shall come for meeting with BHEL along with revised documents to resolve all issues and incorporate all comments in the soft copy here only for further submission to customer.

Further on receipt of customer's comments on the documents a technical representative from Bidder's works shall come for meeting with Customer to resolve all issues and incorporate all comments in the soft copy here only and further resubmission of same to



**TITLE:**

**STANDARD TECHNICAL SPECIFICATION  
HORIZONTAL CENTRIFUGAL PUMPS**

**SPECIFICATION NO.** PES-179-06

**VOLUME:** II B

**SECTION:** D

**REV. NO.** 03

**DATE:** 16.07.2012

**SHEET** 14 of 14

Customer. The representative shall be available here till Category-I approval of all the drawings and documents.


14.00.00 Guarantee for all pumps shall at least remain valid for 18 months from the Unit commissioning date or as specified in NIT.


**15.00.00 The following documents only shall be furnished by the bidder with his offer:**

- a) Compliance certificate duly signed and stamped (enclosed at Vol. III of specn.).
- b) GA drawings of pumps and motors with following: (shall be only for reference purpose, same shall not be reviewed/commented by purchaser at this stage and shall be subject to approval only during contract).
  - Civil static & dynamic loads.
  - Foundation details.
- c) Guarantee Schedule duly signed and stamped (enclosed at Vol. III of specn.).
- d) Technical deviation schedule (if reqd.) (enclosed at Vol. III of specn.).
- e) Data for drive Motor (HT/LT- which is not in bidder's scope of supply - as applicable):  
Load torque speed curves of the pumps, selected motor rating, rpm,  $GD^2$  of driven equipment.

**Apart from above no other Drgs./Docs./Data sheets etc. are required to be submitted at bid stage and even if furnished shall not be taken cognizance of.**

DM/BBHE/179-06/14  
60785/2014/001/14

	TECHNICAL SPECIFICATION FOR		SPECIFICATION NO.:	PE-TS-400/402-100-N001
	MISCELLANEOUS PUMPS (HORIZONTAL)		REV. NO.:	00, DATE: 04.10.2014
	DATA SHEET-A		VOLUME :	II B, SECTION-D
	PROJECT/PACKAGE:	2 X 500 MW NEW NEYVELI TPP (NNTPP)-SG PACKAGE		
<b>Sl. No.</b>	<b>DESCRIPTION</b>	<b>DMCW (SG AUX.) PUMPS</b>		
<b>1.0</b>	<b>SERVICE</b>			
1.1	Total no. of pumps for Project	4		
1.2	No. of working & standby pumps	(1W+1S) per unit		
1.3	Liquid Handled (ref. water analysis enclosed herein)	pH corrected DM Water		
1.4	Location (Indoor / Outdoor)	Indoor		
1.5	Duty	Continuous		
1.6	No. of pumps working in parallel	1		
1.7	Specific gravity	1		
1.8	System design pressure (kg/sqcm (g))	12		
<b>2.0</b>	<b>DESIGN PARAMETERS</b>			
2.1	Design capacity each, M <sup>3</sup> /hr	1070		
2.2	Total dynamic head (MWC)	65		
2.3	Suction Pressure(MWC)	32		
2.4	Design Temperature (°C)	60		
2.5	Maximum permissible speed of pump (RPM)	1500		
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 51.5 Hz	Not to exceed 78 MWC		
2.7	Operating range	30% to 130% of design duty point flow		
2.8	Motor rating	Motor rating (at 50 deg. C ambient) shall be at least 15% above the maximum load demand of the driven equipment at any condition of the entire characteristic curve of the pump including voltage and frequency variations.		
2.9	Permissible tolerance in rated capacity & TDH	no negative tolerance		
2.10	Permissible tolerance in efficiency at rated capacity(%)	no negative tolerance		
2.11	Performance/Design Standard	HIS		
<b>3.0</b>	<b>CONSTRUCTION FEATURES</b>			
3.1	Pump type	Horizontal centrifugal type Between Bearing Pump		
3.2	Impeller type	Closed		
3.3	Casing type	Axial split type		
3.4	Coupling type	Spacer type		
3.5	Sealing arrangement	Gland packing initially & Mechanical seal finally after commissioning		
3.6	Type of Lubrication	Oil/ Grease/ Self Liquid		
3.7	Pump characteristics	Non Overloading type & stable		
3.8	Drain Plugs, vent, lifting lugs, priming connection, Coupling guard etc.	Required		
<b>4.0</b>	<b>MATERIALS OF CONSTRUCTION</b>			
4.1	Casing	ASTM A 351 CF8M		
4.2	Impeller	ASTM A 351 CF8M		
4.3	Shaft	SS 316		
4.4	Shaft Sleeves	SS-410		
4.5	Impeller Wearing rings	SS 316		
4.6	Shaft coupling	SS		
4.7	All Fasteners	SS		
4.8	Gland/Seal Cover	SS 316		
4.9	Lantern Ring	SS 316		
4.10	Mech. seal	Manufacturer standard		
4.11	Gland Packing	PTFE/ Grafoil		
4.12	Base Plate	MS fabricated IS-2062 (min. thk.-10 mm) Epoxy Coated		
4.13	Stuffing Box	ASTM A 351 CF8M		
4.14	Casing Wearing rings (If applicable)	SS 316		
4.15	Connecting Pipe material (for deciding counterflange material)	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589		
<b>5.0</b>	<b>MANDATORY SPARES :</b>			
5.1	Impeller	2 Nos.		
5.2	Shafts	1 No.		
5.3	Shaft Sleeve	3 Sets		
5.4	Casing Wear ring	6 Sets		
5.5	Impeller bearings	2 Sets		
5.6	Thrust bearings	2 Sets		
5.7	Radial bearings	2 Sets		
5.8	Gland Packing	2 Sets		
5.9	Fastners	1 Set		
5.10	Complete coupling (pump & motor)	1 Set		
<b>Remark:</b>	1.0 In case the description / nomenclature of any of the items is differing from the description / nomenclature indicated in the list, the bidder shall offer functionally equivalent part in lieu of the listed item and indicate the same in their offer. 2.0 After the award and during detailed engineering stage, if any items are found "not applicable" then the Bidder shall have to supply alternative items. The alternative items are to be mutually agreed between the PURCHASER and CONTRACTOR.			
<b>6.0</b>	<b>BID EVALUATION RATE</b>			
6.1	Bid evaluation rate	Rs.2 Lacs/KW		
6.2	Maximum permissible efficiency for Bid evaluation			
6.2.1	Pump Efficiency	84		
6.2.2	Motor Efficiency	94		
<b>Notes :</b>				
1	Material of construction for other components not specified above shall be similarly selected in line with the above for the duty intended and subject to approval.			
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.			
3	For all HT motor driven pumps (wherever applicable), bidder shall provide key slots of dimensions 30mm Lx15 mm W x3 mmD on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL.			
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.			

	TECHNICAL SPECIFICATION FOR		SPECIFICATION NO.:	PE-TS-400/402-100-N001
	MISCELLANEOUS PUMPS (HORIZONTAL)		REV. NO.: 00	DATE : 04.10.2014
DATA SHEET-A		VOLUME : II B		SECTION : D
PROJECT/PACKAGE		2 X 500 MW NEW NEYVELI TPP (NNTPP)-TG PACKGE		
Sl. No.	DESCRIPTION	ACW PUMPS	DMCW (TG AUX.) PUMPS	CONDENSATE TRANSFER PUMPS
<b>1.0</b>	<b>SERVICE</b>			
1.1	Total no. of pumps for Project	6	6	3
1.2	No. of working & standby pumps	(2W+1S) per unit	(2W+1S) per unit	(2W+1W) for station
1.3	Liquid Handled (ref. water analysis enclosed herein)	Clarified water	pH corrected DM Water	DM Water
1.4	Location (Indoor / Outdoor)	Indoor	Indoor	Indoor
1.5	Duty	Continuous	Continuous	Continuous
1.6	No. of pumps working in parallel	2	2	2
1.7	Specific gravity	1	1	1
1.8	System design pressure (kg/sqcm (g))	7.5	10	10
<b>2.0</b>	<b>DESIGN PARAMETERS</b>			
2.1	Design capacity each, M <sup>3</sup> /hr	1650	1070	100
2.2	Total dynamic head (MWC)	18.5	38	75
2.3	Suction Pressure(MWC)	15	32	Flooded suction
2.4	Design Temperature (°C)	60	60	60
2.5	Maximum permissible speed of pump (RPM)	1500	1500	3000
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 51.5 Hz	Not to exceed 30 MWC	Not to exceed 46 MWC	-
2.7	Operating range	-----30% to 130% of design duty point flow-----		
2.8	Motor rating	Motor rating (at 50 deg. C ambient) shall be at least 15% above the maximum load demand of the driven equipment at any condition of the entire characteristic curve of the pump including voltage and frequency variations.		
2.9	Permissible tolerance in rated capacity & TDH	no negative tolerance		
2.10	Permissible tolerance in efficiency at rated capacity(%)	no negative tolerance		
2.11	Performance/Design Standard	HIS		
<b>3.0</b>	<b>CONSTRUCTION FEATURES</b>			
3.1	Pump type	-----Horizontal centrifugal type Between Bearing Pump-----		
3.2	Impeller type	Closed	Closed	Closed
3.3	Casing type	Axial split type	Axial split type	Axial split type/Radial split type
3.4	Coupling type	spacer type	Spacer type	spacer type/Flexible type
3.5	Sealing arrangement	Gland packing	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning
3.6	Type of Lubrication	Oil/ Grease/ Self Liquid	Oil/ Grease/ Self Liquid	Oil/ Grease/ Self Liquid
3.7	Pump characteristics	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable
3.8	Drain Plugs, vent, lifting lugs, priming connection, Coupling guard etc.	Required		
<b>4.0</b>	<b>MATERIALS OF CONSTRUCTION</b>			
4.1	Casing	2 % Ni Cl to IS 210 FG 260	ASTM A 351 CF8M	SS 304
4.2	Impeller	ASTM A 351 CF8M	ASTM A 351 CF8M	SS 304
4.3	Shaft	SS-410	SS 316	SS 410
4.4	Shaft Sleeves	SS-410 (hardened)	SS-410	SS-410 (hardened)
4.5	Impeller Wearing rings	SS 316	SS 316	SS 304
4.6	Shaft coupling	SS 410 (Hardened)	SS	SS
4.7	All Fasteners	SS	SS	SS
4.8	Gland/Seal Cover	SS 316	SS 316	SS-304
4.9	Lantern Ring	SS 316	SS 316	SS 304
4.10	Mech. seal	NA	Manufacturer standard	Manufacturer standard
4.11	Gland Packing	PTFE/ Grafoil	PTFE/ Grafoil	PTFE/ Grafoil
4.12	Base Plate	MS fabricated IS-2062 (min. thk.-10 mm) Epoxy Coated		
4.13	Stuffing Box	2 % Ni Cl to IS 210 FG 260	ASTM A 351 CF8M	SS 304
4.14	Casing Wearing rings (If applicable)	SS 316	SS 316	SS 304
4.15	Connecting Pipe material (for deciding counterflange material)	Carbon Steel as per IS:2062; Plates rolled & welded as per IS 3589	Carbon Steel as per IS:2062; Plates rolled & welded as per IS 3589	SA 312 TP 304 (stainless steel)
<b>5.0</b>	<b>MANDATORY SPARES: NIL</b>			
<b>6.0</b>	<b>BID EVALUATION RATE</b>			
6.1	Bid evaluation rate	Rs.2 Lacs/KW	Rs.2 Lacs/KW	Rs.2 Lacs/KW
6.2	Maximum permissible efficiency for Bid evaluation			
6.2.1	Pump Efficiency	86	84	65
6.2.2	Motor Efficiency	92.8	94	90
<b>Notes :</b>				
1	Material of construction for other components not specified above shall be similarly selected in line with the above for the duty intended and subject to approval.			
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.			
3	For all HT motor driven pumps (wherever applicable), bidder shall provide key slots of dimensions 30mm Lx15 mm W x3 mmD on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL.			
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.			

## Clarified Water Analysis and Cycle of Concentration.

### A. Clarified Water Quality:

S. No	DESCRIPTION	Unit	Tentative Values
1.0	Total dissolved solids	mg/l	425
2.0	Suspended solids /Turbidity	mg/l	20
3.0	Calcium hardness as CaCO <sub>3</sub>	mg/l	120
4.0	Magnesium hardness as CaCO <sub>3</sub>	mg/l	78
5.0	Sodium + Potassium as CaCO <sub>3</sub>	mg/l	95.35
6.0	Chloride as CaCO <sub>3</sub>	mg/l	84.6
7.0	Sulphate as CaCO <sub>3</sub>	mg/l	84.7
8.0	M alkalinity as CaCO <sub>3</sub>	mg/l	160
9.0	P alkalinity as CaCO <sub>3</sub>	mg/l	Nil
10.0	Iron as CaCO <sub>3</sub>	mg/l	1.25
11.0	Silica as SiO <sub>2</sub>	mg/l	36.4
12.0	Aluminium as CaCO <sub>3</sub>	mg/l	2.0
13.0	Conductivity at 30 °C	m-mho/cm	705
14.0	pH at 30 °C		7.0
15.0	Free CO <sub>2</sub>		19.36
16.0	Total hardness (as CaCO <sub>3</sub> )	mg/l	198

### B. Cycle of concentration: 5

-----

### WATER ANALYSIS FOR DM WATER

Sl. No.	Characteristics	Value
1.	Silica (MAX.)	0.02 ppm as SiO <sub>2</sub>
2.	Iron as Fe	Nil
3.	Total Hardness	Nil
4.	pH Value	6.8-7.2
5.	Conductivity	Not more than 0.1 micro mhos / cm excluding the effects of free CO <sub>2</sub>

pH for passivated DM water shall be 8.5 to 9.5

**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
SHEET 1 OF 6			SYSTEM			BIDDER/VENDOR			QUALITY PLAN NUMBER		PE-QP-999-100-N004 (For Hor. Pumps) PE-QP-999-100-N004 (For Ver. Pumps)	
						ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1	<b>MATERIALS CONTROL</b>											
1.1	CASINGS (INCLUDING BOWLS,DIFFUSERS, STAGE BODIES, DISCH HEAD (IF CAST)), ETC, - (AS APPLICABLE) AND IMPELLER	MECHANICAL AND CHEMICAL PROPS	CR	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.		2,1	
1.2	STUFFING BOX, SUCTION BELL, WEARING RINGS,NECK RINGS, SHAFT SLEEVES	DO-	MA	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.		2,1	
		HARDNESS DIFFERENCE BETWEEN CASING / IMPELLER AND WEARING RING	MA	LAB. TEST	100%	APPROVED CS DRAWING/ DATA SHEET	50 BHN MIN.	LAB. REPORT	3/2.		2,1	
1.3	BARS/FORGINGS FOR SHAFTS, LINE SHAFTS	1.PHYSICAL & CHEMICAL PROPS	CR	1.MECHANICAL & CHEMICAL ANALYSIS.	1/CAST OR 1/BARS	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	MILL T.C, OR LAB.REPORT	3/2.		2,1	CORRELATION REQUIRED, IDENTIFICATION AS PER TC
		2.DIMENSIONS	CR	2.MEASUREMENT	100%	MFR. DRAWING	MFR. DRAWING	INSP.REPORT	3/2.		2,1	
		3.INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS.	CR	3.ULTRA SONIC TEST	100%	ASTMA388 BACK WALL ECHO 100%	DEFECT ECHO MAX 20% OF B.W.E. LOSS OF BACK WALL ECHO 20% MAX	NDT CERTIFICATE	3/2.		2,1	
1.4	STRESS RELIEVING/ HEAT TREATMENT OF CASTING OF ALL ABOVE (IF APPLICABLE) / SOLUTION ANNEALING OF SS CASTING	1. VARIFICATION OF HT CHART	MA	VERIFICATION OF SR/HT CHART	ALL BATCHES	RELEVANT MATERIAL SPECN.	DO-	CORRELATED SR/HT.CHARTS	3/2.		2,1	
		2. IGC TEST FOR SS CASTING	MA	LAB. TEST	ONE SAMPLE/ HT BATCH	ASTM A 262	ASTM A 262 Gr A	LAB. REPORT	3/2.		2,1	
1.5	SHAFT ENCLOSING TUBES, COLUMN PIPES & DISCHARGE ELBOW	1. MECHANICAL & CHEMICAL PROPS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/BATCH 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./MAFG./ APPROVED DOCS	MFR T.C OR LAB. REPORT	3/2.		2,1	
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE						BIDDER/VENDOR SEAL		

**BHARAT HEAVY ELECTRICALS LIMITED**  
**PROJECT ENGINEERING MANAGEMENT**  
**STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
			BIDDER/VENDOR			QUALITY PLAN NUMBER						
SHEET 2 OF 6			SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECKED	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.6	PLATE FLANGE, C/FLANGE	1. MECHANICAL & CHEMICAL PROS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/CAST 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	CORRELATION REQ. FOR MAT OTHER THAN IS 2062
1.7	SUCTION STRAINER (IF APPLICABLE)	MECHANICAL & CHEMICAL PROS.	MI	MECH. & CHEMICAL TEST	1/HEAT	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	
1.8	MECHANICAL SEAL (IF APPLICABLE)	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET / GA MECH. SEAL	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
1.9	PUMP BEARINGS	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
<b>2.0 IN PROCESS CONTROL</b>												
2.1	ALL COMPONENTS UNDER 1.00 ABOVE	VISUAL DEFECTS, DIMENSIONS	MA	VISUAL EXAM, MEASUREMENT	100%	MFG. DRAWING	MFG. DRAWING	COMPLIANCE TC	3/2.		2,1	
2.2	IMPELLER	CLEANING AND DEBURRING	MA	VISUAL	100%	MFG. DRAWING	MFG. DRAWING		3/2.		2,1	
	IMPELLER	DYNAMIC BALANCING	CR	DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2,1		WITNESSING ONLY FOR SIZE GREATER THAN 10KW
2.3	IMPELLER-ALL ACCESSIBLE SURFACES, DIFFUSERS	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VARIFICATION BY CUSTOMER
2.4	WERING RING, SHAFT SLEEVES, CASING	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.		2,1	
2.5	SHAFT	DP TEST	MA	DP TEST ON M/CED AREA	100%	ASTM E 165	NO RELEVANT INDICATION ALLOWED	NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VARIFICATION BY CUSTOMER
2.6	CASINGS/ BOWLS, STAGE BODIES, DISCHARGE HEAD (IF CAST), SUCTION HOUSING, COLUMN PIPE DISCHARGE PIPE ETC	LEAK TIGHTNESS	CR	VISUAL	100%	TECHNICAL DATA SHEET AND NOTE 2	NO LEAKAGE FOR TEST DURATION OF 30 MIN.	HT CERTIFICATE	3/2.	2,1		HAMMERING OF CASTINGS WITH WOODEN/ RUBBER Mallet BEFORE HYDRO TEST
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
			BIDDER/VENDOR			QUALITY PLAN NUMBER						
SHEET 3 OF 6			SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7	FABRICATED COMPONENTS											
2.7.1	WELDING PROCEDURE SPECIFICATION	CORRECTNESS	MA	EXAM.	100%	ASME SEC.IX	ASME SEC.IX	QW 482 OF ASME SEC.IX	3/2.		2,1	WELDING PROCEDURE APPROVAL BY BHEL ALT. 3RD PARTY (LLYODS,BVQI OR EQ.) IS ACCEPTABLE.
2.7.2	WELDING PROCEDURE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 483 OF ASME SEC.IX	3/2.		2,1	
2.7.3	WELDER PERFORMANCE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 484 OF ASME SEC.IX	3/2.		2,1	
2.7.4	WELD FIT-UPS	DIMENSION & ALIGNMENT	MA	MEAS.VISUAL EXAM	100%	WPS, MFG . DRAWING	WPS, MFG . DRAWING	IR/LOGBOOK	3/2.			
2.7.5	ROOT RUNS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	NO SURFACE DEFECT	DO.	3/2.		2,1	
2.7.6	WELDMENTS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	ASME-VIII,DIV I	INSPN REPORT	3/2.		2,1	
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>				CUSTOMER			PROJECT TITLE					
				BIDDER/VENDOR			QUALITY PLAN NUMBER					
SHEET 4 OF 6				SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)					
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7.7	BUTT WELDS	INTERNAL DEFECT	MA	UT/RT	100%			IR	3/2.		2.1	
2.7.8	DICHARGE HEAD, COLUMN PIPE, DISCHARGE PIPE, ETC.	1. LEAK TIGHTNESS 2. DIMENSION	CR	1. HYDROTEST 2. MEASUREMENT	100%	TECHNICAL SPEC/ DATA SHEET, MFR DRAWING	1. NO LEAKAGE 2. MFR. DRAWING	IR	3/2.	2.1		
<b>3.0</b>	<b>SUB-ASSEMBLY CONTROL</b>											
3.1	ROTOR ASSEMBLY	ECCENTRICITY	MA	MEASUREMENT	100%	MFR.DRAWING	MFR.DRAWING	IR/LOG BOOK	3/2.		1	
3.2	ROTOR ASSEMBLY RESIDUAL UNBALACE	STATIC & DYNAMIC	CR	STATIC & DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2.1		WTNESSING ONLY FOR SIZE GREATER THAN 10KW
3.3	COMPLETE PUMP ASSEMBLY	COMPLETENESS, CORRECTNESS, CLEANLINES, CLEARANCES, FREENESS, ALIGNMENT	MA	VISUAL EXAM MEASUREMENT	100%	APPROVED DRG & MFG STANDARDS	APPROVED DRG & MFG STANDARDS	I.R. & CHECK LISTS	3/2.		2.1	
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

<b>QUALITY PLAN FOR MISCELLANEOUS PUMPS</b>				CUSTOMER			PROJECT TITLE					
				BIDDER/VENDOR			QUALITY PLAN NUMBER					
SHEET 5 OF 6				SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)					
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4	<b>FINAL INSPECTION, TESTS &amp; PACKING DESPATCH CONTROL</b>											
4.1	PUMP WITH JOB/SHOP MOTOR ASSEMBLED ON INDIVIDUAL BASE FRAME	1. Q V/S HEAD. 2. Q V/S POWER, 3. Q V/S PUMP EFF. 4. VIBRATION 5. NOISE 6. BEARING TEMP. 7. LEAKAGES	CR	PERFORMANCE TEST	100%	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES <u>FOR VIBRATIONS</u> - AS PER ANSI/HIS 9.6.4-2009 (VALUES AS PER APPROVED DATA SHEET) <u>FOR BEARING TEMP</u> - BEARING HOUSING SHOULD NOT BE UNTOUCHABLY HOT. <u>FOR LEAKAGE</u> - MINOR LEAKAGE (DROP BY DROP) IN CASE OF GLAND PACKING ARRANGEMENT.	I.R., PERF. TEST RECORD, PLOTED CURVES	3/2.	2.1.			* MINIMUM 7 POINTS FROM SHUT-OFF TO MAX. OPERATING FLOW COVERING ENTIRE OPERATION RANGE OF PUMP SHALL BE TAKEN.
		NPSH/ MIN. SUBMERGENCE REQUIRED	CR	NPSH TEST	1/MODEL	DO.	IR. NPSH/MIN. SUBMERGENCE TEST RECORD, PLOTED CURVES	3/2.	2.1.			<b>IF SPECIFIED or INSISTED BY CUSTOMER.</b>
4.2	STRIP DOWN AFTER PERFORMANCE TEST	1UNDUE WEAR TEAR AND RUBBING	MA	VISUAL EXAM AFTER STRIPPING	1/MODEL	NO UNDUE WEAR TEAR & RUBBING ON IMPELLER & WEAR RING	INSP. REPORT	3/2.	1			WITNESS REQUIRED ONLY WHEN ABNORMAL SOUND OBSERVED DURING PERFORMING TEST.
4.3	COMPLETE PUMP WITH UNIT MOTOR BASE FRAME, COUNTER FLANGES ETC. INCLUDING ALL ACCESSORIES AS PER SECTION C OF SPECN.	COMPLETENESS, CLEANLINESS, OVERALL DIMENSIONS ORIENTATION, WORKMANSHIP AND FINISH	MA	VISUAL EXAM MEASUREMENT	100%	APPD. G.A DRAWING	APPD. G.A DRAWING	INSP. REPORT	3/2.	1		
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE								
							BIDDER/VENDOR SEAL					

**BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT  
STANDARD QUALITY PLAN**

**QUALITY PLAN FOR MISCELLANEOUS PUMPS**

CUSTOMER	PROJECT TITLE
BIDDER/VENDOR	QUALITY PLAN NUMBER
SHEET 6 OF 6	SYSTEM
	ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)

S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4.4	COMPLETION OF ALL STAGES	1.COMPLETION	MA	VERIFICATION OF IR/T.C.ETC.	100%	MFG. DRG./TECHNICAL DOCS.	APPD. MFG. DRG./TECHNICAL DOCS	IR.	3/2.	2,1		WTNESSING ONLY BY BHEL, CUSTOMER VARIIFICATION ONLY BUT CHP
4.5	PAINING	1.SURFACE FINISH, DFT, MARKINGS ETC.	MA	VISUAL EXAM MEASURMENT AESTHETIC	100%	APPD.DRG.	APPD.DOCS	IR.	3/2.		2	
4.6	PACKING, MARKING	SOUNDNESS OF PACKING	MI	VISUAL AESTHETIC	100%	MFG. STANDARD	MFG. STANDARD		3/2.		2	

MTC -Mill Test Certificate, MA-Major, MI-Minor, TC-Test Certificate, CR-Critical, IGC- Inter Granular Corrosion

- AS CAST HEAT MARKS SHALL BE PROVIDED ON CI CASTING LIKE TOP & BOTTOM CASING.
- HYDRO TEST PRESSURE SHALL BE AT LEAST 2(TWO) TIMES THE DUTY POINT (OR) 1.5 TIMES OF SHUT OFF HEAD (OR) SYSTEM DESIGN PRESSURE, WHICHEVER IS HIGHER.
- THIS QAP IS ALSO APPLICABLE FOR SPARES.
- NO WELD REPAIRS PERMISSIBLE ON CI CASTING.
- MATERIAL SHALL BE AS PER APPROVED CROSS SECTION DRG./ DATA SHEET.
- STRIP TEST- INCASE OF ABNORMAL NOISE OBSERVED DURING PERF. TEST, THOSE PUMP WILL BE STRIPPED DOWN FOR VISUAL INSPECTION OF IMPELLER & WEAR SHALL BE OFFERED FOR VISUAL INSPECTION FOR WEAR /RUBBING MARKS.
- PUMPS WITH MECHANICAL SEAL ARRANGEMENT TO BE TESTED AND SUPPLIED WITH GLAND PACKING ARRANGEMENT. HOWEVER MANUFACTURER TO ENSURE DIMENTIONAL MATCHING OF MECHANICAL SEAL WITH PUMP GA DRAWING.

LEGEND : 1- BHEL OR BHEL NOMINATED THIRD PARTY /END CUSTOMER OF BHEL,  
2- VENDOR,  
3-SUB-VENDOR

P- PERFORM, W- WITNESS, V-VERIFICATION

BHEL	PARTICULARS	BIDDER / VENDOR	
	NAME		
	SIGNATURE		
	DATE		BIDDER/VENDOR SEAL



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS  
2X500 MW NNTPP (SG & TG)  
DATA SHEET - C

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

D1

REV. NO.

0

DATE:

25.08.14

**Drawings / documents distribution schedule to be followed by successful bidder :**

- 1.0 Drawings/documents submission schedule, shall be as per NIT. The successful bidder shall submit following drawings/ documents.
- 1.1 Fully dimensioned outline general arrangement drawings of the pump and motor assembly. This drawing should include foundation base plate and sole plate details as applicable, civil foundation and anchor bolt details and loading data, points of connections of external piping and cables and mounting of devices furnished by the supplier.
- 1.2 Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction with standard applicable codes. Mechanical seal drawing shall also be submitted.
- 1.3 Characteristic curves of pump showing the following:
  - a) Flow Vs Head
  - b) Flow VS Power
  - c) Flow Vs Efficiency
  - d) Flow Vs NPSHR
- 1.4 Operation and maintenance manual
- 1.5 Lubrication arrangement drawings for external lubrication (if applicable).
- 2.0 Within the stipulated time period as per vendor's drawings/ documents schedule as per NIT, the O&M Manual comprising of minimum following shall be submitted
  - a) Drawings of components & details as deemed necessary.
  - b) Instruction manual for erection, operation & maintenance.
  - c) Storage instruction.
- 3.0 Before despatch of the equipment the bidder shall furnish the following.
  - a) Material test certificates.
  - b) Shop test reports & certificates.
  - c) MDCC after final inspection shall be provided to vendor on the basis of following:-
    - c1) List of items packed in each box with description & quantity.
    - c2) Photograph of each box in open & closed condition.
- 4.0 Distribution of drawings / documents for all projects:

The no. of drawing/ documents to be submitted by the successful bidder, after the award of the contract shall be



TECHNICAL SPECIFICATIONS  
MISCELLANEOUS PUMPS

2X500 MW NTPP (SG & TG)

SPECIFICATION  
NO.:

PE-TS-400/402-100-N001

VOLUME:

IIB

SECTION:

D2

REV. NO.

0

DATE:

25.08.14

## SECTION D2

### STANDARD MOTOR SPECIFICATION

### STANDARD QUALITY PLAN FOR MOTORS



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO. PE-SS-999-506-E101
VOLUME NO. : <b>II-B</b>
SECTION : <b>D</b>
REV NO. : <b>00</b> DATE : 29/08/2005
SHEET : 1 OF 1

**GENERAL TECHNICAL REQUIREMENTS**

**FOR**

**LV MOTORS**

**SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00**



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE : 29/08/2005  
SHEET : 1 OF 4

## 1.0 INTENT OF SPECIFICATION

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

## 2.0 CODES AND STANDARDS

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

IS:325	Three phase Induction motors
IS : 900	Code of practice for installation and maintenance of induction motors
IS: 996	Single phase small AC and universal motors
IS: 4722	Rotating Electrical machines
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines
IS: 4728	Terminal marking and direction of rotation rotating electrical machines
IS: 1231	Dimensions of three phase foot mounted induction motors
IS: 8789	Values of performance characteristics for three phase induction motors
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
IS: 2148	Flame proof enclosures for electrical appliance
IS: 5571	Guide for selection of electrical equipment for hazardous areas
IS: 12824	Type of duty and classes of rating assigned
IS: 12802	Temperature rise measurement for rotating electrical machines
IS: 12065	Permissible limits of noise level for rotating electrical machines
IS: 12075	Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

## 3.0 DESIGN REQUIREMENTS

3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information  
Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

### 3.3 Starting Requirements

3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE : 29/08/2005  
SHEET : 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

#### 3.4 **Running Requirements**

3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.

3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

#### 3.5 **Stress During bus Transfer**

3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.


#### 4.0 **CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy

4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.

	TITLE :	SPECIFICATION NO.
	<b>GENERAL TECHNICAL REQUIREMENTS</b>	PE-SS-999-506-E101
	<b>FOR</b>	VOLUME NO. : <b>II-B</b>
	<b>LV MOTORS</b>	SECTION : <b>D</b>
		REV NO. : <b>00</b> DATE : 29/08/2005
		SHEET : 3 OF 4

- 4.4. Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.
- 4.5. Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.
- 4.6. In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.  
In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.
- 4.7 Terminals and Terminal Boxes**
- 4.7.1 Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.
- Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".
- 4.7.2 unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.7.3 Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or U W & V respectively.
- 4.7.4 Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.7.5 Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.
- 4.7.6 Degree of protection for terminal boxes shall be IP 55 as per IS 4691.
- 4.7.7 Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.
- 4.7.8. Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.
- 4.7.9 Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.
- 4.8 Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE : 29/08/2005  
SHEET : 4 OF 4


- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.

**5.0 INSPECTION AND TESTING**

- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.

**6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT**

- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:  
*(To be given for motor above 55 kW unless otherwise specified in Data Sheet).*
  - i) Current vs. time at rated voltage and minimum starting voltage.
  - ii) Speed vs. time at rated voltage and minimum starting voltage.
  - iii) Torque vs. speed at rated voltage and minimum voltage.  
For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
  - iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.

		QUALITY PLAN		CUSTOMER :			PROJECT			SPECIFICATION :		
				BIDDER/ VENDOR :			TITLE			NUMBER :		
SHEET 1 OF 2		SYSTEM			QUALITY PLAN NUMBER PED-506-00-Q-006, REV-01			SPECIFICATION TITLE				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION VOLUME III			
1	2	3	4	5	6	7	8	9	P	W	V	REMARKS
1.0	ASSEMBLY	1.WORKMANSHIP 2.DIMENSIONS 3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/COLOUR CODE	MA MA MA	VISUAL -DO- VISUAL	100% -DO- 100%	MANUF'S SPEC MFG. DRG./ MFG. SPEC. MFG.SPEC./ RELEVANT IS	MANUF'S SPEC MFG. DRG./ MFG. SPEC. MFG.SPEC. RELEVANT IS	-DO- -DO- -DO-	2 2 2	- - -	- - -	
2.0	PAINTING	1.SHADE	MA	VISUAL	SAMPLE	MANUFR'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
3.0	TESTS	1.ROUTINE TEST INCLUDING SPECIAL TEST AS PER BHEL SPEC. 2.OVERALL DIMENSIONS & ORIENTATION	MA MA	-DO- MEASUREMENT & VISUAL	100% 100%	IS-325/ BHEL SPEC./ DATA SHEET APPROVED DRG/DATA SHEET	SAME AS COL.7 APPROVED DRG/DATA SHEET & RELEVANT IS	TEST REPORT INSPN. REPORT	2 2	1 1	- -	NOTE -1 & NOTE-3  NOTE -1 & NOTE-3
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									



**QUALITY PLAN**

SHEET 2 OF 2

CUSTOMER :

PROJECT

SPECIFICATION :

BIDDER/ :

TITLE

NUMBER :

VENDOR

QUALITY PLAN  
NUMBER PED-506-00-Q-006, REV-01

SPECIFICATION :

SYSTEM

ITEM AC ELECT. MOTORS BELOW 55KW (LV)

TITLE :

SECTION

VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
		3.NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT	2	1	-	
<p>NOTES:</p> <p>1 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON</p> <p>2 WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.</p> <p>3 FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.</p> <p><u>Legends for Inspection agency</u></p> <p>1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)</p> <p>P. PERFORM W. WITNESS V. VERIFY</p>												
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			



**QUALITY PLAN**

SHEET 1 OF 9

CUSTOMER :	PROJECT TITLE	SPECIFICATION : NUMBER :
BIDDER/ VENDOR :	QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03	SPECIFICATION : TITLE
SYSTEM	ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)	SECTION VOLUME III

1	2	3	4	5	6	7	8	9	10			11
									P	W	V	
1.0	RAW MATERIAL & BOUGHT OUT CONTROL											
1.1	SHEET STEEL, PLATES, SECTION, EYEBOLTS	1.SURFACE CONDITION	MA	VISUAL	100%	-	FREE FROM BLINKS, CRACKS, WAVINESS ETC	LOG BOOK	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	-DO-	3	-	-	
		3.PROOF LOAD TEST (EYE BOLT)	MA	MECH. TEST	-DO-	-DO-	-DO-	INSPEC. REPORT	3	-	2	
1.2	HARDWARES	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, UN-EVENNESS ETC.	-DO-	3	-	-	
		2.PROPERTY CLASS	MA	VISUAL	SAMPLES	MANFR'S DRG./SPEC BOOK	RELEVENT IS/SPEC.	SUPPLIERS TC & LOG	3	-	2	PROPERTY CLASS MARKING SHALL BE CHECKED BY THE VENDOR
1.3	CASTING	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, BLOW HOLES ETC.	LOG BOOK	3	-	2	
		2.CHEM. & PHY. PROP.	MA	CHEM & MECH TEST	1/HEAT NO.	MANFR'S DRG./SPEC	RELEVENT IS/	SUPPLIER'S TC	3	-	2	HEAT NO. SHALL BE VERIFIED
		3.DIMENSIONS	MA	MEASUREMENT	100%	MANUFR'S DRG.	MANUFR'S DRG.	LOG BOOK	3	-	2	
1.4	PAINT & VARNISH	1.MAKE, SHADE, SHELF LIFE & TYPE	MA	VISUAL	100% CONTINUOUS	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	LOG BOOK	3	-	2	

<b>BHEL</b>	<b>PARTICULARS</b>	<b>BIDDER/VENDOR</b>
	NAME	
	SIGNATURE	
	DATE	
		BIDDER'S/VENDORS COMPANY SEAL



**QUALITY PLAN**

SHEET 2 OF 9

CUSTOMER :	PROJECT TITLE	SPECIFICATION : NUMBER :
BIDDER/ VENDOR :	QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03	SPECIFICATION : TITLE
SYSTEM	ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)	SECTION VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.5	SHAFT (FORGED OR ROLLED)	1. SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	VENDOR'S APPROVAL IDENTIFICATION SHALL BE MAINTAINED
		2. CHEM. & PHYSICAL PROPERTIES	MA	CHEM. & PHYSICAL TESTS	1/HEAT NO. OR HEAT TREATMENT BATCH NO	MFG. DRG. SPEC.	RELEVANT IS	SUPPLIER'S TC	3	-	2	
		3. DIMENSIONS	MA	MEASUREMENT	100%	-DO-	MANUFR'S DRG.	LOG BOOK	3	-	2	
		4. INTERNAL FLAWS	CR	UT	-DO-	ASTM-A388	MANUFR'S SPEC. BHEL SPEC.	-DO-	3	2	1	
1.6	SPACE HEATERS, CONNECTORS, TERMINAL BLOCKS, CABLES, CABLE LUGS, CARBON BRUSH TEMP. DETECTORS, RTD, BTD'S	1. MAKE & RATING	MA	VISUAL	-DO-	MANUFR'S DRG. SPEC.	MANUFR'S DRG. SPEC.	-DO-	3	-	2	
		2. PHYSICAL COND.	MA	-DO-	-DO-	-	NO PHYS. DAMAGE. NO ELECTRICAL DISCONTINUITY	-DO-	3	-	2	
		3. DIMENSIONS (WHEREVER APPLICABLE)	MA	MEASUREMENT	SAMPLE	MANUFR'S DRG./ SPEC.	MANUFR'S DRG. / SPEC.	-DO-	3	-	2	
		4. PERFORMANCE/ CALIBRATION	MA	TEST	100%	-DO-	-DO-	INSP. REPORT	3	-	2	
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>									
			<b>SIGNATURE</b>									
			<b>DATE</b>						<b>BIDDER'S/VENDORS COMPANY SEAL</b>			



**QUALITY PLAN**

CUSTOMER :

PROJECT

SPECIFICATION :

BIDDER/  
VENDOR :

TITLE  
QUALITY PLAN  
NUMBER PED-506-00-Q-007, REV-03

NUMBER :

SPECIFICATION :  
TITLE

SHEET 3 OF 9

SYSTEM

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SECTION

VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.7	OTHER INSULATING MATERIALS LIKE SLEEVES, BINDINGS CORDS, PAPERS, PRESS BOARDS ETC.	1. SURFACE COND. ETC.  2. OTHER CHARACTERISTICS	MA  MA	VISUAL  TEST	100%  SAMPLE	-  MANUF'S SPEC.	NO VISUAL DEFECTS  MANUF'S SPEC.	INSPT. REPORT  LOG BOOK AND OR SUPPLIER'S TC	3  3	-  -	2  2	
1.8	SHEET STAMPING (PUNCHED)	1. SURFACE COND.  2. DIMENSIONS INCLUDING BURS HEIGHT  3. ACCEPTANCE TESTS	MA  MA  MA	VISUAL  MEASUREMENT  ELECT. & MECH TESTS	100%  SAMPLE  -DO-	-  MANUFR'S DRG. .  MANUF'S SPEC./ RELEVANT IS	NO VISUAL DEFECTS (FREE FROM BURS)  MANUFR'S DRG.  RELEVANT IS	LOG BOOK  -DO-  SUPPLIER'S TC	3  3  3	-  -	-  2  2	
1.9	CONDUCTORS	1. SURFACE FINISH  2. ELECT. PROP, & MECH. PROP	MA  MA	VISUAL  ELECT. & MECH. TEST	100%  SAMPLES	-  RELEVANT IS/ BS OR OTHER STANDARDS	FREE FROM VISUAL DEFECTS  RELEVANT IS/ BS OR OTHER STANDARDS	LOG BOOK  SUPPLIERS TC & VENDOR'S INSPN. REPORTS	3*  3	-  -	2*  2	* MOTOR MANUFACTURER TO CONDUCT VISUAL CHECK FOR SURFACE FINISH ON RANDOM BASIS (10% SAMPLE) AT HIS WORKS AND MAINTAIN RECORD FOR VERIFICATION BY BHEL/CUSTOMER.
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>									
			<b>SIGNATURE</b>									
			<b>DATE</b>			<b>BIDDER'S/VENDORS COMPANY SEAL</b>						



**QUALITY PLAN**

SHEET 4 OF 9

CUSTOMER :

BIDDER/ VENDOR :

SYSTEM :

PROJECT TITLE

QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SPECIFICATION :

NUMBER :

SPECIFICATION : TITLE

SECTION VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.10	BEARINGS	3.DIMENSIONS	MA	MEASUREMENT	-DO-	-DO-	-DO-	Log Book	3	-	2	
		1.MAKE & TYPE	MA	VISUAL	100%	MANFR'S DRG./ APPROVED DATASHEET	MANFR'S DRG./ APPROVED DATASHEET	-DO-	3	-	2	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	BHEL DATA SHEET	BHEL DATA SHEET BEARING MANUF'S CATALOGUES	-DO-	3	-	2	
1.11	SLIP RING (WHEREVER APPLICABLE)	3.SURFACE FINISH	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	2	
		1.SURFACE COND.	MA	VISUAL	100%	-	-DO-	-DO-	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
		3.TEMP.WITH-STAND CAPACITY	MA	ELECT.TEST	-DO-	MANUF'S SPEC./ BHEL SPEC.	MANUF'S SPEC./ BHEL SPEC.	-DO-	3	-	2	
1.12	OIL SEALS & GASKETS	4.HV/IR	MA	-DO-	100%	-DO-	-DO-	-DO-	3	-	2	
		1.MATERIAL OF GASKET	MA	VISUAL	100%	MANUF'S DRG/SPECS	MANUF'S DRG./ SPECS.	-DO-	3	-	-	
		2.SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	
		3.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>									
			<b>SIGNATURE</b>									
			<b>DATE</b>						<b>BIDDER'S/VENDORS COMPANY SEAL</b>			



**QUALITY PLAN**

SHEET 5 OF 9

CUSTOMER :

PROJECT

SPECIFICATION :

BIDDER/ :

TITLE

NUMBER :

VENDOR :

QUALITY PLAN

SPECIFICATION :

SYSTEM

NUMBER PED-506-00-Q-007, REV-03

TITLE

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SECTION VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.0	IN PROCESS											
2.1	STATOR FRAME WELDING (IN CASE OF FABRICATED STATOR )	1.WORKMANSHIP & CLEANNESS	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	3/2	2	-	
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-	
2.2	MACHINING	1.FINISH	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	2	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-	
		3.SHAFT SURFACE FLOWS	MA	PT	-DO-	RELEVANT SPEC./ ASTM-E165	MANUF'R'S SPEC./ BHEL SPEC./	-DO-	2	-	1	
2.3	PAINING	1.SURFACE PREPARATION	MA	VISUAL	100%	MANFR'S SPEC/BHEL SPEC./ RELEVANT STAND	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
		2.PAINT THICKNESS (BOTH PRIMER & FINISH COAT)	MA	MEASUREMENT BY ELCOMETER	SAMPLE	-DO-	-DO-	-DO-	2	-	-	
		3.SHADE	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-	
		4.ADHESION	MA	CROSS CUTTING & TAPE TEST	-DO-	-DO-	-DO-	Log Book	2	-	-	
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>									
			<b>SIGNATURE</b>									
			<b>DATE</b>						<b>BIDDER'S/VENDORS COMPANY SEAL</b>			



**QUALITY PLAN**

SHEET 6 OF 9

CUSTOMER :

PROJECT  
TITLE

SPECIFICATION :  
NUMBER :

BIDDER/  
VENDOR

QUALITY PLAN  
NUMBER PED-506-00-Q-007, REV-03

SPECIFICATION :  
TITLE

SYSTEM

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SECTION

VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.4	SHEET STACKING	1.COMPLETENESS	MA	MEASUREMENT	SAMPLE	MANUFR'S SPEC.	MANUFR'S SPEC.	Log Book	2	-	-	(FOR MOTORS OF 2MW AND ABOVE) * ON 10% RANDOM SAMPLE
		2.COMPRESSION & TIGHTENING	MA	MEASUREMENT	100%	-DO-	-DO-	Log Book	2	-	-	
		3.CORE LOSS & HOTSPOT	MA	ELECT.TEST	-DO-	-DO-	-DO-	Log Book	2	1*	1	
2.5	WINDING	1.COMPLETENESS	CR	VISUAL	100%	MANUFR'S SPEC./BHEL SPEC.	MANUFR'S SPEC./BHEL SPEC.	Log Book	2	-	-	FOR MV MOTOR
		2.CLEANLINESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-	
		3.IR-HV-IR	CR	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2	-	1	
		4.RESISTANCE	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1	
		5.INTERTURN INSULATION	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-	
		6.SURGE WITH STAND AND TAN. DELTA TEST	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1	
2.6	IMPREGNATION	1.VISCOSITY	MA	PHY. TEST	AT STARTING	-DO-	-DO-	Log Book	2	-	-	THREE DIPS TO BE GIVEN
		2.TEMP. PRESSURE VACCUM	MA	PROCESS CHECK	CONTINUOUS	-DO-	-DO-	Log Book	2	-	-	
		3.NO. OF DIPS	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1	
<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>						
			<b>NAME</b>									
			<b>SIGNATURE</b>									
			<b>DATE</b>						<b>BIDDER'S/VENDORS COMPANY SEAL</b>			



**QUALITY PLAN**

SHEET 7 OF 9

CUSTOMER :

PROJECT

SPECIFICATION :

BIDDER/  
VENDOR

QUALITY PLAN  
NUMBER PED-506-00-Q-007, REV-03

NUMBER :  
TITLE

SYSTEM

ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)

SECTION

VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
2.7	COMPLETE STATOR ASSEMBLY	4.DURATION 1.COMPACTNESS & CLEANLINESS	MA	-DO- VISUAL	-DO- 100%	-DO- -DO-	-DO- -DO-	Log Book Log Book	2	-	1		
2.8	BRAZING/COMPRESSION JOINT	1.COMPLETENESS 2.SOUNDNESS	CR	-DO- MALLET TEST & UT	-DO- -DO-	-DO- -DO-	-DO- -DO-	Log Book Log Book	2	-	-		
2.9	COMPLETE ROTOR ASSEMBLY	3.HV 1.RESIDUAL UNBALANCE	MA	ELECT. TEST DYN. BALANCE	-DO- -DO-	-DO- MFG SPEC./ ISO 1940	-DO- MFG. DWG.	Log Book Log Book	2		1	VERIFICATION FOR MV MOTOR ONLY	
2.10	ASSEMBLY	2.SOUNDNESS OF DIE CASTING 1.ALIGNMENT 2.WORKMANSHIP 3.AXIAL PLAY 4.DIMENSIONS 5.CORRECTNESS, COMPLETENESS TERMINATIONS/ MARKING/ COLOUR CODE 6. RTD, BTD & SPACE HEATER MOUNTING.	CR	ELECT. (GROWLER TEST) MA MEAS. MA VISUAL MA -DO- MA VISUAL MA VISUAL	-DO- -DO- -DO- -DO- -DO- 100% -DO- 100%	-DO- -DO- -DO- -DO- MFG.DRG./ MFG SPEC. MFG SPEC. RELEVANT IS MFG SPEC. RELEVANT IS	-DO- -DO- -DO- -DO- MFG. DRG/ RELEVANT IS MFG. SPEC. RELEVANT IS MFG SPEC. RELEVANT IS	Log Book Log Book Log Book Log Book Log Book Log Book Log Book	2	-	-	1	
<b>BHEL</b>			<b>PARTICULARS</b>		<b>BIDDER/VENDOR</b>								
			<b>NAME</b>										
			<b>SIGNATURE</b>										
			<b>DATE</b>										
									<b>BIDDER'S/VENDORS COMPANY SEAL</b>				



**QUALITY PLAN**

SHEET 8 OF 9

CUSTOMER :			PROJECT TITLE			SPECIFICATION : NUMBER :		
BIDDER/ VENDOR :			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE		
SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION		VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
3.0	TESTS	1.TYPE TESTS INCLUDING SPECIAL TESTS AS PER BHEL SPEC.	MA	ELECT.TEST	1/TYPE/SIZE	IS-325/ BHEL SPEC./ DATA SHEET	IS-325/ BHEL SPEC./ DATA SHEET	TEST REPORT	2	1*	1	* NOTE - 1
		2.ROUTINE TESTS INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 <sup>\$</sup>	1	<sup>\$</sup> NOTE - 2
		3.VIBRATION & NOISE LEVEL	MA	-DO-	100%	IS-12075 & IS-12065	IS-12075 & IS-12065	-DO-	2	1 <sup>\$</sup>	1	<sup>\$</sup> NOTE - 2
		4.OVERALL DIMENSIONS AND ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPC. REPORT	2	1	-	
		5.DEGREE OF PROTECTION	MA	ELECT. & MECH. TEST	1/TYPE/ SIZE	RELEVANT IS	BHEL SPEC. AND DATA SHEET	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		6. MEASUREMENT OF RESISTANCE OF RTD & BTD	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 <sup>\$</sup>	1	<sup>\$</sup> NOTE - 2
		7. MEASUREMENT OF RESISTANCE, IR OF SPACE HEATER	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 <sup>\$</sup>	1	<sup>\$</sup> NOTE - 2
		8. NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPC. REPORT	2	1 <sup>\$</sup>	1	<sup>\$</sup> NOTE - 2
		9.EXPLOSION FLAME PROOF NESS (IF SPECIFIED)	MA	EXPLOSION FLAME PROOF TEST	1/TYPE	IS-3682 IS-8239 IS-8240	IS-3682 IS-8239 IS-8240	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		10. PAINT SHADE, THICKNESS & FINISH	MA	VISUAL & MEASUREMENT BY ELKOMETER	SAMPLE	BHEL SPEC. & DATA SHEET	BHEL SPEC. & DATA SHEET	TC	2	1 <sup>\$</sup>	1	SAMPLING PLAN TO BE DECIDED BY INSPECTION AGENCY <sup>\$</sup> NOTE - 2

<b>BHEL</b>			<b>PARTICULARS</b>			<b>BIDDER/VENDOR</b>					
			NAME								
			SIGNATURE								
			DATE						BIDDER'S/VENDORS COMPANY SEAL		



**QUALITY PLAN**

SHEET 9 OF 9

CUSTOMER :	PROJECT TITLE	SPECIFICATION : NUMBER :
BIDDER/ VENDOR :	QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03	SPECIFICATION : TITLE
SYSTEM	ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)	SECTION VOLUME III

SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11

**NOTES:**

- 1 DEPENDING UPON THE SIZE AND CRITICALLY, WITNESSING BY BHEL SHALL BE DECIDED.
- 2 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON.
- 3 IN CASE TEST CERTIFICATES FOR THESE TESTS ON SIMILAR TYPE, SIZE AND DESIGN OF MOTOR FROM INDEPENDENT LABORATORY ARE AVAILABLE, THESE TEST MAY NOT BE REPEATED.
- 4 WHEREVER CUSTOMER IS INVOLVED IN INSPECTION, AGENCY (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.

Legends for Inspection agency

1. BHEL/CUSTOMER
2. VENDOR (MOTOR MANUFACTURER)
3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)

- P. PERFORM  
W. WITNESS  
V. VERIFY

<b>BHEL</b>	<b>PARTICULARS</b>	<b>BIDDER/VENDOR</b>	<b>BIDDER'S/VENDORS COMPANY SEAL</b>
	<b>NAME</b>		
	<b>SIGNATURE</b>		
	<b>DATE</b>		