

**Specifications for L.P.G. Bullet maintenance Yearly Rate Contract:**

<b>Description</b>	<b>Periodicity / Completion date</b>
1. Testing and issue of certificate duly signed by authorized agency for safety relief valves, and related repairs if any.	<b>15 days from the date order</b>
2. Ensuring leak tightness of LPG pipes, joints, couplings, gaskets etc. by conducting leakage test once in 3 months.	<b>Quarterly – during one year from the date of order</b>
3. Checking LPG pump, motor and keep in good condition Also assist BHEL staff while unloading the LPG whenever required.	<b>Pre-checking and at the time of un-loading the LPG (once during the year)</b>
4. Periodical inspection of LPG storage area and submission of report. Also on safety preventive measures.	<b>15 days from the date of order and six months after the first inspection.</b>
5. Flash back arrestors are to be provided before inlet to the 6 burners and M.S LPG manifold line lay on floor in the kitchen to be replaced with SS with wall support.	<b>Within one month from the date of order</b>