

- 4.00.00 **GUIDELINES FOR ENGINEERING SERVICES**
- 4.01.00 Prior to commencement of the engineering work as part of design submissions, all aspects of design viz., criteria for selection and sizing of all equipment and systems, design margins etc. including that for structural steel and civil work shall be outlined and these shall form the basis for the detailed engineering work.
- 4.02.00 Engineering work shall be performed on modern and proven concepts and internationally accepted good engineering practices but fully compatible with the Indian environments. Owner shall have the right to review and approve the engineering work by themselves and/or through consultant and ask for any clarifications and changes/modifications to the work performed by Contractor.
- 4.03.00 At any stage during the performance of assignment, the Contractor may be required to make certain changes/modification/improvements in design/drawing/other documents which are applicable to 800 MW Unit, which in the opinion of the Owner could result in better improved design, layout, operability, plant availability, maintainability, reliability or economy of the plant and its systems/sub-systems in view of revised and more accurate information/data available at a later date(s) or feedback(s) received during execution / operation of similar units. Such changes / modifications/improvements required could be identified by Owner and/or consultant and mutually discussed. Owner requires the Bidder to incorporate such action in the subject assignment appropriately without any additional cost liability and time implication to the Owner and same shall be within the responsibilities and scope of the Contractor.
- 4.04.00 During the course of review of detailed engineering stages, it may be essential in the opinion of Owner to obtain certain classified data for review purposes only. In case Owner so desires, the Bidder shall submit such data to Owner.
- 4.05.00 During the course of review of detailed engineering, it may be essential in Owner's opinion to obtain data and information on similar equipment and plants engineered by the Bidder. In case Owner so desires the Bidder shall submit such data and information to the Owner.
- 4.06.00 It is not the intent to give details of every single task covered in the total engineering work to be carried out by Contractor, however, all engineering work required for the satisfactory completion of the plant/systems as specified shall be carried out by the Contractor. Broadly, the following are the minimum requirements in respect of scope of major items of work:
- 4.06.01 Preparation, updating and finalisation of scheme drawings, control and interlock diagrams, detailed and fully dimensioned layout drawings (plant layout and equipment layout detailed plan, elevation and cross-sectional drawings at different elevations / floor levels) covering all mechanical, electrical, C&I, civil and structural items, equipment, systems and facilities. Drawings and Schedules prepared by the Contractor from time to time, as detailed designs are developed, shall be submitted for Owner's / Consultant's

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

- approval before the work is taken up. Revisions, corrections, additions to drawings and schedules shall not be considered to change the scope of work.
- 4.06.02 Preparation of detailed technical specifications including data sheets, tender drawings and bill of material for all bought out items, as also finalisation of corresponding sub-contractors.
- 4.06.03 Review of sub-contractor's data, drawings, design calculations, schedules, bill of materials, instruction manuals etc. for all equipment, before forwarding them to Owner/Consultant for approval.
- 4.06.04 Preparation of civil construction drawings for all equipment showing foundation details and full details regarding equipment loads, floor openings, details of embedments etc. required for preparation of civil construction drawings and also as referred at relevant sections of Scope, Terminal Points & Exclusions. These documents shall be preceded by appropriate design calculations, static and dynamic analysis as necessary.
- 4.06.05 Preparation and finalisation of process piping and instrumentation diagrams and schematics, complete in all respects for all systems/packages of the power plant.
- 4.06.06 Preparation of consolidated schedules and bills of materials, including line numbers, tag numbers, source of supply, service conditions, specifications, materials, types and connections details, quantities for items of the plant including dampers, steam traps, strainers, instrumentations, ducting.
- 4.06.07 Sizing of all piping and equipment as per the stipulated design criteria; carrying out of flexibility analysis/dynamic analysis as necessary; hangers & support engineering.
- 4.06.08 Final revision of all documents including preparation and compilation of Instruction Manuals for installation, commissioning, operation and maintenance for all equipment and systems. Refer clause 5.00.00 for the specific requirement in this regard.
- 4.06.09 Certification and submission of final as-built drawings for all areas.
- 4.06.10 Preparation and compilation of all drawings, schedules and instructions which may be required at site, whether separately mentioned or not.
- 4.06.11 All erection and assembly drawings which may be required at site.
- 4.06.12 For all bought out item packages, the Contractor shall provide complete material / component list along with detail specification, drawings, component part no. etc. during detail engineering stage prior to final approval. Such approved drawing/document shall be made available at site in adequate number prior to commencement of work. Moreover, such document/drawing shall be provided in soft form (CD)
- 4.06.13 Preparation of necessary documentation, design calculations etc. required for submission to statutory authorities like IBR, Chief Electric Inspector, Factory Inspector etc.

5.00.00 **OPERATING MANUALS AND MAINTENANCE INSTRUCTIONS**

5.01.00 The Contractor shall provide at least six (6) months before the time of commissioning and before taking over of the plant and equipment, all necessary maintenance manuals and operating instructions. The instruction manual shall be submitted in the form of one (1) soft copy in CD and 15 hard copies as per distribution schedule (Annexure-1).

5.02.00 The information provided, which shall be contained in loose leaf stiff backed covers, shall include :

- a) A complete inventory of all main items of plant, with identification details.
- b) Service manuals for all plant and equipment giving full descriptions of the main items and auxiliary items such as power packs, hydraulic equipment, actuators, lubricating pumps, etc.
- c) A separate electrical manual covering items such as switchgear, cabling, instrumentation, controls, cabling layouts and wiring diagrams.
- d) A schedule of recommendations for routine maintenance of all electrical and mechanical equipment, recommended inspection point, information on detection, cause and rectifications of troubles & faults.
- e) A lubrication schedule with all necessary drawings diagrams to identify the lubrication points.
- f) Manufacturer's literature.

5.03.00 The instruction manual shall be subject to the approval of Owner.

6.00.00 **PLANT HANDBOOK**

The Contractor shall submit to the Engineer, a preliminary plant handbook preferably in A-4 size sheets which shall contain the design and performance data of various plant, equipment and systems covering the complete project including single line flow diagrams, within twenty four (24) months from the date of his acceptance of the Letter of Intent. The final plant handbook complete in all respects shall be submitted by the Contractor six (6) months before start-up and commissioning activities. The plant handbook shall be submitted as per distribution schedule.

7.00.00 **CONTRACT STAGE DOCUMENT SUBMISSION AND APPROVAL PROCEDURE**

7.01.00 Within fifteen (15) days to one month of issue of Letter of Intent (LOI) by the Owner, the Contractor shall furnish a schedule of drawings and design

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

document to be submitted by him to the Owner/Engineer indicating dates against each document.

The documents shall be divided into two categories : a) for approval and b) for information/further engineering and co-ordination by the Owner.

In preparing this schedule, the Contractor shall allow two (2) weeks from date of receipt for review and comments by the Owner/Engineer for each submission of a document.

This document submission schedule shall require approval by the Owner/Engineer.

7.02.00 All contract documents shall be marked, without fail, with the name of the Owner, the Project, the specification title and number and the unit designation.

All dimensions shall be in metric units.

All notes, markings etc. shall be in English.

7.03.00 Documents/Drawings, submitted during tender stage, shall be revalidated or revised as required and submitted as certified contract document for approval / information of the Owner/Engineer.

7.04.00 Unless specified otherwise, the following categories of documents/drawings would require approval of the Owner/Engineer:

- a) List of sub-vendors (from Owner only)
- b) System scheme and instrumentation diagrams
- c) Design basis justifying selection of equipment & process parameters where not specified in the Contract
- d) Equipment data sheets and general arrangement drawings
- e) Materials of construction
- f) Layout drawings.
- g) Operation logic diagrams.
- h) Typical control circuit.
- i) Drawings of Instrumentation and control.

7.05.00 Unless specified otherwise, the following categories of documents/ drawings would be treated for information/further engineering by the Owner/Engineer. The Contractor shall, however, incorporate all additional information and clarifications in these documents / drawings as and when desired by the Owner/Engineer.

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

- a) Equipment foundation drawings.
- b) Equipment cross-section drawings, product literature etc. which are of proprietary nature.
- c) Predicted performance curves of equipment.
- d) Various bills of quantity, schedules etc.
- e) Piping fabrication drawings, isometrics etc.
- f) Panel wiring diagrams.
- g) Instruction/Operation manuals.
- h) Service manuals and trouble shooting guide for C & I system including field instruments.
- i) Cable schedule and interconnection chart.
- j) Drive/feederwise control scheme showing all external interfaces.

In essence, the Contractor is solely responsible for corrections and adequacy of design & engineering for documents under this category.

7.06.00 Upon review, the Owner/Engineer shall put his remarks and one of the following action stamps on the drawing/document:

- a) A - Drawing submitted as approved, proceed with fabrication
- b) B - Drawing approved subject to comments noted, proceed with fabrication, considering our comments. Correct as necessary and resubmit for record.
- c) C - See attached memo.
- d) D - Correct your original drawing incorporating our comments and resubmit for approval.
- e) E - Information furnished is noted.
- f) F - Prints not enclosed

For action stamps in category (c) & (d), documents must be resubmitted for review by the Owner/Engineer. For action stamp in category (b), further review by Owner/Engineer would not be necessary provided the Contractor agrees & incorporates the comments made on the document.

Except for action stamp under category (c) & (d), the Contractor can proceed with manufacturing and other sequential activities for those areas of a drawing/document which do not have any review comment by the Owner/Engineer.

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

The Owner/Engineer may accord approval in category (c) or (d) in more than one submission of a document till he is satisfied that the intent of the specification has been fully complied with. The Contractor shall be responsible for delay in such cases and no extension of time shall ordinarily be allowed on such grounds. Approval of contract documents by the Owner/Engineer shall not relieve the Contractor of his responsibility for any errors and fulfillment of contract requirements.

The Contractor's work shall be in strict accordance with the finally approved drawings and no deviation shall be permitted without written approval of the Owner/Engineer.

- 7.07.00 Except key plan/general yard plan, any layout drawing requiring scrutiny shall not be drawn to a scale less than 1:50.
- 7.08.00 For review by the Consulting Engineer, the Contractor shall furnish soft copies of drawings & documents and three (3) prints of each drawing/document. Two (2) prints of such submission shall also be sent to the Owner. After review, comment/approval will be sent to the Contractor. Upon action under category (a) or (e), the Contractor shall directly distribute the documents to the various offices of the Owner and other agencies in number of copies as specified in the contract document. Such distribution copies shall be marked with the reference and date of the letter by which the Owner/Engineer has accorded his final approval. Penal action shall be taken against the Contractor for any unauthorised revision in the drawings so distributed from the drawings approved by the Owner/Engineer. The contractor shall furnish three (3) CDs of all as built/final drawings for Owner/Consultant site.
- 7.09.00 In case of contradiction between the stipulations above and those stated elsewhere in the specification, the stipulations herein shall prevail.
- 7.10.00 For details of documentation for Civil, Structural and Architectural works, VII-A, VII-B and VII-C may be referred.
- 8.00.00 **TENDER STAGE DOCUMENT SUBMISSION**
- 8.01.00 The Bidder shall submit along with his bid all documents/drawings as requested in respective specifications. The documents shall include but not be limited to the following :
- a) All Bid proposal sheets duly filled up.
 - b) Detailed experience list and financial resources of the prime bidder his collaborators/associates in this bid as well as the sub-vendors proposed.
 - c) Scheme drawings indicating scope of supply and service as offered by the Bidder indicating clearly exclusions, if any.
 - d) List of terminal points of the package offered together with quality and quantity of various input (i.e. water, air, electricity etc.) as required from the Owner at such interfaces.

- e) Equipment GA, Layout, Design Calculations, interlock and other write-up, catalogues/literature etc. as required for clear understanding of the bid submitted.
- f) L-1 network indicating target dates for intermediate milestones and final commissioning of equipment supplied; This network shall be supplemented by a detailed write-up on proposal procedure of project implementation, deployment schedule for Key personnel with their bio-data, schedule of construction machinery etc.
- g) List of suppliers for all bought out items.

ANNEXURE-1

DISTRIBUTION SCHEDULE

S. No	Description	TSGENCO										M/S DCPL, KOLKATA			Equipment Vendor	Remarks
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/ KTPS	SE/ Civil KTPS	SE/E&M / KTPS	DE Constr. KTPS	Kolkata	HYD	KTPS				
A	Letter Of Intent or Contract Documents	1	1	1	S	1	2	2	1	1	1	1	1	2		
B	Vendor Drawings															
1.	Preliminary	1	1	1	2	1	1	2	2	12	1	-	S			
2.	Return preliminary with comments	-	-	1	2	1	1	1	1	S	1	-	1			
3.	Final and any revision thereof															
	a. Civil	1	1	6+1T	1	1	6+1T	1	1	2+1T	1	1	S			
	b. E&M	1	1	1	6+1T	1	1	6+1T	1	2+1T	1	1	S			
C.	Design Drawings															
1.	Preliminary															
	a. Civil	1	1	2	1	1	2	1	1	4	1	1	S			
	b. E&M	1	1	1	2	1	1	2	1	4	1	1	S			
2.	Released for construction															
	a. Civil	1	1	2	1	1	6	1	1	1	1	2	S			
	b. E&M	1	1	1	1	2	1	6	1	1	1	2	S			
3.	Return marked 'As built'															
	a. Civil	-	-	1	-	-	1	-	-	1	1	S	1			
	b. E&M	-	-	-	1	-	-	1	-	1	1	S	1			
4.	As built drawings															
	a. Civil	-	-	1+1T	-	2+1T	5+1T	-	1	1+1T	-	1	S			
	b. E&M	-	-	1	2+1T	2+1T	-	5+1T	1+1T	1+1T	-	1	S			

DEVELOPMENT CONSULTANTS

(e-PCT-TS-K-02-2014-15-Vol. IIA-6 Annx.docx)

V.II/A/S-6 Anx-1: 1

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

S. No	Description	TSGENCO							M/S DCPL, KOLKATA			Equipment Vendor	Remarks	
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/ KTPS	SE/ Civil KTPS	SE/E&M / KTPS	DE Constr. KTPS	Kolkata	HYD			KTPS
D	Progress Report Monthly													
1.	Equipment vendor	1	1	1	2	1	1	2	1	1	1	1	S	
2.	M/s DCPL, Kolkata	1	1	2	2	1	1	2	1	1	1	1	Nil	
E	Test & Inspection Reports													
1.	Equipment manufacturer													
	a. Civil	1	1	1	2	1	1	1	1	1	1	1	S	
	b. E&M	1	1	-	2	1	1	1	-	1	1	1	S	
2.	M/s DCPL, Kolkata	1	1	-	2	1	1	1	-	1	-	1	-	
F	Instruction Manuals/Data Books													
1.	Equipment manufacturer													
	a. Civil	1	1	1+1T	1	1	1	1	6+1T	1	2+1T	1	S	
	b. E&M	1	1	-	3+1T	1	1	6+1T	-	1	3+1T	1	S	
2.	M/s DCPL, Kolkata	1	1	-	10+1T	1	1	15+1T	-	1	S	1	Nil	
G	M/s DCPL, Kolkata Criteria	1	1	1	8+1T	1	1	2	1	1	1	1	S	
H	Design Calculations	1	1	1	8+1T	1	1	2	1	1	1	1	S	
I	Final consulting Engineering Report	1	1	1	10	1	1	2	1	1	S	1	Nil	

S – Source, T – Transparency & Soft Copy on CD,

TSGENCO : Telangana State Power Generation Corporation Limited
 Director, Projects, Hyd : Director/ Projects, TSGENCO, Vidhut Soudha, Hyderabad – 500 082

DEVELOPMENT CONSULTANTS
 (e-PCT-TS-K-02-2014-15-Vol. IIA-6 Annx.docx)

V.IIA/S-6 Anx-1: 2

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

Director, Technical, Hyd	:	Director/ Technical, TSGENCO, Vidyut Soudha, Hyderabad – 500 082
CE/ Civil, Hyd	:	Chief Engineer/Civil, Thermal Projects, TSGENCO, Vidyut Soudha, Hyderabad – 500 082
CE/ TPC-I, Hyd	:	Chief Engineer/TPC, TSGENCO, Vidyut Soudha, Hyderabad – 500 082
CE/ O&M/ KTPS	:	Chief Engineer(O&M), KTPS, Kothagudem, Telangana
SE/Civil, KTPS	:	Superintending Engineer (Civil), KTPS, Kothagudem, Telangana
SE/E&M, KTPS	:	Superintending Engineer (E&M), KTPS, Kothagudem, Telangana
DE/Constr./ KTPS	:	Divisional Engineer/Construction, KTPS, Kothagudem, Telangana
M/s DCPL, Kolkata	:	M/s DCPL, Kolkata.
M/s DCPL, Hyd	:	M/s DCPL, Hyderabad.
M/s DCPL, KTPS	:	M/s DCPL, KTPS, Kothagudem, Telangana

QUALITY ASSURANCE REQUIREMENTS

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	QUALITY ASSURANCE PROGRAMME
2.00.00	GENERAL REQUIREMENTS QUALITY ASSURANCE
3.00.00	QUALITY ASSURANCE DOCUMENTS
4.00.00	INSPECTION, TESTING & INSPECTION CERTIFICATES

ATTACHMENTS

ANNEXURE-I	FORMAT OF QUALITY ASSURANCE PROGRAMME
ANNEXURE-II	FIELD WELDING SCHEDULE

QUALITY ASSURANCE REQUIREMENTS

1.00.00 QUALITY ASSURANCE PROGRAMME

1.01.00 To ensure that the equipment and services under the scope of Contract whether manufactured or performed within the Contractor's works or at his Sub-contractor's premises or at the Owner's site or at any other place or work are in accordance with the specifications, the Contractor shall adopt suitable quality assurance programme to control such activities at all points, as necessary. Such programmes shall be outlined by the Contractor and shall be finally accepted by the Owner/Authorised representative after discussions before the award of contract. A quality assurance programme of the Contractor shall generally cover the following :

- a) His organisation structure for the management and implementation of the proposed quality assurance programme.
- b) Documentation control system.
- c) Qualification data for Bidder's key personnel.
- d) The procedure for purchase of materials, parts, components and selection of Sub-contractor's services including vendor analysis, source inspection, incoming raw-material inspection, verification of materials purchased etc.
- e) System for shop manufacturing and site erection control including process controls and fabrication and assembly controls.
- f) Control of non-conforming items and system for corrective actions.
- g) Inspection and test procedure both for manufacture and all site related works.
- h) Control of calibration and testing of measuring and testing equipments.
- i) System for quality audit.
- j) System for indication and appraisal of inspection status.
- k) System for authorising release of manufactured product to the Owner.
- l) System for handling storage and delivery.
- m) System for maintenance of records.

- n) Furnishing of quality plans for manufacturing and field activities detailing out the specific quality control procedure adopted for controlling the quality characteristics relevant to each item of equipment/component as per format enclosed at Annexure-I to this section for Owners approval
- o) Internal standards, if referred in the quality plans shall generally be compatible with National / International standards and shall be mentioned in the quality plans. Alternatively bidder shall furnish extracts of the internal standards detailing out acceptance norm for the product / material.

2.00.00 **GENERAL REQUIREMENTS - QUALITY ASSURANCE**

2.01.00 All materials, components and equipment covered under this specification shall be procured, manufactured, erected, commissioned and tested at all the stages, as per a comprehensive Quality Assurance Programme. An indicative programme of inspection/tests to be carried out by the Contractor for some of the major items is given in the respective technical specification. This is however, not intended to form a comprehensive programme as it is the Contractor's responsibility to draw up and implement such programme duly approved by the Owner/Consultant. The detailed Quality Plans for manufacturing and field activities should be drawn up by the Bidder, separately in the format attached at Annexure-I and will be submitted to Owner/Authorised representative for approval. Schedule of finalisation of such quality plans will be finalised before award.

Contractor shall furnish list of Manufacturing Quality Plans of major equipments indicating proposed inspection categorisation indicating items that will be offered for Owner's inspection etc and the Field Quality Plans

2.02.00 Manufacturing Quality Plan for all the major equipment will detail out their respective important components, their in-process various tests/inspection & final inspection / tests, to be carried out as per the requirements of this specification and standards mentioned therein and quality practices and procedures followed by Contractor's Quality Control organization. The relevant reference documents and standards, acceptance norms, inspection documents raised etc., during all stages of materials procurement, manufacture, assembly and final testing/performance testing are to be comprehensibly documented by Contractor.

Manufacturing Quality Plan for all major equipments/ items will be approved by owner. In these approved quality plans, Owner / Authorised representative shall identify customer hold points (CHP), test / checks which shall be carried out in presence of the Owners Engineer or his authorised representative and beyond which the work shall not proceed without consent of Owner / Authorised representative in writing. Inspection/ Test reports are to be submitted to owner as specified in final approved Manufacturing Quality Plans.

2.03.00 Field Quality Plans / Procedures for all field activities shall be submitted to

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

- owner for review / approval. These Quality Plans / procedures will detail out, for all equipment, the quality practices and procedures etc. to be followed by the Contractor's site Quality Control organisation, during various stages of site activities from receipt of materials/ equipment at site.
- 2.04.00 The Bidder shall also furnish copies of the reference documents/plant standards/acceptance norms/tests and inspection procedure etc., as referred in Quality Plans along with Quality Plans. These Quality plans and reference documents/standards etc. will be subject to Owner's approval without which manufacture shall not proceed. These approved documents shall form a part of the contract. In these approved quality plans, Owner/Authorised representative shall identify customer hold points (CHP), test/checks which shall be carried out in presence of the Owners Engineer or his authorised representative and beyond which the work will not proceed without consent of Owner/Authorised representative in writing. All deviations to this specification, approved quality plans and applicable standards must be documented and major deviations in the form of Non Conformity Report shall be referred to Owner/Authorised representative for approval and dispositioning.
- 2.05.00 No material shall be despatched from the manufacturer's works before the same is accepted subsequent to pre-despatch final inspection including verification of records of all previous tests/inspections by Owner's Engineer/ Authorised representative for "CHP" and "W" points marked in quality plans , and duly authorised for despatch by issuance of Material Despatch Clearance Certificate (MDCC). For items which is not under owner's inspection the contractor shall apply for despatch clearance (MDCC) from owner by submitting their internal inspection reports and quality records
- 2.06.00 All materials used or supplied shall be accompanied by valid and approved materials certificates and tests and inspection report. These certificates and reports shall indicate the sheet serial numbers or other such acceptable identification numbers of the material. The material certified shall also have the identification details stamped on it.
- 2.07.00 Castings and forgings used for construction shall be of tested quality. Details of results of chemical analysis, heat treatment record, mechanical property test results shall be furnished.
- 2.08.00 All welding and brazing shall be carried out as per procedure drawn and qualified in accordance with requirements of ASME Section - IX (latest edition) or other International equivalent standard acceptable to the Owner.
- All brazers, welders etc. employed on any part of the contract at Contractor's/ Sub-Contractor's works or at site shall be qualified as per ASME Section-IX (latest edition) or equivalent international standard approved by the Owner. Such qualification tests shall be conducted in presence of Owner / his authorised representative or owner approved Third Party Inspection Agency(TPIA). Previously qualified WPS & PQR shall be acceptable if witnessed by owner's approved TPIA.
- For welding of pressure parts and high pressure piping coming under IBR purview, the requirements of IBR shall also be complied with.

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

- 2.09.00 All non-destructive examination (NDT) shall be carried out in accordance with LIST OF STANDARDS FOR REFERENCE as given below in this section.
- The NDT operator shall be qualified as per SNT-TC-IA (of American Society of non- destructive examination). Results of NDT for the list major equipments / items identified for owner's inspection shall be properly recorded and submitted for review and approval. Other items not covered under owner's inspection, contractor shall review and approve the NDT results and such reports shall be submitted to owner in the final documentation of the items / equipments
- 2.10.00 All the sub-vendors proposed by the Contractor for procurement of major bought out items including castings, forgings, semi-finished and finished components/equipment list of which shall be drawn up by the Contractor and finalised with the Owner shall be subject to Owner's approval. Quality Plans of the successful vendors shall be discussed, finalised and approved by the Owner/Authorised representative and form part of the Purchase Order between the Contractor and the Vendor.
- 2.11.00 All the purchase specifications for the major bought-out items, list of which shall be drawn up by the Contractor and finalised with the Owner shall be furnished to the Owner for comments and subsequent approval before orders are placed.
- Owner reserves the right to carry out quality audit and quality surveillance of the systems and procedures of the Contractor's or their sub-vendor's quality management and control activities. The Contractor shall provide all necessary assistance to enable the Owner carry out such audit and surveillance.
- Quality audit/approval of the results of tests and inspection will not prejudice the right of the Owner to reject equipment not giving the desired performance after erection and shall not in no way limit the liabilities and responsibilities of the Contractor in earning satisfactory performance of equipment as per specification.
- 2.12.00 Quality requirements for main equipment shall equally apply for spares and replacement items.
- 2.13.00 Repair/rectification procedures to be adopted to make any job acceptable shall be subject to the approval of the Owner.
- 2.14.00 For quality assurance of all civil works refer to the specifications for civil works.
- 3.00.00 **QUALITY ASSURANCE DOCUMENTS**
- 3.01.00 The Contractor shall be required to submit two (2) copies and two (2) sets of microfilms / CDs of the following Quality Assurance documents within three (3) weeks after despatch of the equipment:
- a) Material mill test reports on components as specified by the specification.

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

- b) The inspection plan with verification, inspection plan check points, verification sketches, if used and methods used to verify that the inspection and testing points in the inspection plan were performed satisfactorily.
- c) Non-destructive examination results /reports including radiography interpretation reports.
- d) Factory tests results for testing required as per applicable codes and standards referred in the specification.
- e) Welder identification list listing welder's and welding operator's qualification procedure and welding identification symbols.
- f) Sketches and drawings used for indicating the method of traceability of the radiographs to the location on the equipment.
- g) Stress relief time temperature charts.
- h) Inspection reports duly signed by QA personnel of the Owner and Contractor for the agreed inspection hold points. During the course of inspection, the following will also be recorded :
 - i) When some important repair work is involved to make the job acceptable.
 - ii) The repair work remains part of the accepted product quality.
- i) Letter of conformity certifying that the requirement is in compliance with finalised specification requirements.

4.00.00 INSPECTION, TESTING AND INSPECTION CERTIFICATES

4.01.00 The Owner's Engineer, or his duly authorised representative and/or an outside inspection agency acting on behalf of the Owner shall have access inside the workshops, test labs, establishments at all reasonable times to inspect and examine the materials and workmanship of the works during its manufacture or erection and if part of the works is being manufactured or assembled on other premises or works, the Contractor shall obtain for the Owner's Engineer and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Contractor's own premises or works.

4.02.00 The Contractor shall give the Owner's Engineer/ Authorized Inspector twenty one (21) days written notice for "CHP" / "W" points of any material being ready for testing by owner' engineer / Authorized inspector. Such tests shall be to the Contractor's account except for the expenses of the Inspector. The Engineer/ Inspector, unless the witnessing of the tests is virtually waived, will attend such tests within fifteen (15) days of the date on which the equipment is notified as being ready for test/inspection. If owner's Engineer / Authorised Inspector fail to attend the inspection, next mutually convenient date for test shall be agreed with Contractor. Contractor shall, in

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS****EPC Bid Document
e-PCT/TS/K/02/2014-15**

- no case proceed with the test without owner or his authorized inspectors, unless the witnessing is officially waived and advised Contactor to proceed with the test. Contactor shall forthwith forward duly certified completed test report and a product quality certificate in six (6) copies to owner upon completion of such test.
- 4.03.00 The Engineer or Inspector shall within fifteen (15) days from the date of Inspection as defined herein give notice in writing to the Contractor, or any objection to any drawings and all or any equipment and workmanship which is in his opinion not in accordance with the contract / QAP or other approved quality documents. The Contractor shall give due consideration to such objections and shall either make modifications that may be necessary to meet the said objections or shall confirm in writing to the Engineer/Inspector giving reasons therein, that no modifications are necessary to comply with the contract / QAP or other approved quality documents.
- 4.04.00 When the factory tests have been completed at the Contractor's or sub-contractor's works, the Engineer/Inspector shall issue a certificate to this effect fifteen (15) days after completion of tests excluding the test completion date subject to submission of all certified documents related to the test, If the tests are not witnessed by the Engineer/Inspectors, the certificate shall be issued within fifteen (15) days of the receipt of the Contractor's test certificate by the Engineer/Inspector. Failure of the owner's Engineer/Inspector to issue such a certificate shall not prevent the Contractor from proceeding with the works. The completion of these tests, or the issue of the certificates shall not bind the Owner to accept the equipment should it, on further tests after erection be found not to comply with the contract / QAP or other approved quality documents.
- 4.05.00 In all cases where the contract provides for tests whether at the premises or works of the Contractor or any sub-contractor, the Contractor, except where otherwise specified shall provide free of charge such items as labour, materials, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the owner's Engineer/Inspector or his authorised representatives to carry out effectively such tests on the equipment in accordance with the Contract / QAP or other approved quality documents. Contractor and shall give facilities to the owner's Engineer/ Inspector or to his authorised representative to accomplish testing.
- 4.06.00 To facilitate advance planning of inspection in addition to giving inspection notice as per Clause 4.02.00, the Contractor shall furnish quarterly inspection programme indicating proposed schedule dates of inspection at customer hold point and final inspection stages. Updated quarterly inspection plans will be made for each three consecutive months and shall be furnished before beginning of each calendar month.

LIST OF STANDARDS FOR REFERENCE

- a) International Standards Organisation (ISO).
- b) International Electro-technical Commission (IEC).
- c) American Society of Mechanical Engineers(ASME)
- d) American National Standards Institute (ANSI).
- e) American Society for Testing and Materials (ASTM).
- f) American Institute of Steel Construction (AISC).
- g) American Welding Society (AWS).
- h) Architecture Institute of Japan (AIJ).
- i) National Fire Protection Association (NFPA).
- j) National Electrical Manufacturer's Association (NEMA).
- k) Japanese Electro-technical Committee (JEC).
- l) Institute of Electrical and Electronics Engineers (IEEE).
- m) Federal Occupational Safety and Health Regulations (OSHA).
- n) Instrument Society of America (ISA).
- o) National Electric Code (NEC).
- p) Heat Exchanger Institute (HEI).
- q) Tubular Exchanger Manufacturer's Association (TEMA).
- r) Hydraulic Institute (HIS).
- s) International Electro-Technical Commission Publications.
- t) Power Test Code for Steam Turbines (PTC).
- u) Applicable German Standards (DIN).
- v) Applicable British Standards (BS).
- w) Applicable Japanese Standards (JIS).
- x) Electric Power Research Institute (EPRI).
- y) Standards of Manufacturer's Standardization Society (MSS)

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS**

**EPC Bid Document
e-PCT/TS/K/02/2014-15**

- z) Bureau of Indian Standards Institution (BIS).
- aa) Indian Electricity Rules.
- bb) Indian Boiler Regulations (IBR).
- cc) Indian Explosives Act.
- dd) Indian Factories Act.
- ee) Tariff Advisory Committee (TAC) rules.
- ff) Emission regulation of Central Pollution Control Board (CPCB).
- gg) Pollution Control regulations of Dept. of Environment, Govt. of India
- hh) Central Board of Irrigation and Power (CBIP) Publications

Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS

EPC Bid Document
e-PCT/TS/K/02/2014-15

**ANNEXURE-I
FORMAT OF QUALITY ASSURANCE PROGRAMME**

VENDOR'S LOGO , NAME & ADDRESS	MANUFACTURING QUALITY ASSURANCE PLAN	DOC NO: XXXXX-CAL-QAP-M-0001	0 1 2 3 4	
ITEM : -				
CLIENT :	LOCATION :			
PROJECT :	REFERENCE PURCHASE ORDER NO. & DT :			
VENDOR :	REFERENCE APPROVED DATA SHEET :			
SUB VENDOR :	REFERENCE APPROVED DRAWING. NO. :			
ABBREVIATIONS :				
QAP - QUALITY ASSURANCE PLAN,	MATL - MATERIAL,	1 - DCPL/PROJECT AUTHORITY		
CR - CRITICAL,	APP - APPROVED,	2 - SUPPLIER		
MA - MAJOR,	DWG - DRAWING,	3 - SUB-SUPPLIER		
MI - MINOR	SUPL - SUPPLIER,	4 - MANUFACTURER		
SPEC - SPECIFICATION,	PROC - PROCEDURE	5 - THIRD PARTY INSPECTION AGENCY		
TC - TEST CERTIFICATES				
P - PERFORM				
w - WITNESS				
V - VERIFY				
CHP - CUSTOMER HOLD POINT				
NOTES:				
1. EXACT MATERIAL / PROCESS / INSPECTION / TESTS FOLLOWED BY THE MANUFACTURER SHALL BE SPECIFIED 2. EXACT REFERENCE DOCUMENT/ACCEPTANCE STANDARD SHALL BE SPECIFIED 3. IN CASE SPECIFIED ACCEPTANCE STANDARD / NORMS IS OTHER THAN NATIONAL / INTERNATIONAL STANDARDS . STANDARD / COPY OF THE ACCEPTANCE NORMS FOLLOWED BY THE MANUFACTURER SHALL BE SUBMITTED FOR REVIEW RECORD 4 FINAL INSPECTION DOSSIER SHALL BE PREPARED BY MANUFACTURER & SHALL BE ENDORSED BY INSPECTION AGENCY				
Prepared by		Checked by		
Revision	R0	R1	R2	R0
DATE				
Approved By		Approved By		
		R0	R1	R2

DEVELOPMENT CONSULTANTS
(e-PCT-TS-K-02-2014-15-Vol. IIA-6&7.doc)

V.IIA/S-7 : 9

Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS

EPC Bid Document
e-PCT/TS/K/02/2014-15

ANNEXURE-II

FIELD WELDING SCHEDULE

PROJECT : FWS NO :
 CONTRACTOR : REV NO. :
 PACKAGE : FIELD WELDING CODE :
 SYSTEM : PAGE NO. :

Sl No.	Drawing No. for Weld Locations & Identification mark	Description of parts to be welded	Material specification	Dimensions	Process of Welding	Type of Weld	Electrode Filler Specification	WPS No.	Minimum Pre-heat Temperature	Heat Treatment Temperature [Holding Time in secs]	NDT Method	NDT Specification Number	Acceptance Norm Ref.	Remarks
--------	--	-----------------------------------	------------------------	------------	--------------------	--------------	--------------------------------	---------	------------------------------	---	------------	--------------------------	----------------------	---------

The Field Welding Schedule should be submitted for :

- 0 Pressure Parts
- 0 Tanks/Vessels
- 0 Piping
- 0 Heavy/Important Structural Steel
- 0 Heat Exchangers
- 0 Bus Ducts

REQUIREMENTS OF SPARES, TOOLS & TACKLE, LUBRICANTS/OIL/CONSUMABLES

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	TOOLS AND TACKLE
2.00.00	SPARES
	ATTACHMENT
ANNEXURE-I	MANDATORY SPARE LIST

**REQUIREMENTS OF SPARES, TOOLS & TACKLE,
LUBRICANTS/OIL/CONSUMABLES**

1.00.00 TOOLS & TACKLE

The Contractor shall supply with the equipment one complete set of special tools and tackle as required for the erection, assembly, dismantling & maintenance of the equipment. These special tools will also include special material handling equipment, jigs & fixtures for maintenance and calibration/readjustment, checking & measurement aids etc. A list of such tools & tackle shall be submitted by the Bidder along with the offer. Detailed description of each tools/tackle, its function along with the equipment/part for which it is meant for and the price of each tools/tackle shall also be indicated in the offer. These tools & tackle shall be separately packed and sent to site before the first unit commissioning. The Bidder shall also ensure that these tools are not used for erection purpose.

2.00.00 SPARES

2.01.00 General

The Bidder shall indicate and include in his scope of supply all the necessary start-up, commissioning and recommended spares in addition to mandatory spares as specified elsewhere in the specification. The Owner reserves the right to buy any or all mandatory and recommended spares. The Contractor shall also state for each item of spares both mandatory and recommended, the normal expected service life.

2.01.01 All spares supplied under this contract shall be strictly interchangeable with the parts for which they are intended to replace. The spares shall be treated and packed for long storage under the climatic conditions prevailing at the site, e.g. small items shall be packed in sealed transparent plastic bags with dessicator packs as necessary.

2.01.02 Each spare part shall be clearly marked or labelled on the outside of the packing with the description. When more than one spare part is packed in a single case, a general description of the contents shall be shown on the outside and a detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purposes of identification.

2.01.03 All cases, containers or other packages are liable to be opened for examination as may be considered necessary by the Engineer.

2.01.04 All mandatory spares shall be delivered to site within one to three months prior to the scheduled date of the trial operation of the plant. However, they shall not be despatched before the despatch of the associated main equipment.

- 2.01.05 The Bidder shall also guarantee supply of spare parts, which will be made, based on manufacturer's drawings on special order from the Purchaser for 30 years after commissioning of the plant.
- 2.01.06 Warranty period for all kinds of spares shall be six thousand (6000) hours of operation, except normal wear or eighteen (18) months from the date of receipt at site, whichever is earlier. In case of failure or non-conformance to specifications, the Contractor shall replace them free of cost.
- 2.02.00 **Recommended Spares**
- 2.02.01 The Contractor shall provide a list of recommended spares giving unit prices and total prices for 2 years of normal operation of the plant for spares of indigenous origin, and for 5 years of normal operation for spares of non-indigenous origin. This list shall take into consideration the mandatory spares specified elsewhere in the specification and should be a separate list.
- 2.02.02 The price of recommended spares will not be used for the evaluation of bids. The price of these spares shall remain valid for a period as specified elsewhere in the specification from the date of Award of the Contract. Where the recommended spares are the same as mandatory spares, the prices shall be the same. The prices of any recommended spares, which are not common with mandatory spares, shall be subject to review by the Owner, and shall be finalised after mutual discussion.
- 2.03.00 **Start-up Commissioning Spares**
- 2.03.01 Start-up commissioning spares are those spares which may be required during the start-up and commissioning of the equipment/system. All spares used until the plant is handed over to the Owner shall come under this category. Said spares, properly marked, shall be supplied together with the main equipment and shall be used by the Contractor, if needed, during erection & commissioning stage. All such spares which remain unused till issuance of Taking Over Certificate by the Owner, along with an equipment-wise quantitative consumption report shall be returned to the Owner during time of handover. The list of commissioning spares to be brought by the Contractor to ensure smooth commissioning of the plant shall be subject to the Engineer's approval.
- 2.03.02 The Contractor shall submit a complete BBU list inclusive of recommended, mandatory, initial start-up and commissioning spares. Costs of the above spares, which are consumed before the handing-over of the plant, shall be deemed to have been included in the lump sum proposal price of the package, and the Contractor shall have no claim on this account to the Owner.
- 2.04.00 **Mandatory Spare Parts**
- 2.04.01 The Owner considers some of the spares are essential for running the equipment irrespective of whether they are included in the list of recommended spares by the Bidder as mentioned above.

Since the components involved can not be foreseen at the bidding stage, only

**Telangana State Power Generation Corporation Ltd.
1x800 MW Kothagudem TPS****EPC Bid Document
e-PCT/TS/K/02/2014-15**

broad requirements of the Owner in this respect are outlined hereinafter. The bidder shall include his proposal, on the basis of this guideline, an item-wise list of all components and the quantity, unit prices & total price thereof, offered as mandatory spares for each and every equipment. This list shall be separate from the list of recommended spares and shall be used for bid evaluation purposes. Any clarification in this respect may be obtained by the Bidder at the pre-bidding stage.

2.04.02 The mandatory spares should be supplied to the Owner at least one month before the trial run. The despatch programme is subject to approval of the Owner/Consultant after award of contract.

2.04.03.1 Criteria for selection of Quantity of Mandatory Spares :

For Mandatory Spares refer Annexure-V

2.04.04 Purchaser will have the option to procure any or all of the mandatory spares at his discretion.

**TECHNICAL SPECIFICATION
FOR
PRESSURE AND STORAGE VESSELS**

**TECHNICAL SPECIFICATION
FOR
PRESSURE AND STORAGE VESSELS**

C O N T E N T S

CLAUSE NO.	DESCRIPTION	PAGE NO.
1.00.00	INTENT OF SPECIFICATION	1 OF 9
2.00.00	CODES AND STANDARDS	1 OF 9
3.00.00	GENERAL DESIGN FEATURES	2 OF 9
4.00.00	MATERIAL OF CONSTRUCTION	3 OF 9
5.00.00	FABRICATION	4 OF 9
6.00.00	APPURTENANCES	5 OF 9
7.00.00	ERECTION	7 OF 9
8.00.00	PROTECTIVE LINING AND PAINTING	8 OF 9
9.00.00	TESTS & INSPECTION	9 OF 9

**TECHNICAL SPECIFICATION
FOR
PRESSURE AND STORAGE VESSELS**

1.00.00 INTENT OF SPECIFICATION

This specification covers the design, manufacture, shop testing, shop testing, construction, fabrication, erection, testing, inspection & commissioning of pressure and storage vessels at works & site.

2.00.00 CODES AND STANDARDS

The design, manufacture, shop testing, site fabrication and erection, testing and commissioning of the pressure vessels and atmospheric storage tanks vessels shall conform to the latest revisions of the following standards, in addition to other standards addressed elsewhere in the Bid Specification subject to any modification and requirement, as specified elsewhere:

a)	ASME Section VIII	Rules for Construction of Pressure Vessels
b)	ASTM Standards	Standards published by American Society for Testing and Materials
c)	BS EN 12285-2	Workshop fabricated steel tanks. Horizontal cylindrical single skin and double skin tanks for the aboveground storage of flammable and non-flammable water polluting liquids
d)	IS-803	Code of Practice for Design Fabrication and Erection of Vertical Mild Steel Cylindrical Welded Oil Storage Tanks
e)	IS-816	Code of Practice for Use of Metal Arc Welding for General Construction in Mild Steel
f)	IS-817	Code of Practice for Training and Testing of Metal Arc Welders
g)	IS-822	Code of Procedure for Inspection of Welds
h)	IS-1363 Part 1 to Part 3	Hexagon Head Bolts, Screws and Nuts of Product Grade C
i)	IS-1367 Part 1 to Part 16	Technical Supply Conditions for Threaded Steel Fasteners
j)	IS-2002	Steel Plates for Pressure Vessels for Intermediate

		and High Temperature Service including Boilers
k)	IS-2062	Hot Rolled Medium and High Tensile Structural Steel
l)	IS-2825	Code for Unfired Pressure Vessels
m)	IS-3133	Manhole and Inspection Openings for Chemical Equipment - General Requirements
n)	IS-4049 Part 1 & Part 2	Formed Ends for Tanks and Pressure Vessels
o)	IS-4682 Part 1 to Part 10	Code of Practice for Lining of Vessels and Equipment for Chemical Processes
p)	IS-4864 to IS-4870	Shell Flanges for Vessels and Equipment

3. 00.00 GENERAL DESIGN FEATURES

3. 01.00 Design of all pressure vessels shall conform to IS 2825 or ASME Section VIII Division-I or equivalent code / standard (subject to approval by Purchaser).

3. 02.00 Design of all vertical cylindrical atmospheric storage tanks containing water, acid, alkali and other chemicals shall conform to IS-803.

Supporting frame where required for design of Demineralized Water Storage Tanks shall be in accordance with IS-800. The tank shall be "Non-pressure" fixed roof type with atmospheric vents.

3. 03.00 Design of all horizontal cylindrical atmospheric storage tank containing decationized water, acid, alkali and other chemicals shall conform to BS EN 12285-2.

3. 04.00 Design temperature of all pressure vessels and atmospheric storage tanks shall be 10 deg. C higher than the maximum temperature that any part of the vessel / tank is likely to attain during operation.

3. 05.00 Design pressure shall be the maximum expected pressure to which the vessels may be subjected to plus 5% additional margin. Maximum expected pressure for vessels placed in the discharge line of pumps shall be based on the shut-off head of the pumps plus static head at pumps suction, if any.

3. 06.00 In case, tank is subjected to vacuum under any situation, the same shall be duly considered as one of the criteria for design of the tank.

3. 07.00 Each pressure vessel / atmospheric storage tank without inside rubber lining shall have a corrosion allowance of minimum 2.0 mm.

3. 08.00 Mill tolerance as per applicable code (minimum 0.3 mm) shall be duly considered for each shell as well as dished end.

3. 09.00 Thinning allowance of 2.0 mm (minimum) shall be considered for each dished end.

3. 10.00 Effective liquid volume for an atmospheric storage tanks tank shall be considered as the liquid volume in between the design highest operating level / design highest level switch set point and design lowest operating level / design lowest level switch set point.
3. 11.00 A liquid volume (corresponding to a minimum of 100 mm shell / liquid height in between design lowest operating level / design lowest level switch set point and top of side mounted outlet nozzle / bottom of tank) below the required effective liquid volume shall be considered & provided for satisfactory functioning of concerned level switch.
3. 12.00 Each atmospheric tank shall have sufficient free board (minimum 300 mm unless specified otherwise) above the design highest level / design highest level switch set point.
3. 13.00 The invert of overflow nozzle shall be kept at least 50 mm or 5 % of total height whichever is higher above the design highest level / design highest level switch set point for each of the atmospheric tanks, except for the Demineralized Water Storage Tanks.
3. 14.00 For Demineralized Water Storage Tanks, the invert of overflow nozzle shall be kept at least 500 mm or 5 % of total shell height whichever is higher above the design highest level / design highest level switch set point.
3. 15.00 A minimum 100 mm shell height shall be provided above the top of overflow nozzle of each atmospheric storage tank.
3. 16.00 Wall thickness of each of atmospheric tanks shall not be less than 6 mm. If higher thickness for any atmospheric storage tank is specified elsewhere in this Specification, the same shall be provided.
3. 17.00 Vessels coming under preview of IBR shall be designed accordingly.
4. 00.00 **MATERIAL OF CONSTRUCTION**
4. 01.00 The pressure vessels shall be designed as Class 3 vessels (as per IS-2825) and fabricated of steel as per IS-2062 / IS-2002 Grade 3 or SA-515 / 516 Grade 60 / 70 In case, the vessels are designed as Class 1 or Class 2 vessels (as per IS-2825), the material of construction shall conform to IS-2002 Grade 3.
4. 02.00 Atmospheric storage tanks shall be fabricated of mild steel as per IS-2062.
4. 03.00 The material of construction for various connections, for all the lined or unlined vessels/tanks shall be same as that of interconnecting piping material suitably lined wherever required. The pipe flanges, manhole/manhole covers, reinforcement pads etc. shall be fabricated out of the same material as that one used for the vessel / tank. However, screwed fittings for instrumentation, sample connection, drain connection of size 25 mm NB and less shall be of stainless steel construction (SS-316).

5. 00.00 FABRICATION

5. 01.00 All pressure vessels and storage tanks except the large tanks like Demineralised Water Storage Tanks should preferably be fabricated and tested completely at manufacturer's works to ensure better workmanship.
5. 02.00 The plates to be used for fabrication shall preferably have a minimum width of 1500 mm.
5. 03.00 Ends of pressure vessels shall be of dished design and constructed of forging, pressing or spinning as per IS-4049.
5. 04.00 Interior surfaces of all atmospheric storage tanks shall be clear of stiffeners and other structural supports. Tanks shall be reinforced and stiffened externally as required.
5. 05.00 Plates to be used for fabrication of atmospheric vertical storage tanks shall be accurately formed in bending rolls to the diameters called for and cold rolled through plate bending machine by several number of passes to true curvature and joined by welding.
5. 06.00 The atmospheric vertical storage tanks shall have flat bottom.
5. 07.00 Ends of atmospheric horizontal storage tanks shall be of dished design and constructed of forging, pressing or spinning as per IS-4049. Conical or Flat Ends shall not be accepted.
5. 08.00 All welding shall be as per IS-816 or equivalent code (subject to approval by Purchaser). The qualification of the welders should be as specified in IS-817 and welding electrodes shall be as per relevant Codes / Standards.
5. 09.00 Bidder shall state clearly in his proposal the make and type of welding rods necessary for fabrication / construction work.
5. 10.00 Welding sequence shall be adopted in such a way so as to minimize the distortion due to welding shrinkage. The Bidder shall indicate in drawing, the sequence of welding proposed which should meet prior approval of the Purchaser. Welding shall not be carried out when the surface of the parts to be welded are wet from any cause and during periods of rain and high winds unless the welder and work are properly shielded.
5. 11.00 All seams shall be so positioned that they do not pass through connections of vessel / tank. The connections shall be flushed with inner surface of vessel / tank and welded continuous on both sides of the vessel / tank. Sharp inside edges shall be rounded to a minimum 3 mm radius. Inside seam weld shall be ground smooth, suitable for applicable of corrosion resistant coating / lining.
5. 12.00 All the joints (circumferential / longitudinal) shall be double butt welded with full penetration or single butt welded without backing strip. For joints involving small thickness 6 mm or less, back chipping to metal followed by DP test and re-welding shall be done to have full penetration.
5. 13.00 All internal baffles, wear plates, pipes etc. shall be continuously welded on both sides at all contact points with full fillet welds which shall be free of voids, gaps,

- craters, high spots, sharp edges, and undercutting. Sharp edges shall be ground to a 3 mm minimum radius.
5. 14.00 All welds on inner surface of vessel / tank shall be free of voids, gaps, craters, pits, high spots, sharp edges, abrupt ridges and valleys or undercut edges. High spots, irregularities and sharp edges shall be removed by grinding.
5. 15.00 Weld splatter shall be removed.
5. 16.00 Inspection of all welds shall be carried out in accordance with IS-822 'Code of Practice for Inspection of Welds.'
6. 00.00 **APPURTENANCES**
6. 01.00 Internals for pressure vessels and atmospheric storage tanks shall be provided as detailed out elsewhere in the specification and as further required.
6. 02.00 All the pressure vessels and atmospheric storage tanks shall be provided with drain connections along with drain valves of suitable size.
6. 03.00 All the pressure vessels and atmospheric storage tanks shall be provided with the vent connections. The design shall be as to offer adequate area for venting. Venting area shall be such that over pressure/vacuum is not created during maximum filling / withdrawal rate. The maximum withdrawal rate for the Demineralized Water Storage Tanks shall be intimated later at detail engineering stage to the Bidder.
6. 04.00 Various instrumentation and the fittings required for the pressure vessels and atmospheric storage tanks shall be provided as elaborated elsewhere in the specification.
6. 05.00 **Manholes / Hand Holes**
- 6.05.01 Manholes shall be provided for all pressure vessels and atmospheric storage tanks to provide easy access into the same. The diameter shall be minimum 500 mm and each manhole will be provided with cover plate, nuts, bolts and gaskets to ensure leak tightness at the test pressure. Manholes shall be davit type for rubber lined vessels.
- 6.05.02 Each of the pressure vessels and horizontal type storage tanks shall be provided with at least one manhole at the top.
- 6.05.03 Each of the vertical type atmospheric storage tanks with diameter 1200 mm or more shall be provided with a manhole on the top. For the Demineralized Water Storage Tanks, manholes shall be provided as per IS-803.
- 6.05.04 Each of the pressure vessels filled with ion exchange resins shall be provided with a handhold of diameter at least 150 mm at a level in the vicinity of bottom of resin bed.
- 6.05.05 The required lining / coating for the inside surface of the manhole / handhold, nozzle and cover plate of the manhole/ handhold shall be same as that of the respective vessel/tank.
6. 06.00 **Nozzle Connections**

- 6.06.01 Bidder shall furnish all materials required for nozzle connections with reference to system requirements. In addition to these, additional nozzle connections, if required by the Purchaser for the inter-connection with other systems / piping / instruments etc. shall also be provided. Such additional requirements may be intimated to the Bidder later at detail engineering stage and Bidder shall provide the same complete with necessary supports and other accessories without any sort of price implication whatsoever.
- 6.06.02 Nozzle wall thickness shall be as per relevant code for design to be followed for the vessel/tank in questions.
- 6.06.03 All flanged connections should be supplied complete with matching counter flanges, bolts, nuts and gasket materials. The flange design (thickness and drilling etc.) shall match with the interconnected piping flanges.
- 6.06.04 Bolts and nuts to be used externally to the vessels shall be of hexagonal head conforming to IS-1367. However fasteners if any within tanks shall be of SS-316 / SS-304 or Hastalloy-B as per the duty conditions / requirements.
- 6.06.05 Gaskets shall be of full face type.
- 6.07.00 Sight glasses shall be provided for the tanks/vessels as specified elsewhere in the specification. The material for sight glass shall be high quality transparent PLEXIGLASS of sufficient thickness to withstand the test pressure. The sight glass shall be provided with suitable gaskets and bolts to ensure leak tightness at the test pressure.
- 6.08.00 **Vessels Supports / Lifting Lugs**
- 6.08.01 Adequate supporting arrangements like legs, straps, saddles, skirt boards, pillars etc. for the pressure vessels and atmospheric storage tanks shall be provided to transfer all loads to civil foundation. All foundation bolts, inserts etc. shall also be provided.
- 6.08.02 All vessels shall be provided with lifting lugs, eye bolts etc. for effective handling during erection.
- 6.08.03 All vessels of internal, diameter of 1200 mm or greater shall be provided with minimum four (4) lifting lugs for safe and effective handling during erection. Smaller vessels shall be provided with atleast two (2) lifting lugs.
- 6.08.04 Material of construction for these vessel supports, saddles, lugs shall conform to IS-2062.
- 6.09.00 **Special Accessories for Tanks**
- 6.09.01 Each of all the tanks shall be provided with over flow connection designed for the filling rate of the respective tank.
- 6.09.02 Water Seal shall be provided for the overflow line of Demineralized Water Storage Tanks. Vent line of Demineralized Water Storage Tanks shall be provided with Carbon-Di-Oxide Absorber / Breather of proven design to prevent contamination from atmospheric air. Carbon-Di-Oxide Absorber / Breather shall preferably be located at finished floor / pavement level.

- 6.09.03 The vent and overflow lines of Acid Bulk Storage / Day / Measuring Tanks shall be provided with fume absorber using suitable packing material, such as pall rings / raschig rings.
- 6.09.04 The vent and overflow lines of Alkali Bulk Storage / Preparation / Day / Measuring Tanks shall be provided with Carbon-Di-Oxide Absorber / Breather as addressed under clause no. 6.05.02 above.
- 6.09.05 Conservation Vent Valve shall provided on each of Demineralized Water Storage Tanks to ensure minimum contact with air. The valve should normally be closed. With vacuum or pressure to the extent of 65mm water gauge into the tank, the valve shall open to relieve the vacuum or pressure.

Material of construction should be as follows:

Body & valve disc	-	Die cast aluminium.
Spindle	-	Steel
Spring	-	Phosphor Bronze
Seal	-	Rubber

7.00.00 **ERECTION**

- 7.01.00 Each of all pressure vessels and atmospheric storage tanks should be directly placed on the civil foundation when supplied in fully fabricated form.
- 7.02.00 All fabricated part, before assembly, shall be transported by the Bidder to installation at site. All preliminary work and fabrication in part or full shall be done at the Bidder's fabrication yard or shop.
- 7.03.00 All material before final installation over the foundation at the respective locality shall be inspected and faired as necessary to ensure that any damage received during transportation is corrected before erection to the satisfaction of the Purchaser. Particular attention shall be given towards removal of buckles and other form of distortion in shell and bottom plates of vertical atmospheric storage tanks. Irregularities and dirt which would prevent metal to metal contact at the jointing faces shall be removed.
- 7.04.00 The method of holding the plates in position during welding and all devices used for this purpose should be approved by the Purchaser. All lap joints shall be held in close contact during welding and the surface in contact shall be thoroughly cleaned before assembly.
- 7.05.00 Holes in plate work to assist in erection should be avoided as far as possible. The location of the holes shall be indicated in the fabrication drawing. The method of filling holes shall be approved by the Purchaser. Lugs attached by welding to the tank and required only for the purpose of erection shall be removed and any projections of weld metal shall be chipped and grounded flush with the plate surface.
- 7.06.00 In the construction of the shell, every care shall be taken to minimize distortion or lack of circularity due to welding or for any other reason.

- 7.07.00 Tanks shall be safeguarded against damage due to wind or any other external causes by providing suitable steel cable guys until completion.
- 7.08.00 All materials used by the Bidder such as electrodes, gaskets, bolts and nuts, paints and any other appurtenance shall be conforming to relevant Indian Standard Code of Practice or equivalent (subject to approval by the Purchaser). Manufacturer's test certificate for guaranteed performance shall have to be provided when called for.
- 7.09.00 The finished bottom plate of vertical atmospheric tanks shall be crowned from the outer periphery to the centre with a slope of 1:36. Sufficient number of plugged holes shall be provided in bottom plate of the tanks for bottom testing.
- 8.00.00 **PROTECTIVE LINING AND PAINTING**
- 8.01.00 Inside surfaces of all pressure vessels and atmospheric storage tanks shall be protected by anticorrosive paints or rubber lining as required / specified. External surfaces of all pressure vessels and atmospheric storage tanks shall be protected by anti corrosive painting.
- 8.02.00 The supply and application of Protective Lining and Painting with reference to pressure vessels and atmospheric storage tanks need to be as per **Sub Section: M7 – Technical Specification for Protective Lining and Painting**, attached herewith.
- 9.00.00 **TESTS AND INSPECTION**
- 9.01.00 All pressure vessels shall be hydraulically tested at 1.5 times design pressure or 2 times the maximum working pressure whichever is higher, for a period not less than one (1) hour.
- 9.02.00 All atmospheric storage tanks shall be tested for leak tightness by filling up with water up to the highest level for a period not less than 8 hours.
- 9.03.00 Full rubber lining is to be tested as per IS-4682 Part I for the following tests:
- (a) Adhesion tests
 - (b) Tests to check resistance to bleeding
 - (c) Measurement of lining thickness
 - (d) Shore hardness test
 - (e) Spark test at high voltages 5 KV / mm of thickness with a gap of 8 mm between the probe and lining.
- 9.04.00 Thickness of painting shall be checked with dry type thickness gauge.
- 9.05.00 Vessels as per IBR shall be tested accordingly.
- 9.06.00 DP test after back gauging and on complete welds on atmospheric tanks and pressure vessels need to be carried out.
- 9.07.00 All non-destructive tests shall be carried out as per the applicable design code / standard for all pressure vessels and atmospheric tanks.

9. 08.00 Buttwelds if any on the dished ends shall be radiographed after dishing and shall be stress relieved.
9. 09.00 All dished ends for pressure vessels shall be stress relieved after dishing.
9. 10.00 All weld procedure and welder qualification certificates shall be verified.
9. 11.00 All painting on vessels and tanks shall be checked for the thickness as per the specification mentioned elsewhere.
9. 12.00 All materials to be used for the pressure vessels and atmospheric tanks and accessories should be of tested quality and test certificates shall be made available to the Purchaser.