



An ISO 9001
Company

Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Tiruchirappalli – 620014, TAMIL NADU, INDIA

CAPITAL EQUIPMENT / MATERIALS MANAGEMENT

ENQUIRY	Phone: +91 431 257 76 53 Fax : +91 431 252 00 31 Email : skaruna@bheltry.co.in Web : www.bhel.com
NOTICE INVITING TENDER	

TWO PART BID Tender to be submitted in two Parts	Enquiry Number: 2621400033	Enquiry Date: 10.07.2014	Due date for submission of quotation: 04.08.2014
--	---	---	---

You are requested to quote the Enquiry number date and due date in all your correspondence. This is only a request for quotation and not an order.


Please note that under any circumstances both delayed offer and late offers will not be considered. Hence vendors are requested to ensure that the offer is reaching physically our office before 14.00 hrs on the Date of tender opening.

Item	Description	Quantity
10	Compensating Cable - K-Type (Thermocouple Extension Wire) as per the technical specification & commercial conditions applicable (to be downloaded from web site www.bhel.com or http://tenders.gov.in)	24000 Mtrs

Important points to be taken care during submission of offer


1. The rate of EMD for this Tender will be (INR) : 40,000/-
2. The Checklist for Acceptance of Commercial Terms & Conditions to be filled and enclosed along with the offer failing which, the offer will not be considered for evaluation.
3. All updates, amendments, corrigenda, etc., (if any), for each tender will be posted only on the above websites from time to time, as and when required, until each tender is opened. There will be no publication of such updates, amendments, corrigenda, etc., through newspapers or any other media.

BHEL's General guidelines / instructions (refer MM/CE/GENL/001-EMD) including bank guarantee formats and list of consortium banks, commercial terms check-list can be downloaded from BHEL web site <http://www.bhel.com> or from the Government tender website <http://tenders.gov.in> (public sector units > Bharat Heavy Electricals Limited page) under above Enquiry reference

<p>Tenders should reach us before 14:00 hours on the due date Tenders will be opened at 14:30 hours on the due date Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present</p>	<p>Yours faithfully, For BHARAT HEAVY ELECTRICALS LIMITED  Sr. Engineer/MM/Capital Equipment</p>
---	---

COMPENSATING CABLE – ‘K’ TYPE – Specification
(Thermocouple Extension Wire)

TYPE	: Cr. Al (TYPE K)
ELEMENT	: 20 Gauge
COLOUR CODE	: ANSI - Kx +ve (Yellow) Kx -ve (Red)
CONSTRUCTION & INSULATION	: As shown in sketch.
LIMITS OF ERROR	: 0 °C To 204 °C error \pm 2.2 °C (maximum)
SAMPLE	: One metre long sample should be supplied along with quotation.



Construction & Insulations –Compensating cable – K Type (Thermocouple Extension wire)

Note: Attached compliance report must be submitted along with offer.

COMPENSATING CABLE – ‘K’ TYPE
(Thermocouple Extension Wire)

QUALIFYING CRITERIA

The BIDDER has to meet the following requirements to get qualified for considering the technical offer

Sl.No.	REQUIREMENTS	VENDOR's RESPONSE
1	Copy of certificate of Manufacturer / 'Distributor Authentication Certificate' given by principle should be produced.	
2	The Technical offer should be supported by product Catalogues & Data sheets.	
3	Attached compliance report must be submitted along with offer.	

COMPLIANCE REPORT

COMPENSATING CABLE – ‘K’ TYPE

(Thermocouple Extension Wire)

BHEL SPECIFICATION		VENDOR 'SCONFIRMATION OFFER	DEVIATION IF ANY
1	TYPE	Cr. Al (TYPE K)	
2	ELEMENT SIZE	20 Gauge	
3	COLOUR CODE	ANSI - Kx +ve (Yellow) Kx –ve (Red)	
4	CONSTRUCTION	As shown in sketch. Refer specification sheet	
5	LIMITS OF ERROR	0 °C To 204 °C error ± 2.2 °C (maximum)	
6	PACKING	200/100 metre roll	
7	SAMPLE	Sample should be supplied (1 metre long) along with quotation.	

Note: Vendor has to fill and submit this form separately against all the model for which they are submitting offer.
For each model, vendor has to submit separate form.