


PRE—QUALIFICATION REQUIREMENTS

	POWER SECTOR-PEM NOIDA TECHNICAL PRE-QUALIFICATION REQUIREMENTS FOR OPEN/GLOBAL TENDERS To be read in conjunction with PEM general PQR Air Conditioning System	PACKAGE: AIR CONDITIONING SYSTEM
		DEPARTMENT : MECHANICAL AUXILIARY
		REVISION : 00
		DATE : 07-04-2015
		PAGE : 1 of 2

- A) Supplier should have designing/manufacturing capability and having testing facility (in house or outsourced).
- B) Minimum capacity of single installed machine (Screw/ VAM) shall be 100 TR.
- C) Air conditioning system should have been successfully in use for at least one year in power plant or other industries e.g. refinery/steel/process/commercial etc. For this the supplier has to submit either of following supporting documents meeting below mentioned conditions.
- i) Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order specifying that the product is running successfully for one (1) year from date of commissioning.


OR

- ii) Minimum one second/repeat purchase order (placed with a minimum gap of one (1) year after commissioning of first order) from same purchaser meeting the minimum pre-qualifying requirement.

OR

- iii) Minimum three purchase orders (placed with minimum gap of one(1) year from previous purchase order) from same purchaser meeting the minimum pre-qualifying requirement
- D) Supplier to submit the following major documents:
- i) Vendor shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- ii) Minimum two (2) nos. Purchase orders shall be submitted which should not be more than ten (10) years old as on date of application for registration/bid submission, for establishing continuity in business.
- iii) Vendor may also qualify based on the credential of principal meeting package specific pre-qualifying requirements having technical valid collaboration/licensing agreement.
- iv) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.
- v) PEM registered vendors are also required to submit the credentials to meet the PQR.

PRE—QUALIFICATION REQUIREMENTS

	POWER SECTOR-PEM NOIDA TECHNICAL PRE-QUALIFICATION REQUIREMENTS FOR OPEN/GLOBAL TENDERS To be read in conjunction with PEM general PQR Air Conditioning System	PACKAGE: AIR CONDITIONING SYSTEM
		DEPARTMENT : MECHANICAL AUXILIARY
		REVISION : 00
		DATE : 07-04-2015
		PAGE : 2 of 2

- vi) Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, as per BHEL evaluation procedure, should the circumstances warrant such assessment in the overall interest of BHEL.
- vii) Final acceptance of bidder is subject to End Customer's approval.