	Power Sector – PEM Noida Technical Pre - Qualification Requirements (For Open/Global Tender) To be read in conjunction with PEM general PQR	Project: 2x660 MW ENNORE SEZ Package: MISC. TANKS-SITE FABRICATED DEPARTMENT: Mechanical Auxiliary Engineering
	Sheet 1 of 2	REV 00

Following technical details are required from bidder to comply technical PQR:

1. Fixed roof tanks with minimum 200 cum storage capacity.
2. Depending upon the maximum capacity of the storage tank being designed by the vendor, suitable technical limit will be applied at the time of registration/evaluation for the bids as below:

Sl no	Min Tank Capacity executed (Cum)	Technical limit on the vendor of maximum capacity of tank qualified (Cum)
1	200	1500
2	1500	5000





Supplier should have design & fabrication capability and having in house or outsourced testing facility.

Tanks should have been successfully in use for at least one year as on dt of bid opening in power plant or other industries e.g. refinery/steel/process/commercial etc. For this the supplier has to submit either of following supporting documents meeting below mentioned conditions

- i. Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order specifying that the product is running successfully for one (1) year from date of commissioning.
OR
- ii. Minimum one second/repeat purchase order (placed with a minimum gap of one(1) year after commissioning of first order) from same purchaser meeting the minimum pre-qualifying requirement.
OR
- iii. Minimum three purchase orders (placed with minimum gap of one(1) year from previous purchase order) from same purchaser meeting the minimum pre-qualifying requirement

Note:

- 1) Vendor shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- 2) Minimum two (2) nos. Purchase orders shall be submitted which should not be more than ten (10) years old as on date of application for registration/bid submission, for establishing continuity in business.
- 3) Vendor may also qualify based on the credential of principal meeting package specific pre-qualifying requirements having technical valid collaboration/licensing agreement.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
PANKAJ KUMAR		18/7/14	HARISH KUMAR		18/7/14	PRAVEEN KISHORE		
NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE



Power Sector – PEM Noida

Technical Pre - Qualification Requirements

(For Open/Global Tender)

To be read in conjunction with PEM general PQR

Sheet 2 of 2

Project: 2x660 MW ENNORE SEZ

Package: MISC. TANKS-SITE FABRICATED


DEPARTMENT: Mechanical Auxiliary Engineering

REV 00

- 4) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.

General:

- 1) PEM registered vendors are also required to submit the credentials to meet the PQR.
- 2) Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, as per BHEL evaluation procedure, should the circumstances warrant such assessment in the overall interest of BHEL.
- 3) Final acceptance of bidder is subjected to End Customer's approval.



PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
PANKAJ KUMAR		18/07/14	HARISH KUMAR		18/07/14	PRAVEEN KISHORE		18/07/14
NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE	NAME	SIGNATURE	DATE