


	PRE - QUALIFYING REQUIREMENTS	DOCUMENT NO: PE-TS-411-100-Q030
		REVISION NO: 00      DATE: 12.08.2015
		SHEET: 1 of 1
ENQUIRY NO:		
PROJECT: 4X270 MW BHADRADRI TPP		
PACKAGE: AUXILIARY PRDS (Auxiliary Steam Pressure Reducing & Desuperheating Station)		
<p><b>CRITERIA FOR EVALUATION (TECHNICAL):</b></p> <p><b>1. The bidder should have designed, manufactured, tested, inspected &amp; supplied the Auxiliary PRDS (a Pressure Reducing Valve alongwith separate desuperheater) of inlet steam capacity of minimum 50 Tonnes/hour and minimum pressure class rating of 1500 or above for a Thermal Power plant. In addition to above, the auxiliary PRDS package shall also comprise of the associated spray control valves.</b>  <b>Bidders having experience of SCV (steam conditioning valves) for the high pressure turbine bypass system for thermal power plants of unit rating 150 MW or above are also acceptable, in lieu of auxiliary PRDS application.</b></p> <p>2. Bidder should be an engineering organization/ manufacturer for the subject package/items of the subject package dealing with this package on regular basis. The bidder should have testing and inspection facility at their works for the subject package.</p> <p>3. The Bidder shall furnish following documents, for assessing Bidder's pre-qualification as indicated at Sl. No. 1 above along with technical offer:</p> <p>a. Bidder's Experience list specifically for each item/arrangement for SCV/Auxiliary PRDS, for last 9 years in enclosed format (Annexure-1). Same shall be considered for PQR assessment in line with subsequent sub paras of point 3, i.e. performance feedback certificates/repeat order contract certificates should not be more than 9 years old as on date of tender enquiry. In the experience list, vendor to clearly furnish the arrangement offered, year of supply, MW rating of the power plant, Valve sizes, operating Temp./Pressure etc.</p> <p>b. In support of point 3-a), any one from i) or ii) or iii) below:</p> <p>i) Furnish minimum two (02) nos. of feedback certificates (in English) for SCV/Auxiliary PRDS, from two different end-users / customers (indicating salient features like year of commissioning, duty parameters (Flow, Size), project name etc., date of issue of certificate and name/ designation of the certificate issuer), working satisfactorily for atleast two years.</p> <p style="text-align: center;">OR</p> <p>ii) Furnish one (01) no. of feedback certificate (in English) for SCV/Auxiliary PRDS from end-user / customer (indicating salient features like year of commissioning, duty parameters (Flow, Size), project name etc., date of issue of certificate and name/ designation of the certificate issuer), working satisfactorily for atleast two years.</p> <p style="text-align: center;">AND</p> <p>The supplier has been awarded repeat contracts for SCV/Auxiliary PRDS from minimum one end-user / customer (other than the one for which the bidder has furnished the performance feedback above). Supporting documents for execution of the Contract like dispatch details, MDCC, Inspection report etc. along with the PO Copy, if bidder intends to submit the documents for Repeat Contracts.</p> <p style="text-align: center;">OR</p> <p>iii) The supplier has been awarded two repeat contracts for SCV/Auxiliary PRDS from two different end-users/customers. Repeat contract shall be considered when the second contract is given by the same customer after lapse of minimum 2 years from execution of first contract. Supporting documents for execution of the Contract like dispatch details, MDCC, Inspection report etc. along with the PO Copy requested to be furnished, if bidder intends to submit the documents for Repeat Contracts.</p> <p>c. Copy of approved drgs, technical data sheets &amp; Purchase order of which the bidder intends to furnish the performance feedbacks / repeat contracts for reference purpose only.</p> <p>4. The Bidder who is already registered with BHEL PEM is also required to submit documents listed at point no.1, 2, 3 above for assessing pre-qualification.</p> <p>5. If documents submitted by supplier are in language other than English, a self-attested English translated document should be attached.</p>		
<b>PREPARED BY:</b>  <b>NAME:</b> RAVEESH K.R. VERMA <b>DESIGNATION / DEPT.:</b> MSE	<b>REVIEWED BY:</b>  <b>NAME:</b> S.S. VERMA <b>DESIGNATION / DEPT.:</b> DGM/MSE	<b>APPROVED BY:</b>  <b>NAME:</b> <b>DESIGNATION / DEPT.:</b>