



Power Sector – PEM Noida

Technical Pre - Qualification Requirements
(For Open /Global Tender/Registration)
To be read in conjunction with PEM General
PQR

PROJECT:

1 X 800 MW WANAKBORI TPS .

PACKAGE: FUEL OIL UNLOADING &
STORAGE SYSEM

DEPARTMENT: MECHANICAL AUXILIARY

Sheet 1 of 2

REV. NO. 01

DATE: 02/09/2015

Fuel oil handling installation shall consist of:

1. Railway/Road tanker unloading system and
2. Fixed/Floating roof tanks with minimum 200-1500 m3 storage capacity.

Depending upon the maximum capacity of the storage tank being designed by the vendor, suitable technical limit will be applied at the time of registration/evaluation for the bids as below:

Sl no	Min Tank Capacity executed (Cum)	Technical limit on the vendor of maximum capacity of tank qualified (Cum)
1	200	1500
2	1500	5000

For higher capacity of tankage above 5000 cum, actual design and execution experience of the vendor will be checked to meet the project specific requirement.

The above facilities can be in different installations.

Supplier should have designing/manufacturing capability and having testing facility (in house or outsourced).

Product/package should have been successfully in use for at least one year as on Dt. _____ in power plant or other industries e.g. refinery/steel/process/commercial etc. For this the supplier has to submit either of following supporting documents meeting below mentioned conditions

- Copy of minimum one (1) performance certificate in English from end user along with copy of related Purchase Order specifying that the product is running successfully for one (1) year from date of commissioning.
- OR
- Minimum one second/repeat purchase order (placed with a minimum gap of one (1) year after commissioning of first order) from same purchaser meeting the minimum pre-qualifying requirement.
- OR
- Minimum three purchase orders (placed with minimum gap of one(1) year from previous purchase order) from same purchaser meeting the minimum pre-qualifying requirement

Note:

- 1) Vendor shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- 2) Minimum two (2) nos. Purchase orders shall be submitted which should not be more than ten (10) years old as on date of application for registration/bid submission, for establishing continuity in business.
- 3) Vendor may also qualify based on the credential of principal meeting package specific pre-qualifying requirements having technical valid collaboration/licensing agreement.
- 4) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
VIPIN NAUNI		02/09/15	HARISH KUMAR / S. K. BHOMIK			P. KISHORE		02/09/2015
Name	Signature	Date	Name	Signature	Date	Name	Signature	Date



Power Sector – PEM Noida

Technical Pre - Qualification Requirements
(For Open /Global Tender/Registration)
To be read in conjunction with PEM General
PQR

PROJECT:

PACKAGE: FUEL OIL UNLOADING &
STORAGE SYSEM

DEPARTMENT: MECHANICAL AUXILIARY

Sheet 2 of 2

REV. NO. 01

DATE: 02/09/2015

General:

- 1) PEM registered vendors are also required to submit the credentials to meet the PQR.
- 2) Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, as per BHEL evaluation procedure, should the circumstances warrant such assessment in the overall interest of BHEL.
- 3) Final acceptance of bidder is subject to End Customer approval.

PREPARED BY			CHECKED & REVIEWED BY			APPROVED BY		
VIPIN NAUNI		02/09/15	HARISH KUMAR / S. K. BHOMIK			P. KISHORE		02/09/2015
Name	Signature	Date	Name	Signature	Date	Name	Signature	Date