

TECHNICAL SPECIFICATION OF 11KV 630A VCB PANEL WITH 5 NOS 11KV LBS O/G.

GENERAL

The 11KV 630A VCB PANEL shall be of modular construction housed in a single enclosure consisting of HT six control Panels comprising with one number 11KV VCB as incomer and FIVE numbers 11KV Load break switches with fuse unit (suitable for 500 KVA Transformer) as outgoing for the part of distributing 11KV supply system and all other metering and protection as detailed in the enclosed specification with all protections like over current, earth fault and under voltage etc.

The HT Panel should be suitable for outdoor application, compact and easily transportable and installation shall have minimum maintenance requirement with no accidental access to live parts and fully complied with all statutory requirements. The panel shall be fully compartmentalized and suitable for bottom cable entry.

The panel shall be Metal clad housing fabricated out of CRCA sheet steel of min.3mm thick for outer enclosure, hinged front and bolted rear doors and 2mm for the partitions shall have suitable mechanical strength for lifting.

All sheet Metal components shall undergo rigorous seven tank process (degreasing de-rusting, phosphating and sealing). Painting shall be of epoxy powder coating to shade RAL 7032 (Siemens Grey).

Epoxy encapsulated copper busbar shall be provided. Electrical continuity between all metal parts not alive and the earth terminals of the unit shall be ensured. Insulated partition shall be provided for busbars, CTs, PTs, outgoing cables & circuit breaker and relay controls. Tinned copper busbars with suitable heat shrink sleeves shall be provided.

Hinged doors shall be provided for accessing the switchgear section. Three point locking arrangement with single operating handle shall be provided for all hind doors. Hinge locks, lock covers etc. shall be fabricated from anti-corrosive material. The hinges shall be sturdy and robust. The doors shall be provided with additional members for strengthening to avoid any warping (or) bending.

Cubicles will be exposed to high winds, dust and rain. Neoprene gaskets of high quality shall be used. The top cover of kiosk shall have necessary slope to avoid stagnation of rainwater.

Base frame shall be of sufficient thickness and tar painted to give corrosion resistance even if water accumulation is there.

All mechanical indications of breaker / LBS position, operation shall be visible from outside. Suitable transparent cover shall be provided on the front door of compact unit.

Emergency push button shall be accessible from outside.

Safety shutters to cover live part to prevent accidental contact and explosion vents to release the gases during fault occurrences shall be provided.

Lifting lugs base frame of adequate thickness, foundation bolts of min.19mm dia with suitable washers shall be provided. Lifting guides shall be provided at the top to prevent touching of wire ropes with body of unit while lifting the panel.

ND

RELAYS.

All relays specified shall be flush mounted in dustproof cases and shall match the appearance of the instruments mounted on the same panel. Each relay shall be identified with relay number indicated in the approved control scheme.

Protective relays shall be of easy with draw able type. Trip circuits shall be automatically broken and current transformer secondary circuits shorted, when a relay is withdrawn from its case. A marking strip shall be provided in front of each terminal block and diagram plate at the back of each case to identify connections.

Relay contacts shall withstand repeated operation and shall make or break the maximum currents in their circuit without deteriorating. All spare contacts shall also be wired up to the external terminals.

Relay coils shall carry their normal currents indefinitely and such currents as can occur under fault conditions. Relay mechanism shall not be affected by vibration or external magnetic fields, which may occur in normal operation.

All relays in tripping circuits shall have mechanically operated flag indicators, Indicators, mechanical or electrical, shall also be provided on other relays to identify type of fault that may have occurred. Indicators shall be capable of being reset without opening the relay case. It shall not be possible to operate the relay by hand or to alter its setting, without opening the case. All relays shall operate satisfactorily from 70% to 110% of rated voltage.

INDICATING INSTRUMENTS

All indicating instruments shall conform to IS 1248 and integrating meters to IS 722.

Indicating instruments shall be of size 96x96mm and shall conform to 1.0 Accuracy class Meters shall be suitable to PT secondary of 110V (line) and CT secondary of 5A. Scales shall be suitably provided depending on the ratio of Instrument transformer. All indicating instruments shall have non-reflecting bezels, clearly divided and legibly marked scales and sharply out line pointers. They shall be provided with zero adjusting devices for external operation. Indicating Instruments shall be taut band type.

One no. static type, class 0.5 accuracy ENERGY METERS shall be provided.

CONTROL CIRCUITS

Control switches shall be suitable for use in AC circuit's upto 440V and rating of 5A.

All incoming control and power circuits shall be fed through isolating ON/OFF rotary switch and HRC fuses with insulating base and holder. Closing circuit, tripping and control circuit and lamp circuit shall be segregated and protected by independent fuses.

CONTROL WIRING AND FERRULES

All wiring shall be carried out with 1100 volts grade core wires having multi strand copper conductor. All control circuit shall be with copper conductor having a minimum cross-sectional area of 1.5sq.mm per core and CT circuit shall be 2.5sq.mm copper conductors. The wire shall be insulated with PVC.

ND

All control wiring shall be terminated using eye type tinned copper lugs on to the stud type terminals. More than two wires shall not be terminated onto a single terminal.

All holes or tubes for wiring runs shall be bushed and shall have room for reasonable future additions. All cable runs shall clear injurious gases and heat emitted by control gear operation or shall be adequately protected from them.

Control cables when laid in HT busbar chamber, cable shall be taken through conduits. No joints or tees shall be made in wires between terminals. The wire shall be identified by numbered ferrules at each end, all in accordance with the connection diagram, equipotential terminals shall have the same ferrule numbers.

All ferrules shall be made of non-deteriorating materials. They shall be white except in case of warning ferrules, which shall be red. Ring type ferrules shall have the character engraved on it. The ferrules shall be firmly located in each wire so that they cannot move freely on the wire. Wiring across hinges shall be by flexible wires.

The colour code for control wiring shall be as enumerated below

- a) Metering circuits-Black
- b) Closing, tripping, protection relays and main power supply circuits- Red.
- c) Annunciation and indication circuits-White.

EARTHING

An earth bar adequate cross section shall be fixed preferably at the back of the switch board. The earth bar shall be electrically continuous and shall run the full extent of each board. The earth bar shall be of same material as the busbars and shall have a minimum cross section of 300 sq.mm. Each unit shall be constructed to ensure satisfactory electrical continuity between all metal parts not intended to be a live part and the earth terminal of the unit. Double earthing shall be provided from each equipment to the earth bus by suitable size of wire (or) flat

SPACE HEATER

Space heater with isolating switch fuse unit shall be provided.

TESTING AND COMMISSIONING

Routine tests as per relevant IS standards to be conducted at works & site and test certificates shall be furnished. Type test certificates for identical equipment shall be provided.

DRAWING

The following drawings shall be submitted for approval. Copies of approved drawings along with reproducible and soft copies in COs shall be furnished at the time of supply of equipment. As built drawings incorporating site modifications along with reproducible and soft copies in COs shall be furnished.

ND

- a) Dimensional GA drawing of switch gear indicating foundation details, cable gland plate location for each cable plan and elevation of switch board.
- b) Cross sectional drawing of cubicle busbars CTs. Cable breaker HV chambers and indicating all electrical clearances between busbars and earth.
- c) Front view of the switchboard indicating arrangement of relays, controls operating heights.
- d) Control schemes of each feeder breaker with components specification.
- e) SLD, Power circuit and AC & DC control circuits.
- f) Terminal plan and internal wiring drawing so fall the cubicles.

PAINTING

The switch gear unit cubicle shall be furnished with colour code to be indicated at the time of drawing approval conforming to IS 5-1961 latest The sheet metal parts shall be subjected to following pre-treatment before final painting,

- a) Degreasing
- b) Pickling for complete rust removal
- c) Phosphating
- d) Corrosionresistantprimerpainting.Twofinalcoatsspraypaintingshall be given.
- e) The cubicle shall be painted with colors as follows:- Internal-Glossy white.

CICUIT BREAKER

The circuit breaker shall be three pole 630A vacuum circuit breaker with spring charged operating mechanism. Plug in isolating contacts and 4NO+4NC auxiliary contacts all mounted on a with drawble carriage

The air clearance between phases and between phase to earth at the breaker incoming and outgoing terminals shall not be less than those indicated in the IS/IEC/British standards. Corresponding to the basic insulation level of the Circuit breaker as indicated in the criteria.

The temperature rise of the breaker contacts terminals while carrying the rated continuously or the rated short circuit current of rated duration shall not exceed 40degC.Over ambient of 50 deg C. Further to minimize burning and pitting of contacts all parts exposed to the arc created by current interruption shall be protected by special arc resistance material.

The circuit breaker shall be designed such that the peak short circuit current {i.e. 2.5times the RMS short circuit current) specified can be interrupted without causing appreciable damage to main contacts.

The arc extinguishing chamber sand the contact assembly shall be enclosed in an insulating tube made of FRP/tough glass/ceramic or other suitable arc resistant material with sufficient strength to with stand the internal pressure forces developed while clearing rated short circuit current.

Surge Arrestor shall be provided wherever necessary.

ND

110V DC for operation of the Circuit Breaker and protection relays shall be taken from power pack (110V DC). This is to ensure the operation of breaker in case of power supply failure. (2 open and 2 close operations).

OPERATING MECHANISM

Circuit breakers shall be provided with spring charged. Manual & Electrical independent closing and shunt trip and series trip for opening.

Trip coil shall operate satisfactory between 70% and 110% of rated voltage.

The closing and tripping circuits shall be self-opening on completion of their respective functions irrespective of position of the breaker

A readily identifiable mechanical emergency trip device as well as provision for manual charging of springs through the cubicle door shall be provided for each breaker.

In case of circuit breakers with more than one operating spring, they shall be so interlocked such that the springs are charged to the same extent and the breaker can be closed only if all the springs are charged to the required values. Further in case of multiple pole 1 phase breakers equal current sharing between poles shall be ensured by means of current balance schemes.

In order to ensure the reliability and long operating life for the mechanism, the mechanism shall be light. With a high mechanical strength and abrasion resistance to avoid high rate of wear and tear and with few components. The number of components in the breaker and operating mechanism shall be kept to a minimum and they shall be designed to be free of undue stresses during normal or short circuit operations. Further they shall ensure a high frequency of operations indicated in technical particulars. All the moving parts of the mechanism requiring inspection, maintenance and lubrication shall be easily accessible.

Operation counter shall be provided on the breaker for recording number of ON/OFF operations.

A visual ON/OFF indication and SPRING CHARGED indication shall be provided positively coupled to the operating mechanism and visible from front with the cubicle door closed. Indications shall be provided for limit switches for spring charged and discharged condition. The Mechanism shall be TRIP FREE as per IEC.

The life of the operating mechanism shall not be less than 2000 operations.

It shall not be possible to open the doors with out opening the Circuit Breaker.

AUXILIARY CONTACTS

Each circuit breaker shall have 4NO+4NC of auxiliary contacts to control circuit changes for indication, protection, interlocking. Supervision. Metering and others.

Breaker auxiliary contacts available in test and service position and those available in service position only shall be clearly indicated.

Normally open and normally closed contacts shall be interchangeable at site.

ND

All auxiliary contacts shall be positively operated by the main apparatus and all contacts shall be adequate to make, carry and interrupt the currents in their circuits.

Emergency push button to trip the VCB shall be provided inside a weather proof box on the outer side wall of the panel.

11KV LOAD BREAK SWITCH

General

HT 11KV 630A Load break switches with earth switch are intended to connect / disconnect from the 11KV supply main system.

RATING

The load break switch shall be fault make, load break type. The load break switch shall have rated current, fault making capacity, short time thermal rating, dynamic through fault withstand capability as specified in the design criteria without HRC fuses in the circuit.

TYPE OF LOAD BREAK SWITCH

Load break switch shall be air break type in fixed design.

OPERATINGMECHANISM

The load switch shall have quick make & quick break independent manual operating mechanism with mechanical ON/OFF indication. Load Break Switch with switch fuse unit, shunt trip coil, manually operated spring charged mechanism.

INTERLOCKS

It shall not be possible to open the door with Load break switch on.

AUXILIARYCONTACTS

4NO+4NC auxiliary contacts rated to make and break 5A at 110V AC shall be provided.

INSTRUMENTTRANSFORMER

CURRENTTRANSFORMER (CTI)

Separate cores shall be used for metering and protection.

All current transformers shall be designed to have over current factors to with stand the fault currents of the associated system as applicable to the switchboard.

Current transformer used for protection shall an accuracy limit factor not less than 15. Those used for metering shall have a saturationfactorof2.

All current transformers shall have 5Amp.Secondaries and shall be of resin cast with bar primary.

Polarity of primary and secondary's of all the CTs shall be clearly marked.

ND

VOLTAGE TRANSFORMER (PT)

Voltage transformer shall be built up of CRGO electrical steel. The voltage transformers shall be resin cast dry type. The PTs shall be 3 nos. of single-phase type of suitable ratio and burden.

PTs shall be protected by HRC fuses.

Input source for 110V DC Power pack 110V DC for operation of the Circuit Breaker and Protection relays shall be taken from power pack (110VDC). This is to ensure the operation of breaker in case of power supply failure. (2 open and 2 close operations).

PT signal to the static Energy meter (only in the case of 11KV entry point kiosk) 11KV Bus PT burden shall be suitably designed to cater the above needs also.

SELECTOR SWITCHES

The rating and other features of the switches shall be suitable for the application. The number of positions and the number of contacts required for each switch shall be as indicated in the schemes enclosed.

Selector switches shall be stay put type, provided with properly designated escutcheon plates clearly marked to show operating position.

Terminals carrying potential above 120V shall be shrouded to prevent accidental contact with personnel.

Ammeter selector switches shall have make before break contacts.

The switches shall be suitable for semi-flush mounting with the front plate and operating handle projecting out. All connections to the switches shall be from the back.

The arrangement for front mounting of these devices shall be such as to make them reasonably dust free so as not to interfere with normal operation.

TERMINALS:

Terminals shall be stud type of copper material.

Terminals shall be provided with transparent cover(s).

Terminals shall be suitable for ring type copper cable lugs of size depending upon the circuit rating.

LABELLING:

Labels to identify all the main assemblies, sub-assemblies and components of the Kiosk shall be provided.

Name and rating plate/markings shall be provided as required by relevant standard applicable to each component assembly to be identified.

Labels shall be of two color, three layer plastic material with matte semi matt finish or of the anodized aluminum sheet.

MD

page: 7 of 10

All labels other than "danger" or "warning" labels shall have black lettering on a white back ground
Danger label shall be as per applicable standard and shall not be fixed on to removable parts.

All labels shall be securely fixed on to the equipment by means of self- tapping screws or other approved means.

Stick-on type labels of good quality and permanent mounting shall be

Acceptable for interlay mounted components only.

SURFACE TREATMENT:

All metal parts and the surfaces (exterior & interior) of equipment. Unless stated otherwise in case of reflectors, shall be degreased by dipping in hot alkaline solution and rubbed with wire brush to remove oil & scale from them & then rinsed in water alternatively, they may be shots and blasted.

Parts shall be pickled by dipping in hydrochloric acid tank to remove the rust from the surfaces for med during storage of sheets & then rinsed to remove traces of the acid. The cleaning and pretreatment of all metal parts shall be as per applicable standards.

All parts shall then be subjected to a coat of red oxide primer paint.

All inside and outside surfaces of panel shall be spray painted with synthetic enamel of the shade.

The surfaces to be painted shall then be prepared by phosphatizing to protect them from further rusting & to create a good bond with the paint. The pretreatment shall confirm to the applicable standard.

Paint thickness shall be as per applicable standard.

Electrostatic or powder painting shall be acceptable subject to purchaser's approval.

Wherever possible finished parts shall be coated with peel able compound by spraying method to protect the finished product from scratches, grease, dirty and oily spots during handling and transportation.

ADDITIONAL REQUIREMENTS:

1No emergency trip push button (mechanical).

Mimic: A single line diagram showing the direction of power flow shall be dawn on the front of load break switch. The mechanical operation of switch shall automatically indicate ON/OFF status of both main switch as well as the earth switch in the mimic diagram.

Fluorescent lamps for sufficient illumination shall be provided.

CURRENT TRANSFORMER

Type --	Resin cast, bar primary
Ratio, burden accuracy class, cores -----	50/25/5/5A, 15VA, class 1.0formetering.5P15for
	Protection for transformer feeder.

ND

page : 8 of 10

Short time rating	current 18.4 KA for 3sec
Dynamic stability	47KA peak
Insulation level	
a) Impulse with stand voltage	75 KV PEAK
b) PF with stand voltage	28KV (RMS)
Thermal over load capacity	120%continuous
Applicable standard	IS 2705

POTENTIAL TRANSFORMER:

Type	Resin cast. Natural air cooled
Ratio	11KV/3, 110V/3
Rated burden	20VA/Phase.class1.0
Connection	Three single phase PT with suitable power pack for DC Shunt trip
Voltage factor	1.1continuous, 1.5 for 30 sec

INSULATION LEVEL

Impulse with stand voltage:	75KV (P)
PF with stand voltage	28KVRMS

Protection	HV side 2Amp.HT HRC fuse for each phase
Applicable standard	IS 3156

INDICATING METERS

Type of meters	Ammeters. Voltmeters
Type of movement	Taut band
Size	96x96mm
Dial finish	White painted dial with pointer type needle
Mounting	Flush mounting'
Accuracy Class	1.0
Voltage / current	110 V PT.5A CT sec current
Applicable standard	IS 1248

hsh

page: 9 of 10

INDICATING LMPS:

VCB ON/OFF/AUTO TRIP/Trip Circuit Healthy/Spring Charged indication lamps

LBS ON/OFF Indication lamp

RYB Indication Lamps

Indication lamps shall be complete with lens cover sand holders

Each lamp shall be fitted with a durable resistance integrally wired in series within the lamp.

The lamp cover (lens) shall be translucent of red color.

Bulbs and covers shall be inter changeable easily replaceable from the front without the need for any special means.

Terminals having potential above 120V shall be shrouded to prevent. Contact with personnel.

M. Lazar

M. LAZAR
Engineer / Facility Engineering
Bharat Heavy Electricals Ltd., PS-SR
Periyar EVR Building, 690, Anna Salai,
Nandanam, Chennai - 600 035.

Pa