



TITLE: **ELECTRICAL EQUIPMENT SPECIFICATION**  
**PACKAGE: COMPRESSED AIR SYSTEM**

SPECIFICATION NO.  
PE-TS-401-555-A001

VOLUME NO. : **IIB**

SECTION : **C.3**

VOLUME IIB

SECTION C.3

SPECIFIC TECHNICAL REQUIREMENTS  
(ELECTRICAL PORTION)



TITLE:  
**ELECTRICAL EQUIPMENT SPECIFICATION**  
  
(GENERAL)

SPECIFICATION NO.  
PE-TS--  
VOLUME NO. : **II-B**  
SECTION : **C**  
REV NO. : **00** DATE :  
SHEET : **1** OF **1**

#### **1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER :**

- a) Services and equipment as per “Electrical Scope between BHEL and Vendor”.
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Erection and Commissioning spares.
- e) Erection & Maintenance tools & tackles.
- f) Electrical load requirement for the Plant.
- g) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- h) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer /BHEL approval without any commercial and delivery implications to BHEL.
- i) Various drawings, data sheet as per required format, quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer /BHEL approval without any commercial implications to BHEL.
- j) Motor shall meet minimum requirement of motor specification.
- k) The sub-vendor list for various electrical items is subject to BHEL/Customer approval without Any commercial implications.

#### **2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:**

Refer “Electrical Scope between BHEL and Vendor”.

#### **3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID**

- 3.1 Bidder shall confirm total compliance to the electrical specification without any deviation from the technical/ quality assurance requirements stipulated. In line with this, two signed and stamped copies of the following shall be furnished by the bidder as technical offer:
- a) A copy of this sheet “Electrical Equipment Specification’ and sheet “Electrical Scope between BHEL and Vendor” with bidder’s signature and company stamp.
  - b) List of Erection and Commissioning spares.
  - c) List of Erection & Maintenance tools & tackles.
  - d) Electrical load requirement in enclosed load data format.
  - e) If there is any conflict, customer motor specification will prevail over BHEL motor Specification.
- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

#### **4.0 LIST OF ENCLOSURES**

- 4.1 Electrical scope sheet between BHEL & vendor.
- 4.2 Customer Spec. for LV Motors
- 4.3 General requirement of LV Motors.
- 4.4 Data Sheet - A for LV Motors.
- 4.5 Electrical Load Data Format.
- 4.6 Datasheet-C (to be filled by Vendor)

**ANNEXURE – I TO SECTION – C: STANDARD ELECTRICAL SCOPE BETWEEN NBPPL AND VENDOR**

**PROJECT: 1X500 MW UNCHAHAR TPP**  
**PACKAGE: COMPRESSED AIR SYSTEM**

<u>S.NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&amp;C</u>	<u>REMARKS</u>
1	6.6 KV / 3.3 KV / 415 V Switchgear	NBPPL	NBPPL	1.6.6 kV / 3.3 kV / 415 V AC/240 V AC supply shall be provided by BHEL based on load data provided by vendor at contract stage for all equipment supplied by vendor as part of contract. DC supply (battery bank, charger etc) and any other supply as required for PLC/control panel (as applicable) shall be provided by vendor. 2. Interposing relays (RE 302 of Jyoti make or equivalent), if required for PLC and microprocessor based systems, shall be provided by BHEL in MCCs/switchgear. Requirement of these relays shall be furnished by vendor during detailed engineering stage.
2	Local Push Button Station ( for motors)	NBPPL	NBPPL	Located near the motors.
3	Power cables, control cables and screened control cables for a) both end equipment in BHEL's scope b) both end equipment in vendor's scope c) one end equipment in vendor's scope	NBPPL NBPPL NBPPL	NBPPL Vendor NBPPL	Sizes and quantity of cables required shall be informed by vendor at contract stage (based on inputs provided by BHEL). Finalisation of cable sizes shall be done by BHEL. Vendor shall provide lugs & glands accordingly.
4	Any special type of cable like compensating, co-axial, prefab, MICC, fibre optical etc	Vendor	Vendor	
5	Cable trays, accessories & cable trays supporting system	NBPPL	NBPPL	
6	Cable glands and lugs for equipments supplied by Vendor	Vendor	Vendor	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power cables 3. solder less crimping type heavy duty copper lugs for control cables.
7	Conduit and conduit accessories for cabling between equipments supplied by vendor	Vendor	Vendor	Cabling shall be through conduits. However vendor can use the trunk route where available for laying of cables. Conduits shall be supplied by vendor and shall be medium duty, hot dip galvanised cold rolled mild steel rigid conduit as per IS: 9537. Makes of conduits shall be subject to customer/ BHEL approval at contract stage.
8	Lighting	NBPPL	NBPPL	
9	Equipment grounding & lightning protection	NBPPL	NBPPL	
10	Below grade grounding	NBPPL	NBPPL	
11	Motors with base plate and foundation hardware	Vendor	Vendor	Makes shall be subject to customer/ BHEL approval at contract stage.
12	Mandatory spares	Vendor	-	Vendor to quote as per specification.
13	Recommended O & M spares, E & C spares, erection & maintenance tools & tackle	Vendor	-	


14	Any other equipment/material/service required for completeness of system but not specified above (to ensure trouble free and efficient operation of the system).	Vendor	Vendor	
15	a) Input cable schedules (C & I) b) Cable interconnection detail for the above c) Cable block diagram	Vendor Vendor Vendor	- - -	Cable listing for control cables for vendor supplied equipment (soft copies in the BHEL cable schedule format) shall be furnished during detail engineering by vendor.
16	Equipment layout drawings	Vendor	-	For ensuring cabling requirements are met, vendor shall furnish layout drawings (both in print form as well as in AUTOCAD) of the complete plant (including electrical area) indicating location and identification of all equipments requiring cabling, and shall incorporate cable routing details marked on the drawing as per PEM interface comments. Electrical equipment layout drawing shall be to BHEL approval.
17	Electrical equipment GA drawing	Vendor	-	


NOTES:


1. Make of all electrical equipments/items supplied shall be reputed make & shall be subject to approval of BHEL/customer after award of contract.
2. All QPs shall be subject to approval of BHEL/customer after award of contract without any commercial implication.


# SUB-SECTION – B-09


## **MOTORS**


CLAUSE NO.	TECHNICAL REQUIREMENTS			
<b>1.00.00</b>	<b>GENERAL REQUIREMENTS</b>			
1.01.00	For the purpose of design of equipment/systems, an ambient temperature of 50 deg. Centigrade and relative humidity of 95% (at 40 deg C) shall be considered. The equipment shall operate in a highly polluted environment.			
1.02.00	All equipments shall be suitable for rated frequency of 50 Hz with a variation of +3% & -5%, and 10% combined variation of voltage and frequency unless specifically brought out in the specification.			
1.03.00	Contractor shall provide fully compatible electrical system, equipments, accessories and services.			
1.04.00	All the equipment, material and systems shall, in general, conform to the latest edition of relevant National and international Codes & Standards, especially the Indian Statutory Regulations.			
1.05.00	The auxiliary AC voltage supply arrangement shall have 11kV, 3.3 kV and 415V systems. It shall be designed to limit voltage variations as given below under worst operating condition :			
	(a) 11kV, 3.3 kV		+/- 6%	
	(b) 415/240V		+/- 10%	
1.06.00	The voltage level for motors shall be as follows :- a) Upto 0.2KW : Single phase 240V AC / 3 phase 415V AC b) Above 0.2KW and upto 200KW : 3 phase 415V AC c) Above 200KW and upto 1500 KW: 3.3 kV d) Above 1500 KW : 11 kV  Voltage rating for special purpose motors viz. screw compressors and those with VFD shall be as per manufacturer standard.  For CHP conveyor's motor above 160KW rating 3.3KV, three phase AC supply is to be used. However all the motors on the Stacker/ Reclaimer machine shall be on 415V AC only.			
1.07.00	Fault level shall be limited to 40kA RMS for 1 second for 11kV & 3.3 kV system and 45 kA RMS 1 second for 415V system. 415V system shall be solidly grounded and 220 VDC system shall be isolated type.			
1.08.00	Paint shade shall be as per RAL 5012 (Blue) for indoor and outdoor equipment.			
<b>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</b>	<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>SUB-SECTION-B-09 MOTORS</b>	<b>PAGE 1 OF 9</b>	


CLAUSE NO.	TECHNICAL REQUIREMENTS			
1.09.00	The responsibility of coordination with electrical agencies and obtaining all necessary clearances shall be of the contractor.			
1.10.00	Degree of Protection  Degree of protection for various enclosures as per IS:4691, IEC60034-05 shall be as follows :-  i) Indoor motors - IP 54 ii) Outdoor motors - IP 55 iii) Cable box-indoor area - IP 54 iv) Cable box-Outdoor area - IP 55			
<b>2.00.00</b>	<b>CODES AND STANDARDS</b>			
	1) Three phase induction motors : IS:325, IEC:60034			
	2) Single phase AC motors : IS:996, IEC:60034			
	3) Crane duty motors : IS:3177, IEC:60034			
	4) DC motors/generators : IS:4722			
	5) Energy Efficient motors : IS:12615 or IEC:60034-30			
<b>3.00.00</b>	<b>TYPE</b>			
3.01.00	<b>AC Motors:</b>			
	a) Squirrel cage induction motor suitable for direct-on-line starting.			
	b) Continuous duty LT motors upto 160 KW Output rating (at 50 deg.C ambient temperature), shall be Energy Efficient motors, Efficiency class-Eff 1, conforming to IS 12615 or high efficiency (IE2) as per IEC:60034-30			
	c) Crane duty motors shall be slip ring/ squirrel cage Induction motor as per the requirement.			
3.02.00	DC Motors Shunt wound.			
<b>4.00.00</b>	<b>RATING</b>			
	(a) Continuously rated (S1). However, crane motors shall be rated for S4 duty, 40% cyclic duration factor.			
	(b) Whenever the basis for motor ratings are not specified in the corresponding mechanical specification sub-sections, maximum continuous motor ratings			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-B-09 MOTORS	PAGE 2 OF 9	


CLAUSE NO.	TECHNICAL REQUIREMENTS			
<p><b>5.00.00</b></p>	<p>shall be at least 10% above the maximum load demand of the driven equipment under entire operating range including voltage and frequency variations.</p> <p>(c) For BFP motor the starting MVA shall be restricted to 58 MVA.</p> <p><b>TEMPERATURE RISE</b></p> <p><b>Air cooled motors</b></p> <p>70 deg. C by resistance method for both thermal class 130(B) &amp; 155(F) insulation.</p> <p><b>Water cooled</b></p> <p>80 deg. C over inlet cooling water temperature mentioned elsewhere, by resistance method for both thermal class 130(B) &amp; 155(F) insulation.</p> <p>41 deg.C over inlet cooling water maximum temperature of 39 deg.C for thermal class Y wet wound Boiler circulation pump motor.</p>			
<p><b>6.00.00</b></p>	<p><b>OPERATIONAL REQUIREMENTS</b></p>			
<p>6.01.00</p>	<p><b>Starting Time</b></p>			
<p>6.01.01</p>	<p>For motors with starting time upto 20 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 2.5 secs. more than starting time.</p>			
<p>6.01.02</p>	<p>For motors with starting time more than 20 secs. and upto 45 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 5 secs. more than starting time.</p>			
<p>6.01.03</p>	<p>For motors with starting time more than 45 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be more than starting time by at least 10% of the starting time.</p>			
<p>6.01.04</p>	<p>Speed switches mounted on the motor shaft shall be provided in cases where above requirements are not met.</p>			
<p>6.02.00</p>	<p><b>Torque Requirements</b></p>			
<p>6.02.01</p>	<p>Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% motor full load torque.</p>			
<p>6.02.02</p>	<p>Pull out torque at rated voltage shall not be less than 205% of full load torque. It shall be 275% for crane duty motors.</p>			
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-B-09 MOTORS</p>	<p>PAGE 3 OF 9</p>	


CLAUSE NO.	TECHNICAL REQUIREMENTS			
6.03.00	<p><b>Starting voltage requirement</b></p> <p>a) 85% below 110 KW  b) 80% from 110 KW to 200 KW  c) 85% above 200 KW to 1000 KW  d) 80% from 1001 KW to 4000 KW  e) 75% &gt; 4000 KW</p>			
7.00.00	<p><b>DESIGN AND CONSTRUCTIONAL FEATURES</b></p>			
7.01.00	<p>Suitable single phase space heaters shall be provided on motors rated 30KW and above to maintain windings in dry condition when motor is standstill. Separate terminal box for space heaters &amp; RTDs shall be provided. However for flame proof motors , space heater terminals inside the main terminal box may be acceptable.</p>			
7.02.00	<p>All motors shall be either Totally enclosed fan cooled (TEFC) or totally enclosed tube ventilated (TETV) or Closed air circuit air cooled (CACA) type. However, motors rated 3000KW or above can be Closed air circuit water cooled (CACW). CW motors can be screen protected drip proof (SPDP) type. Motors located in hazardous areas shall have flame proof enclosures conforming to IS:2148 as detailed below</p> <p>(a) Fuel oil area : Group – IIB</p> <p>(b) Hydrogen generation plant area : Group - IIC (or Group-I, Div-II as per NEC)</p>			
7.03.00	<p>Winding and Insulation</p> <p>(a) Type : Non-hygroscopic, oil resistant, flame resistant</p> <p>(b) Starting duty : Two hot starts in succession, with motor initially at normal running temperature. However the conveyor motor shall be suitable for 3 consecutive hot starts.</p> <p>(c) 11kV &amp; 3.3 kV AC motors : Thermal class 155 (F) insulation. The winding insulation process shall be total Vacuum Pressure Impregnated i.e resin poor method. The lightning Impulse &amp; interturn insulation surge withstand level shall be as per IEC-60034 part-15</p> <p>(d) 240VAC, 415V AC &amp; 220V DC motors : Thermal Class( B ) or better</p>			
7.04.00	<p>Motors rated above 1000KW shall have insulated bearings to prevent flow of shaft currents.</p>			
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-B-09 MOTORS</p>	<p>PAGE 4 OF 9</p>	

CLAUSE NO.	TECHNICAL REQUIREMENTS		
7.05.00	Motors with heat exchangers shall have dial type thermometer with adjustable alarm contacts to indicate inlet and outlet primary air temperature.		
7.06.00	Noise level for all the motors shall be limited to 85dB(A) except for BFP motor for which the maximum limit shall be 90dB(A). Vibration shall be limited within the limits prescribed in IS:12075 / IEC 60034-14 . Motors shall withstand vibrations produced by driven equipment. HT motor bearing housings shall have flat surfaces, in both X and Y directions, suitable for mounting 80mmX80mm vibration pads.		
7.07.00	In HT motors, at least four numbers simplex / two numbers duplex platinum resistance type temperature detectors shall be provided in each phase stator winding. Each bearing of HT motor shall be provided with dial type thermometer with adjustable alarm contact and preferably 2 numbers duplex platinum resistance type temperature detectors.		
7.08.00	Motor body shall have two earthing points on opposite sides.		
7.09.00	HT motors can be offered with either elastimould termination or dust tight phase separated double walled (metallic as well as insulated barrier) cable boxes. In case elastimould terminations are offered, then protective cover and trifurcating sleeves shall also be provided. In case cable box is offered, then Employer shall provide termination kit. Removable gland plates of thickness 3 mm (hot/cold rolled sheet steel) or 4 mm (non magnetic material for single core cables) shall be provided in case of cable boxes.		
7.10.00	The spacing between gland plate & centre of terminal stud shall be as per Table-I.		
7.11.00	All motors shall be so designed that maximum inrush currents and locked rotor and pullout torque developed by them at extreme voltage and frequency variations do not endanger the motor and driven equipment.		
7.12.00	The motors shall be suitable for bus transfer schemes provided on the 11kV, 3.3 kV /415V systems without any injurious effect on its life.		
7.13.00	For motors rated 2000 KW & above, neutral current transformers of PS class shall be provided on each phase in a separate neutral terminal box.		
7.14.00	11kV and 3.3 kV motor Terminal Box shall be suitable for fault level of 750MVA for 0.12 sec and 250 MVA for 0.12 sec respectively. Elastimould termination kit shall be suitable for fault level of 25 KA for 0.17 seconds.		
7.15.00	The size and number of cables (for HT and LT motors) to be intimated to the successful bidder during detailed engineering and the contractor shall provide terminal box suitable for the same.		
8.00.00	The ratio of locked rotor KVA at rated voltage to rated KW shall not exceed the following (without any further tolerance) except for BFP Motor.		
<b>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</b>	<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>SUB-SECTION-B-09 MOTORS</b>	<b>PAGE 5 OF 9</b>

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	(a) Upto 110KW : 11.0 (For AOP motor it shall be 8.0) (b) Above 110KW & upto 1500KW : 10.0 (c) Above 1500KW & upto 4000KW : 9.0 (d) Above 4000KW : 6 to 6.5			
9.00.00	CW Motor shall be designed with minimum power factor of 0.8 at design point.			
<b>10.00.00</b>	<b>TYPE TEST</b>			
10.01.00	<b>HT MOTORS</b>			
10.01.01	The contractor shall carry out the type tests as listed in this specification on the equipment to be supplied under this contract. The bidder shall indicate the charges for each of these type tests separately in the relevant schedule of Section - VII-(BPS) and the same shall be considered for the evaluation of the bids. The type tests charges shall be paid only for the test(s) actually conducted successfully under this contract and upon certification by the employer's engineer.			
10.01.02	The type tests shall be carried out in presence of the employer's representative, for which minimum 15 days notice shall be given by the contractor. The contractor shall obtain the employer's approval for the type test procedure before conducting the type test. The type test procedure shall clearly specify the test set-up, instruments to be used, procedure, acceptance norms, recording of different parameters, interval of recording, precautions to be taken etc. for the type test(s) to be carried out.			
10.01.03	In case the contractor has conducted such specified type test(s) within last ten years as on the date of bid opening, he may submit during detailed engineering the type test reports to the owner for waiver of conductance of such test(s). These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. The owner reserves the right to waive conducting of any or all the specified type test(s) under this contract. In case type tests are waived, the type test charges shall not be payable to the contractor.			
10.01.04	Further the Contractor shall only submit the reports of the type tests as listed in "LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED" and carried out within last ten years from the date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this			
<b>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</b>	<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>SUB-SECTION-B-09 MOTORS</b>	<b>PAGE 6 OF 9</b>	

CLAUSE NO.	TECHNICAL REQUIREMENTS			
10.01.05	<p>contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.</p> <p><b>LIST OF TYPE TESTS TO BE CONDUCTED</b></p> <p><b>The following type tests shall be conducted on each type and rating of HT motor</b></p> <p>(a) No load saturation and loss curves upto approximately 115% of rated voltage</p> <p>(b) Measurement of noise at no load.</p> <p>(c) Momentary excess torque test (subject to test bed constraint).</p> <p>(d) Full load test(subject to test bed constraint)</p> <p>(e) Temperature rise test at rated conditions. During heat run test, bearing temp., winding temp., coolant flow and its temp. shall also be measured. In case the temperature rise test is carried at load other than rated load, specific approval for the test method and procedure is required to be obtained. Wherever ETD's are provided, the temperature shall be measured by ETD's also for the record purpose.</p> <p>(f) Lightning Impulse withstand test on the sample coil shall be as per IEC-60034, part-15</p> <p>(g) Surge-withstand test on interturn insulation shall be as per clause no. 5.1.2 of IEC 60034, part-15</p>			
10.01.06	<p><b>LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED</b></p> <p>The following type test reports shall be submitted for each type and rating of HT motor</p> <p>(a) Degree of protection test for the enclosure followed by IR, HV and no load run test.</p> <p>(b) Terminal box-fault level withstand test for each type of terminal box of HT motors only.</p>			
10.02.00	<p><b>LT Motors</b></p>			
10.02.01	<p>LT Motors supplied shall be of type tested design. During detailed engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last <i>ten</i> years from the date of bid opening.</p>			
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-B-09 MOTORS</p>	<p>PAGE 7 OF 9</p>	

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	<p>These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.</p>			
10.02.02	<p>However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.</p>			
10.02.03	<p><b>LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED</b></p> <p><b>The following type test reports shall be submitted for each type and rating of LT motor of above 50 KW only</b></p> <ol style="list-style-type: none"> <li>1. Measurement of resistance of windings of stator and wound rotor.</li> <li>2. No load test at rated voltage to determine input current power and speed</li> <li>3. Open circuit voltage ratio of wound rotor motors ( in case of Slip ring motors)</li> <li>4. Full load test to determine efficiency power factor and slip .</li> <li>5. Temperature rise test .</li> <li>6. Momentary excess torque test.</li> <li>7. High voltage test .</li> <li>8. Test for vibration severity of motor.</li> <li>9. Test for noise levels of motor(Shall be limited as per clause no 7.06.00 of this section)</li> <li>10. Test for degree of protection and</li> <li>11. Overspeed test.</li> </ol>			
10.03.00	<p>All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.</p>			
10.04.00	<p>The type test reports once approved for any projects shall be treated as reference. For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and “No design Change”. Minor changes if any shall be highlighted on the endorsement sheet.</p>			
<p align="center"><b>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</b></p>	<p align="center"><b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b></p>	<p align="center"><b>SUB-SECTION-B-09 MOTORS</b></p>	<p align="center"><b>PAGE 8 OF 9</b></p>	

CLAUSE NO.	TECHNICAL REQUIREMENTS																															
	<p style="text-align: center;"><b>TABLE - I</b></p> <p style="text-align: center;"><b>DIMENSIONS OF TERMINAL BOXES FOR LV MOTORS</b></p> <table border="0" style="width: 100%;"> <tr> <td style="width: 60%;"><b>Motor MCR in KW</b></td> <td style="width: 40%;"><b>Minimum distance between centre of stud and gland plate in mm</b></td> </tr> <tr> <td><b>UP to 3 KW</b></td> <td><b>As per manufacturer's practice.</b></td> </tr> <tr> <td>Above 3 KW - upto 7 KW</td> <td style="text-align: right;">85</td> </tr> <tr> <td>Above 7 KW - upto 13 KW</td> <td style="text-align: right;">115</td> </tr> <tr> <td>Above 13 KW - upto 24 KW</td> <td style="text-align: right;">167</td> </tr> <tr> <td>Above 24 KW - upto 37 KW</td> <td style="text-align: right;">196</td> </tr> <tr> <td>Above 37 KW - upto 55 KW</td> <td style="text-align: right;">249</td> </tr> <tr> <td>Above 55 KW - upto 90 KW</td> <td style="text-align: right;">277</td> </tr> <tr> <td>Above 90 KW - upto 125 KW</td> <td style="text-align: right;">331</td> </tr> <tr> <td>Above 125 KW-upto 200 KW</td> <td style="text-align: right;">203</td> </tr> </table> <p>For HT motors the distance between gland plate and the terminal studs shall not be less than 500 mm.</p> <p><b>PHASE TO PHASE/ PHASE TO EARTH AIR CLEARANCE:</b></p> <p>NOTE: Minimum inter-phase and phase-earth air clearances for LT motors with lugs installed shall be as follows:</p> <table border="0" style="width: 100%;"> <tr> <td style="width: 60%;"><b>Motor MCR in KW</b></td> <td style="width: 40%;"><b>Clearance</b></td> </tr> <tr> <td>UP to 110 KW</td> <td style="text-align: right;">10mm</td> </tr> <tr> <td>Above 110 KW and upto 150 KW</td> <td style="text-align: right;">12.5mm</td> </tr> <tr> <td>Above 150 KW</td> <td style="text-align: right;">19mm</td> </tr> </table>				<b>Motor MCR in KW</b>	<b>Minimum distance between centre of stud and gland plate in mm</b>	<b>UP to 3 KW</b>	<b>As per manufacturer's practice.</b>	Above 3 KW - upto 7 KW	85	Above 7 KW - upto 13 KW	115	Above 13 KW - upto 24 KW	167	Above 24 KW - upto 37 KW	196	Above 37 KW - upto 55 KW	249	Above 55 KW - upto 90 KW	277	Above 90 KW - upto 125 KW	331	Above 125 KW-upto 200 KW	203	<b>Motor MCR in KW</b>	<b>Clearance</b>	UP to 110 KW	10mm	Above 110 KW and upto 150 KW	12.5mm	Above 150 KW	19mm
<b>Motor MCR in KW</b>	<b>Minimum distance between centre of stud and gland plate in mm</b>																															
<b>UP to 3 KW</b>	<b>As per manufacturer's practice.</b>																															
Above 3 KW - upto 7 KW	85																															
Above 7 KW - upto 13 KW	115																															
Above 13 KW - upto 24 KW	167																															
Above 24 KW - upto 37 KW	196																															
Above 37 KW - upto 55 KW	249																															
Above 55 KW - upto 90 KW	277																															
Above 90 KW - upto 125 KW	331																															
Above 125 KW-upto 200 KW	203																															
<b>Motor MCR in KW</b>	<b>Clearance</b>																															
UP to 110 KW	10mm																															
Above 110 KW and upto 150 KW	12.5mm																															
Above 150 KW	19mm																															
<b>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</b>	<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>SUB-SECTION-B-09 MOTORS</b>	<b>PAGE 9 OF 9</b>																													



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO. PE-SS-999-506-E101
VOLUME NO. : <b>II-B</b>
SECTION : <b>D</b>
REV NO. : <b>00</b> DATE :
SHEET : 1 OF 1

**GENERAL TECHNICAL REQUIREMENTS**

**FOR**

**LV MOTORS**

**SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00**



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE :  
SHEET : 1 OF 4

### 1.0 INTENT OF SPECIFICATION

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

### 2.0 CODES AND STANDARDS

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

IS:325	Three phase Induction motors
IS : 900	Code of practice for installation and maintenance of induction motors
IS: 996	Single phase small AC and universal motors
IS: 4722	Rotating Electrical machines
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines
IS: 4728	Terminal marking and direction of rotation rotating electrical machines
IS: 1231	Dimensions of three phase foot mounted induction motors
IS: 8789	Values of performance characteristics for three phase induction motors
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
IS: 2148	Flame proof enclosures for electrical appliance
IS: 5571	Guide for selection of electrical equipment for hazardous areas
IS: 12824	Type of duty and classes of rating assigned
IS: 12802	Temperature rise measurement of rotating electrical machines
IS: 12065	Permissible limits of noise level for rotating electrical machines
IS: 12075	Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

### 3.0 DESIGN REQUIREMENTS

3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information  
Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

#### 3.3 Starting Requirements

3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE :  
SHEET : 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

3.4 **Running Requirements**

3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.

3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

3.5 **Stress During bus Transfer**

3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.

4.0 **CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy

4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE :  
SHEET : 3 OF 4

- 4.4. Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.
- 4.5 Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.
- 4.6 In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.  
In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.
- 4.7 **Terminals and Terminal Boxes**
- 4.7.1 Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.  
  
Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".
- 4.7.2 Unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.7.3 Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or V W & V respectively.
- 4.7.4 Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.7.5 Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.
- 4.7.6 Degree of protection for terminal boxes shall be IP 55 as per IS 4691.
- 4.7.7 Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.
- 4.7.8. Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.
- 4.7.9 Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.
- 4.8 Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.



TITLE :  
**GENERAL TECHNICAL REQUIREMENTS**  
  
**FOR**  
  
**LV MOTORS**

SPECIFICATION NO.  
PE-SS-999-506-E101  
VOLUME NO. : **II-B**  
SECTION : **D**  
REV NO. : **00** DATE :  
SHEET : 4 OF 4

- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.

**5.0 INSPECTION AND TESTING**

- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.

**6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT**

- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:  
*(To be given for motor above 55 kW unless otherwise specified in Data Sheet).*
  - i) Current vs. time at rated voltage and minimum starting voltage.
  - ii) Speed vs. time at rated voltage and minimum starting voltage.
  - iii) Torque vs. speed at rated voltage and minimum voltage.  
For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
  - iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.



TITLE

**LV MOTORS****DATA SHEET-A**

SPECIFICATION NO.

VOLUME II B


SECTION D

REV NO. 00 DATE

SHEET 1 OF 1


- 1.0 Design ambient temperature : 50 °C
- 2.0 Maximum acceptable kW rating of LV motor : ≤200KW
- 3.0 Installation (Indoors/ Outdoors) : As required
- 4.0 Degree Of Protection (Indoor/Outdoor) : IP54/IP55
- 5.0 Type of Cooling : TEFC/CACA/TETV
- 6.0 Details of supply system
- a) Rated voltage (with variation) : 415V ± 10%
- b) Rated frequency (with variation) : 50 Hz (Variation: +3% TO -5%)
- c) Combined voltage & freq. variation : 10%
- d) System fault level at rated voltage : 45 kA for 1 sec
- e) Short time rating for terminal boxes
- o 110kW & Above : 45 kA for 1 sec  
(Breaker controlled)
- o Below 110kW (SFU+ : 45 KA for 0.20 sec.  
Contactor controlled)
- f) LV System grounding : Solidly
- 7.0 Class of insulation : Class 'F', with temp rise limited to class B.  
(Refer clause 5.00.00 of Motors)
- 8.0 Minimum voltage for starting : 85% of rated voltage  
(As percentage of rated voltage)
- 9.0 Power cables data : Shall be given during Detailed engg.
- 10.0 Earth Conductor Size & Material : Shall be given during Detailed engg.
- 11.0 Space heater supply : 240 V, 1Φ , 50 Hz
- 12.0 Rating up to which Single phase motor : Acceptable below 0.20 kW
- 13.0 Tests : As per Customer motor spec. (enclosed)
- 14.0 Energy efficient/ Flame proof motor : As per Customer spec. requirement

- Also detail Customer spec. for Motors to be referred as enclosed with spec.

	TITLE	SPECIFICATION NO.
	<b>LV MOTOR DATA SHEET - C</b>	VOLUME II B
		SECTION D
		REV NO. 00 DATE
		SHEET 1 OF 2

S. No.	Description	Data to be filled by successful bidder
<b>A.</b>	<b>General</b>	
1	Manufacturer & country of origin	
2	Motor type	
3	Type of starting	
4	Name of the equipment driven by motor & Quantity	
5	Maximum Power requirement of driven equipment	
6	Rated speed of Driven Equipment	
7	Design ambient temperature	
<b>B.</b>	<b>Design and Performance Data</b>	
1	Frame size & type designation	
2	Type of duty	
3	Rated Voltage	
4	Permissible variation for	
5	a) Voltage	
6	b) Frequency	
7	c) Combined voltage & frequency	
8	Rated output at design ambient temp (by resistance method)	
9	Synchronous speed & Rated slip	
10	Minimum permissible starting voltage	
11	Starting time in sec with mechanism coupled	
12	a) At rated voltage	
13	b) At min starting voltage	
14	Locked rotor current as percentage of FLC (including IS tolerance)	
15	Torque	
	a) Starting	
	b) Maximum	
16	Permissible temp rise at rated output over ambient temp & method	
17	Noise level at 1.0 m (dB)	
18	Amplitude of vibration	
19	Efficiency & P.F. at rated voltage & frequency	
	a) At 100% load	
	c) At 75% load	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

	TITLE	SPECIFICATION NO.	
	<p style="text-align: center;"><b>LV MOTOR</b></p> <p style="text-align: center;"><b>DATA SHEET - C</b></p>	VOLUME	II B
		SECTION D	
		REV NO. 00	DATE
		SHEET	2 OF 2

S. No.	Description	Data to be filled by successful bidder
	c) At starting	
<b>C.</b>	<b>Constructional Features</b>	
1	Method of connection of motor driven equipment	
2	Applicable Standard	
3	DOP of Enclosure	
4	Method of cooling	
5	Class of insulation	
6	Main terminal box	
	a) Type	
	b) Power Cable details (Conductor, size, armour/unarmour)	
	c) Cable Gland & lugs details (Size, type & material)	
	d) Permissible Fault level ( kArms & duration in sec)	
7	Space heater details (Voltage & watts)	
8	Flame proof motor details (if applicable)	
	a) Enclosure	
	b) suitability for hazardous area	
	i Zone	O / I / II
	ii Group	IIA / IIB / IIC
9	No. of Stator winding	
10	Winding connection	
11	Kind of rotor winding	
12	Kind of bearings	
13	Direction of rotation when viewed from NDE	
14	Paint Shade & type	
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	
<b>D.</b>	<b>Characteristic curves/ drawings</b> (To be enclosed for motors of rating $\geq 55KW$ )	
	a) Torque speed characteristic	
	b) Thermal withstand characteristic	
	c) Current vs time	
	d) Speed vs time	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			



TITLE: **ELECTRICAL EQUIPMENT SPECIFICATION**  
**PACKAGE: COMPRESSED AIR SYSTEM**

SPECIFICATION NO.  
PE-TS-401-555-A001

VOLUME NO. : **IIB**

SECTION : **C.4**

VOLUME IIB  
SECTION C.4

SPECIFIC TECHNICAL REQUIREMENTS  
(CONTROL AND INSTRUMENTS PORTION)

## FIROZ GANDHI UNCHAHAAR THERMAL POWER PLANT (1 X 500 MW)

### COMPRESSED AIR SYSTEM SCOPE OF SUPPLY

#### 1. GENERAL

The Contractor shall provide complete Instrumentation for control, monitoring and operation of entire COMPRESS AIR SYSTEM. The requirements given below are to be read in conjunction with detailed Technical specification enclosed in the specification. Further in case of any discrepancy in the requirement within the same section noted by the bidder in the specification, the same will be brought to the notice of BHEL in the form of pre- bid clarification.

In absence of any pre-bid clarification, the more stringent requirement as per interpretation of customer shall prevail without any commercial implication.

The make/model of various instruments/items/systems shall be as per NTPC/NBPPL approved vendor list. No commercial and delivery implication in this regard shall be acceptable. In case of any conflict and repetition of clauses in the specification, the more stringent requirements among them are to be complied with.

#### 2. CONTROL SYSTEM

2.1 The control of Compress air system (CAS) shall be realized in Microprocessor based control system (including power supply) as per vendor's practice for individual Air compressors. Overall control through DDCMIS system. Microprocessor based control system shall be in bidder's scope. Control of individual compressor shall be through microprocessor based control panel (integral to compressor). Commands to individual compressor shall be issued through TFT screen on the panel. Also, Hardwired remote START/STOP operation of compressors shall be provided from DCS. If any signals are require for control and monitoring and the same are not available through link, the same shall be hardwired to BOP C&I.

2.2. Depending upon operational requirement each compressor can be selected and operated in following mode:

**Local Mode:** Individual compressor is operated from Local Integral Control System.

**Remote Mode:** Individual compressor is operated (only start/stop) through DDCMIS OWS.

2.3 All the process inputs (Digital or Analog), other than specific to compressors are taken directly to DDCMIS for monitoring.

2.4 Any accessories including cable required for interfacing of vendor panels with DCS at vendor panel end shall be in bidder scope.

2.5 All bidirectional drives are integral starter type, typical Hook Up diagram of drives is included for reference (subject to Customer approval). Also, drive control philosophy has been enclosed in C&I specification.

2.7 Drawings/Documents and data to be furnished after award of the contract:

- Control & operational write-up for the system.
- Configuration diagram for microprocessor based control system
- I/O list for DCS.
- Recommended control scheme/ logic diagram for start/stop commands from DCS
- Field instruments data sheet.
- Panel GA drawings & Termination details.
- Cable schedule and cable interconnection drawing.
- Instrument schedule.
- Drive List and Analog / Binary I/O List.

- List of Drives (Solenoid valves etc.)
- Recommended Control write-up
- JB grouping, Annunciation list, SOE list
- Any other document decided during detailed engineering.

### 3.0 MEASURING INSTRUMENTS

Primary instruments like Microprocessor based transmitters and temperature transmitters employing HART protocol, thermocouples & RTDs, pressure/diff. Pressure/ temperature/flow/ level switches & gauges for :

3.1 All instruments/drives shall be terminated on JB/Panel by Bidder. Instruments/Drives, JB/Panel, connecting instrument cable & control cable are in Bidder's scope.

3.2 All the Instrumentation as shown in P&ID shall be in bidder's scope. All Primary and Secondary Instruments for the package shall be supplied, along with accessories like impulse pipe, fittings & valve manifolds etc. as per Installation diagram. Necessary racks required for mounting of these instruments shall be supplied by bidder.

3.3 For Binary and analog inputs required in major equipment protection, triple-sensing devices shall be provided. Binary and analog inputs, which are, required for protection of more than one equipment as well as protection signals for important auxiliaries and HT Drives (fed by a supply feeder of ratings 3.3 kV onwards) etc., triple sensing devices shall be provided.

3.4. Temperature transmitters are to be provided by the contractor for all the temperature elements in the scope of the contractor. Compensating Cables, JB/rack & other erection hardware shall also be in scope of contractor.

3.5 Rail mounted/ Rack mounted (Dual input Field mounted temperature transmitters) /Field Bus Compatible temperature transmitters for temperature elements (for all the temperature elements being procured by the contractor) are to be provided by the contractor as per the followings:

- i. Contractor shall provide atleast one dual input transmitter for temperature measurements being used in trip/protection/major interlock of Turbine Generator and Major Auxiliaries. E.g. when three/two temperature measurement points are being used to for monitoring one bearing temperature, both elements of one duplex temperature element is to be connected to one dual input temperature transmitter.
- ii. Remaining temperature transmitter are to be Single Input DIN rail mounting type.
- iii. Head mounted transmitters may be provided for temperature elements which are located in accessible areas as decided during detailed engineering.

3.6 Complete Microprocessor based Vibration monitoring system for monitoring of vibration of HT Drives (if any).

3.7 All the instruments shall be terminated up to JB's by Contractor. JB's shall be in Contractor's scope.

3.8 Instrument installation and accessories required for the same shall be in Contractor's scope and shall be as per the instrument installation diagrams enclosed in the specification.

3.9 The solenoid valves shall have limit switches for open/close feedback.

3.10 Detailed specification of instruments, VMS, JB, Control panel etc. & Instrument Stub details, Instrument installation diagrams shall be as defined in Sub Section- Measuring Instruments, C&I Specification of technical specification.

3.11 Diaphragm to be used for instrumentation having corrosive media contact.

3.12. Bidder to perform tests of C&I items/instruments/systems as per C&I specification.

3.13 Bidder to note that all the transmitters supplied by Bidder shall be rack mounted. The transmitter racks shall be in Bidder's scope. Also no instruments / analyzers & JB's/Racks should be protruding on the walkway.

3.14 The make/model of various instruments/items/systems shall be subject to approval of BHEL/Customer during detailed engineering stage. No commercial and delivery implication in this regard shall be acceptable. In case of any conflict and repetition of clauses if the specification, the more stringent requirements among them are to be complied with.

3.15 Signals from CAS shall be connected to DDCMIS by two links using RS 485/ RS232 protocol. The maximum signal handled by link1 is 100 Nos. and by link2 is 70 Nos. approx.

#### **4. INSTRUMENTATION CABLES & CONTROL CABLES**

4.1 Scope of Instrumentation cables (Screened Control Cables) & Control cables shall be as per Electrical Cable scope matrix in Electrical portion of specification.

#### **5. ELECTRICAL ACTUATORS**

5.1 Electrical Actuators with Integral starter shall be provided for all on/off and inching type valves in main plant and offsite areas along with necessary interface units for linking to Control System as applicable as detailed out in Sub Section- Electric Actuator, C&I Specification, Section-D of Technical Specification.

For manually operated valves, limit switches where specified shall be wired to the terminal Boxes/JB provided by bidder on the valves.

#### **6. QUALITY ASSURANCE**

Contractor shall perform tests of C&I items/instruments/systems as per Quality Assurance for C&I of the technical specification.

#### **7. DOCUMENTS TO BE SUBMITTED AFTER AWARD OF CONTRACT**

Documents to be submitted after award of Contract shall be as defined in Sub Section- C&I Documents to be submitted after Award of Contract, C&I Specification, Section-D of technical specification.



**SPECIFICATION FOR  
CONTROL & INSTRUMENTATION FOR AUX  
PACKAGES**


SPECIFICATION NO.:	
VOLUME	
SUB SECTION	
REV. NO.	DATE :
SHEET	OF

**GENERAL REQUIREMENT**

- 1.0 Bidder shall provide complete and independent control & instrumentation system with all accessories, auxiliaries and associated equipments for the safe, efficient and reliable operation of auxiliary systems.
  
- 2.0 The quantity of instruments for auxiliary system shall be as per tender P & ID wherever provided of the respective system as a minimum, for bidding purpose. However, Bidder shall also include in his proposal all the instruments and devices that are needed for the completeness of the plant auxiliary system/ equipment supplied by the bidder, even if the same is not specifically appearing in the P & ID. During detail engineering if any additional instruments are required for safe & reliable operation of plant, bidder shall supply the same without any price implication.
  
- 3.0 Measuring instruments/equipment and subsystems offered by the bidder shall be from reputed experienced manufacturers of specified type and range of equipment, whose guaranteed and trouble free operation has been proven. Further all the instruments shall be of proven reliability, accuracy, and acceptable international standards and shall be subject to employer's approval. All instrumentation equipment and accessories under this specification shall be furnished as per technical specification, ranges, makes/ numbers as approved by the employer' during detail engineering.
  
- 4.0 The necessary root valves, impulse piping, drain cocks, gauge-zeroing cocks, valve manifold and all the other accessories required for mounting/ erection of these local instruments shall be furnished, even if not specifically asked for, on as required basis. The contacts of equipment mounted instruments; sensors, switches etc for external connection including spare contacts shall be wired out to suitably located junction boxes.
  
- 5.0 The customer specification attached as Specific Technical Requirement will supercede the Data sheets, if there is any mismatch.


# **SPECIFICATION OF MEASURING INSTRUMENTS**


CLAUSE NO.	TECHNICAL REQUIREMENTS	एनटीपीसी NTPC						
1.00.00	<b>MEASURING INSTRUMENTS (PRIMARY AND SECONDARY)</b>							
1.01.00	Measuring instruments/equipment and subsystems offered by the Bidder shall be from reputed experienced manufacturers of specified type and range of equipment, whose guaranteed and trouble free operation has been proven. Refer Sub-section Basic Design Criteria. Further, all instruments shall be of proven reliability, accuracy, and repeatability requiring a minimum of maintenance and shall comply with the acceptable international standards and shall be subject to Employer's approval.							
1.02.00	Every panel-mounted instrument requiring power supply shall be provided with a pair of easily replaceable glass cartridge fuses of suitable rating. Every instrument shall be provided with a grounding terminal and shall be suitably connected to the panel grounding bus.							
1.03.00	All transmitters, sensors, and switches for parameters like pressure, temperature, level, flow etc. as required for the safe and efficient operation and maintenance as well as for operator and management information (including all computation) of equipment in the system under the scope of specification shall be provided as indicated in the APPENDIX-I TO PART A OF TECHNICAL SPECIFICATIONS/ tender drawings. Estimated system parameters & instrument ranges etc. are indicated in the I & C device list. The exact value shall be provided by Employer during detailed engineering. The Contractor shall furnish all Instrumentation / Control equipment & accessories under this specification as per technical specification, ranges, makes & model as approved by the Employer during detailed engineering.							
1.04.00	The necessary root valves, impulse piping, drain cocks, gauge-zeroing cocks, valve manifolds and all the other accessories required for mounting/erection of these local instruments shall be furnished, even if not specifically asked for, on as required basis. The contacts of equipment mounted instruments, sensors, switches etc. for external connection including spare contacts shall be wired out in flexible/rigid conduits, independently to suitably located common junction boxes. The proposal shall include the necessary cables, flexible conduits, junction boxes and accessories for the above purpose. Double root valves shall be provided for all pressure tapping where the pressure exceeds 40 Kg./sq.cm.							
1.05.00	The quantity of secondary instruments etc. to be provided by Contractor is listed in Appendix-I to Part A of Technical Specifications.							
2.00.00	<p><b>SPECIFICATION FOR ELECTRONIC TRANSMITTER FOR PRESSURE, D.P., FLOW AND LEVEL</b></p> <p><b>ELECTRONIC TRANSMITTERS</b></p> <table border="1"> <thead> <tr> <th data-bbox="391 1668 470 1697">Sl.No.</th> <th data-bbox="502 1668 614 1697">Features</th> <th data-bbox="742 1668 1157 1697">Essential/Minimum Requirements</th> </tr> </thead> <tbody> <tr> <td data-bbox="391 1724 406 1753">1.</td> <td data-bbox="502 1724 630 1787">Type of Transmitter</td> <td data-bbox="742 1724 1300 1787">Microprocessor based 2 wire type, Hart protocol compatible.</td> </tr> </tbody> </table>		Sl.No.	Features	Essential/Minimum Requirements	1.	Type of Transmitter	Microprocessor based 2 wire type, Hart protocol compatible.
Sl.No.	Features	Essential/Minimum Requirements						
1.	Type of Transmitter	Microprocessor based 2 wire type, Hart protocol compatible.						
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 1 OF 45					




10h


08470

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	2.	Accuracy	± 0.1% of calibrated span (minimum) (upto turn down ratio of 10:1)	
	3.	Output signal range	4-20 mA DC (Analog) along with superimposed digital signal (based on HART protocol)	
	4.	Turn down ratio	10:1 for vacuum/very low pressure applications. 5:1 for very high pressure application. 30:1 for other applications.	
	5.	Stability	± 0.1% of calibrated span for six months for Ranges up to and including 70 Kg/cm <sup>2</sup> . ± 0.25% of calibrated span for six months for Ranges more than 70 Kg/cm <sup>2</sup> (g).	
	6.	Zero and span drift	+/- 0.015% per deg.C at max span. +/-0.11% per deg.C at min. Span.	
	7.	Load impedance	500 ohm (min.)	
	8.	Housing	Weather proof as per IP-55 with durable corrosion resistant coating.	
	9.	Over Pressure	150% of max. Operating pressure	
	10.	Connection (Electrical)	Plug and socket type	
	11.	Process connection	1/2 inch NPT (F)	
	12.	Span and Zero	Continuous, tamper proof, Remote as well as adjustability manual from instrument with zero suppression and elevation facility.	
	13.	Accessories	-Diaphragm seal, pulsation dampeners, syphon etc. as required by service and operating condition.  -2 valve manifold for absolute & Gauge pressure transmitters, 3-valve manifold for vacuum pressure transmitters & where DP transmitters are being used for pressure measurement and 5 valve manifold for DP/Level/Flow applicable.  -For hazardous area, explosions proof enclosure as described in NEC article 500.	
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 2 OF 45	



08471

CLAUSE NO.	TECHNICAL REQUIREMENTS																				
	14. Diagnostics 15. Power supply 16. Adjustment/calibration/maintenance	Self Indicating feature 24V DC ± 10%. From hand held calibrator/centralized PC based system (as applicable).																			
	<p>Notes</p> <p>For air/flue gas applications, DP type transmitters shall be provided for pressure measurement.</p> <p>LVDT type is not acceptable.</p> <p>Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application.</p>																				
2.01.00	<p><b>GUIDED WAVE RADAR TYPE LEVEL TRANSMITTER</b></p> <p>Guided wave radar type level transmitters shall be provided for level measurements of the vessel under vacuum or low pressure applications.</p> <table border="0"> <tr> <td>Type</td> <td>Guided wave Radar</td> </tr> <tr> <td>Principle</td> <td>TDR (Time domain reflectometry)</td> </tr> <tr> <td>Probe Type &amp; Material</td> <td>Coaxial, SS316/316L. If required, probe shall be suitable for overflow prevention.</td> </tr> <tr> <td>Signal o/p</td> <td>4-20mA with HART signal suitable for overflow prevention.</td> </tr> <tr> <td>Display</td> <td>Integral</td> </tr> <tr> <td>Power supply</td> <td>24 VDC</td> </tr> <tr> <td>Accuracy</td> <td>5mm</td> </tr> <tr> <td>Electromagnetic compatibility</td> <td>Shall meet EN 61326-1 (1997) and AmdtA1, class A equipment/EN 50081-2 &amp; EN 50082-2</td> </tr> <tr> <td>Mounting</td> <td>External cage mounting</td> </tr> </table> <p>The transmitters shall be provided with IP-55 protection class with durable corrosion resistant coating.</p>		Type	Guided wave Radar	Principle	TDR (Time domain reflectometry)	Probe Type & Material	Coaxial, SS316/316L. If required, probe shall be suitable for overflow prevention.	Signal o/p	4-20mA with HART signal suitable for overflow prevention.	Display	Integral	Power supply	24 VDC	Accuracy	5mm	Electromagnetic compatibility	Shall meet EN 61326-1 (1997) and AmdtA1, class A equipment/EN 50081-2 & EN 50082-2	Mounting	External cage mounting	
Type	Guided wave Radar																				
Principle	TDR (Time domain reflectometry)																				
Probe Type & Material	Coaxial, SS316/316L. If required, probe shall be suitable for overflow prevention.																				
Signal o/p	4-20mA with HART signal suitable for overflow prevention.																				
Display	Integral																				
Power supply	24 VDC																				
Accuracy	5mm																				
Electromagnetic compatibility	Shall meet EN 61326-1 (1997) and AmdtA1, class A equipment/EN 50081-2 & EN 50082-2																				
Mounting	External cage mounting																				
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 3 OF 45																		




08473


S. NO.	TECHNICAL REQUIREMENTS	एनटीपीसी NTPC																											
2.00.00	<p><b>HART Hand Held calibrator</b></p> <p>Hand held calibrator shall be provided for adjustment/calibration/maintenance of the HART compatible transmitters. The hand held calibrator shall be suitable for all types of transmitters supplied in the package. If one type of hand held type calibrator is not suitable for communicating with all types of transmitters then separate hand held calibrator will be provided.</p>																												
3.00.00	<p><b>TEMPERATURE ELEMENTS AND ACCESSORIES</b></p>																												
3.00.00	<p><b>Thermocouple</b></p>																												
	<table border="1"> <thead> <tr> <th data-bbox="391 705 454 772">Sr. No.</th> <th data-bbox="502 705 774 750">Features</th> <th data-bbox="869 705 1284 750">Essential/Minimum Requirements</th> </tr> </thead> <tbody> <tr> <td data-bbox="391 795 422 840">1</td> <td data-bbox="502 795 774 840">Type of Thermocouple.</td> <td data-bbox="869 795 1284 929">: 16 AWG wire of Chromel-Alumel (Type K) or 24 AWG wire Pt-Rhodium Pt (Type R) depending on operating temperature Range (ungrounded type).</td> </tr> <tr> <td data-bbox="391 952 422 996">2</td> <td data-bbox="502 952 774 996">No. of element</td> <td data-bbox="869 952 1284 996">: Duplex</td> </tr> <tr> <td data-bbox="391 1008 422 1052">3</td> <td data-bbox="502 1008 774 1052">Housing/Head</td> <td data-bbox="869 1008 1284 1198">: IP-65/Diecast Aluminium. Head of TE to be provided with sufficient space and arrangement to mount head mounted temperature transmitter (as applicable). Plug in connectors are to be provided for external signal cable connection.</td> </tr> <tr> <td data-bbox="391 1220 422 1265">4</td> <td data-bbox="502 1220 774 1265">Sheathing of Thermocouple</td> <td data-bbox="869 1220 1284 1288">: Swaged type magnesium oxide insulation.</td> </tr> <tr> <td data-bbox="391 1310 422 1355">5</td> <td data-bbox="502 1310 774 1355">Calibration and accuracy</td> <td data-bbox="869 1310 1284 1377">: As per IEC-751/ANSI-C-96.1(special class)for T/C.</td> </tr> <tr> <td data-bbox="391 1400 422 1444">6</td> <td data-bbox="502 1400 774 1444">Characteristic</td> <td data-bbox="869 1400 1284 1467">: Linear with respect to temp, within <math>\pm 1/2</math> percent of top range value.</td> </tr> <tr> <td data-bbox="391 1489 422 1534">7</td> <td data-bbox="502 1489 774 1534">Accessories</td> <td data-bbox="869 1489 1284 1579">: Thermo well (as specified below) and shall be spring loaded for positive contacts with the well.</td> </tr> <tr> <td data-bbox="391 1601 422 1646">8</td> <td data-bbox="502 1601 774 1646">Standard</td> <td data-bbox="869 1601 1284 1668">: ANSI C 96.1 for Thermocouple and ASME PTC-19.3 for Thermo-well.</td> </tr> </tbody> </table>	Sr. No.	Features	Essential/Minimum Requirements	1	Type of Thermocouple.	: 16 AWG wire of Chromel-Alumel (Type K) or 24 AWG wire Pt-Rhodium Pt (Type R) depending on operating temperature Range (ungrounded type).	2	No. of element	: Duplex	3	Housing/Head	: IP-65/Diecast Aluminium. Head of TE to be provided with sufficient space and arrangement to mount head mounted temperature transmitter (as applicable). Plug in connectors are to be provided for external signal cable connection.	4	Sheathing of Thermocouple	: Swaged type magnesium oxide insulation.	5	Calibration and accuracy	: As per IEC-751/ANSI-C-96.1(special class)for T/C.	6	Characteristic	: Linear with respect to temp, within $\pm 1/2$ percent of top range value.	7	Accessories	: Thermo well (as specified below) and shall be spring loaded for positive contacts with the well.	8	Standard	: ANSI C 96.1 for Thermocouple and ASME PTC-19.3 for Thermo-well.	
Sr. No.	Features	Essential/Minimum Requirements																											
1	Type of Thermocouple.	: 16 AWG wire of Chromel-Alumel (Type K) or 24 AWG wire Pt-Rhodium Pt (Type R) depending on operating temperature Range (ungrounded type).																											
2	No. of element	: Duplex																											
3	Housing/Head	: IP-65/Diecast Aluminium. Head of TE to be provided with sufficient space and arrangement to mount head mounted temperature transmitter (as applicable). Plug in connectors are to be provided for external signal cable connection.																											
4	Sheathing of Thermocouple	: Swaged type magnesium oxide insulation.																											
5	Calibration and accuracy	: As per IEC-751/ANSI-C-96.1(special class)for T/C.																											
6	Characteristic	: Linear with respect to temp, within $\pm 1/2$ percent of top range value.																											
7	Accessories	: Thermo well (as specified below) and shall be spring loaded for positive contacts with the well.																											
8	Standard	: ANSI C 96.1 for Thermocouple and ASME PTC-19.3 for Thermo-well.																											
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY &amp; SECONDARY)</p>	<p>PAGE 5 OF 45</p>																										




08475


CLAUSE NO.	TECHNICAL REQUIREMENTS		एनटीपीसी NTPC
3.04.00	Characteristics of Thermocouple	Special limits of error as in ANSI thermocouple MC 96.01.1975	
	Mounting accessories	1/2" BSP SS sliding end connector, weld pad, clamps of heat resistant steel SS310.	
	Cold end sealing	SS pot weal with colour coded PTFE headed sleeve Insulated flexible tails. Sealing compound- Epoxy resin.	
	Minimum bending radius	30 mm	
	Length of T/C	30 Mtr. (minimum)	
3.04.00	<b>TEMPERATURE TRANSMITTER</b>		
	<p>Following types of 2-wire temperature transmitter (directly powered from 4-20mA input cards of DDCMIS) shall be provided. The temperature transmitter shall be fully compatible with thermocouples and RTDs being provided by the contractor as well as Employer. Temperature compensation of the thermocouples shall be performed in the temperature transmitter itself.</p>		
	<p>a. Single Input Head mounted Temperature Transmitter</p>		
	<p>These shall be suitable for mounting in the head of temperature element itself. The protection class of head of thermo well along with its plug-in connector shall be min. IP65.</p>		
	<p>b. Single Input DIN-rail mounted Temperature Transmitter</p>		
	<p>These shall be suitable for mounting on DIN-rails in JB's. The specifications of the JB's shall be same as indicated in Subsection INST CABLE with additional DIN-rails and IP 65 Protection class. This temperature transmitter shall be the ones which are especially designed for DIN-rail mounting with IP 20 protection class. These shall have terminals for input/output provided on front side when mounted on DIN-rail. Head mounted temperature transmitter with clamps to make it suitable for DIN-rail mounting shall not be acceptable under this category.</p>		
	<p>c. Dual-input Temperature Transmitter With Indicator:</p>		
	<p>These shall be suitable for mounting on pipes/ support. Indicator shall be provided with these transmitters. These transmitters shall have bump less change over facility to second sensor in case first sensor fails. This change-over is to be alarmed. Protection class shall be IP65 minimum.</p>		
	<p><b><i>The exact applications for which this type of transmitter is to be provided shall be finalized during detailed engineering. However, the quantity shall be as per Appendix-I to Part-A.</i></b></p>		
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 7 OF 45





CLAUSE NO.	TECHNICAL REQUIREMENTS			
	<p>d. Common requirements for each of the above type of temperature transmitters.</p> <p>Output : 2-wire (power supply from input card of Control System) with 4-20mA output with superimposed HART protocol signal.</p> <p>Input : Same transmitter shall be capable to handle Pt-100 RTD , Thermocouples –K&amp;R types (input type to be selectable at site through HART terminal)</p> <p>Isolation : min. 500 V AC</p> <p>EMC compatibility : as per EN 61326</p> <p>Operating ambient temperature : 0 to 85 deg C (without indicator) 0 to 70 deg C (with indicator)</p> <p>Power supply : compatible with input module of Control System</p> <p>Accessories : Mounting arrangements including clamps etc.</p> <p>Composite Accuracy (a) For head mounted and DIN-rail mounted types: (Refer note 2 )</p> <p>RTD = &lt;math&gt;\leq 0.4\%&lt;/math&gt; of 0-250 deg C span T/C-K type = &lt;math&gt;\leq 0.4\%&lt;/math&gt; of 0-600 deg C span T/C-R type = &lt;math&gt;\leq 0.4\%&lt;/math&gt; of 0-1000 deg C span CJC accuracy (for thermocouples) shall be = &lt;math&gt;\leq 1&lt;/math&gt; deg C</p> <p>(b) For dual-input type: RTD = &lt;math&gt;\leq 0.25\%&lt;/math&gt; of 0-250 deg C span T/C-K type = &lt;math&gt;\leq 0.2\%&lt;/math&gt; of 0-600 deg C span CJC accuracy (for thermocouples) shall be = &lt;math&gt;\leq 1&lt;/math&gt; deg C</p> <p>e. Field bus compatible temperature transmitters</p> <p><i>Temperature transmitters of this category shall be field mounting type &amp; shall be capable of withstanding operating ambient temperature upto 85 deg C. These modules shall be connected to DDCMIS through field bus such as Profibus, Foundation Field bus etc directly from the transmitter. Maximum Number of inputs per such temperature transmitter shall be eight. These shall be mounted in cabinets in non-AC areas.</i></p>			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 8 OF 45	





08477


CLAUSE NO.	TECHNICAL REQUIREMENTS											
	<p>As an alternate, these signals from temperature transmitters can be connected to DDCMIS through standard remote I/O modules of the DCS, in which case, the temperature transmitter signals will be acquired through 4-20mA input modules in the remote I/O cabinet for connecting to DDCMIS through remote I/O bus.</p> <p>The no. of such modular systems/ JB's shall be provided as per Appendix-1 to Part-A.</p> <p>Notes (Common for a) to e) above):-</p> <ol style="list-style-type: none"> <li>In case of failure (open or burn-out) of RTD/thermocouple, temp. Transmitter shall provide low temperature output.</li> <li>Composite Accuracy is to be calculated as summation of all applicable accuracies of temp transmitter, for converting sensor input to output in 4-20 mA (e.g., basic accuracy, digital accuracy, D/A accuracy, etc.) and temperature effect on these accuracies at ambient temperature of 50 deg C, based on the figure/ formula given in the standard product catalogue for span as specified above for various types of Temperature Elements specified. All such accuracy/ temp effect figures in catalogue shall be first converted to deg C, and then percentage of this converted accuracy in specified span shall be calculated to compare with the specified composite accuracy figures.</li> </ol>											
3.05.00	<p><b>Thermo well (for all process temp. elements)</b></p> <ol style="list-style-type: none"> <li>Shall be one piece solid bored type of 316 SS of step-less tapered design. (As per ASME PTC 19.3 1974)</li> <li>For Mill classifier outlet long life solid sintered tungsten carbide material of high abrasion resistance shall be provided.</li> <li>For Air &amp; Flue gas 316 SS protecting tube with welded cap. (However contractor shall provide better material for Flue gas service if required based on the specified boiler design parameters).</li> <li>For furnace zone, impervious ceramic protecting tube of suitable material along with Incoloy supporting tubes and adjustable flanges.</li> </ol>											
3.06.00	<p><b>Cold Junction Compensation (CJC) Boxes</b></p> <table border="0"> <tr> <td>a) Ref. temp.</td> <td>60°C ± 1.3 °C for type K Thermocouple</td> </tr> <tr> <td></td> <td>60°C ± 2°C for type R Thermocouple</td> </tr> <tr> <td>b) Effect of ambient temp. variation</td> <td>± 0.1% per 10°C</td> </tr> <tr> <td>c) Material</td> <td>4 mm thick fiberglass reinforced polyester with Polyurethane paint &amp; glazed finish.</td> </tr> </table>			a) Ref. temp.	60°C ± 1.3 °C for type K Thermocouple		60°C ± 2°C for type R Thermocouple	b) Effect of ambient temp. variation	± 0.1% per 10°C	c) Material	4 mm thick fiberglass reinforced polyester with Polyurethane paint & glazed finish.	
a) Ref. temp.	60°C ± 1.3 °C for type K Thermocouple											
	60°C ± 2°C for type R Thermocouple											
b) Effect of ambient temp. variation	± 0.1% per 10°C											
c) Material	4 mm thick fiberglass reinforced polyester with Polyurethane paint & glazed finish.											
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 9 OF 45									




<p>CLAUSE NO.</p>	<p align="center"><b>MEASURING INSTRUMENTS (C-03)</b></p> <p align="right"></p>		
<p><b>7.00.00</b></p>	<p><b>VIBRATION MONITORING SYSTEM :</b></p> <p>Microprocessor based vibration monitoring system shall be provided for fan/pumps/motors etc. qty. of which shall be as indicated in Appendix I to Part A.</p> <p>The Vibration Monitoring System shall be furnished on a system basis including, vibration transducers with low noise flexible cables in flexible conduit, terminated in local terminal boxes, necessary pre-amplifier/electronics mounted in local weather proof boxes, vibration monitors, mounting racks and cabinets etc. The vibration monitoring system shall include all power supplies, interconnecting cabling, calibration equipment, indicators, integrating units, signal conditioning devices and all other accessories, erection hardware required for monitoring of Vibration at each point. The contractor shall provide the vibration pads.</p> <p>Contractor can offer up to Four Channel Vibration monitors. The allocation of channels shall be such that loss of one monitor shall not affect more than one side of the bearing of one machine. In the case of more than two channel Vibration monitors being provided by the Contractor, then one spare monitor shall be provided mounted in the panel to take care of immediate replacement of any failed monitors. Offered vibration monitors shall be modular in construction, plug in type.</p> <p>Inductance / piezoelectric type transducers shall be used. The sensors shall be either velocity or accelerometer type. However, the finally selected sensor type shall also depend on recommendation of the equipment manufacturer &amp; suitable for application requirement which shall be finalised during detail engineering and without any extra price. Transducers shall be furnished in weatherproof housing suitable for field conditions. Cables/cabling from transducers local JB to Vibration Monitoring system in Control Room/Control Equipment Room shall be provided by the Contractor.</p> <p>Vibration monitoring system shall give one no. buffered output of 4-20 mA DC and two no. of buffered raw signal for each point monitored. The signal shall be suitable for use as an input to DDCMIS as well as for analog recording &amp; analysis, linear in proportion to vibration velocity as well as displacement. Monitor shall provide vibration indication calibrated in velocity units along with provisions of changing to displacement unit (field-programmable) for each measurement point in both horizontal &amp; vertical planes. In addition to the above Analog output to DDCMIS, RS 485/ Ethernet communication link with MODBUS/OPC protocol and suitable hardware/software for interfacing with Unit LAN/ Station LAN for transfer of on line data and history to employers remote engineering office shall also be provided.</p> <p>The Vibration monitor racks with power supplies shall be mounted in a separate self standing cabinet to be located in Control Equipment Room except for CW pumps Auxiliary Cooling Tower Fans, which shall be located in remote CW control room. Contractor shall feed the vibration monitoring cabinet from redundant UPS feeders with Auto changeover scheme. The power supply arrangement shall ensure that if external power supplies are used, failure of one</p>		
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY &amp; SECONDARY)</p>	<p>PAGE 16 OF 45</p>




CLAUSE NO.	<p align="center"><b>MEASURING INSTRUMENTS (C-03)</b></p> 		
<p>8.00.00</p> <p>9.00.00</p>	<p>power supply shall not affect any monitoring function in the system. Also any power supply failure /earth fault in any of the monitors will be isolated without affecting other monitors/ common power supply. However, if any power supply modules internal to the monitors are envisaged, the failure of one such module should not affect more than one monitor.</p> <p>The functional requirement for vibration monitoring system shall include but not be limited to the following:</p> <ul style="list-style-type: none"> <li>- Vibration monitor front face status indications shall be available for indications of healthy conditions of pick up circuit, monitor circuit and power supply. On sensor fault/wire break in the sensor circuit, the system shall have the feature of identifying the same through suitable means like the big not forced to a value less than 4 mA. In case, such a feature is not available then suitable contact shall be provided from the monitor for sensor fault.</li> <li>- The facility shall be available from front of mounting rack for functional checking of monitors.</li> <li>- All vibration monitoring equipment shall be functionally tested for circuit continuity and output response. All the components &amp; interconnection cables shall be tested to ensure compliance with the specification requirements &amp; all other applicable codes &amp; standards.</li> </ul> <p>In case it is the proven standard practice of a Contractor to provide vibration monitoring PC with TFT LCD monitor, instead of dedicated monitors with the signal conditioning equipment in control equipment room, the same shall also be acceptable. However, all relevant functional requirements detailed above shall be met and the system shall be subject to Employer's approval.</p> <p><b>E-P CONVERTER</b></p> <p>E-P converters and associated accessories shall be furnished in accordance with the specifications given below :</p> <p>Air supply: 1.5 kg/cm sq., Input signal: 4-20m A dc (as required by the design of control system), Output signal: 0.2 to 1.0 kg/cm sq., Linearity: 0.5% of span or better, Hysteresis: 0.5% of span or better, Ambient Temperature Effect: less than 0.02% of span per deg C between -20 to +60 deg C. Mounting: Close to actuator (but not on the actuator), output capacity-to suit the actuator, protection class IP 55. On loss of control signal, the last set point pressure shall be maintained so that the associated control valve remains in stay put condition without any additional solenoid valve. The allowable drift rate will be <math>\pm 2\%</math> of set point/ hour maximum.</p> <p><del><b>COAL BUNKER LEVEL MONITORING SYSTEM</b></del></p> <p><del>Complete Coal Bunker Level Monitoring System consisting of strain gauge sensors, electronic units, interconnecting cables etc. shall be provided. The number &amp; location of the strain gauge sensors shall be selected by the Contractor to ensure</del></p>		
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY &amp; SECONDARY)</p>	<p>PAGE 17 OF 45</p>



08501


CLAUSE NO.	MEASURING INSTRUMENTS (C-03)																										
15.00.00	<p>The transmitter shall provide suitable 4-20mA dc output signal for control and indication/recording. Converters if necessary shall be provided to generate the 4-20mA signal.</p> <p>A local indicator of fuel oil flow shall also be provided. The instrument shall be calibrated in Tons/hr.</p> <p>Suitable strainer shall be provided before the transmitter for the protection of oval wheel meters against foreign matter contained in the fuel oil.</p> <p>The exact model no. and type of material being used, etc., shall be subject to Employer's approval during detailed engineering without any price repercussion to Employer.</p>																										
	<p><b>PROCESS ACTUATED SWITCHES</b></p> <table border="1"> <thead> <tr> <th data-bbox="440 898 587 927">FEATURES</th> <th colspan="3" data-bbox="746 898 1241 927">ESSENTIAL / MINIMUM REQUIREMENTS</th> </tr> </thead> <tbody> <tr> <td data-bbox="440 958 587 1043"></td> <td data-bbox="632 958 746 1043">Pressure/ Draft Switches/ Switches</td> <td data-bbox="791 958 906 1043">Temperature DP switches</td> <td data-bbox="1031 958 1206 1043">Level switches</td> </tr> <tr> <td data-bbox="440 1077 587 1128">Sensing Element</td> <td data-bbox="632 1077 823 1249">Piston actuated for high pressure and liquid diaphragm or bellows for low pr./ vacuum</td> <td data-bbox="839 1077 1015 1308">Vapor high pressure sensing, liquid filled bellow type with SS bulb and capillary (10 m minimum)</td> <td data-bbox="1031 1077 1401 1536">Capacitance types for oil and dirty medium, water, condensate application. Float type switches for applications as decided by Employer during detailed engineering. Capacitance/ Conductivity/ Ultrasonic type for acid and alkali application. Radio-frequency/ Ultrasonic type for ash hopper, ash slurry application.</td> </tr> <tr> <td data-bbox="440 1563 587 1592">Material</td> <td data-bbox="632 1563 746 1592">316 SS</td> <td data-bbox="839 1563 1015 1648">Bulb 316 SS/ capillary 304 SS</td> <td data-bbox="1031 1563 1126 1592">316 SS</td> </tr> <tr> <td data-bbox="440 1682 587 1733">End connection</td> <td data-bbox="632 1682 823 1711">½ inch NPT (F)</td> <td data-bbox="839 1682 1015 1733">½ inch NPT (F)</td> <td data-bbox="1031 1682 1302 1711">Manufacturer standard</td> </tr> <tr> <td data-bbox="440 1765 587 1850">Over range proof pressure</td> <td colspan="2" data-bbox="632 1765 823 1823">150% of max. design pr.</td> <td data-bbox="1031 1765 1401 1794">150% of max. design pressure</td> </tr> </tbody> </table>				FEATURES	ESSENTIAL / MINIMUM REQUIREMENTS				Pressure/ Draft Switches/ Switches	Temperature DP switches	Level switches	Sensing Element	Piston actuated for high pressure and liquid diaphragm or bellows for low pr./ vacuum	Vapor high pressure sensing, liquid filled bellow type with SS bulb and capillary (10 m minimum)	Capacitance types for oil and dirty medium, water, condensate application. Float type switches for applications as decided by Employer during detailed engineering. Capacitance/ Conductivity/ Ultrasonic type for acid and alkali application. Radio-frequency/ Ultrasonic type for ash hopper, ash slurry application.	Material	316 SS	Bulb 316 SS/ capillary 304 SS	316 SS	End connection	½ inch NPT (F)	½ inch NPT (F)	Manufacturer standard	Over range proof pressure	150% of max. design pr.	
FEATURES	ESSENTIAL / MINIMUM REQUIREMENTS																										
	Pressure/ Draft Switches/ Switches	Temperature DP switches	Level switches																								
Sensing Element	Piston actuated for high pressure and liquid diaphragm or bellows for low pr./ vacuum	Vapor high pressure sensing, liquid filled bellow type with SS bulb and capillary (10 m minimum)	Capacitance types for oil and dirty medium, water, condensate application. Float type switches for applications as decided by Employer during detailed engineering. Capacitance/ Conductivity/ Ultrasonic type for acid and alkali application. Radio-frequency/ Ultrasonic type for ash hopper, ash slurry application.																								
Material	316 SS	Bulb 316 SS/ capillary 304 SS	316 SS																								
End connection	½ inch NPT (F)	½ inch NPT (F)	Manufacturer standard																								
Over range proof pressure	150% of max. design pr.		150% of max. design pressure																								
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 33 OF 45																								





*Handwritten signature*

08502


CLAUSE NO.	MEASURING INSTRUMENTS (C-03)			एनटीपीसी NTPC
	<p>Repeatability <math>\pm 0.5\%</math> of full range</p> <p>No. of 2 No.+2NC. SPDT snap action dry contact contacts</p> <p>Rating of 60 V DC, 6 VA (or more if required by DDCMIS) contacts</p> <p>Elect. Plug in socket. Connection</p> <p>Set point/ dead band adjustment Provided over full range.</p> <p>Enclosure Weather and dust proof as per IP-55</p> <p>Accessories Siphon, Thermo well of All mounting accessories snubber, 316 SS and chemical packing glands seal, pulsation dampeners as required by process</p> <p>Mounting Suitable for Suitable for rack - enclosure/ mounting or rack direct mounting mounting or direct mounting</p> <p>Power Supply 24 V DC, to be arranged by Contractor except for Ash Level (wherever Switches, where the same shall be as per Contractor's Standard required) practice.</p> <p>Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application.</p>			
SINGRAULI STPP STAGE-III (1X600 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 34 OF 45	




CLAUSE NO.	MEASURING INSTRUMENTS (C-03)				
16.00.00	<b>SPECIFICATIONS FOR PR. GAUGE, D.P. GAUGE, TEMP. GAUGE AND LEVEL GAUGE.</b>				
	<b>Sl. No</b>	<b>FEATURES</b>	<b>ESSENTIAL/MINIMUM REQUIREMENTS</b>		
			Pr. Gauge/ DP Gauge/ Draught gauges	Temperature Gauge	Level Gauge
	1	Sensing Element and material	Bourdon for high pressure, Diaphragm/Bellow for low pr. Of 316 SS	Mercury in steel for below 450°C and inert gas actuated for above 450°C of SS bulb and capillary.	Tempered * toughened Borosilicate gauge glass steel armoured reflex or transparent type.
	2	Body material	Die-cast aluminium	Die-cast aluminium	Forged carbon steel/304 SS
	3	Dial size	150mm	150 mm	Tubular covering entire range
	4	End connection	1/2 inch NPT (M)	3/4" NPT (M)	Process connection as per ASME PTC and drain/vent 15 NB
	5	Accuracy	±1% of span	± 1% of span	± 2%
	6	Scale	Linear, 270° arc graduated in metric units	Linear, 270° arc graduated in °C	Linear vertical
	7	Range selection	Cover 125% of max. of scale	Cover 125% of max. of scale	Cover 125% of max. of scale
	8	Over range test	Test pr. for the assembly shall be 1.5 to the max. Design pr. at 38°C.		
	9	Housing	Weather and dust proof as per IP-55	Weather and dust proof as per IP-55	CS/304 SS leak proof
	10	Zero/span adjustment	Provided	Provided	--
	11	Identification	Engraved with service legend or laminated phenolic name plate		
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 35 OF 45		








CLAUSE NO.	MEASURING INSTRUMENTS (C-03)		
	7. Digital Signal transmission 8. Calibration 9. Error Diagnostic 10. Others	RS 232 Link & to suit connections protocol to DDCMIS Auto & Manual (from Remote) To be provided If analyser provides superimposed HART signal on 4-20 mA DC output, it shall also be connected to PC based station (In Employer's Scope).	
17.02.00	<b>Hydrogen Analyser</b> 1. Output signals: 2. Zero & span Adjustment 3. Ambient temp. 4. Indication 5. Enclosure Type/Material 6. Type of Electronics 7. Digital transmission protocol 8. Calibration 9. Error Diagnostic 10. Repeatability 11. Linearity	Analog 4-20 mA DC Available 50°C Digital Weather & Dust proof (IP 55) Die cast Aluminum/SS Microprocessor based with self diagnostic facility RS 232 Link & to suit connections to Control System Auto & Manual (from Remote) To be provided ± 1% of calibrated span ± 2% of calibrated span	
17.03.00	<b>PH Analyser</b> 1. Type 2. Accuracy 3. Range 4. No. of steams 5. Stability	Cell - flow through < ± 1% of span 0 - 14 pH, programmable Single < 0.001 pH / week	
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 37 OF 45




CLAUSE NO.	MEASURING INSTRUMENTS (C-03)			एनटीपीसी NTPC	
<del>18.00.00</del>	6. Temp. Coefficient / Temp. error	0.001 pH / Deg. C			
	7. Type of electronics	Microprocessor based with self-diagnostic Facility.			
	8. Indication	Digital			
	9. Enclosure	Weather dust proof (IP55) Die cast aluminum.			
	18.00.00	<b>DEW POINT METER</b>			
		Sensor			
		Type	:	Capacitance type with change in output proportional to moisture present.	
		Service	:	Dry Air	
		Range	:	-50 to 0 Degree Centigrade Dew-Point	
Sensor Accuracy		:	Better than +/-0.5^		
Operating Temperature		:	0 to 50 degree C.		
Operating Pressure		:	0-10 Kg./Cm2, suitable for process application.		
Analyser					
Input		:	Change in capacitance from dew point sensor.		
Display		:	Combined enclosure with two three-digit seven segments LED display with decimal point after two digits. LED height shall be 4 inches, clearly legible from a distance of atleast 10 meters.		
Range		:	-50 to 0 Degree Centigrade Dew-Point		
Display Accuracy		:	Better than +/-2 Degree C.		
Mounting	:	Table top/Flush mounting, to be finalised during detailed engineering.			
Power supply	:	240V AC, 50 Hz to be arranged by the contractor.			
Output	:	5-20 mA DC capable of driving a load impedance of 500 ohms minimum.			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 38 OF 45		




CLAUSE NO.	<p style="text-align: center;"><b>MEASURING INSTRUMENTS (C-03)</b></p> <div style="text-align: right; border: 1px solid black; padding: 2px;">  </div>																											
18.00.00	<p>4-20 mA DC Output signal is to be connected to control system in Contractor's Scope (Interconnection cables are to be provided by the Contractor).</p> <p>In case the system is not suitable for Direct online mounting, then all the required sampling system is to be provided by the contractor.</p> <p>All required accessories including cables, sensor holder, desiccant chambers, mounting fixtures etc. are to be supplied by the Contractor within his quoted lumpsum price.</p> <p><b>SOLENOID VALVES</b></p> <p>Solenoid valves shall fulfil the following requirements :</p> <ol style="list-style-type: none"> <li>a. Type 2/3/4 way SS 316/Forged Brass (depending on the application subject to Employer's approval during detailed Engg.)</li> <li>b. Power supply 24 V DC <math>\pm</math> 10%.</li> <li>c. Plug and socket electrical connection.</li> <li>d. Insulation : Class 'H'</li> </ol>																											
20.00.00	<p><b>SG Related Special Instruments</b></p>																											
21.00.00	<p><b>WATER SYSTEM RELATED SPECIAL INSTRUMENTS( DM PLANT, CPU PLANT, PT PLANT, AWRS ETC )</b></p>																											
21.01.00	<p><b>ANALYSER INSTRUMENTS:</b></p> <p><b>Common Requirements</b></p> <table border="0"> <tr> <td style="width: 5%;">1</td> <td style="width: 45%;">Output signals Analog</td> <td style="width: 50%;">4-20 mA DC</td> </tr> <tr> <td>2.</td> <td>Zero &amp; span Adjustment</td> <td>To be provided</td> </tr> <tr> <td>3.</td> <td>Ambient temp.</td> <td>50°C</td> </tr> <tr> <td>4.</td> <td>Indication</td> <td>LCD</td> </tr> <tr> <td>5.</td> <td>Enclosure Type/Material</td> <td>Weather &amp; Dust proof (IP 55) Die cast Aluminium/SS</td> </tr> <tr> <td>6.</td> <td>Type of Electronics</td> <td>Microprocessor based</td> </tr> <tr> <td>7.</td> <td>Calibration</td> <td>Auto &amp; Manual (hand held HART calibrator)</td> </tr> <tr> <td>8.</td> <td>Error Diagnostic</td> <td>To be provided.</td> </tr> <tr> <td>9.</td> <td>Power supply</td> <td>240V AC 50, Hz single phase/ 24 V DC. Power supply is to be arranged by Contractor. In case the Analysers require UPS, then the same shall also be in the scope of Contractor.</td> </tr> </table>	1	Output signals Analog	4-20 mA DC	2.	Zero & span Adjustment	To be provided	3.	Ambient temp.	50°C	4.	Indication	LCD	5.	Enclosure Type/Material	Weather & Dust proof (IP 55) Die cast Aluminium/SS	6.	Type of Electronics	Microprocessor based	7.	Calibration	Auto & Manual (hand held HART calibrator)	8.	Error Diagnostic	To be provided.	9.	Power supply	240V AC 50, Hz single phase/ 24 V DC. Power supply is to be arranged by Contractor. In case the Analysers require UPS, then the same shall also be in the scope of Contractor.
1	Output signals Analog	4-20 mA DC																										
2.	Zero & span Adjustment	To be provided																										
3.	Ambient temp.	50°C																										
4.	Indication	LCD																										
5.	Enclosure Type/Material	Weather & Dust proof (IP 55) Die cast Aluminium/SS																										
6.	Type of Electronics	Microprocessor based																										
7.	Calibration	Auto & Manual (hand held HART calibrator)																										
8.	Error Diagnostic	To be provided.																										
9.	Power supply	240V AC 50, Hz single phase/ 24 V DC. Power supply is to be arranged by Contractor. In case the Analysers require UPS, then the same shall also be in the scope of Contractor.																										
<p style="text-align: center;">SINGRAULI STPP STAGE-III (1X600 MW) EPC PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p style="text-align: center;">SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY &amp; SECONDARY)</p>	<p style="text-align: center;">PAGE 39 OF 45</p>																									




08513

DRAWING NO.	MEASURING INSTRUMENTS (C-03)			
100200	<p><b>TEMPERATURE/ HUMIDITY INDICATOR</b></p> <p>Sensor : RTD for( Pt 100 ) for temperature</p> <p>: Capacitance Type for Humidity (specs for humidity and temperature shall be as mentioned above)</p> <p>Display : Combined enclosure with two three digit seven segments LED display with decimal point after two digits. LED height shall be 4 inches, clearly legible from a distance of at least 10 meters.</p> <p>Range : 0-99.9 Deg C for temperature.</p> <p>: 0-95.0 % for Relative Humidity.</p> <p>Accuracy : Better than +/- 0.5 % for Temperature</p> <p>: Better than +/- 2.5 % for Relative Humidity</p> <p>Mounting : Table Top/ wall mounting.</p> <p>Power supply : 240 V AC, 50 Hz.</p> <p>Output : 4-20 mA signal each for temperature.</p> <p>Qty. : 15 nos. each of temperature &amp; Humidity indicators.</p> <p>One Set of output signal is to be connected to PLC system in Contractor's Scope (Interconnection cables are to be provided by The Contractor). Apart from displaying the temperature/humidity values on indicator.</p>			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-03(A) MEASURING INSTRUMENTS (PRIMARY & SECONDARY)	PAGE 45 OF 45	





08565


CLAUSE NO.	TECHNICAL REQUIREMENTS			एनडीपीसी NTPC
	instrumentation cable shields at same potential. This shall be completed prior to system tests. All the cables etc. required for grounding of all equipments supplied under this package are to be supplied by the Bidder.			
9.07.00	The Contractor shall take full care while laying / installing cables as recommended by cable manufacturers regarding pulling tensions and cable bends. Cables damaged in any way during installation shall be replaced at the expense of the Contractor.			
10.00.00	<p><b>FIELD MOUNTED LOCAL JUNCTION BOXES</b></p> <p>(i) No. of ways 12/24/36/48/64/72/96/128 with 20% spares terminals.</p> <p>(ii) Material and Thickness 4mm thick Fiberglass Reinforced Polyester (FRP).</p> <p>(iii) Type Screwed at all four corners for door. Door gasket shall be of synthetic rubber.</p> <p>(iv) Mounting clamps and accessories Suitable for mounting on walls, columns, structures etc. The brackets, bolts, nuts, screws, glands required for erection shall be of SS, included in Bidders scope of supply.</p> <p>(v) Type of terminal blocks Rail mounted cage-clamp type suitable for conductor size upto 2.5 mm<sup>2</sup>. A M6 earthing stud shall be provided.</p> <p>(vi) Protection Class IP: 55 minimum for indoor &amp; IP-65 minimum for outdoor applications.</p> <p>(vii) Grounding To be provided.</p> <p>(viii) Color To be decided during detailed engineering &amp; subject to Employer's approval.</p>			
11.00.00	<b>CONDUITS</b>			
11.01.00	<p>Conduits shall be generally used for interconnecting cables from field instruments to Local JB's. All rigid conduits, couplings and elbows shall be hot dipped galvanised rigid mild steel in accordance with IS: 9537 Part-I (1980) and Part-II (1981). The conduit interior and exterior surfaces shall have continuous zinc coating with an overcoat of transparent enamel lacker or zinc chromate. Flexible conduit shall be heat resistant lead coated steel, water leak, fire and rust proof for the following areas:-</p> <p>(i) Mills,</p> <p>(ii) Drum,</p> <p>(iii) Main Steam, RH steam</p>			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-06 INSTRUMENTATION POWER SUPPLY CABLE	PAGE 15 OF 17	




08566

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	(iv) Air Heaters (v) Furnace, BFPDT's <i>And for remaining applications, water leak, fire and rust proof flexible GI conduits shall be provided. The temperature rating of flexible conduit shall be suitable for actual application.</i>			
11.02.00	The Bidder shall install conduits according to the general routing as approved by Employer and shall coordinate conduit locations with other works.			
11.03.00	All grounding bushings within all enclosures shall be wired together and connected internally to the enclosure grounding lug or grounding bus with 8 AWG bare copper conductor. Conduit runs to individually mounted equipment shall be grounded to the Employer's cable tray grounding conductor with 12 AEG bare copper conductor. All grounding bushings, clamps and connectors shall be subject to approval of the Employer.			
11.04.00	All rigid conduit fittings shall conform to the requirements of IS: 2667, 1976. Galvanized steel fitting shall be used with steel conduit. All flexible conduit fittings shall be liquid tight, galvanized steel. The end fittings shall be compatible with the flexible conduit supplied.			
11.05.00	All individually mounted equipment and devices shall be connected to the supply conduit, using not more than one metre of flexible conduit adjacent to the equipment or device. Flexible conduit shall be installed in all conduit runs, which are supported by both building steel and structures subject to vibration or thermal expansion. This shall include locations where conduit supported by building steel enters or becomes supported by the turbine generator foundation and where conduit supported by building steel or foundation becomes supported by steam generator framing.			
11.06.00	Special areas, such as control rooms in which external noise is to be minimized, shall have flexible conduit in conduit runs where the runs cross from the main building framing to the control room framing.			
11.07.00	Conduit supports shall be furnished and installed in accordance with these specifications. Support material shall comply with the following requirements.  i) Hanger rods shall be 12 mm diameter galvanized threaded steel rods.  ii) Single conduit supports shall be one-hole cast metal straps and clamp backs unless other types are acceptable to the Employer. Multiple conduit bank supports shall be constructed of special galvanized support channels with associated conduit clips.			
11.08.00	Conduit sealing, explosion proof, dust proof and other types of special fittings shall be provided as required by these specifications and shall be consistent with the area and equipment with which they are installed. Fittings installed outdoors and in damp locations shall be sealed and gasketed. Hazardous area fittings and conduits sealing shall conform with NEC requirements for the area classification.			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-06 INSTRUMENTATION POWER SUPPLY CABLE	PAGE 16 OF 17	





S.No.	TECHNICAL REQUIREMENTS		
11.00	Contractor shall provide double locknuts on all conduit terminations not provided with threaded hubs and couplings. Water tight conduit unions and rain tight conduit hubs shall be utilised for all the application which shall be exposed to weather. Moisture pockets shall be eliminated from conduits.		
11.10.00	Conduits shall be securely fastened to all boxes and cabinets.		
12.00.00	<b>CABLE SUB-TRAY &amp; SUPPORT</b>		
12.01.00	The cable sub-trays and the supporting system, to be generally used between Local/Group JB's and the main cable trays and the same shall be furnished and installed by the Contractor. It is the assembly of sections and associated fittings forming a rigid structural system used to support the cable from the equipment or instrument enclosure upto the main cable trays (trunk route).		
12.02.00	The covers on the cable sub-trays shall be used for protection of cables in areas where damage may occur from falling objects, welding spark, corrosive environment, etc. & shall be electrically continuous and solidly grounded. The cable trays shall not have sharp edges, burrs or projections injurious to the insulation or outer sheath of the cables.		
12.03.00	The supporting arrangement of cable tray system shall be able to withstand the weight of the cable and cable tray system. The supporting interval shall not be more than the recommended span for the above loading for the type of cable tray selected. The tray shall not overhang by more than one meter from the support at the dead end. As far as practicable the cable sub-tray system shall be supported from one side only, in order to facilitate installation and maintenance of cables.		
12.04.00	The Bidder shall furnish and install the estimated quantities and sizes of sub trays/troughs including all required fittings and adaptors on as required basis.		
13.00.00	<p><b>CONTRACT QUANTITIES</b></p> <p>Refer appendix-I to Part-A for quantities of cables (Employer Supplied), sub trays and conduits.</p>		
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-06 INSTRUMENTATION POWER SUPPLY CABLE	PAGE 17 OF 17




# **CABLING PHILOSOPHY**


08559

CLAUSE NO.	TECHNICAL REQUIREMENTS																																										
<p>0.00.00</p>	<p><b>INSTRUMENTATION CABLE INTERCONNECTION AND TERMINATION PHILOSOPHY</b></p> <p>The cable interconnection philosophy to be adopted shall be such that extensive grouping of signals by large scale use of field mounted Group Junction Boxes (JBs) at strategic locations (where large concentration of signals are available, e.g. valves limit &amp; torque switches, switchgear) is done and consequently cable with higher number of pairs are extensively used. The details of termination to be followed are mentioned in the given Table A.</p> <p style="text-align: center;"><b>TABLE A: CABLE TERMINATION TO BE FOLLOWED</b></p> <table border="1" data-bbox="443 846 1321 1724"> <thead> <tr> <th colspan="2" data-bbox="443 846 890 902">Application</th> <th colspan="2" data-bbox="890 846 1217 902">Type Of Termination</th> <th data-bbox="1217 846 1321 958" rowspan="2">Type Of Cable</th> </tr> <tr> <th data-bbox="443 902 667 958">FROM (A)</th> <th data-bbox="667 902 890 958">TO (B)</th> <th data-bbox="890 902 1074 958">END A</th> <th data-bbox="1074 902 1217 958">END B</th> </tr> </thead> <tbody> <tr> <td data-bbox="443 958 667 1115">Valves/dampers drives (Integral Junction box)</td> <td data-bbox="667 958 890 1115">Marshalling / Marshalling – cum Termination Cubicle / local group JB</td> <td data-bbox="890 958 1074 1115">Plug in connector</td> <td data-bbox="1074 958 1217 1115">Post mount cage clamp type.</td> <td data-bbox="1217 958 1321 1115">G</td> </tr> <tr> <td data-bbox="443 1115 667 1238">Transmitters, Process Actuated switches mounted in LIE/LIR</td> <td data-bbox="667 1115 890 1238">Integral Junction box of LIE/LIR</td> <td data-bbox="890 1115 1074 1238">Plug in connector</td> <td data-bbox="1074 1115 1217 1238">Cage clamp (Rail mount) type.</td> <td data-bbox="1217 1115 1321 1238">F,G</td> </tr> <tr> <td data-bbox="443 1238 667 1373">RTD heads</td> <td data-bbox="667 1238 890 1373">Local junction box</td> <td data-bbox="890 1238 1074 1373">Plug in connector</td> <td data-bbox="1074 1238 1217 1373">Cage clamp (Rail mount) type.</td> <td data-bbox="1217 1238 1321 1373">F</td> </tr> <tr> <td data-bbox="443 1373 667 1507">Thermocouple</td> <td data-bbox="667 1373 890 1507">Local junction box / CJC box (if applicable)</td> <td data-bbox="890 1373 1074 1507">Plug in connector</td> <td data-bbox="1074 1373 1217 1507">Cage clamp (Rail mount) type.</td> <td data-bbox="1217 1373 1321 1507">A, B, C*</td> </tr> <tr> <td data-bbox="443 1507 667 1630">Other Field mounted Instrument</td> <td data-bbox="667 1507 890 1630">Local JB / Group JB</td> <td data-bbox="890 1507 1074 1630">Plug in connector</td> <td data-bbox="1074 1507 1217 1630">Cage clamp (Rail mount) type.</td> <td data-bbox="1217 1507 1321 1630">F,G</td> </tr> <tr> <td data-bbox="443 1630 667 1724">RTD</td> <td data-bbox="667 1630 890 1724">Temperature transmitter</td> <td data-bbox="890 1630 1074 1724">Plug in connector</td> <td data-bbox="1074 1630 1217 1724">Screwed, Cage clamp type</td> <td data-bbox="1217 1630 1321 1724">F</td> </tr> </tbody> </table>				Application		Type Of Termination		Type Of Cable	FROM (A)	TO (B)	END A	END B	Valves/dampers drives (Integral Junction box)	Marshalling / Marshalling – cum Termination Cubicle / local group JB	Plug in connector	Post mount cage clamp type.	G	Transmitters, Process Actuated switches mounted in LIE/LIR	Integral Junction box of LIE/LIR	Plug in connector	Cage clamp (Rail mount) type.	F,G	RTD heads	Local junction box	Plug in connector	Cage clamp (Rail mount) type.	F	Thermocouple	Local junction box / CJC box (if applicable)	Plug in connector	Cage clamp (Rail mount) type.	A, B, C*	Other Field mounted Instrument	Local JB / Group JB	Plug in connector	Cage clamp (Rail mount) type.	F,G	RTD	Temperature transmitter	Plug in connector	Screwed, Cage clamp type	F
Application		Type Of Termination		Type Of Cable																																							
FROM (A)	TO (B)	END A	END B																																								
Valves/dampers drives (Integral Junction box)	Marshalling / Marshalling – cum Termination Cubicle / local group JB	Plug in connector	Post mount cage clamp type.	G																																							
Transmitters, Process Actuated switches mounted in LIE/LIR	Integral Junction box of LIE/LIR	Plug in connector	Cage clamp (Rail mount) type.	F,G																																							
RTD heads	Local junction box	Plug in connector	Cage clamp (Rail mount) type.	F																																							
Thermocouple	Local junction box / CJC box (if applicable)	Plug in connector	Cage clamp (Rail mount) type.	A, B, C*																																							
Other Field mounted Instrument	Local JB / Group JB	Plug in connector	Cage clamp (Rail mount) type.	F,G																																							
RTD	Temperature transmitter	Plug in connector	Screwed, Cage clamp type	F																																							
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-C-06 INSTRUMENTATION POWER SUPPLY CABLE</p>	<p>PAGE 9 OF 17</p>																																								




08560

CLAUSE NO.	TECHNICAL REQUIREMENTS				
	Application		Type Of Termination		
	FROM (A)	TO (B)	END A	END B	
	Thermocouple	Temperature transmitter	Plug in connector	Screwed, Cage clamp type	A, B, C*
	Local Junction box, Temperature Transmitter, Int. Junction box of LIE/ LIR/ MCC/SWGR	Group JB	Cage clamp (Rail mount) type.	Cage clamp (Rail mount) type.	F,G
	Local Junction box, Temperature Transmitter, Int. Junction box of LIE/ LIR/ Group JB / MCC/SWGR	Marshalling / Marshalling – cum Termination Cubicle	Cage clamp (Rail mount) type.	Cage clamp (Post mounted) type.	F,G
	Marshalling cubicle/ Termination Cabinet	Electronic system cabinet	Cage clamp (Post mounted) type.	Plug-in connector / other system as per Mfr.'s Standard	Internal wiring
	Marshalling/ Termination System Cabinets	UCD mounted equipments	Cage clamp (Post mounted) type.	Plug in connector / Cage clamp type (rail mounted).	F,G (with plug-in connect or at one end)
	DDCMIS/PLC cabinets	PC, Printers etc.	Plug in connector	Plug in connector	Mfr.'s Standard
<p>Notes</p> <ol style="list-style-type: none"> <li>Normally 10% spare cores shall be provided when the numbers of pairs of cables are more than four pairs, except for pre-fabricated cables which shall be as per manufacturer's standard.</li> <li>For analog signals, individual pair shielding &amp; overall shielding &amp; for Binary signals, only overall shielding of instrumentation cables shall be provided.</li> <li>Also refer drg. X-405-POI-A-021.</li> <li>*For high temperature applications only.</li> </ol>					
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE		TECHNICAL SPECIFICATION SECTION - VI PART-B		SUB-SECTION-C-06 INSTRUMENTATION POWER SUPPLY CABLE	PAGE 10 OF 17



08561


CLAUSE NO.	TECHNICAL REQUIREMENTS		
6.00.00	<b>TERMINAL BLOCKS</b>		
6.01.00	All terminal blocks shall be rail mounted/post mounted, cage clamp type with high quality non-flammable insulating material of melamine suitable for working temperature of 105 deg. C. The terminal blocks in field mounted junction boxes, temperature transmitters, instrument enclosures/racks, etc., shall be suitable for cage clamp connections. The terminal blocks in Control Equipment Room logic/termination/marshalling cubicles shall be suitable for post mounted cage clamp connection at the field input end. The terminal blocks for DDCMIS input/output connections from/to SWGR/MCC, Actuators with Integral Starter (for coupling relays and check back signals of 11 kV and 3.3 kV auxiliaries, LT drives/valves & dampers/solenoids, CT & VT, etc.) shall be provided with built in test and disconnect facilities complete with plug, slide clamp, test socket etc. The exact type of terminal blocks to be provided by the Bidder and the technical details of the same including width etc. shall be subject to Employer's approval.		
6.02.00	All the terminal blocks shall be provided complete with all required accessories including assembly rail, locking pin and section, end brackets, partitions, small partitions, test plug bolts and test plug (as specified above for SWGR connections) transparent covers, support brackets, distance sleeves, warning label, marking, etc.		
6.03.00	The marking on terminal strips shall correspond to the terminal numbering on wiring diagrams. At least 20% spare unused terminals shall be provided everywhere including local junction boxes, instrument racks/enclosures, termination/marshalling cabinets, etc. All terminal blocks shall be numbered for identification and grouped according to the function. Engraved labels shall be provided on the terminal blocks.		
6.04.00	For terminating each process actuated switches, drive actuators, control valves, Thermocouple,RTD, etc. in Local Junction Boxes, etc, refer Drg no. 0000-999-POI-A-065.		
6.05.00	The terminal blocks shall be arranged with at least 100 mm clearance between two sets of terminal blocks and between terminal blocks and junction box walls.		
6.06.00	For ensuring proper connections, Bidder shall provide suitable accessories, along with insulation sleeves. The exact connecting accessory shall be finalised as per application during detail engineering stage subject to Employer's approval without any cost repercussions.		
6.07.00	Internal wiring in factory pre-wired electronic equipment cabinets may be installed according to the Bidder's standard as to wire size and method of termination or internal equipment. Terminal blocks for connection of external circuits into factory prewired electronic equipment cabinets shall meet all the requirements as specified above.		
7.00.00	<b>INTERNAL PANELS/ SYSTEM CABINETS WIRING</b>		
7.01.00	Internal panel/cabinet wiring shall be of multi-stranded copper conductor with FRLS PVC insulation <del>without shield</del> and outer sheath meeting the requirements of VDE 0815.		
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-C-06 INSTRUMENTATION POWER SUPPLY CABLE	PAGE 11 OF 17




-08269

# ELECTRICAL ACTUATORS WITH INTEGRAL STARTERS




CLAUSE NO.	TECHNICAL REQUIREMENTS	
<p>1.00.00</p> <p>1.01.00</p> <p>1.01.01</p> <p>1.01.02</p> <p>1.02.00</p> <p>1.02.01</p> <p>1.03.00</p>	<div style="text-align: right; margin-bottom: 10px;"><b>08270</b></div> <p><b>ELECTRIC ACTUATORS WITH INTEGRAL STARTERS</b></p> <p><b>TYPE:</b></p> <p>The actuators shall have integral starters along with over load relays with built in SPP (Single Phasing Preventer). A 415, 3 phase 3 wire power supply shall be given to the actuator from vendor's/employer's switch board as applicable through a switch fuse unit. Control voltage of the motor starter shall be 110 V AC / 24 V DC, derived suitably from 415V power supply.</p> <p>In case supplier's standard control voltage for Open/Close contactors is 110V AC, the same is acceptable if suitable Opto Isolation circuit is provided with coupling relays for 24 V DC command inputs.</p> <p><b>INTERFACES:</b></p> <p>Open/Close command termination logic with position &amp; torque Limit Switches, positioner circuit shall be suitably built in the PCB inside the actuator.</p> <p>(a) For Binary Drive (both ON-OFF and INCHING type) :- Open/Close command &amp; status thereof and disturbance monitoring signal (common contact for Overload, Thermostat, control supply failure, L/R selector switch at local &amp; other protections operated) shall be provided.</p> <p>Interface with the control system shall be through hardware signal only. Interposing relays provided (with coil burden 2.5 VA) in the actuator shall be energized to initiate opening and closing, by 24V DC signal from the external control system.</p> <p>(b) For Modulating Drive:- the command to actuator shall be in form of 4-20mA signal. The necessary positioning circuit and motor protection shall be provided</p> <p>(c) Open/close command termination logic shall be suitably built inside actuator.</p> <p><b>RATING :</b></p> <p>(a) Supply Voltage &amp; frequency: 415V +/- 10%, 3 Phase, 3 Wire 50HZ +/-5%.</p> <p>(b) Sizing:-</p> <p>For Open/Close at rated speed against designed differential pressure at 90% of rated voltage.</p> <p>For isolating service:- three successive open-close operations or 15 mins, whichever is higher. For regulating service 150 starts per hour or required cycles, whichever is higher.</p>	
<p>SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>SUB-SECTION-B-30 ELECTRICAL ACTUATORS WITH INTEGRAL STATORS</p> <div style="text-align: right;">  </div>


CLAUSE NO.	TECHNICAL REQUIREMENTS			
1.04.00	<b>CONSTRUCTION:</b> 08271 (a) Enclosure: Totally enclosed weatherproof minimum IP-55 degree of protection. (b) Gear Train : Metal (Fibre gears are not acceptable) self-locking to prevent drift under torque switch (where ever applicable) spring pressure when motor is de-energised. (c) Manual Wheel: Shall disengage automatically during motor operation.			
1.05.00	<b>MOTOR :</b> (a) Type : Squirrel cage induction motor suitable for Direct On Line ( DOL )starting. (b) Enclosure: Totally enclosed, self ventilated IP-55 degree of protection. (c) Insulation Class B or better. Temperature rise 70 Deg C. over 50 Deg C ambient (d) Bearings: Double shielded, grease lubricated antifriction. (e) Earth Terminals: Two (f) Protection: Single Phasing Protection, Over heating protection through Thermostat and wrong phase sequence protection shall be provided over and above other protection features standard to bidder's design Suitable means shall be provided to diagnose the type of fault locally.			
1.06.00	<b>POSITION/TORQUE SWITCHES:</b>			
1.06.01	Four nos. (2 each in open and close position) position limit switches and two nos. (one in open and other in close direction) torque switches each having two nos. NO			
	SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION - VI PART-B	SUB-SECTION-B-30 ELECTRICAL ACTUATORS WITH INTEGRAL STATERS	PAGE 2 OF 4



	<p>and two nos. NC contacts shall be provided. A single shaft shall actuate all contacts of limit switches at each position.</p> <p>Limit switch and disturbance signals shall be available to DCS even when the power supply to the actuators is not available.</p> <p>Torque switches shall be bypassed in both the end positions with the other end Limit switches.</p> <p><b>Limit switches</b></p> <p>Limit switches shall be Silver plated with high conductivity and non –corrosive type. Contact rating shall be sufficient to meet the requirement of Control System subject to a minimum of 60 V, 6 VA rating. Protection class shall be IP-55.</p>
1.07.00	<b>LOCAL OPERATION:</b>
1.07.01	It shall be possible to operate the actuator locally also. Lockable local/remote selection shall be provided on the actuator.
1.08.00	<b>POSITION INDICATOR :</b>
1.08.01	To be provided for 0 to 100% travel.
1.09.00	<b>POSITION TRANSMITTER (FOR MODULATING/INCHING TYPE) :</b>
1.09.01	As required. Suitable for stabilized 4-20 mA signal, 2 wire inductive type, 24 volts DC operated.
1.10.00	<b>WIRING :</b>
1.10.01	Suitable voltage grade copper wire.
1.11.00	<b>TERMINAL BOX :</b>
	<ul style="list-style-type: none"> <li>(i) 9 pin plug and socket (1 no. per actuator to suit 4 pair 0.5 sq.mm. copper overall shielded (16 mm OD), instrumentation cable) suitably mounted in the starter box itself to terminate open/close command and status feedback signals with external control systems.</li> <li>(ii) Additional one number 9 pin plug and socket (to suit 4 pair 0.5 sq.mm copper (16 mm OD) individual and overall shielded instrumentation cable) suitably mounted in the starter box itself for actuators with 4-20 mA position transmitters.</li> <li>(iii) Necessary glands for power cables shall be provided.</li> </ul>




CLAUSE NO.	08273 TECHNICAL REQUIREMENTS			एनटीपीसी NTPC
1.12.00	<b>TERMINAL BLOCK :</b>			
1.12.01	650V grade. For power cables.			
1.13.00	<b>SPACE HEATER :</b>			
1.13.01	Space heater of suitable rating. The supply shall be derived from the main power supply available in the actuator.			
1.14.00	<b>TYPICAL WIRING DIAGRAM :</b>			
1.14.01	Refer Tender Drawing No. 0000-999-POI-A-063.			
SINGRAULI STPP STAGE-III (1X500 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION -VI PART-B	SUB-SECTION-B-30 ELECTRICAL ACTUATORS WITH INTEGRAL STATERS	PAGE 4 OF 4	




CLAUSE NO.	TECHNICAL REQUIREMENTS		
	<p><b>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</b></p>		
	<p>TECHNICAL SPECIFICATION SECTION - VI PART-B</p>	<p>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</p>	<p>PAGE 1 OF 7</p>



CLAUSE NO.	<b>TECHNICAL REQUIREMENTS</b> 		
	<b>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</b>		
1.00.00	<b>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</b>		
1.01.00	<b>General Requirements</b>		
1.01.01	<p>The control valves and accessories equipment furnished by the Bidder shall be designed, constructed and tested in accordance with the latest applicable requirements of code for pressure piping ANSI B 31.1, the ASME Boiler &amp; pressure vessel code, Indian Boiler Regulation (IBR), ISA, and other standards specified elsewhere as well as in accordance with all applicable requirements of the “Federal Occupational Safety and Health Standards, USA” or acceptable equal standards. All the Control Valves, their actuators and accessories to be furnished under this Sub-section will be fully suitable and compatible with the modulating loops covered under the Specification.</p>		
1.01.02	<p>All the control valves and accessories offered by the Bidder shall be from reputed, experienced manufacturers of specified type and range of valves.</p>		
1.01.03	<p>For control valve such as pressure and temperature control valve for Aux PRDS applications, Separator Drain Control Valves etc., also refer to the corresponding mechanical section in addition to requirements stipulated in this subsection.</p>		
1.02.00	<b>CONTROL VALVE SIZING &amp; CONSTRUCTION</b>		
1.02.01	<p>The design of all valve bodies shall meet the specification requirements and shall conform to the requirements of ANSI (USA) for dimensions, material thickness and material specification for their respective pressure classes.</p>		
1.02.02	<p>The valve sizing shall be suitable for obtaining maximum flow conditions with valve opening at approximately 80% of total valve stem travel and minimum flow conditions with valve stem travel not less than 10% of total valve stem travel. All the valves shall be capable of handling at least 120% of the required maximum flow. Further, the valve stem travel range from minimum flow condition to maximum flow condition shall not be less than 50% of the total valve stem travel. The sizing shall be in accordance with the latest edition of ISA handbook on control valves. While deciding the size of valves, Bidder shall ensure that valves trim exit outlet velocity as defined in ISA handbook does not exceed 8 m/sec for liquid services, 150 m/sec. for steam services and 50% of sonic velocity for flashing services. Bidder shall furnish the sizing calculations clearly indicating the outlet velocity achieved with the valve size selected by him as well as noise calculations, which will be subject to Employer’s approval during detailed engineering.</p>		
1.02.03	<p>Control valves for steam and water applications shall be designed to prevent cavitation, wire drawing, flashing on the downstream side of valve and down stream piping. Thus for cavitation/flashing service, only valve with anti cavitation trim shall be provided. Detailed calculations to establish whether cavitation will occur or not for any given application shall be furnished.</p>		
1.02.04	<p>Control valves for application such as SH Spray Control, RH spray Control, Heavy Oil Heating, pressurizing and Control system shall have permissible leakage rate as per leakage Class V. All other control valves shall have leakage rate as per leakage Class-IV.</p>		
1.02.05	<p>The control valve induced noise shall be limited to 85 dBA at 1 meter from the valve surface under actual operating conditions. The noise abatement shall be achieved by valve body and trim design and not by use of silencers.</p>		
	<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</b>	<b>PAGE 2 OF 7</b>


CLAUSE NO.	TECHNICAL REQUIREMENTS			एनटीपीसी NTPC																			
<p><b>2.00.00</b></p> <p>2.01.00</p> <p>2.02.00</p> <p>2.03.00</p> <p>2.04.00</p> <p>2.05.00</p> <p>2.06.00</p> <p>2.07.00</p> <p>2.08.00</p> <p>2.09.00</p>	<p><b>VALVE CONSTRUCTION</b></p> <p>All valves shall be of globe body design &amp; straightaway pattern with single or double port, unless other wise specified or recommended by the manufacturer to be of angle body type. Rotary valve may alternatively be offered when pressure and pressure drops permit.</p> <p>Valves with high lift cage guided plugs &amp; quick-change trims shall be supplied.</p> <p>Cast Iron valves are not acceptable.</p> <p>Bonnet joints for all control valves shall be of the flanged and bolted type or other construction acceptable to the Employer. Bonnet joints of the internal threaded or union type will not be acceptable.</p> <p>Plug shall be of one-piece construction cast, forged or machined from solid bar stock. Plug shall be screwed and pinned to valve stems or shall be integral with the valve stems.</p> <p>All valves connected to vacuum on down stream side shall be provided with packing suitable for vacuum applications (e.g. double vee type chevron packing)</p> <p>Valve characteristic shall match with the process characteristics.</p> <p>Extension bonnets shall be provided when the maximum temperature of flowing fluid is greater than 280 deg. C.</p> <p>Flanged valves shall be rated at no less then ANSI press class of 300 lbs.</p>																						
<p><b>3.00.00</b></p>	<p><b>VALVE MATERIALS</b></p> <table border="1" data-bbox="391 911 1406 1520"> <thead> <tr> <th data-bbox="391 911 456 968">Sr. No.</th> <th data-bbox="472 911 651 936">Service</th> <th data-bbox="667 911 1040 936">Body material</th> <th data-bbox="1057 911 1406 936">Trim Material</th> </tr> </thead> <tbody> <tr> <td data-bbox="391 999 415 1024">1</td> <td data-bbox="472 999 651 1167">Non-corrosive, non-flashing and non-cavitation service except DM water</td> <td data-bbox="667 999 1040 1199">Carbon steel ASTM-A216 Gr. WCB for fluid temperature below 275 Deg. C Alloy steel ASTM-A217Gr. WC9 for fluid temperature above 275 Deg. C</td> <td data-bbox="1057 999 1406 1083">316SS stellite with stellite faced guide posts and bushings.</td> </tr> <tr> <td data-bbox="391 1230 415 1255">2.</td> <td data-bbox="472 1230 651 1314">Severe flashing/cavitation services</td> <td data-bbox="667 1230 1040 1255">Alloy steel ASTM-A217 Gr. WC9</td> <td data-bbox="1057 1230 1406 1255">440 C</td> </tr> <tr> <td data-bbox="391 1346 415 1371">3.</td> <td data-bbox="472 1346 651 1430">Low flashing/cavitation on service</td> <td data-bbox="667 1346 1040 1371">Alloy steel ASTM-A217 Gr. WC6</td> <td data-bbox="1057 1346 1406 1371">17-4 PH SS</td> </tr> <tr> <td data-bbox="391 1461 415 1486">4.</td> <td data-bbox="472 1461 651 1514">DM water service</td> <td data-bbox="667 1461 1040 1486">316 SS</td> <td data-bbox="1057 1461 1406 1486">316 SS</td> </tr> </tbody> </table> <p>NOTE Valve body rating shall meet the process pressure and temperature requirement as per ANSI B16.34.</p> <p>However, Bidder may offer valves with body and trim materials better than specified materials and in such cases Bidder shall furnish the comparison of properties including cavitation resistance, hardness, tensile strength, strain energy, corrosion resistance and erosion resistance etc. of the offered material vis-a-vis the specified material for Employer's consideration and approval.</p>			Sr. No.	Service	Body material	Trim Material	1	Non-corrosive, non-flashing and non-cavitation service except DM water	Carbon steel ASTM-A216 Gr. WCB for fluid temperature below 275 Deg. C Alloy steel ASTM-A217Gr. WC9 for fluid temperature above 275 Deg. C	316SS stellite with stellite faced guide posts and bushings.	2.	Severe flashing/cavitation services	Alloy steel ASTM-A217 Gr. WC9	440 C	3.	Low flashing/cavitation on service	Alloy steel ASTM-A217 Gr. WC6	17-4 PH SS	4.	DM water service	316 SS	316 SS
Sr. No.	Service	Body material	Trim Material																				
1	Non-corrosive, non-flashing and non-cavitation service except DM water	Carbon steel ASTM-A216 Gr. WCB for fluid temperature below 275 Deg. C Alloy steel ASTM-A217Gr. WC9 for fluid temperature above 275 Deg. C	316SS stellite with stellite faced guide posts and bushings.																				
2.	Severe flashing/cavitation services	Alloy steel ASTM-A217 Gr. WC9	440 C																				
3.	Low flashing/cavitation on service	Alloy steel ASTM-A217 Gr. WC6	17-4 PH SS																				
4.	DM water service	316 SS	316 SS																				
	<p><b>TECHNICAL SPECIFICATION</b></p> <p><b>SECTION - VI</b></p> <p><b>PART-B</b></p>	<p><b>CONTROL VALVES,</b></p> <p><b>ACTUATORS &amp;</b></p> <p><b>ACCESSORIES</b></p>	<p><b>PAGE 3 OF 7</b></p>																				

CLAUSE NO.	<b>TECHNICAL REQUIREMENTS</b> 																		
<b>4.00.00</b>	<b>END PREPARATION</b> Valve body ends shall be either butt welded/socket welded, flanged (Rubber lined for condensate service) or screwed as finalized during detailed engineering and as per Employer's approval. The welded ends wherever required shall be butt welded type as per ANSI B 16.25 for control valves of sizes 65 mm and above. For valves size 50 mm and below welded ends shall be socket welded as per ANSI B 16.11. Flanged ends wherever required shall be of ANSI pressure-temperature class equal to or greater than that of the control valve body.																		
<b>5.00.00</b>	<b>VALVE ACTUATORS</b> All control valves shall be furnished with pneumatic actuators except for pressure and temperature control valve for auxiliary PRDS application (electro-hydraulic / pneumatically operated) and separator drain control valve (electro-hydraulic type). The Bidder shall be responsible for proper selection and sizing of valve actuators in accordance with the pressure drop and maximum shut off pressure and leakage class requirements. The valve actuators shall be capable of operating at 60 deg.C continuously.  Valve actuators and stems shall be adequate to handle the unbalanced forces occurring under the specified flow conditions or the maximum differential pressure specified. An adequate allowance for stem force, at least 0.15 Kg/sq.cm. per linear millimeter of seating surface, shall be provided in the selection of the actuator to ensure tight seating unless otherwise specified.  The travel time of the pneumatic actuators shall not exceed 10 seconds.																		
<b>6.00.00</b>	<b>CONTROL VALVE ACCESSORY DEVICES</b>																		
6.01.00	All pneumatic actuated control valve accessories such as air locks, hand wheels/hand-jacks, limit switches, microprocessor based electronic Positioner, diffusers, external volume chambers, position transmitters (capacitance or resistance type only), reversible pilot for Positioner, tubing and air sets, solenoid valves and junction boxes etc. shall be provided as per the requirements.																		
<b>7.00.00</b>	<b>SPECIFICATIONS FOR MICROPROCESSOR BASED ELECTRONIC POSITIONER</b>  <table border="1" data-bbox="397 1270 1409 1774"> <tbody> <tr> <td data-bbox="397 1270 467 1654" rowspan="4">1</td> <td data-bbox="467 1270 667 1654" rowspan="4">Electrical</td> <td data-bbox="667 1270 915 1360">a) Input Demand Signal</td> <td data-bbox="915 1270 1409 1360">4-20 mA</td> </tr> <tr> <td data-bbox="667 1360 915 1451">b) Power Supply</td> <td data-bbox="915 1360 1409 1451">Loop Powered from the output card of Control System.</td> </tr> <tr> <td data-bbox="667 1451 915 1570">c) HART Protocol</td> <td data-bbox="915 1451 1409 1570">Compatibility for Remote Calibration &amp; Diagnostics (Super-imposed HART signal on input Signal (4-20 mA))</td> </tr> <tr> <td data-bbox="667 1570 915 1654">d. Valve position sensing</td> <td data-bbox="915 1570 1409 1654">Position sensing, 4-20 mA output signal to be provided for control system.</td> </tr> <tr> <td data-bbox="397 1654 467 1774" rowspan="2">2</td> <td data-bbox="467 1654 667 1774" rowspan="2">Environment</td> <td data-bbox="667 1654 915 1717">a) Operating temp.</td> <td data-bbox="915 1654 1409 1717">(-)30 To 80 Deg. C</td> </tr> <tr> <td data-bbox="667 1717 915 1774">b) Humidity</td> <td data-bbox="915 1717 1409 1774">0-95 %</td> </tr> </tbody> </table>			1	Electrical	a) Input Demand Signal	4-20 mA	b) Power Supply	Loop Powered from the output card of Control System.	c) HART Protocol	Compatibility for Remote Calibration & Diagnostics (Super-imposed HART signal on input Signal (4-20 mA))	d. Valve position sensing	Position sensing, 4-20 mA output signal to be provided for control system.	2	Environment	a) Operating temp.	(-)30 To 80 Deg. C	b) Humidity	0-95 %
1	Electrical	a) Input Demand Signal	4-20 mA																
		b) Power Supply	Loop Powered from the output card of Control System.																
		c) HART Protocol	Compatibility for Remote Calibration & Diagnostics (Super-imposed HART signal on input Signal (4-20 mA))																
		d. Valve position sensing	Position sensing, 4-20 mA output signal to be provided for control system.																
2	Environment	a) Operating temp.	(-)30 To 80 Deg. C																
		b) Humidity	0-95 %																
		<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</b>	<b>PAGE 4 OF 7</b>															


CLAUSE NO.	TECHNICAL REQUIREMENTS			एनटीपीसी NTPC
		c) Protection class	IP-65 Minimum	
	3	Software for Configuration and Diagnostics	Software	Windows based software. Software shall meet the requirements for Configuration, Diagnostics, Calibration and Testing of the actuator.
		Diagnostic/Test features		Advanced diagnostic features like Stroke counter or Travel counter, Leakage in actuators, Valve Signature analysis, Step Response test, Valve friction /Jamming detection etc to be provided.
	4	Test reports/ Certificates	Factory Valve Signature Tests Reports (Pr Vs Valve travel and Travel Vs I/P signal) are to be provided.	
			Test certificates as per Manufacture Standard/Relevant Standard are to be submitted.	
	5	Configuration/ Calibration.	Remote & Local Calibration, Auto & Manual Calibration shall be possible.	
	6	Operating Range	Full range/ Split range.	
	7	Modes	Valve Action	Direct / Reverse Valve Action
			Flow Characterization	Possible to fit Valve Characteristic Curves-Linear , Equal percentage etc.
	8	Fail Safe/Fail Freeze	Fail Safe/Fail Freeze feature is to be provided. (In case the fail freeze feature is not intrinsic to the positioner, Bidder shall achieve the same externally through solenoid valve connected in the pneumatic circuit).	
	9	Pneumatic	Air capacity	Sufficient to handle the valves & actuators selected/ Boosters to be supplied, if required.
			Air pressure	To suit the air supply pressure/quality available.
			Process connection	1/4" NPT
	10	Performance	Characteristic deviation	<=0.5 % of span.
			TECHNICAL SPECIFICATION SECTION - VI PART-B	CONTROL VALVES, ACTUATORS & ACCESSORIES
			PAGE 5 OF 7	

CLAUSE NO.	TECHNICAL REQUIREMENTS			एनटीपीसी NTPC
		c) Protection class	IP-65 Minimum	
	3	Software for Configuration and Diagnostics	Software	Windows based software. Software shall meet the requirements for Configuration, Diagnostics, Calibration and Testing of the actuator.
		Diagnostic/Test features		Advanced diagnostic features like Stroke counter or Travel counter, Leakage in actuators, Valve Signature analysis, Step Response test, Valve friction /Jamming detection etc to be provided.
	4	Test reports/ Certificates	Factory Valve Signature Tests Reports (Pr Vs Valve travel and Travel Vs I/P signal) are to be provided.	
			Test certificates as per Manufacture Standard/Relevant Standard are to be submitted.	
	5	Configuration/ Calibration.	Remote & Local Calibration, Auto & Manual Calibration shall be possible.	
	6	Operating Range	Full range/ Split range.	
	7	Modes	Valve Action	Direct / Reverse Valve Action
			Flow Characterization	Possible to fit Valve Characteristic Curves-Linear , Equal percentage etc.
	8	Fail Safe/Fail Freeze	Fail Safe/Fail Freeze feature is to be provided. (In case the fail freeze feature is not intrinsic to the positioner, Bidder shall achieve the same externally through solenoid valve connected in the pneumatic circuit).	
	9	Pneumatic	Air capacity	Sufficient to handle the valves & actuators selected/ Boosters to be supplied, if required.
			Air pressure	To suit the air supply pressure/quality available.
			Process connection	1/4" NPT
	10	Performance	Characteristic deviation	<=0.5 % of span.
	TECHNICAL SPECIFICATION SECTION - VI PART-B		CONTROL VALVES, ACTUATORS & ACCESSORIES	PAGE 5 OF 7

CLAUSE NO.	TECHNICAL REQUIREMENTS		
		Ambient temp effect	<=0.01 %/ deg C or better.
10	EMC & CE Compliance	Required to International Standard like EN/IEC.	EN50081-2 & EN50082 or equivalent.
11	Accessories	In-built Operator Panel	Display with push buttons for configuration and display on the positioner itself (Password protected/Hardware lock).
		<del>Hand Held Hart Calibrator</del>	<del>Universal Hart Calibrator to be provided (for quantity, refer Part-A: Contract quantities of the specification).</del>
		Press Gauge Block	For supply & output pressures, Air Filter Regulator and other accessories shall be provided on as required basis for making system complete.
		Electrical Cable Entry	1/2"NPT, side or bottom entry to avoid water ingress.
		Valves Mounting Assembly	For Sliding Stem/Rotary/Single acting/Double acting actuators on as required basis
<p><b>* Note:</b></p> <p>Employer is providing a centralized HART management system including the HART multiplexing/ interfacing system. The HART signals shall be picked up from marshalling terminals of DDCMIS (SG/TG DDCMIS as well as BOP DDCMIS), as applicable. The details of the above mentioned employer's HART management system are as below:</p> <p>The following functionalities are achieved through industry standard softwares of the HART management system for electronic transmitters, temperature transmitters and analysers:</p> <ol style="list-style-type: none"> <li>Constant scanning to monitor faults or changes to instrument configuration.</li> <li>Employer-defined and standard calibration and configuration procedures for all transmitters.</li> <li>Constant signal data collection facilities to maintain continuously updated records.</li> <li>Automatic tracking of configuration changes made in the field, such as may be introduced by hand-held communicator. All configuration function associated with hand-held communicators shall be available in the system.</li> </ol>			
	<b>TECHNICAL SPECIFICATION SECTION - VI PART-B</b>	<b>CONTROL VALVES, ACTUATORS &amp; ACCESSORIES</b>	<b>PAGE 6 OF 7</b>


CLAUSE NO.	<b>TECHNICAL REQUIREMENTS</b> 		
<p>8.00.00</p>	<p>e) Event and log reports on screen as well as on printer.  f) Any addition/deletion of transmitter will be reported on printer and logged in hard disk.</p> <p>Further, the positioners shall be monitored from the above described HART management system .To achieve this, Bidder shall provide the necessary software to achieve the functionalities described above under "Remote Configuration and Diagnostics", and this software shall be loaded in the Employer's HART management system.</p> <p><b>TEST AND EXAMINATION</b></p> <p>All valves shall be tested in accordance with the quality assurance programme agreed between the Employer and Contractor, which shall meet the requirements of IBR and other applicable codes mentioned elsewhere in the specifications. The tests shall include but not be limited to the following:</p> <p>8.01.00 Non Destructive Test as per ANSI B-16.34.</p> <p>8.02.00 Hydrostatic shell test in accordance with ANSI B 16.34 prior to seat leakage test.</p> <p>8.03.00 Valve closure test and seat leakage test in accordance with ANSI-B 16.34 and as per the leakage class indicated above.</p> <p>8.04.00 Functional Test: The fully assembled valves including actuators control devices and accessories shall be functionally tested to demonstrate times from open to close position.</p> <p>8.05.00 CV Test: Please refer CI No. 1.00.00, Sub-section-IV:19 (Type test requirements), Control Valves.</p> <p>Bidder shall furnish all the control valves under this main plant package as finalized during detailed engineering stage without any price repercussions whatsoever depending on the process requirements. All the control valves provided by the Bidder for this project shall meet the specifications requirements specified herein. Specification for control valves in this Sub-section has to be read in conjunction with other relevant Sub-sections of this specification.</p>		
	<p><b>TECHNICAL SPECIFICATION</b>  <b>SECTION - VI</b>  <b>PART-B</b></p>	<p><b>CONTROL VALVES,  ACTUATORS &amp;  ACCESSORIES</b></p>	<p><b>PAGE 7 OF 7</b></p>

# **GROUNDING SCHEME OF CABINETS/ PANELS**




This document is the property of NTPC LTD. No part of this document will be reproduced by any means without the written permission.


**SYSTEM GROUNDING (TYPICAL)**



**POWER GROUNDING (TYPICAL)**



**PANEL GROUNDING (TYPICAL)**



**NOTES:-**

- SUPPLY, ERECTION, TERMINATION OF CABLES (OTHER THAN THOSE INDICATED IN EMPLOYER'S SCOPE), FLATS ETC. REQUIRED FOR PROPER GROUNDING OF CONTRACTOR'S CONTROL SYSTEM, SYSTEM CABINETS, POWER SUPPLY CABINETS ETC. ARE IN THE SCOPE OF CONTRACTOR.
- 
- TO BE LOCATED IN DCDB.
- EXACT LOCATION, ARRANGEMENTS OF FLATS ETC. SHALL BE AS FINALISED WITH CONTRACTOR. DURING DETAILED ENGINEERING.
- CABINET BODY, CABINET BOTTOM PLATE, CABINET DOORS ARE TO BE CONNECTED TO PANEL EARTH FLAT COPPER CABLE BY CONTRACTOR.
- TWO WIRE EARTHING PHILOSOPHY IS TO BE FOLLOWED FOR EACH CABINET.

FOR TENDER PURPOSE ONLY

<b>एन टी पी सी</b> <b>NTPC</b>		<b>NTPC LIMITED</b> (A GOVT. OF INDIA ENTERPRISE)	
PROJECT RIHAND SUPER THERMAL POWER PROJECT STAGE-III 2 X 500 MW (STATION C&I PACKAGE)			
TITLE GROUNDING SCHEME FOR CABINETS / PANEL			
REV. NO.	DESCRIPTION	DRWN	DESIGN
A	FIRST ISSUE		
		M	E
		C	C&I
		ARCH.	APPD.
		DATE	SIZE
			SCALE
			DRG. NO.
			1150-999 -POI-A-021
			REV. NO.
			A

00927



## SPECIFICATION FOR LOCAL PANELS

SPECIFICATION NO.: PES – 145 – 054A	
VOLUME	II B
SECTION	D
REV. NO.	02
DATE :	22-02-2008
SHEET	1 OF 5

### 1.0 SCOPE

This specification covers the Design, Manufacture, Inspection and Testing at the manufacturer's works, proper packing for transportation and delivery to site of Local Panels required for control and monitoring of the Auxiliary Plant & Equipment.

### 2.0 CODES AND STANDARDS

2.1 All the equipments specified herein shall comply with the requirements of the latest issue of the relevant National and International standards.

2.2 As a minimum requirement, the following standards shall be complied with:

- |    |                          |   |   |
|----|--------------------------|---|---|
| a) | IS-6005 : 1970           | : | Code of practice for phosphating of iron and steel.                             |
| b) | IS-5 : 1978              | : | Colours for ready mixed paints and enamels.                                     |
| c) | IS-1248:1983             | : | Direct Acting Indicating Instruments.   |
| d) | IS-13947 (Part-III):1993 | : | Rotary Cam Switches.  |
| e) | IS-6875:1973             | : | Auxiliary relays.   |
| f) | IS-8828:1993             | : | Circuit breaker for household and similar installations.                        |
| g) | IS-13947 (Part-I):1993   | : | Low Voltage switchgear & control gear : Part-I (General Rules)                  |
| h) | NFPA-496:1974            | : | Purged & Pressurised Enclosure for Electrical Equipment in Hazardous Locations. |

### 3.0 TECHNICAL REQUIREMENTS

#### 3.1 Panel Construction

3.1.1 The local panels shall house the secondary instruments, annunciation system, Single loop controller, Control switches / push buttons, indicating lamps, relays, timers and other devices required for operation and monitoring of the equipment locally.

3.1.2 The panels shall be of free standing type either welded construction on angle iron (minimum section of 50 x 50 x 4 mm) structure or folded construction by sheet metal formation depending upon the equipments to be mounted on it. The panels shall be robustly built and stiffeners as necessary shall be provided.

3.1.3 The panel shall be suitably reinforced to ensure adequate support for all instruments mounted thereon. All welds on exposed panel surfaces shall be ground smooth.

#### 3.1.4 The salient features of construction shall be:

Sheet material: Cold rolled sheet steel

Frame thickness: Not less than 3.0mm

Enclosure thickness: Not less than 2.5 mm for load bearing sections (Mounted with instruments),  
1.6 mm for doors and Not less than 2.0 mm for others

Panel Height: Not less than 2365 mm

Gland plate thickness: 3.0mm

Base channel: ISMC 100 with anti-vibration mounting & foundation bolts.

3.1.5 The panel shall be provided with rear doors with integral lockable handle. The door when locked shall be held at minimum three places. The door width shall not be more than 550mm. The doors shall be provided with suitable stiffeners to prevent buckling. The handle shall be on the right side of the door. The door shall be removable type with concealed hinges to facilitate maintenance work. Suitable pocket inside the door shall be provided for keeping the drawings / documents.

3.1.6 Suitable neoprene gasket shall be provided on all doors and removable covers. Suitable ventilation louvers shall be provided at bottom and top of the doors covered with removable wire mesh.



### SPECIFICATION FOR LOCAL PANELS

SPECIFICATION NO.: PES – 145 – 054A	
VOLUME	II B
SECTION	D
REV. NO.	02
DATE :	22-02-2008
SHEET	2 OF 5

- 3.1.7 The class of protection shall be in accordance with IP-42 unless otherwise specified in the data sheet – A (No. PES-145-54A-DS1-0).
- 3.1.8 All steel surfaces shall be cleaned by sand / pellet blasting, treated for pickling, degreasing and phosphating etc. by seven tank method. The panel shall have a high quality finish and appearance. The panel shall be painted with two coats of primer followed by two coats of epoxy / synthetic enamel based final paint of color shade and finish as given in data sheet-A (No. PES-145-54A-DS1-0). Minimum thickness of the paint shall be 85 microns for external paint and 70 microns for internal paint.
- 3.1.9 The cable glands of the required size and type as given in data sheet-A (No. PES-145-54A-DS1-0) shall be supplied alongwith the Panel.
- 3.1.10 All operable and indicating devices shall be mounted on the front of the panel while aux. Relays / timers MCBs etc. required for realization of control logics shall be mounted on a mounting plate inside the panel. Auxiliary relays and timers etc. shall be grouped according to the control function.  
No operable or indicating devices shall be mounted below 750 mm and above 1800 mm (w.r.t. finished ground level). The devices shall be located in such a way so as to ensure easy access for operation / maintenance.
- 3.1.11 Single / dual control power supply feeders of voltage class as specified in data sheet-A (No. PES-145-54A-DS1-0) shall be provided by the purchaser. **In case redundant power supply feeders are provided then auto changeover unit shall be mounted on the panel are in the panel supplier's scope.** Where DC control power supply is specified an additional 240V, 50 Hz AC supply feeder for powering of space heater and lighting shall be provided by the purchaser. Suitable arrangement shall be provided inside the panel to receive and terminate the power supply feeder(s). For this purpose MCBs of suitable current rating shall be provided by the vendor. A supervisory relay along with a pilot lamp to indicate control supply 'ON' shall be provided on the panel. Any other power supply required for the operation of the devices mounted in the panel shall be arranged by the vendor.
- 3.1.12 The internal wiring shall be carried out with 1100 volt grade PVC insulated copper multi strand wire / flexible of 1.5mm<sup>2</sup> size. AC & DC wires shall be kept separate from each other. Separate coloured wires to be used for AC and DC circuits. All wires shall be properly numbered and identified with ferrules as per the Control scheme / wiring diagram. Wires shall be routed and run through PVC troughs.
- 3.1.13 Terminal blocks shall be clip on type, 1100 volts grade. Separate terminal blocks shall be used for AC & DC circuits. The terminals shall be suitable for terminating 0.5 mm<sup>2</sup> to 2.5mm<sup>2</sup> external cables. The terminal for ammeters shall be provided with removable links for shorting CTs. Each terminal strip shall be provided with identification strip. The terminal shall not be mounted below 250 mm **height from finished floor**. The panel shall have ten (10) percent spare terminal.
- 3.1.14 The interior of each panel shall be suitably illuminated through fluorescent lamps operable on 240V 50 Hz AC power supply through panel door switch. A 15 Amp. 3-pin Power receptacle shall be provided.
- 3.1.15 Suitable space heaters operable on 240 Volts 50 Hz AC power system shall be provided at the panel bottom. These shall be designed to maintain the panel temperature five (5) deg. C above the ambient temperature during maintenance shutdown. Suitable isolating and control devices comprising of MCB, thermostat etc. shall be provided for the space heater.
- 3.1.16 The panel shall be provided with a copper earth bus of 25 x 6 mm size running throughout the width of the panel. It shall be terminated internally with 10 mm bolts at extreme ends for connection to; main station earth. The panel mounted equipments / devices shall be connected to earth bus through green coloured PVC insulated stranded copper conductor of 2.5 mm<sup>2</sup> size.
- 3.1.17 Local Panel shall be provided with main name plate of 150 mm x 40 mm size having inscription of 20 mm height. The individual devices on the panels shall be as provided with separate name plate with inscription of 3 mm height. The instrument / devices shall be provided with stick on label plates inside the panel. The material of the main and individual labels shall be three (3) ply 3 mm thick Traffolyte Sheet / 2 mm Anodised Aluminium Plate. The inscription shall be with white letters on black background on traffolyte sheet. The labels shall be fixed by self tapping non-rusting screws.



## SPECIFICATION FOR LOCAL PANELS

SPECIFICATION NO.: PES – 145 – 054A	
VOLUME	II B
SECTION	D
REV. NO.	02
DATE :	22-02-2008
SHEET	3 OF 5

### 3.2 Hazardous Area Panel Requirement

3.2.1 The Local Panel located in hazardous area shall be pressurized as per NFPA-496 requirements to render it non-hazardous. Alarms shall be provided for local and remote annunciation when pressurisation falls below 2.5 mm of water column. Protection shall be of type Z of NFPA-496. It shall not be possible to switch ON the power of purged section unless it is purged as per the recommendation of NFPA-496. Vendor must provide a protective device on the panel to protect the panel from over pressurisation.

3.2.2 Vendor shall supply pressurisation kit consisting of valves, restriction orifices, dual filter regulation, pressure gauges, pressure switches, rotameter etc. Pressurisation kit shall be surface mounting on a metal board and located outside the local panel. Pressurisation kit shall further consist of solenoid valve flow switch, timer blow off safety device etc., so as to make purging fully automatic. However final start shall be manual. Panel protection against over pressure to be provided as per NFPA-496.

3.2.3 Pressurised local control panel pressurization kit assembly design shall provide minimum leakage flow through the Local Control Panel. Panel venting shall be as per NFPA-496.

3.2.4 All components in the local panel like indicating instruments, push buttons switches, lamps etc., which are required to be energized without panel pressurization or before completion of purge cycle shall be explosion proof as per NEMA-7 & suitable for area classification.

3.2.5 All push buttons etc. requiring frequent operation during machine running shall have good positive sealing. Weatherproof housing or cover to be provided wherever necessary. Vendor shall provide pressurisation bypass switch outside explosion proof enclosure of pressurized panel with lamp indication. This shall be used only during maintenance. All hinges, screws, other non-painted metallic parts shall be of stainless steel material.

3.2.6 Provision to switch off manually all types of power shall be provided in the panel. In addition, it shall also be possible to switch off power circuits / components which are powered from motor control centre or control room manually in case of pressurization failure. All such cables from MCC and main control room shall be terminated in explosion proof boxes (NEMA-7).

### 3.3 Control & Monitoring devices

3.3.1 Instruments like Indicators, recorders, single loop controllers etc. as applicable and specified elsewhere for the plant / equipment shall be supplied and mounted on the panel.

#### 3.3.2 Alarm Annunciator System

It shall be solid state discrete facia type having a sequence of ISA-S18.1A or as specified, opaque facia windows of 70 mm x 50 mm size, having two (2) lamps per window, and hooter of 10W, and provision for repeat group alarm at remote. The annunciator shall be provided with ten (10) percent spare windows or minimum two (2) windows along with electronics.

#### 3.3.3 Relays

The relays shall be electromagnetic type suitable for specified control supply. Its contact configuration and rating shall be suitable for the specified control function. However minimum contact rating shall be 5 Amp AC & 2 Amp DC as applicable. There shall be ten (10) percent spare contacts.

#### 3.3.4 Timers

The timers shall be electronic type suitable for specified control supply. Its contact configuration and rating shall be suitable for the specified control function. However, minimum contact rating shall be 5 Amp AC & 2 Amp DC as applicable.

#### 3.3.5 Control / Selector Switches

Switches shall be Rotary Cam type with minimum of 5 Amps AC & 2 Amp DC continuous current rating. Selector switches shall be stay put type while control switches shall be spring-return-to-neutral type. Contact configuration and rating shall be as per the control function requirement. The switches shall be lockable type wherever specified. Each switch shall be provided with engraved plates indicating the switch position / functions.



## SPECIFICATION FOR LOCAL PANELS

SPECIFICATION NO.: PES – 145 – 054A	
VOLUME	II B
SECTION	D
REV. NO.	02
DATE :	22-02-2008
SHEET	4 OF 5

### 3.3.6 Push Buttons / Indicating Lights

The push buttons shall be momentary action self-resetting type, however stop P.B. for unidirectional drives shall be provided with manual reset facility. Its contact configuration & rating shall be as required for the control function but minimum 2 NO + 2 NC of 5 Amp. AC rating. It shall have round coloured projecting tab and engraved escutcheon plate / inscription plate. Colour coding of push buttons shall be as under:

RED	Motor OFF / Valve CLOSE	YELLOW	Alarm acknowledge.
GREEN	Motor ON / Valve OPEN	BLACK	Lamp test

Indicating lights shall be suitable for direct connections across specified power supplies. It shall be fitted with built in resistance to prevent circuit tripping on shorting of lamp filament. It shall be fitted with LED cluster type lamp replaceable from front.

GREEN	Motor OFF / Valve CLOSED condition	AMBER	Motor tripped condition.
RED	Motor ON / Valve OPEN condition	WHITE	Normal / healthy condition

### 3.3.7 Ammeters

Ammeter shall be 96 x 96 mm size, 90 deg. deflection, 1.5% accuracy, 1 Amp. CT operated or with 4-20mA input and Flush mounting type as called for in the data sheet-A (No. PES-145-54A-DS1-0). Ammeters for motors shall have six (6) times folded scale at upper end to enable motor starting current indication.

### 3.3.8 Miniature Circuit Breaker (MCB)

These shall be instantaneous magnetic trip type for short circuit in addition to current time inverse delayed thermal trip feature for over current protection. The housing of MCB shall be made of non-ignitable, high impact material. It shall have minimum short circuit rating of 9 KA for AC Voltages and 4 KA for DC Voltages.

### 3.3.9 Makes of various instruments / devices shall be as given below

1.	Alarm Annunciators	:	Procon / IIC
2.	Ammeters	:	AEP / IMP
3.	Control / Selector Switches	:	Alsthom / Kaycee / Siemens / L&T
4.	Push Buttons / Indicating Lamps	:	Siemens / L&T / Teknic / Alsthom
5.	Auxiliary Relays	:	Jyoti / Siemens / L&T / OEN
6.	Timers	:	L&T / Alsthom / Bhartiya Cutler Hammer
7.	MCBs	:	S&S Power Engg. / Indo Asian / MDS
8.	Terminal Blocks	:	Jyoti / Elmex

## 4.0 TESTING AND INSPECTION

4.1 The bidder shall adopt suitable quality assurance program to ensure that the equipments offered will meet the specification requirements in full.

4.2 BHEL's standard Quality Plan for LCP is enclosed with the specification. The bidder shall furnish his acceptance to BHEL's QP and submit the signed and stamped copy of QP along with the offer.

4.3 The vendor shall conduct the following tests as a minimum requirement:

#### 4.3.1 Routine Tests

1. High Voltage (H.V.)
2. Insulation Resistance (I.R.)
3. Functional

#### 4.3.2 Type Tests

1. Enclosure Class Test



## SPECIFICATION FOR LOCAL PANELS

SPECIFICATION NO.: PES – 145 – 054A	
VOLUME	II B
SECTION	D
REV. NO.	02
DATE :	22-02-2008
SHEET	5 OF 5

### 5.0 SPARES AND CONSUMABLES

#### 5.1 Commissioning Spares and consumables

The bidder shall supply all commissioning spares and consumables 'as required' during Start-up, as part of the main equipment supply.

#### 5.2. Mandatory Spares

The bidder shall offer alongwith main offer, the Mandatory Spares as specified elsewhere in the specification. The Mandatory Spares offered shall be of the same make and type as the main equipment.

#### 5.3. Recommended Spares

The bidder shall furnish a list of Recommended Spares indicating the normal service expectancy period and frequency of replacement; quantities recommended for 3 years operation alongwith unit rate against each item to enable BHEL/BHEL's Customer to place a separate order later, if required.

### 6.0 DRAWINGS AND DOCUMENTS

6.1 The bidder shall furnish the following documents in required number of copies along with the bid :

1. Data Sheet no. PES-145-54A-DS1-0
2. General Arrangement Drawing.
3. Catalogue and technical information for instruments and devices.
4. Quality Plan.

6.2 The vendor shall furnish the following documents in required number as agreed after the award of contract:

1. Data Shee No. PES-145-54A-DS2-0
2. GA Drawing indicating layout of instruments, construction details, foundation details, cable gland plate alongwith cable glands and all details mentioned in this specification.
3. Control Schematic Diagram along with grouping of different terminals for various functions.
4. Catalogue and technical information for instruments and devices with selected options clearly marked.
5. O&M Manuals.
6. "As Built" Drawing.
7. **CDs.**


### 7.0 MARKING AND PACKING


7.1 Panel with all instruments / devices mounted on it shall be suitably packed & protected for the entire period of despatch, storage and erection against impact, abrasion, corrosion, incidental damage due to vermin, sunlight, high temperature, rain moisture, humidity, dust, sea-water spray (where applicable) as well as rough handling and delays in Transit and storage in open.

### 8.0 APPLICABLE DATA SHEET FORMS

This document shall be read with one or more of the following data sheet forms :

- |                                   |   |                                  |
|-----------------------------------|---|----------------------------------|
| - Data sheet A&B for Local Panels | : | Data sheet no. PES-145-54A-DS1-0 |
| - Data sheet C for Local Panels   | : | Data sheet no. PES-145-54A-DS2-0 |

	<b>DATA SHEET FOR LOCAL PANELS</b>		SPECIFICATION NO.:	
			VOLUME	
			SECTION	
			REV. NO.	DATE:
			SHEET	1 OF 2
TAG No. .... Qty.....		Data Sheet No.: <b>PES-145A-DS1-0</b>		
<b>Data Sheet A &amp; B</b>				
DATA SHEET-A FOR LOCAL PANEL (TO BE FILLED BY PURCHASER)			DATA SHEET-B (TO BE FILLED-UP BY BIDDER)	
<b>GENERAL</b>	MANUFACTURER			
	CONSTRUCTION	<input checked="" type="checkbox"/> FOLDED <input type="checkbox"/> WELDED (As per requirement)		
<b>TECHNICAL</b>	INPUT POWER SUPPLY	<input type="checkbox"/> 240V 50 Hz AC <input type="checkbox"/> 220V DC <input checked="" type="checkbox"/> 415V 3 PHASE		
	NO. OF FEEDERS	<input type="checkbox"/> ONE <input checked="" type="checkbox"/> TWO		
	CONTROL SUPPLY	<input checked="" type="checkbox"/> 110V AC <input type="checkbox"/> 220V AC <input type="checkbox"/> 220V DC <input type="checkbox"/> (As per requirement)		
	ALARM ANNUNCIATOR WINDOW (EXCLUDING SPARES)	(AS REQUIRED) TO BE DECIDED DURING DETAILED ENGINEERING		
	PAINT TYPE	<input type="checkbox"/> EPOXY <input type="checkbox"/> SYNTHETIC ENAMEL <input checked="" type="checkbox"/> EPOXY POWDER COATED		
	PANEL COLOUR (EXTERNAL)	<input type="checkbox"/> LIGHT GREY (Shade 631 IS-5) <input type="checkbox"/> DARK GREY (SHADE 632 IS-5) <b>(TO BE FINALISED DURING DETAILED ENGINEERING)</b>		
	FINISH	<input type="checkbox"/> SEMI MAT <input type="checkbox"/> MATT <input type="checkbox"/> GLOSSY <input checked="" type="checkbox"/> SEMI GLOSSY		
	PANEL COLOUR (INTERNAL)	<input checked="" type="checkbox"/> WHITE <input type="checkbox"/> CREAM <input type="checkbox"/> OFF WHITE		
	FINISH	<input type="checkbox"/> SEMI MAT <input type="checkbox"/> MATT <input checked="" type="checkbox"/> GLOSSY <input type="checkbox"/> SEMI GLOSSY		
	CLASS OF PROTECTION	<input checked="" type="checkbox"/> IP-54 <input type="checkbox"/> IP-53		
	CONTROL HARDWARE	<input checked="" type="checkbox"/> RELAY BASED <input type="checkbox"/> PLC		
	FOUNDATION ARRANGEMENT	<input checked="" type="checkbox"/> FOUNDATION BOLTS <input type="checkbox"/> ANCHOR FASTENERS		
	WEIGHT OF PANEL (Kg.)			
	PANEL TYPE	<input type="checkbox"/> PRESSURISED <input checked="" type="checkbox"/> UNPRESSURISED As per Requirement		
CABLE GLAND	<input type="checkbox"/> SINGLE COMPRESSION <input checked="" type="checkbox"/> DOUBLE COMPRESSION			

1	 <p style="font-size: 1.2em; font-weight: bold; margin-top: 10px;">DATA SHEET FOR LOCAL PANELS</p>	SPECIFICATION NO.: VOLUME SECTION REV. NO. _____ DATE: _____ SHEET      2      OF      2
TAG No. .... Qty.....		Data Sheet No.: <b>PES-145A-DS1-0</b>
Data Sheet C		
DATA SHEET-C FOR LOCAL PANEL (TO BE FILLED BY CONTRACTOR AFTER AWARD OF CONTRACT)		
GENERAL	MANUFACTURER	
	CONSTRUCTION	
TECHNICAL	INPUT POWER SUPPLY	
	NO. OF FEEDERS	
	CONTROL SUPPLY	
	ALARM ANNUNCIATOR WINDOW (EXCLUDING SPARES)	
	PAINT TYPE	
	PANEL COLOUR (EXTERNAL)	
	FINISH	
	PANEL COLOUR (INTERNAL)	
	FINISH	
	CLASS OF PROTECTION	
	CONTROL HARDWARE	
	FOUNDATION ARRANGEMENT	
	WEIGHT OF PANEL (Kg.)	
	PANEL TYPE	
	CABLE GLAND	