

TELANGANA STATE POWER GENERATION CORPORATION LIMITED

1x800 MW KOTHAGUEM THERMAL POWER STATION
STAGE-VII, UNIT#12

TECHNICAL SPECIFICATION FOR ELECTRIC HOISTS

SPECIFICATION NO.: PE-TS-410-563-A201



BHARAT HEAVY ELECTRICALS LTD
POWER SECTOR PROJECT ENGINEERING MANAGEMENT
NOIDA (U.P.)
INDIA



TITLE

**1X800 MW KOTHAGUDEM TPP
ELECTRIC HOISTS
INDEX**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME: II B

REV 00

30.07 2015

SHEET 1 OF 1

VOLUME – IIB

SECTIONS	TITLE	Page
SECTION-A	INTENT OF SPECIFICATION	3-4
SECTION-B	PROJECT INFORMATION	5-10
SECTION-C		
SECTION-C1	SPECIFIC TECHNICAL REQUIREMENT	11-45
SECTION-C2	ELECTRICAL SPECIFICATION	46-85

SECTION-C3	<u>ANNEXURES</u>		
i)	Scope	ANNEXURE-I	86-87
ii)	Painting specification	ANNEXURE-II	88
iii)	Makes of sub-vendor items	ANNEXURE-III	89-94
iv	Number of drawings/documents for submission	ANNEXURE-IV	95
v)	List of mandatory spares	ANNEXURE-V	96
vi)	Drawing distribution schedule	ANNEXURE-VI	97-98
SECTION-D	STANDARD TECHNICAL SPECIFICATIONS		99-104

VOLUME-III

SECTIONS	TITLE	Page
1	Compliance cum confirmation certificate	105-107
2	Pre Bid Clarification Schedule	108
3	Schedule of Technical Deviation	109
4	List of documents to be submitted with bid	110



TITLE TECHNICAL SPECIFICATION FOR ELECTRIC WIRE ROPE HOISTS 1X800 MW KOTHAGUDEM TPS,	SPECIFICATION NO. PE-TS-410-563-A201	
	VOLUME II B	
	SECTION A	
	REV 00	DATE 30-07-15
	SHEET 1	OF 2

1.0 SCOPE OF INQUIRY

- 1.1 This specification includes, but not limited to design, engineering, manufacture, inspection and testing at vendor's/ sub-vendor's works, painting, forwarding, proper packing and shipment and delivery at site as required on FOR site basis, performance and guarantee testing at vendor's works (as mentioned elsewhere in the specification) of ELECTRIC HOISTS as per details in different sections / volumes of this specification for **1X800 MW KOTHAGUDEM TPP STAGE-VII, UNIT#12**.
- 1.2 The contractor shall be responsible for providing all material, equipment & services, which are required to fulfil the intent of ensuring operability, maintainability, reliability and complete safety of the complete work covered under this specification, irrespective of whether it has been specifically listed herein or not. **Omission of specific reference to any component / accessory necessary for proper performance of the equipment shall not relieve the contractor of the responsibility of providing such facilities to complete the supply of ELECTRIC HOISTS & its accessories**
- 1.3 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship and shall be capable of performing the required duties in a manner acceptable to purchaser who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material which in his judgement is not in full accordance herewith.
- 1.4 The extent of supply under the contract includes all items shown in the drawings, notwithstanding the fact that such items may have been omitted from the specification or schedules. Similarly, the extent of supply also includes all items mentioned in the specification and /or schedules, notwithstanding the fact that such items may have been omitted in the drawing.
- 1.5 The general term and conditions, instructions to tenderer and other attachment referred to elsewhere are made part of the tender specification. The equipment materials and works covered by this specification is subject to compliance to all attachments referred to in the specification. The bidder shall be responsible for and governed by all requirements stipulated herein.
- 1.6 While all efforts have been made to make the specification requirement complete & unambiguous, it shall be bidders' responsibility to ask for missing information , ensure completeness of specification, to bring out any contradictory / conflicting requirement in different sections of the specification and within a section itself to the notice of BHEL and to seek any clarification on specification requirement in the format enclosed under Vol-III of the specification **within 10 days of receipt of tender documents**. In absence of any such clarifications, in case of any contradictory requirement, the more stringent requirement as per interpretation of Purchaser/Customer shall prevail and shall be complied by the bidder without any commercial implication on account of the same. Further in case of any missing information in the specification not brought out by the prospective bidders as part of pre-bid clarification, the same shall be furnished by Purchaser/ Customer as and when brought to their notice either by the bidder or by purchaser/ customer themselves. However, such requirements shall be binding on the successful bidder without any commercial & delivery implication.



TITLE	TECHNICAL SPECIFICATION FOR ELECTRIC WIRE ROPE HOISTS 1X800 MW KOTHAGUDEM TPS,		SPECIFICATION NO. PE-TS-410-563-A201	
			VOLUME II B	
			SECTION A	
			REV 00	DATE 30-07-15
			SHEET 2	OF 2

- 1.7 The bidder's offer shall not carry any sections like clarification, interpretations and /or assumptions.
- 1.8 Deviations, if any, should be very clearly brought out clause by clause in the enclosed deviation schedule along with cost of withdrawal; otherwise, it will be presumed that the vendor's offer is strictly in line with NIT specification. If no cost of withdrawal is given against the deviation, it will be presumed that deviation can be withdrawn without any cost to BHEL/its customer
- 1.9 In the event of any conflict between the requirements of two clauses of this specification documents or requirements of different codes and standards specified, Section - C shall prevail over section – D, however more stringent requirement as per the interpretation of the owner shall apply.
- 1.10 In case all above requirements are not complied with, the offer may be considered as incomplete and would become liable for rejection.
- 1.11 Unless specified otherwise, all through the specification, the word contractor shall have same meaning as successful bidder /vendor and Customer/ Purchaser/Employer will mean BHEL and /or TELANGANA STATE POWER GENERATION CORPORATION LIMITED including their consultant as interpreted by BHEL in the relevant context. For details refer the relevant clause in GCC

VOLUME : IIA

SECTION-II

PROJECT SYNOPSIS AND GENERAL INFORMATION

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	INTRODUCTION
2.00.00	APPROACH TO SITE
3.00.00	LAND
4.00.00	SOURCE OF COAL
5.00.00	SOURCE OF WATER
6.00.00	ASH DISPOSAL AREA
7.00.00	SALIENT DESIGN DATA

VOLUME : IIA

SECTION-II

PROJECT SYNOPSIS AND GENERAL INFORMATION

1.00.00 INTRODUCTION

The proposed 1x800 MW Kothagudem Thermal Power Station (KTPS), Stage-VII, Unit-12 would be set up by Telangana State Power Corporation Ltd. (TSGENCO) at Kothagudem, Telangana. The proposed Power Plant will be installed adjacent to the existing D colony of Kothagudem Thermal Power Station, at Kothagudem.

The Bidder shall acquaint himself by a visit to the site, if felt necessary, with the conditions prevailing at site before submission of the bid. The information given here in under is for general guidance and shall not be contractually binding on the Owner. All relevant site data /information as may be necessary shall have to be obtained /collected by the Bidder.

2.00.00 APPROACH TO SITE

Site is located in the existing D Colony of Kothagudem Thermal Power Station, which is at a distance 30 km from temple town of Bhadrachalam and 300 km from Hyderabad by road. The Nearest railway station is Bhadrachalam Road (Known as Kothagudem) at a distance of 12 km. Kothagudem- Bhadrachalam National Highway branches off to the power station site near village Paloncha.

3.00.00 LAND

Land is primarily required for the main plant & auxiliaries (BTG) and balance of plant (BOP) like ash handling, coal storage, cooling tower, switchyard etc., which is available within the existing plant boundary.

The existing colony is to be dismantled, and the land of about 137 acres will be used for the main plant building, water facilities, switchyard, coal handling etc. The raw water reservoir will be located adjacent to the existing raw water reservoirs.

230 acres of land required for Ash Dyke will be procured. Land is available for staff colony, which is to be constructed by the EPC contractor.

4.00.00 SOURCE OF COAL

100% Imported and Blended coal (50% imported + 50% indigenous) will be used. Indigenous coal shall be sourced from Suliyari coal mines, Madhya Pradesh.

5.00.00 **SOURCE OF WATER**

Source of water (total quantity of water is 2192 m³/hr) is Godavari River near Burgampahad & water will be pumped through existing GRP pipe line (of length approx. 26 km).

6.00.00 **ASH DISPOSAL AREA**

Ash shall be dumped in the ash dump area which will be about 9 km from plant. The ash dyke area of 230 acres is adequate for 1x800 MW unit as per MOEF norms.

7.00.00 **SALIENT DESIGN DATA**

7.01.00 Meteorological data of site is given below:-

Elevation above MSL : 89 m

Monthly highest temperature : 44.9 °C

Monthly lowest temperature. : 12.9 °C

Rainfall

Average.: 1031 mm

Max. : 100 mm/ hr

Mean Wind speed : 44M/s

Relative Humidity

Max : 82%

Min : 35%

Seismic Zone : Zone-III as per IS- 1893 (Part-IV)

[Climatological data of Khammam is attached for reference].

TABLE - VII

STATION : Khammam 43137 LAT: 17 15 N LONG: 80 09 E HT. ABOVE M.S.L. 112 METERS DATA 1951 TO 1980

MN	Mean Temperature					Extremes			Cloud			Rainfall										
	DB	WB	MAX	MIN	HIGH	LOW	MAX	DT	MIN	DT	RH	VP	TOT	LOW	TOT	RAINY	WET	DRY	HEAVY	DAY	WS	
1	1003.4	21.2	19.0	30.8	17.9	32.8	14.0	35.0	31	9.4	08	80	20.3	2.1	1.2	4.6	0.2	84.5	0.0	84.5	13	4.3
	999.1	29.2	20.7					1950	1946		44	17.5	2.3	1.1			1966				1966	
2	1001.5	23.7	20.9	33.7	20.4	36.9	16.9	39.4	21	11.7	03	77	22.6	2.6	2.0	6.0	0.5	45.0	0.0	39.6	18	5.6
	997.3	32.3	21.9					1969	1943		38	17.9	1.9	0.9			1971				1946	
3	999.7	26.1	23.2	36.8	23.1	39.8	19.8	43.3	28	16.1	01	76	26.0	3.0	2.4	9.8	0.7	129.4	0.0	66.0	18	6.8
	995.1	35.3	23.5					1953	1952		35	19.5	1.8	0.9			1967				1967	
4	997.2	28.9	25.2	39.0	25.9	42.3	22.5	45.5	30	18.0	17	73	29.1	3.4	2.3	20.7	1.6	125.5	0.0	63.0	20	7.6
	992.2	37.3	25.1					1973	1972		36	22.2	2.8	1.3			1945				1945	
5	993.2	31.5	26.0	40.9	27.9	44.7	23.4	47.2	25	20.1	14	64	29.2	3.7	1.9	43.6	2.4	465.2	0.0	227.2	20	7.8
	988.1	38.7	26.2					1947	1971		36	23.8	3.9	2.0			1969				1969	
6	991.2	29.8	25.3	37.0	26.9	42.8	22.8	46.7	03	21.6	19	70	28.6	5.6	2.4	153.3	8.0	351.0	12.5	92.7	17	9.0
	987.0	34.9	26.3					1953	1961		52	27.2	5.9	3.4			1978		1948		1953	
7	991.4	27.2	24.7	32.6	25.0	36.3	22.6	40.6	07	20.5	21	81	29.1	6.5	3.4	260.2	12.9	494.0	47.6	299.7	10	7.6
	988.3	30.9	25.8					1966	1959		67	29.0	6.5	4.0			1956		1964		1954	
8	992.2	26.9	24.6	32.0	24.7	35.1	22.6	41.2	16	20.2	23	83	29.1	6.2	3.5	200.4	11.5	483.5	29.2	143.2	15	6.5
	988.9	30.1	25.7					1972	1961		70	29.4	6.4	4.0			1970		1941		1978	
9	994.4	27.1	24.8	32.7	24.5	35.9	22.3	37.6	22 *	20.6	30	82	29.5	5.3	2.6	184.7	9.0	413.9	34.9	177.4	07	4.5
	990.7	30.1	25.5					1977	1942		69	29.0	6.0	3.6			1975		1973		1968	
10	998.0	26.6	24.2	32.5	23.3	35.5	19.7	39.6	30	16.0	31	81	28.2	3.9	2.2	114.3	6.9	264.3	14.0	130.8	08	3.1
	994.4	29.8	24.3					1978	1974		63	26.0	4.9	2.8			1974		1957		1941	
11	1001.6	23.7	21.0	30.9	19.9	33.3	15.8	35.4	04	11.7	30	77	22.8	3.2	1.4	29.1	1.6	166.9	0.0	86.4	09	3.3
	998.0	28.6	21.7					1965	1941		54	20.6	3.6	1.9			1946				1946	
12	1003.6	20.8	18.4	29.9	17.1	32.0	13.5	34.6	01	9.7	13	78	19.3	2.5	0.9	4.9	0.4	57.0	0.0	33.0	13	3.0
	999.6	27.8	20.1					1972	1966		46	17.3	2.6	1.2			1969				1969	
YR	997.3	26.1	23.1	34.1	23.1	44.9	12.9	47.2		9.4		77	26.2	4.0	2.2	1031.6	55.7	1832.3	530.8	299.7		5.8
IY	993.2	32.1	23.9								51	23.3	4.1	2.3			1969		1952			
YRS	30	30	30	30	30	30	30	39	39	39	30	30	30	30	23	30	30	39	39	39	39	28
	30	30	30								30	30	30	30	23	30	30	39	39	39	39	

* Occurred More Than Once

STATION : Khammam

43137 .. contd

MN	Weather		Wind speed		% Wind Direction				Total Cloud			Low cloud			Visibility																			
	PPT	HALL	THUN	FOG	D.STM	SQUA	61	19	0	N	NE	E	SE	S	SW	W	NW	0	T-2	3-5	6-7	8	F8	<1	1-4	4-10	10-20	>20						
1	0.5	0.0	0.1	1.7	0.0	0.0	0	15	16	6	3	29	10	3	1	0	1	47	17	4	4	2	23	3	2	2	1	0	1.4	5.2	5.5	18.1	0.8	
2	0.7	0.0	0.2	0.8	0.0	0.0	0	18	13	4	2	33	12	7	2	1	1	38	13	7	6	4	1	19	7	4	1	0	0.0	0.1	5.8	24.1	1.0	
3	0.8	0.0	0.3	0.1	0.0	0.0	0	21	7	2	2	30	33	9	1	0	1	22	11	5	4	6	2	16	4	3	4	1	0	0.2	3.5	6.5	17.2	0.6
4	1.9	0.0	1.4	0.0	0.6	0.0	0	19	9	5	2	27	17	11	3	5	2	28	13	7	5	3	0	18	6	3	1	0	0.0	0.0	4.1	23.2	0.7	
5	3.4	0.0	2.5	0.0	1.2	0.0	0	28	3	1	2	29	39	18	1	0	0	10	11	4	6	8	2	15	4	5	6	1	0	0.0	3.4	5.9	21.6	0.1
6	10.6	0.0	2.6	0.0	0.2	0.0	0	22	9	3	1	17	19	22	6	5	1	26	16	6	5	3	1	20	7	3	1	0	0.0	1.1	5.5	23.5	0.9	
7	16.2	0.0	1.0	0.0	0.0	0.0	0	27	3	2	1	21	37	25	3	1	0	10	7	6	8	8	1	12	6	6	5	1	0	0.0	2.0	6.5	20.7	0.8
8	15.8	0.0	0.8	0.0	0.0	0.0	0	21	9	3	1	17	20	22	5	4	1	27	10	6	8	5	1	15	9	4	2	0	0.0	0.7	4.3	22.8	2.2	
9	11.8	0.0	1.7	0.0	0.0	0.0	0	26	5	6	1	13	22	18	8	13	5	14	7	5	7	8	4	16	5	5	3	2	0	0.0	1.8	5.7	22.0	1.5
10	9.0	0.0	0.9	0.0	0.0	0.0	0	23	8	12	2	15	12	12	5	13	5	24	6	6	9	8	2	11	10	7	2	1	0	0.0	0.6	5.3	22.6	2.5
11	2.3	0.0	0.4	0.1	0.0	0.0	0	25	4	5	1	3	2	4	13	45	14	13	3	2	5	10	10	15	4	4	2	5	0	0.0	1.8	6.6	19.5	2.1
12	0.8	0.0	0.0	0.6	0.0	0.0	0	24	6	10	0	7	2	8	12	37	7	17	1	2	7	11	9	7	8	3	4	0	0.0	1.1	5.5	21.4	2.0	
13	16.2	0.0	1.0	0.0	0.0	0.0	0	26	5	2	0	1	2	5	20	47	9	14	1	1	4	10	15	11	3	7	3	7	0	0.0	3.1	7.7	18.1	2.1
14	15.8	0.0	0.8	0.0	0.0	0.0	0	24	6	7	0	2	4	10	45	9	21	0	1	1	5	11	14	5	6	10	4	6	0	0.0	2.2	5.4	21.6	1.8
15	11.8	0.0	1.7	0.0	0.0	0.0	0	25	6	3	0	1	2	3	15	49	11	16	2	1	5	12	11	10	4	7	4	6	0	0.0	2.6	5.7	20.4	2.3
16	9.0	0.0	0.9	0.0	0.0	0.0	0	22	9	10	1	2	2	8	39	10	26	1	1	6	12	11	6	6	10	4	5	0	0.0	2.6	4.7	21.9	1.8	
17	11.8	0.0	1.7	0.0	0.0	0.0	0	20	10	9	1	4	1	6	10	29	8	32	3	3	7	10	7	12	6	6	3	3	0	0.1	1.8	5.8	20.4	1.9
18	9.0	0.0	0.9	0.0	0.0	0.0	0	20	10	16	2	9	3	4	5	24	8	29	0	2	7	12	9	4	8	10	4	4	0	0.0	2.1	4.0	22.2	1.7
19	2.3	0.0	0.4	0.1	0.0	0.0	0	15	16	14	4	13	4	3	2	5	5	50	8	5	6	7	5	15	5	5	3	3	0	0.0	2.7	5.8	20.6	1.9
20	0.8	0.0	0.0	0.6	0.0	0.0	0	17	14	14	6	23	4	3	2	3	2	43	5	3	8	10	5	9	8	8	3	3	0	0.0	1.8	5.5	22.4	1.3
21	0.8	0.0	0.0	0.6	0.0	0.0	0	14	16	17	5	20	3	1	1	3	49	8	6	6	7	3	20	4	3	2	1	0	0.0	4.5	5.3	19.6	0.6	
22	0.8	0.0	0.0	0.6	0.0	0.0	0	16	14	11	8	32	4	2	0	1	1	41	8	5	7	6	4	14	7	5	2	2	0	0.0	1.3	4.8	22.7	1.2
23	0.8	0.0	0.0	0.6	0.0	0.0	0	13	18	18	4	15	5	1	0	0	2	55	14	5	4	6	2	26	1	2	1	1	0	0.5	4.8	5.7	20.0	0.0
24	0.8	0.0	0.0	0.6	0.0	0.0	0	15	16	6	6	34	3	2	0	1	1	47	13	6	6	5	1	21	5	3	1	1	0	0.0	0.4	5.8	24.5	0.3
YR	73.8	0.0	11.9	3.3	2.0	0.0	0	1255	109	7	2	15	13	8	6	16	5	28	92	47	66	96	64	191	49	55	38	32	0	2.2	37.2	72.7	238.2	14.7
LY							0	1241	123	8	3	18	8	8	5	15	4	31	86	52	79	90	58	149	87	75	28	26	0	0.0	14.0	60.7	272.9	17.4
YRS							25	24											25	25														



TECHNICAL SPECIFICATION FOR
ELECTRIC HOISTS
1X800 MW KOTHAGUDEM TPP

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME II - B

SECTION - C-1

Rev 00

30.07.15

VOLUME - IIB
SECTION – C-1
SPECIFIC TECHNICAL REQUIREMENTS



TITLE TECHNICAL SPECIFICATION FOR WIRE ROPE ELECTRIC HOIST 1X800 MW KOTHAGUDEM TPS,	SPECIFICATION NO. PE-TS- 410-563-A201	
	VOLUME II - B	
	SECTION - C -1	
	REV No.: 00	DATE: 20.07.15
	SHEET 1 OF 3	

1.0.0 SCOPE OF WORK

1.1.0 SUPPLIES

1.1.1 Equipment and services to be furnished by the bidder for the **WIRE ROPE ELECTRIC HOIST** with accessories. Any equipment / accessories not specified in the specification but required to make the hoist units complete and efficient shall also be under the bidder's scope of work.

Each hoist shall include all necessary items but shall not be limited to the following: -

1. Travelling Trolley
2. Hoisting mechanism (motor and gear box, wire rope, load hook and hook block)
3. Electrical equipment (control panel, motor, limit switches)
4. Flexible trailing cable for motor, brake, limit switches, etc.
5. Painting of hoist.
6. Power supply thru' DSL including current collector, brackets etc.
7. O & M Manual, drawings and documents.
8. Testing of hoist.
9. Main isolating switch and power cable from 1.5M above ground / operating floor.
10. Any equipment / accessories not specified here but required to make the equipment complete and efficient shall be under bidder's scope of work.
11. Commissioning spares
12. Mandatory Spares

1.1.2 Maintenance Tools and Tackles

One (1) complete unused new set of maintenance tools, tackles and accessories along with detailed instructions and maintenance manual shall be supplied. **Tools shall be of suitable sizes for maintenance of electric hoist of each type and capacity.** Each tool and wrench shall be stamped so as to be identified easy for its use. The tools shall be supplied in steel toolbox and with a copy of instruction manual. The items supplied shall be of the best quality, specially protected against rusting. The following shall be provided as minimum requirement:

S-No.	Description	Qty.
1	Complete set of ring spanners	1 Set**



TITLE TECHNICAL SPECIFICATION FOR WIRE ROPE ELECTRIC HOIST 1X800 MW KOTHAGUDEM TPS,	SPECIFICATION NO. PE-TS- 410-563-A201	
	VOLUME II - B	
	SECTION - C -1	
	REV No.: 00	DATE: 20.07.15
	SHEET 2 OF 3	

(Indicate the sizes offered)

2 Complete set of screwdrivers 1 Set**

(Indicate the sizes)

3. Adjustable Spanner 1 No.

4. Insulated plier 1 No.

5. Grease gun 1 No.

6. Oil gun 1 No.

7. Line tester 1 No.

8. Any other tool and tackle.

(**) – Set shall comprise of complete range of spanners suiting requirement for various capacities of electric hoists.

Note: - Bidder to include additional tool, if required over and above specified.

1.2.0 Services to be provided by the bidder

1.2.1. Packing and forwarding and transportation to site.

1.2.2. Erection and commissioning procedure shall be submitted by successful bidder for carrying out the erection and commissioning at site by customer.

1.3.0. Inspection and Testing

As per enclosed BHEL standard quality plan / Customer approved QAP. Prime inspection agency shall be BHEL/End Customer Equipment supplied shall be strictly in accordance with nomenclature & technical specification Any additional testing requirement/ CHP(Customer Hold Point) at any stage of inspection deemed necessary by Customer/BHEL during detailed engineering shall be carried out without any commercial or technical implication.

1.4.0. Drawing / design document for submission

As per Volume III.

2.0.0. Works Excluded

2.1.0 Supply of ISMB monorail.

2.2.0 Purchaser shall provide single point 415V, 3 phase, and 50Hz power feeder at any point of the bay or in the middle of the bay. Vendor shall provide main isolating switch at 1.5 M above the ground / operating floor level and cable required from isolating switch to DSL.

Any other supply required by the bidder shall be arranged by the bidder himself, using suitable transformer as per the specification.

3.0.0. Deviations



TITLE TECHNICAL SPECIFICATION FOR WIRE ROPE ELECTRIC HOIST 1X800 MW KOTHAGUDEM TPS,	SPECIFICATION NO. PE-TS- 410-563-A201	
	VOLUME II - B	
	SECTION - C -1	
	REV No.: 00	DATE: 20.07.15
	SHEET 3	OF 3

If the offer submitted has got any deviation from the technical stipulations in the tender document, bidder shall tabulate the same in the “Deviation format” furnishing full particular of such deviations. Deviations are to be furnished with mention to specific clause number. Reasons / explanations for such deviations shall be furnished. If there are no deviations from the tender document, bidder shall indicate “NO DEVIATION” in the Deviation Format attached with unpriced bid (also attached in Volume-III).

4.0.0. **Demonstration Guarantee**

Refer Customer specification in Volume II B, Section-C.

Hoist along with its drives, controls and other accessories shall be guaranteed for the rated capacity against the rated speed of motions and for the service conditions specified. The bidder shall have the full responsibility for the safe and efficient operation of the hoist with associated accessories as a single unit. If the shop performance tests indicate the failure of any of the components to achieve the guaranteed performance, the deficiency shall be made good at bidder’s cost.

Performance tests shall be carried out each time after the rectification /modification is carried out.

5.0.0. **Make of Sub - Vendor items**

The make of bought out items shall be considered as per Annexure-III, section C-3, Volume II-B of the specification.

6.0.0 **Packing**

Refer General Technical Requirement.

7.0.0 **Painting**

Refer annexure –II “Painting Requirements” in Volume-II B, Section-C-3.



TITLE	DATA SHEET – A	SPECIFICATION NO. PE-TS-410-563-A201
	ELECTRIC HOIST WITH ELECTRICALLY OPERATED TROLLEY	VOLUME II-B
	1X800 MW KOTHAGUDEM TPS	SECTION - C-1
		REV 00
		DATE 30.07.2015
		SHEET 1 OF 3

Sl.no	DESCRIPTION	TECHNICAL PARTICULARS
1.0	Type	Steel wire electric hoist with electrically operated trolley
2.0	Scope (Qty., Capacity, Lift, Travel Length)	Refer the Annexure 1.
3.0	Type of service	Indoor
4.0	Overload test	125% of SWL
5.0	Design Ambient temperature	50° C
6.0	General Design	As per IS: 3938 / 1983 or latest, Class-II duty
7.0	Operating speed	
7.1	Hoisting speed	3 Mtr per min.
7.2	Trolley speed	15 Mtrs per min.
8.0	Type of transmission	Through Electric motor and gear box.
9.0	Wire Rope	Ultimate strength-180Kg/mm ²
9.1	Construction / core	6 x36 construction, steel core/ Fibre core
9.2	Code	IS:2266
9.3	Number of falls	Min. 4
9.4	Factor of safety	Not less than 5
10.0	Load Hook and block	NORMALISED HOOK ONLY
10.1	Type of load hook	Forged steel to IS 15560 C shank, swiveling type with safety Latch and pin
10.2	Load hook Code	IS: 15560
10.3	Load hook Material	Alloy steel/carbon steel as per IS:15560
10.4	Hook suspension	Thrust bearing
10.5	Material of block suspension	Fabricated from steel plate, Material: IS: 2062 Gr.A/B
11.0	Gearing	
11.1	Type	Spur / Helical, hardened and tempered with machine cut teeth
11.2	Gear material	Forged steel as per IS 3938
11.3	Lubrication	Oil splash/ grease lubricated
11.4	Bearing type	Antifriction Ball / Roller
12.0	Trolley drive	
12.1	Wheel	Single flange taper thread
12.2	Wheel conform to (Std. / code)	IS: 3938




TITLE	DATA SHEET – A	SPECIFICATION NO. PE-TS-410-563-A201
	ELECTRIC HOIST WITH ELECTRICALLY OPERATED TROLLEY	VOLUME II-B
	1X800 MW KOTHAGUDEM TPS	SECTION - C-1
		REV 00
		DATE 30.07.2015
		SHEET 2 OF 3

12.3	Wheel material	Heat treated carbon steel/ low alloy steel
12.4	Bearing type	Antifriction Ball / Roller
12.5	Trolley type	Rolled structural steel with side plates extended beyond wheel flanges to protect wheels.
12.6	Hardness	Max hardness 200 BHN
13.0	SHEAVE	
13.1	Material	Fabricated from steel plate. IS:2062Gr.B/as per IS:3938
13.2	Bearing type	Antifriction Ball / Roller.
14.0	BRAKE (HOIST)	
14.1	Type	DC EM brakes disc type (fail to safety).
14.2	Capacity	As per IS 3938.
14.3	Number	One number for each motor.
15.0	BRAKE (TROLLEY)	
15.1	Type	DC EM brakes disc type (fail to safety).
15.2	Capacity	As per IS 3938.
15.3	Number	One number for each motor
16.0	ROPE DRUM	
16.1	Material	Seamless steel pipe. ASTM A106 grade B/Fabricated
16.2	Flange / Flangeless	Flanged
16.3	Type of groove	Right hand groove or Right hand and left hand groove
17.0	TYPE OF DSL	
17.1	CT travel	Shrouded bus bar Cu conductor type DSL
18.0	MOTORS	
18.1	Type	Sq. Cage induction, TEFC, S4 duty, 40% CDF.
18.2	Number of start	150 starts / hr,
18.3	Voltage , Phase and Frequency	415V \pm 10%, 3 phase, 50 Hz \pm 5
18.4	Class of insulation	Class "F" and temperature rise limited to class B.
18.5	Type of enclosure	TEFC
18.6	Degree of protection provided for enclosure	IP-55
18.7	Margin	Motor rating will be calculated keeping margin of at least 15% Over the maximum power requirement in the duty condition Specified




TITLE	DATA SHEET – A	SPECIFICATION NO. PE-TS-410-563-A201
	ELECTRIC HOIST WITH ELECTRICALLY OPERATED TROLLEY	VOLUME II-B
	1X800 MW KOTHAGUDEM TPS	SECTION - C-1
		REV 00 DATE 30.07.2015
		SHEET 3 OF 3


	LIMIT SWITCHES	Hoisting	Trolley
19.1	Type	2nos.Snap action, self actuating type	One (1) no. two way limit switch
20.0	Control panel		<ul style="list-style-type: none"> * Fabricated from Cold rolled sheet steel not less than 2.5mm for front & rear & 2mm for side, top & bottom portion with gland plate of 3mm thick. * Degree of protection shall be IP 54. * Power on indicating lamps shall be provided * Panel illumination lamps operated by door switch. * 2 nos earthing terminals on panel. * 20 % spares terminals (clip on type) shall be provided. * Power and control terminals (clip on type) shall be on separate channels. * Gland plate thickness shall be minimum 3mm. * Gland plate shall be double brass compression type.
20.1	Qty		1 No.
21.0	Pendent Push buttons		Up /down / forward / Reverse push buttons. With indicating lamps
22.0	Emergency stop push button		Provided.(Mushroom head)
23.0	Cables		All cabling shall be XLPE insulated fire resistant (FRLS) cables
24.0	Control Voltage		110 V

MANUFACTURER'S NAME & ADDRESS		MANUFACTURING QUALITY PLAN					PROJECT: 1X800 MW KOTHAGUDEM				
 MANUFACTURER'S NAME & ADDRESS		ITEM: ELECTRIC HOIST		REV			Rev 00		PACKAGE: Electric hoist		
		CAPACITY: -		DATE			Page 1 of 5		BHEL NO: PE-V0-410-563-A201		
		Class		Quantum of check			Reference Document		Acceptance Norms		CONTRACTOR: BHEL
S.NO.	Component & Operation	Characteristics	Class	Type of check	Quantum of check	Reference Document	Acceptance Norms	Format of Record	Agency	Remark	
1	2	3	4	5	6	7	8	9	D M C N	10	
FOR EOT CRANE											
RECEIVING INSPECTION											
1.0	Structural-Plates/RSJ for Main Girders, End Carriages Trolley, Pulley, Gearbox housing, rope drum (if fabricated) etc.	Physical & Chemical	Major	Lab Analysis	100%	IS:2062 Gr. A or B / As per approved G.A.		MTC / Lab Report	P/V	V	
1.2	Rope Drum (Seamless Pipe)	Chemical Mechanical	Major	Lab Analysis	1/pipe	Approved drg/DS ASTM A106 Gr A or B		Lab Report	P	V	
		Flattening & Acid etching Test Surface defect	Major	Mech test Visual	1/pipe 100%	no cracks, pitting, rusting, damage ,etc		I.R.	P	V	
1.3	Gears, pinions, shafts, axles & wheels (#)	Chemical & Mechanical,	Major	Lab Analysis	1/lot	Relevant IS/appd drg		MTC	P	V	
			Major	UT	100%	ASTM A388/NOTE 1		I.R	P	V	
1.4	Hook	Chemical & Mechanical	Major	Lab Analysis	100%	IS: 15560 Related Std. As per appd. Drg./data sheet		MTC	V	V	
		UT (above 50 mm dia)	Major	UT on shank portion only	100%	ASTM A388 / ASME Sec VIII Divn 2 UT report - NOTE:1		UT report	P	V	
1.5	Wire Rope	Examination of report of breaking load Dimension & Type, construction	Major	Review of TC Measurement	100%	IS: 2266 Appd G A drg	IS: 2266 Appd G A drg	Mfr's TC QCR	P	V	
			Major	Measurement	100%				P	V	

		LEGEND: CLASS A: Critical, B: Major, C: Minor		DOC. NO.:	
		** M: MANUFACTURER / SUB-CONTRACTOR D: Records for Data Fold C: CONTRACTOR /NOMINATED INSPECTION AGENCY, ND: NDT LAB N: Customer R: Test / Dim Report, IR-Inspection Report INDICATE "P" PERFORMS, "W" WITNESS, MTC: Mfr's Test Cert. "V" VERIFICATION, ALC: Approved Laboratory Certificate, QCR: Quality Control Report			
MANUFACTURER NAME & SIGNATURE		CONTRACTOR		NAME & SIGN OF APPROVING AUTHORITY & SEAL	

MANUFACTURER'S NAME & ADDRESS		MANUFACTURING QUALITY PLAN					PROJECT: 1X800 MW KOTHAGUDEM						
 BHEL BHEL NO: PE-V0-410-563-A201 CONTRACTOR: BHEL		ITEM: ELECTRIC HOIST					REV	Rev 00	PACKAGE: Electric hoist				
		CAPACITY: -					DATE	Page 2 of 5	BHEL NO: PE-V0-410-563-A201				
S.NO.	Component & Operation	Characteristics	Class	Type of check	Quantum of check	Reference Document	Acceptance Norms	Format of Record	Agency	Remark			
1	2	3	4	5	6	7	8	9	D	M	C	N	
1.6	Motors & cables. Brakes	Make/Type/Rating/ Routine test Make/ type / rating/ HV/IR functional test	Major	Visual / Measurement	100%	Appd drg/DS/Tech spec/Rel IS	I.R	STC	P	V	V	V	For motor, ref. Note 2
1.7	Sheaves	Mech		Tensile & Hardness	1/lot	Approved Drg / Mfg drg		MTC	P	V	V		
1.8	Limit switch, SFU, Relays, MCB, Fuses, Push buttons Etc Control transformer	Make/Type/Rating Functional /continuity Make , type, rating, input/output	Major	Review of TC	100%	Appd drg./DS/Scheme ./Manu.Std		QCR Routine TC/CO C of mfrg	V	V	V		
1.9	DSL	Make , type, rating, Dimension.	Major	Review of TC	100%	Appd drg./DS/Scheme / Manu.Std		QCR Routine TC/CO C of mfrg.	V	V	V		
2	INPROCESS- INSPECTION												
2.1	WPS,PQR & WPQ	Verification of approval				WPS,PQR & WPQ			P	V	V		IN CASE OF NTPC/ LLOYDS / EIL / TPL QUALIFIED WELDERS AVAILABLE, REQUALIFICATION OF WELDER IS NOT REQUIRED.
2.2	Assembled gear box	No load run test backlash & contact pattern, noise, vibration & oil temp rise (for oil lubrictd)	Major	Performance	100%	Apprvd drg/DS/Mfg std Noise 85dba max, vibration 75 mi- crons max, oil temp rise – 30 °C above ambient max			P	V	V		
2.3	Welding of end carriage, Main Girder, Trolley , rope drum (if fabricated) etc.,	DPT of Welds(all) RT of Butt weld	Major Major	LPI RT	100% on butt&10% on fillet 100%/10%	ASTM E 165 or Eq. / No crack or linear indication ASME Sec.VIII,Div.1, UW 51/52		I.R. RT film & report	P P	V V	V V		@RT-100%, for Butt weld in tension & 25% in compression. 100% RT on butt weld for fabricated rope drum

		LEGEND: CLASS A: Critical, B: Major, C: Minor		DOC. NO.:	
		** M: MANUFACTURER / SUB-CONTRACTOR D: Records for Data Fold C: CONTRACTOR /NOMINATED INSPECTION AGENCY, ND: NDT LAB N: Customer R: Test / Dim Report, IR-Inspection Report INDICATE "P" PERFORMS, "W" WITNESS, MTC: Mfr's Test Cert. "V" VERIFICATION, ALC: Approved Laboratory Certificate, QCR: Quality Control Report			
MANUFACTURER		CONTRACTOR		NAME & SIGN OF APPROVING AUTHORITY & SEAL	
NAME & SIGNATURE		19 of 110			

		MANUFACTURER'S NAME & ADDRESS			MANUFACTURING QUALITY PLAN			PROJECT: 1X800 MW KOTHAGUDEM			
		ITEM: ELECTRIC HOIST			REV			PACKAGE: Electric hoist			
CAPACITY: -		DATE			PAGE			BHEL NO: PE-V0-410-563-A201			
Component & Operation		Type of check			Reference Document			CONTRACTOR: BHEL			
S.NO.	Class	Quantum of check	Acceptance Norms	Format of Record	Agency		Remark				
1	4	6	8	9	D	M	C	N	11		
Dry Film Thickness		Measurement			Sample						
Major					P			V -			

NOTE1:*** When back wall echo is set to 100% in sound area then,

- defect echo shall not exceed 20%
- Back echo shall be minimum 80% in any area

Note 2:- Less than 30 KW. Acceptance of motor less than 30 KW is based on COC of the manufacturer & the contractor confirming as follows : It is hereby confirmed that the above mentioned motor/motors was/were manufactured taking care of customer specific requirement regarding ambient temp, voltage & frequency variation, hot start, pull out torque, start current KVA/KW, temp rise, distance between center of stud and gland plate and tested in accordance with approved drawing/data sheet.

MANUFACTURER'S NAME & SIGNATURE		CONTRACTOR'S NAME & SIGNATURE		DOC. NO.:	
<p>LEGEND: CLASS A: Critical, B: Major, C: Minor</p> <p>** M: MANUFACTURER / SUB-CONTRACTOR D: Records for Data Fold C: CONTRACTOR /NOMINATED INSPECTION AGENCY, ND: NDT LAB N: Customer R: Test / Dim Report, IR-Inspection Report INDICATE "P" PERFORMS, "W" WITNESS, MTC: Mfr's Test Cert. "V" VERIFICATION, ALC: Approved Laboratory Certificate, QCR: Quality Control Report 21 of 110</p>					
NAME & SIGN OF APPROVING AUTHORITY & SEAL					

VOLUME : IIIF

SECTION-III

MISCELLANEOUS HOISTS

1.00.00 GENERAL INFORMATION

1.01.00 The hoists will be used for erection and maintenance of various equipment in different buildings.

1.02.00 Hoists are divided into two separate groups - (a) Hand operated and (b) Electric operated.

2.00.00 CODES AND STANDARDS

The design, manufacture and testing of the equipment covered under this specification shall conform to the latest editions of the following Indian Standards:

2.01.00 IS : 3832 : Specification for Hand Operated Chain Pulley-blocks.

2.02.00 IS : 807 : Code of Practice for Design, Manufacture, Erection and Testing (Structural Portion) of Cranes and Hoists.

2.03.00 IS : 6216 : Short link Chain, Grade T(8) for Pulley-blocks & other Lifting Appliances.

2.04.00 IS : 4164 : Lifting 'C' Hooks with Eye Capacity upto 25 tonnes.

2.05.00 IS : 2429 (part -I) : Non-calibrated Load Chain for Lifting Purposes.

2.06.00 IS : 3938 : Specification for Electric Wire Rope Hoists. and other Indian Standards referred to in the above standards.

3.00.00 SCOPE OF WORK

3.01.00 Hoists shall be provided in all areas where any equipment/component weighing above 500 kg is installed and needs to be handled for maintenance purposes. Number of monorail beams shall be such that the centre line of the hoist and the centre line of equipment to be handled shall be not more than 500 mm.

- 3.01.01 The location and no. of hoists is to be finalised during detailed engineering. Final arrangement is subject to approval of Owner/Consultant.
- 3.01.02 Monorail hoists shall at least be provided in the areas mentioned in Annexure-I. The list is indicative only and not an exhaustive one.
- 3.02.00 All drive motors and driving gears as necessary.
- 3.03.00 Limit switches for electrical hoist as necessary.
- 3.04.00 Trailing cable with all supporting fixtures as necessary for electric hoists.
- 3.05.00 Pendant control station with all accessories for electric hoists.
- 3.06.00 Lifting lug, eye bolts etc., for handling hoist parts.
- 3.07.00 Protection guard as specified.
- 3.08.00 Lifting hook block assembly for hoists.
- 4.00.00 **SPECIFIC DESIGN REQUIREMENTS**
- 4.01.00 Lifting capacity
- 4.01.01 Capacity of each hoist shall be 1.2 times the maximum working load.
- 4.01.02 Hoists of capacity upto 5 tones shall be manual hoists.
Hoists of capacity above 5 tones shall be electric hoists.
- 4.02.00 ~~**Effort for Mechanical Hoists**~~
- 4.02.01 ~~Hoisting~~
~~Hoisting effort for hoists upto 3 tones capacity shall not be more than 20 kg.~~
~~Hoisting effort for hoists above 3 tones capacity shall not be more than 25 kg~~
- 4.02.02 ~~Trolley Motion~~
~~Effort for trolley motion for hoists upto 3 tones capacity shall not be more than 15 kg.~~
~~Effort for trolley motion for hoists above 3 tones capacity shall not be more than 20 Kg.~~
- 4.02.03 ~~For Electric operated hoist both hoisting and trolley motion shall be motor operated.~~
- 4.03.00 **Lift**

- 4.03.01 Lift above operating floor
- Highest position of the hook shall be such that during operation of hoists, the vertical distance between bottom of any equipment handled and top of any permanent structure or equipment in the operating area shall be at least one metre.
- 4.03.02 Approach below operating floor
- To be decided by the Bidder for safe and reliable handling of any equipment above half ton below the operating floor.
- 4.04.00 **Length of Monorail Hoist**
- To be decided by the Bidder depending on the floor and machine layout. The horizontal distance between the centre line of the hoist and centre line of any installed equipment in its operating shall not be more than half metre.
- 5.00.00 **DESIGN AND CONSTRUCTION**
- 5.01.00 All parts requiring replacement or lubrication shall be easily accessible without the need for dismantling of other equipment and structures.
- Robust construction and ample rating merging which experience has shown to be necessary shall be ensured throughout manufacture.
- 5.02.00 All components of hoists of identical capacity and duty shall be interchangeable. The hoists of identical capacity and duty shall be identical in all respects unless otherwise required. The hoist design shall be such that these can be quickly removed from one monorail beam and fixed on another beam without disassembling major components.
- 5.03.00 All machinery and equipment included under this specification must be equipped with safety devices and clearances to comply with recognized standards and specification requirements.
- 5.04.00 Cast iron parts wherever used, shall conform to IS:210 - FG 260. Also no wood or other combustible materials shall be used.
- 5.05.00 Defects in material like fractures, cracks, blowholes, laminations, pitting etc. are not allowed. Rectifications of any such flaw is permissible only with the approval of the Purchaser.
- 5.06.00 Each hoist shall be permanently and legibly stamped with the tag number, manufacturer's name, safe working load, grade of load chain (where applicable), range of lift etc.

- 5.07.00 Load chain (where applicable) shall be of grade T(8) as per IS:6216 and Hand chain shall be as per IS:2429 (Part-I) grade 30.
- 5.08.00 Wheels in trolley unit travel shall be single flanged with straight/tapper/barrel shaped tread to suit the monorail. Wheels should be preferably of forged steel construction. Material of construction for wheels of traversing block and hoist gear for hoist used in hazardous areas shall be of non-ferrous material to avoid spark during operation.
- 5.09.00 All gears shall be hardened and tempered steel with machine out teeth.
- 5.10.00 **Hoist (Manually Operated)**
- 5.10.01 Manually operated hoists shall be of spur gear chain pulley block type. It shall be suspended from the trolley by a hook. The design of the hoist shall conform to IS:3832 (Specification for hand operated chain pulley blocks). The hooks and brakes of hoist shall conform to the requirements stipulated in (a) and (b) below
- a) Hooks shall conform to and IS:3832. The load hook shall be swivelling type fitted with a locking device.
 - b) The pulley blocks shall be fitted with an automatic mechanical load brake to prevent self lowering of load in all working positions. The load brake shall also allow smooth lowering of load without serious overheating.
 - c) All manually operated hoists, unless stated otherwise, shall be trolley suspended type.
- 5.10.02 The trolley of hoists shall be manually operated.
- 5.10.03 The hoists shall be of Mechanism class 2 as per IS:3832.
- 5.11.00 **Electric Hoist**
- 5.11.01 Electric hoist shall be electric wire rope trolley suspended type. The design, operation, testing of electric hoist shall conform to IS:3938 (Specification for electric wire rope hoist).
- Minimum speed for hoisting shall be 3 m/min. and that of for trolley motion shall be 15 m/min.
- 5.11.02 Lifting hook shall conform to IS-4164 as applicable.
- 5.11.03 Wire rope for hoists shall conform to IS-2266.
- 5.11.04 Electro-mechanical brakes of fail to safety type shall be provided for hoist motion as well as per trolley motion for electrically driven trolley. Load brake shall allow smooth lowering of load and arrangement shall be such as it can not be released accidentally. Capacity of brake and other relevant data shall conform to IS:3938.

- 5.11.05 The trolley of the hoists shall be electrically driven.
- 5.11.06 For other components of hoist such as rope, sheave, drum, bearings, gears etc. stipulations of IS: 3938 shall be followed.
- 5.11.07 Motor shall be rated for duty S4. Service class of motor shall be "M8" as per IS:3177. Conditions given in IS:3938 for hoist motor shall be followed over and above the specification of electric motor in Volume-V. In case of any contradiction of the aforesaid standard and the motor specification, the conditions which are more stringent shall be considered. All the motors shall be suitable for reversing, frequent starting and braking. Motors shall be provided with suitable space heating arrangement.
- 5.11.08 Hoist shall be designed so that remote control can be effected by means of pendant push button switch from the operating floor. Operation, arrangement etc. of pendant push button switch shall conform to IS:3938.
- 5.11.09 Micro-speed attachment in hoist shall be provided if considered necessary by the Bidder.
- 5.11.10 The hoists shall be of mechanism class 2 as per IS-3938.
- 5.12.00 Ball and roller bearings of reputed make shall be used throughout.
- 5.13.00 Suitable lubrication system shall be provided for all gear drives.
- 5.14.00 **Other Electrical Items**
- 5.14.01 The cross conductor on monorail for power supply to the hoist shall be of festoon type flexible insulated cable conductors. All fixtures and accessories shall be provided by the Bidder for this purpose.
- 5.14.02 Necessary insulators, supports, clamps and all other accessories shall be provided as per standard design.
- 5.14.03 Each hoist shall be provided with a starter panel with protective relays.
- 5.14.04 One main isolating switch shall be used to cut-off the supply to the hoist assembly.
- 5.14.05 One main electro-magnetic contactor together with magnetic overload relay (hand reset) for each motor circuit shall be housed in the protection panel.
- 5.14.06 The operation of overload relay shall interrupt the main magnetic contactor.
- 5.14.07 Adequate short circuit protection shall be provided for main and individual circuits.
- 5.14.08 415V \pm 10%, 3 Phase, 4 Wire, 50 Hz \pm 5%, power supply for the hoist shall be arranged through MCCB unit mounted at standing height at a convenient location near each hoist.

- 5.14.09 Transformers to step down the voltage and rectifiers as necessary shall be provided by the Bidder.
- 5.14.10 All external and internal power, control and auxiliary circuit wiring of the electrical drive and accessories and panels shall be provided. The wiring shall be done with 1100 V grade PVC insulated stranded aluminium conductor cable of suitable size not less than 2.5 sq.mm nominal equivalent copper area of cross-section. All control and auxiliary circuit wiring shall be done with 1100 V grade PVC insulated, 2.5 sq.mm stranded copper conductor. Control wire terminations to the panels shall be made with compression type connectors. Multiway terminal blocks shall be furnished for terminating panel wiring and outgoing cable.
- 5.14.11 The hoist structure, motor frame and metal cases of all electrical equipment including metal conduit shall be effectively connected to earth. All grounding materials shall be supplied under this specification to grounding risers.
- 5.14.12 Single speed control shall be used for both hoist and trolley travel in each direction of motion.
- 6.00.00 **INSPECTION AND TESTING**
- 6.01.00 The manufacturer shall conduct all tests required to ensure that the equipment furnished shall conform to the requirements of the specification and in compliance with the requirements of the latest edition of IS:3832 or equivalent standards for manually operated hoists and shall be as per IS:3938 for electrically operated hoist.
- 6.02.00 All the mono-rail hoists shall also be tested at site as per the stipulation of relevant Indian Standards.
- 7.00.00 **DRAWINGS, DATA AND INFORMATION**
- 7.01.00 General arrangement drawings incorporating all dimensions information on head rooms, lift, wheel loads, hook suspension arrangement and other relevant data for all the hoists.
- 7.02.00 For Mandatory Spares, Spares required for erection and commissioning, Recommended Spares, Special Tools And Tackles, fixtures etc., as required for regular operation and maintenance of the equipment offered and supply of first charge of lubricating oil, inhibitor oil and also adequate quantity of the consumables, please refer Technical Specification Volume-II A.
- 7.03.00 Design calculation for selection of electric motor capacities for electric hoist.
- 7.04.00 Complete list of location, number and capacity of hoists provided.

VOLUME : IIA

SECTION-IV

GENERAL TECHNICAL REQUIREMENTS (As applicable)

1.00.00 CODES AND STANDARDS

1.01.00 Except where otherwise specified, the Plant shall comply with the appropriate Indian Standard or an agreed internationally accepted Standard Specification as listed in the annexure to this Section and mentioned in detailed specifications, each incorporating the latest revisions at the time of tendering. Where no internationally accepted standard is applicable, the Bidder shall give all particulars and details as necessary; to enable the Owner to identify all of the Plant in the same detail as would be possible had there been a Standard Specification.

1.02.00 Where the Bidder proposes alternative codes or standards he shall include in his tender one copy (in English) of each Standard Specification to which materials offered shall comply. In such case, the adopted alternative standard shall be equivalent or superior to the standards mentioned in the specification.

1.03.00 The plant will be designed in compliance with applicable National and International Codes and Standards such as ASME, ASTM, DIN, BS, IEC, IEEE, IS, etc. Wherever specified or required the Plant shall conform to various statutory regulations such as Indian Boiler Regulations, Indian Explosives Act, Indian Factories Act, Indian Electricity Act, Environmental Regulations, etc. Wherever required, approval for the plant supplied under the specification from statutory authorities shall be the responsibility of the Contractor.

1.04.00 In the event of any conflict between the codes and standards referred above, and the requirements of this specification, the requirements, which are more stringent, shall govern.

1.05.00 In case of any change of code, standards and regulations between the date of purchase order and the date the Contractor proceeds with manufacturing the Owner shall have the option to incorporate the changed requirements. It shall be the responsibility of the Contractor to advise Owner of the resulting effect.

1.06.00 Successful Bidder to furnish two (2) sets of latest of national/inter-national codes and standards to owner.

2.00.00 RESPONSIBILITY FOR DESIGN

2.01.00 The Contractor shall assume full responsibility for the design of the whole and every portion of the Plant, whether or not the design work was undertaken specifically in relation to the Contract and whether or not the Contractor was directly involved in the design work.

- 2.02.00 Notwithstanding the Owner's wish to receive the benefits of new, advanced and improved technologies, a prime requirement is that all the systems and components proposed shall have been already adequately developed and shall have demonstrated good reliability under similar, or more arduous conditions elsewhere, at least for continuous 2 years in two different power station.
- 2.03.00 The successful bidder shall have to carry out surge analysis, BFP transient analysis and other transient condition studies as may be necessary and as required by the Owner as per proven engineering practice.
- 2.04.00 The Bid shall include a detailed discussion on the development status of, and the reasons for any changes made in proposed systems or components for the Plant, as compared with similar items previously supplied in other installations cited by the bidder as reference plants.
- 2.05.00 The Bidder may also make alternate offers, provided such offers are superior in his opinion in which case adequate technical information, operating feed back, etc. are to be enclosed with the offer, to enable the Owner to assess the superiority and reliability of the alternatives offered. In case of each alternative offer, its implications on the performance, guaranteed efficiency, auxiliary power consumptions, etc. shall be clearly brought out to the Owner to make an overall assessment. In any case, the base offer shall necessarily be in line with the specifications i.e. Base offer shall be as per the technical specifications and the same will be considered for techno-commercial evaluation.
- 3.00.00 **NAME PLATES (RATING PLATES)**
- 3.01.00 Instruction plates, name plates or labels shall be permanently attached to each main and auxiliary item of plant in a conspicuous position. These plates shall be engraved with the identifying name, type and manufacturers serial number, together with the loading conditions under which the item of plant has been designed to operate.
- 3.02.00 Items such as valves, etc. which are subject to hand operation, shall be provided with nameplates so constructed as to remain clearly legible throughout the life of the plant giving due consideration to the difficult climatic conditions to be encountered. Nameplates shall be securely mounted where they will not be obscured in service by insulation, cladding, actuators or other equipment. Direction of flow is also to be engraved.
- 3.03.00 All trade nameplates and labels shall be in English language. All measurements shall be in M.K.S. Units.
- 3.04.00 The size and location of nameplates shall be subject to Approval of the Engineer.
- 4.00.00 **SAFETY AND SECURITY**
- 4.01.00 The design shall incorporate every reasonable precaution and provision for the safety of all personnel and for the safety and security of all persons and

property. The design shall comply with all appropriate statutory regulations relating to safety. All structures and equipment shall be designed and constructed to withstand every foreseeable static and dynamic loading condition, including loading under earthquake conditions, with an adequate margin of safety.

4.02.00 Ready and safe access with clear head room shall be provided to all parts of the plant for operation, inspection, cleaning and maintenance.

4.03.00 Escape routes and clear ways shall be provided to allow speedy evacuation of the plant in the event of fire or explosion, and the plant layout shall allow for ease of access to all parts of the Works by rescue and fire fighting teams. The plant layout shall be designed to localise and minimise the effects of any fire or explosion. The recommendations of NFPA, OSHA, and TAC etc. as necessary shall be followed in all respects.

4.04.00 The use of corrosive, explosive, toxic or otherwise hazardous materials shall be kept to a minimum during construction and the design of the plant shall minimise the requirement for such materials during operation and maintenance. Where such materials must be used, all necessary precautions shall be taken in the design, manufacture and layout of equipment to minimise the resulting hazard, and all equipment necessary for the protection and first-aid treatment of personnel in the event of accidents shall be provided. Particular attention is drawn to avoid the use of materials containing asbestos in any form.

5.00.00 **GUARDS**

5.01.00 Effective guards and fences must be provided to prevent injury to operators through accident or malpractice.

5.02.00 Mesh guards which allow visual inspection of equipment with the guard in place are generally preferable. The guards shall be constructed of mesh attached to a rigid framework of mild steel rod, tube, or angle and the whole galvanised to prevent loss of strength by rusting or corrosion. The guards shall be designed to facilitate removal and replacement during maintenance.

5.03.00 All drive belts, couplings, gears, sharp metallic edges and chains must be safely guarded. Any lubricating nipple requiring attention during normal running must be positioned where they can be reached without moving the guards.

5.04.00 Guards for couplings and rotating shafts shall be in accordance with BS 5304-1975 or similar approved standard. All rotating shafts and parts of shafts must be covered.

5.05.00 Suitable fencing shall be provided to enclose all openings or doorways used for the hoisting and lowering of machinery etc. This fencing must be securely fixed but quickly detachable when required. A secure hand hold must be provided on each side of the opening or doorway.

6.00.00

LOCATION AND LAYOUT REQUIREMENTS

The majority of plant and equipment (excluding steam generator and some other auxiliaries) shall all be of indoor installation. A broad list of buildings housing such equipment is given elsewhere in this specification. Layout should facilitate access for operation-maintenance and inspection of any one or more equipment/components at a time without disturbing the operation or installation of rest of the plant. Further, Bidder should comply with the criteria given under the various equipment and system specifications as well as those stipulated in Annexure-II attached to this section.

Enclosed General Layout and other tender layout drawings show the location of major installations and auxiliary buildings. The Bidder shall try to retain these locations as far as practicable. The layout of equipment within the power house as shown in the tender drawings is indicative. The Bidder may, subject to Owner's approval alter the same to suit the space requirement of the equipment offered.

Bidder may give as an alternative his own preferred layout clearly indicating the advantages and other implications, if any. Such alternative will not be considered for evaluating the bid, but may be considered with the successful Bidder if Owner/Engineer finds the proposal more attractive in terms of techno-economic consideration.

While developing the layout of buildings the following criteria shall be given effect :

- a) The minimum width of clear access corridors around equipment shall be 1.2 meter.
- b) Each building shall have an identified vacant space for equipment unloading and maintenance and preferably a separate bay altogether in buildings housing heavy equipment. Provision for handling equipment by monorail hoist and/or overhead crane shall be made as specified.
- c) The minimum clear height available between two consecutive floor slabs shall not be less than five (5) meters. A clear head room of 2.5m shall be maintained between the floor and any overhead piping/ cables or other obstruction. Adequate provision for natural ventilation and illumination shall be made as per good engineering practices.
- d) There shall be at least two (2) nos. main access doors, one on either side of each building, of which one shall be minimum 3 meters wide with rolling shutters for equipment entry. For multistoried buildings, at least two (2) nos. regular staircases diagonally opposite to each other shall be provided connecting all the floors and roof. These minimum requirements shall be augmented as required depending on the floor area, statutory requirements and TAC recommendations.
- e) All buildings shall have provision for toilet and associated effluent discharge system together with facility for drinking water. The criteria for ventilation, fire protection and illumination of building spaces specified

elsewhere in this specification shall be complied with.

- f) All rail/road crossings for pipe/cable racks shall be done with minimum 8 meters headroom from top of rail/road to bottom of rack. Similarly top cover over underground pipes/cables shall be minimum one (1) meter. For other detail refer to Annexure-II.
- g) Cubicle for operating personnel shall be located at safe place near the equipment.
- h) Interplant cable routing will be on overhead cable trays on pipe cum cable trestle or on cable trestle except where approved by purchaser/consultant. In exceptional case, small stretch of outdoor run of interplant cable routing may be taken through cable trench only with the Employer's prior approval.
- i) Concept of various mechanical and electrical equipment location and building dimensions (including column-row spacing) as shown in Plot Plan/Floor Plan drawing are to be adhered to. Any departure from this suggestive layout is primarily not recommended.

7.00.00 OPERATION, MAINTENANCE & AVAILABILITY CONSIDERATIONS

7.01.00 Equipment/works offered shall be designed for high availability, high reliability, low maintenance and ease of operation & maintenance. The Bidder shall specifically state the design features incorporated to achieve high degree of reliability, availability, operability and ease of maintenance. He shall also furnish details of availability records in plants stated in his experience list.

7.02.00 Ample space for ease of operation and maintenance including equipment removal, tube bundle/cartridge/rotor pulling etc. shall be provided. All valves, gates, dampers and other devices shall be located and oriented in such a way that they are accessible from operating floor levels. Where this cannot be adhered to, platforms and walkways with access ladders shall be provided to facilitate operation and maintenance.

7.03.0 Motorised lifting devices, i.e. hoists, chain pulleys, jacks, etc. shall be provided for handling and carrying out maintenance of any equipment and/or part having weight in excess of 3000 Kg. Suitable beams, hooks etc. for this purpose shall be provided in the buildings.

No lifting arrangement is necessary for part having weight less than 500 Kg. Hoist shall be well protected by environment. Suitable painting and coating covering hoist at outdoor shall be provided.

Lifting devices like lifting tackles, slings, etc. to be connected to hook of the hoist/crane shall be provided by the Bidder for lifting the equipment, accessories covered under this specification.

7.04.00 All similar parts of the equipment shall be made to gauge and shall be interchangeable with and shall be made of same material and workmanship as the corresponding parts of the equipment. Where feasible common

components shall be employed in different pieces of equipment in order to optimize the spares inventory and utilization.

8.00.00 **MATERIALS**

8.01.00 In selecting materials of construction of equipment, the Contractor shall pay particular attention to the atmospheric conditions existing at the Site and the nature of material/fluid handled. Wherever deviations are taken in respect of materials specified, the reasons shall be spelt out clearly in the proposal.

All materials shall be new, and shall be of the quality most suited to the proposed application.

8.02.00 In as far as is possible; materials shall be in accordance with Indian or international standard specifications and shall be used in accordance with Indian or international codes of practice. Where such standards or codes of practice are not available sufficient information shall be provided to allow the Owner to assess the suitability of the material for the particular application.

All materials used shall have performed lengthy satisfactory service in similar or more arduous conditions to those proposed by the Contractor.

8.03.00 All parts which could deteriorate or corrode under the influence of the atmospheric, meteorological or soil conditions at the Site, or under the influence of the working conditions shall be suitably and effectively protected so that such deterioration or corrosion is a minimum over the life of the plant.

9.00.00 **LUBRICATION**

9.01.00 Provision shall be made for suitable efficient lubrication where necessary to ensure smooth operation free from undue wear.

9.02.00 Non ferrous capillary tubing shall be used throughout.

9.03.00 Gear boxes and oil baths shall be provided with filling and drain plugs, both of adequate size. An approved means of oil indication including level switches and temperature indication shall be provided.

9.04.00 All high speed gears shall be oil bath lubricated. Low speed gears shall be lubricated by means of soft grease. Removable and accessible drip pans shall be provided to collect lubricant which may drop from operating parts.

9.05.00 All lubrication points shall be conveniently situated for maintenance purposes. It must be possible to carry out lubrication from a gangway or landing and without the removal of guarding or having to insert the hand into it. Where accessibility to a bearing for oiling purposes would be difficult a method of remote lubrication shall be fitted.

9.06.00 The Contractor shall supply grease gun equipment suitable to service each type of nipple fitted.

10.00.00 **LUBRICANTS AND CONTROL FLUIDS**

10.01.00 The Contractor shall provide a detailed and comprehensive specification for all lubricating oils, greases and control fluids required for the entire plant. A sufficient supply of these shall be provided by the Contractor for initial commissioning, first fill and till COD of the unit.

10.02.00 The Contractor shall supply a detailed schedule giving the lubricant testing, cleaning and replacement procedures. All equipment and facilities necessary for the testing, cleaning and changing of lubricants and control fluids shall be provided. The Contractor shall endeavor to reduce the varieties and grades of required lubricants and control fluids to a minimum, matching them where possible to those already in use in the generating station in order to simplify procurement and minimise storage requirements. All lubricants and control fluids shall be of internationally recognised standards and shall be easily obtainable from a large number of Indian suppliers. Bidder shall also indicate the equivalent Indian Standard for the above for easy procurement in future.

10.03.00 No lubricant or control fluid shall have toxic or other harmful effects on personnel or on the environment.

11.00.00 **OPERATION AND MAINTENANCE**

11.01.00 The plant shall be designed and constructed so that operation and maintenance manpower requirements are minimised.

The design and layout shall facilitate inspection, cleaning, maintenance and repair. The importance of continuity of operation is second only to that of safety.

11.02.00 Spare parts for equipment shall be interchangeable with the original components and, so far as possible, be of common design and manufacture.

11.03.00 All similar standard components/parts of similar standard equipment provided shall be interchangeable with one another. Further identical equipments shall be provided for similar duties so that the same are interchangeable with one another in totality and component wise.

11.04.00 All heavy parts (500 Kg and above) must be provided with a convenient arrangement for slinging and handling during erection and overhaul. Any item of plant normally stripped or lifted during periods of maintenance and weighing one tonne or above, shall be clearly marked with its weight.

11.05.00 On completion of commissioning, a complete set of tools for the maintenance of the entire plant shall be provided by the Contractor. This shall include all necessary spanners, special wrenches, extraction equipment and any special tools reasonably required by the Engineer. Tools used during erection and commissioning shall not be accepted except with the specific approval of the Engineer.

11.06.00 All equipment and major valves should be provided with adequate maintenance approach and facility.

12.00.00 **PLANT LIFE AND MODE OF OPERATION**

The complete plant including all the equipment and systems individually and collectively shall be designed for continuous operation for an economic service life of thirty (30) years under the prevailing site conditions and for the type of duty intended.

The critical components of the Steam Generator, Turbine-Generator and Auxiliary equipment, the life of which is limited by time and temperature dependent mechanisms such as thermal stress, creep and low cycle fatigue, are to be designed considering expected (hot, warm and cold) start-up, shut-down and cyclic load variations.

The allowable stresses shall be reduced so that life expectancy to minimum 2,00,000 hours of operation can be achieved. The Bidder shall discuss this aspect in his technical proposal.

The unit would be operated on base load with cyclic load variation. The load variation is expected to be as per schedule depending on power demand.

The expected start-ups should be considered as minimum
(Based on HPT metal temperature)

Cold start-up (>72 hrs. shutdown)	:	6 per year
Warm start-up (between 10 to 72 hrs. of shutdown)	:	40 per year
Hot start-up (less than 10 hrs. shutdown)	:	160 per year

13.00.00 **PACKAGING & MARKING**

All the equipment shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at site till the time of erection. While packing all the materials, the limitations from the point of view of availability of railway wagon sizes in India should be taken account of. The details of various wagons normally available with Indian Railways for transportation of heavy equipment shall be considered by the Bidder. The Contractor shall be responsible for all loss or damage during transportation, handling and storage due to improper packing.

As per the information available, the dimensions of OD consignment for transportation of the equipment by rail (if any equipment to be handled through rail transportation) are as below :

a)	Width of the Package (from centre-line of rails - 1.6 metres on both sides)	:	3.2 Meters
b)	Height of the package from rail top	:	4.47 Meters

The above indicates the dimensions which can be normally transported on the

wagons without infringement of the "moving gauge". This is however not indicative of the consignment which can be carried out with infringement of "moving gauge" duly authorised and approved by the Indian Railways. There may be difference between the "moving gauge" and the "fixed structure gauge" and consignments infringing the "moving gauge" can be moved after investigation regarding possible infringement with the fixed structures. As the critical fixed structures in each route are different, consignments infringing moving dimensions have to be individually investigated to select a route and also determine the restrictions under which such movement is to be carried out. Such routes selected or other mode of transport envisaged is to be clearly brought out in the proposal wherever transport of over dimensional equipment is involved.

Bidder to consider unloading of material delivered through rail transportation, at near by railway station/ site unloading siding. The subsequent transportation up to project work place shall be considered by road only. All unloading and handling equipment both at railway station siding and at project site shall be arranged by the Bidder. Necessary arrangement to be organized with the railway authority for such purpose shall also be under the scope of services of the Bidder. Bidder may consider entire material delivered up to site through rail transportation only.

The identification marking indicating the name and address of the consignee shall be clearly marked in indelible ink on two opposite sides and top of each of the packages. In addition the Contractor shall include in the marking gross and net weight, outer dimension and cubic measurement. Each package shall be accompanied by a packing note (in weather proof paper) quoting specifically the name of the Contractor, the number and date of contract and names of the office placing the contract, nomenclature of contents and Bill of Material.

For imported equipment and material, suitable port facilities may be used in which case material may be transported from the port by tractor-trailer. Bidder may consider this aspect.

14.00.00

PROTECTION

Equipment having antifriction or sleeve bearings shall be protected by weather-tight enclosures. Coated surfaces shall be protected against impact, abrasion, discoloration and other damages. Surfaces that are damaged shall be repainted.

Electrical equipment, controls and insulations shall be protected against moisture and water damages. All external gasket surfaces and flange faces, couplings, rotating equipment shafts, bearings and like items shall be thoroughly cleaned and coated with rust preventive compound as specified above and protected with suitable wood, metal or other substantial type covering to ensure their full protection. All exposed threaded parts shall be greased and protected with metallic or other substantial type protectors.

All piping, tubing and conduit connections on equipment and other equipment openings shall be closed with rough usage covers or plugs. Female threaded openings shall be closed with rough usage covers or forged steel plugs. The closures shall be taped to seal the interior of the equipment. Open ends of

pipng, tubing and conduit shall be sealed and taped.

Returnable containers and special shipping devices shall be returned by the manufacturer's field representative at the Contractor's expense.

15.00.00 **ENVIRONMENT PROTECTION AND NOISE LEVEL REQUIREMENT**

15.01.00 **Environment Protection**

The plant shall be designed for installation and operation in harmony with the surrounding environment and all measures of pollution control shall be ensured by the Bidder to restrict pollution from the liquid effluent and stack emission within the limits as given below with due consideration of Environment (Protection) Rules 1986 as amended till date.

In case the Ministry of Environment & Forest stipulate any other conditions not specified hereunder while clearing the project shall be complied with the plant by the contractor.

15.01.01 For Liquid Effluent

- a) Provision laid down in schedule-I for Thermal Power Plants and also in Schedule-VI. General Standards for discharge of Environmental pollutants Part-A : Effects of Environmental (protection) Rules 1986, as amended till date.
- b) Any specific requirement of State Pollution Authorities over and above the above stipulation.

15.01.02 For Air Emission

- a) Suspended Particulate Matter i.e. dust burden at chimney outlet - Maximum 50 mg/Nm³ (with worst coal and one field out at TMCR).
- b) NO_x - 365 ppm Max. or 750 mg/Nm³ (Equivalent NO₂).
- c) SO₂ - Concentration based standard 2000 mg/Nm³. Load based standard 0.2 metric tonne /MWe/day (for first 500 MW and 0.1 metric tonne/MWe/day for rest of the capacity above 500 MW)

In absence of Indian Standard for emission from power plants as on date, for certain gaseous effluents, the internationally accepted World Bank Standard is to be followed. Indian Standard for emission of power plants are under formulation. Should this standard is published before finalisation of the contract, the bidder has to comply the more stringent of the above norm or the new Indian Standard.

The bidder shall include in his scope all necessary equipment and measuring instruments to comply with above requirements. Location and accessibility of the instruments shall be properly coordinated.

15.02.00 **Noise Level Requirement**

The plant will be designed, constructed and provided with suitable acoustic measures to ensure the noise level criteria as per the following stipulations.

- a) Maximum noise level shall not exceed 85 dB (A) when measured at 1.0M away from the noise emission source.
- b) Maximum noise level from its source within the premises shall not exceed 70 dB (A) as per Environment (Protection) Rules 1986, Schedule-III, 'Ambient Air Quality Standards' in respect of noise.
- c) Any statutory changes in stipulations regarding noise limitation that may occur in future according to State Pollution Control Board or Central pollution Control Board or Ministry of Environment & Forest regulation during tenure of the contract, the contractor shall comply with the requirement.

An exception will be made for the plant at startup operations and other big pressure reducing devices operating during emergency periods and for the safety valves.

16.00.00 **INSPECTION AND TESTING**

16.01.00 **Inspection and Tests during Manufacture**

16.01.01 The method and techniques to be used by the Contractor for the control of quality during manufacture of all plant and equipment shall be agreed with the Owner prior to the Award of Contract.

16.01.02 The Owner's general requirements with respect to quality control and the required shop tests are set out elsewhere in this specification.

16.01.03 Before any item of plant or equipment leaves its place of manufacture the Owner shall be given the option of witnessing inspections and tests for compliance with the specification and related standards.

16.01.04 Advance notice shall be given to the Owner as agreed in the Contract, prior to the stage of manufacture being reached, and the piece of plant must be held at this stage until the Owner has inspected the piece, or has advised in writing that inspection is waived. If having consulted the Owner and given reasonable notice in writing of the date on which the piece of plant will be available for inspection, the Owner does not attend the Contractor may proceed with manufacture having forwarded to the Owner duly certified copies of his own inspection and test results.

The Contractor shall forthwith forward to the engineer duly certified copies of the Test Certificates in six copies (one to the Purchaser and five to the Consulting Engineer) for approval. Distribution of six (6) copies of Test Certificates for approval will be two(2) copies to owner and four(4) copies to consultant. These four(4) copies will be further distributed by consultant after approval to owner, site and bidder. One copy will be retained with the

consultant for record purpose.

Further, nine (9) copies of Shop Test Certificates shall be bound with Instruction Manuals referred to elsewhere. Distribution of nine (9) copies of Shop Test Certificates for approval will be Two (2) copies to owner, Three (3) copies to site, Two (2) copies to consultant, Two (2) copies to owner's library / record.

- 16.01.05 Under no circumstances any repair or welding of castings be carried out without the consent of the Owner's Engineer. Proof of the effectiveness of each repair by radiographic and/or other non-destructive testing technique, shall be provided to the Engineer along with Defect Map.
- 16.01.06 All the individual and assembled rotating parts shall be statically and dynamically balanced in the works.
- Where accurate alignment is necessary for component parts of machinery normally assembled on site, the Contractor shall allow for trial assembly prior to despatch from place of manufacture.
- 16.01.07 All materials used for the manufacture of equipment covered under this specification shall be of tested quality. Relevant test certificates shall be made available to the Purchaser. The certificates shall include tests for mechanical properties and chemical analysis of representative material or any other test as required by approved QAP/ Material specification.
- 16.01.08 All pressure parts connected to pumping main shall be subjected to hydraulic testing at a pressure of 150% of shut-off head for a period not less than one hour. Other parts shall be tested for one and half times the maximum operating pressure or as required by design code of that part, for a period not less than one hour.
- 16.01.09 All necessary non-destructive examinations shall be performed to meet the applicable code requirements.
- 16.01.10 All welding procedures adopted for performing welding work shall be qualified in accordance with the requirements of Section-IX of ASME code or IBR as applicable. All welded joints for pressure parts shall be tested by liquid penetrant examination according to the method outlined in ASME Boiler and Pressure Vessel code. Radiography, magnetic particle examination magnuflux and ultrasonic testing shall be employed wherever necessary/recommended by the applicable code. At least 10% of all major butt welding joints shall be radiographed.
- 16.01.11 Statutory payments in respect of IBR approvals including inspection for design and manufacturer of equipment shall be made by the Bidder. All payment for erection and testing at site (i.e. under IBR jurisdiction) shall also be made by the Bidder. In such case Contractor's scope shall also be extended to preparation of all necessary documents, co-ordination and follow-up with IBR authorities for above approval.
- 16.02.00 **Performance Tests at Site**

16.02.01 The full requirements for testing the system shall be agreed between the Owner and the Bidder prior to Award of Contract. The completely erected System shall be tested by the Contractor on site under normal operating conditions. The Contractor shall also ensure the correct performance of the System under abnormal conditions, i.e. the correct working of the various emergency and safety devices, interlocks, etc.

16.02.02 The Bidder shall provide complete details of his normal procedures for testing, for the quality of erection and for the performance of the erected plant. These tests shall include site pressure test on all erected pipe work to demonstrate the quality of the piping and the adequacy of joints made at site.

16.02.03 The Contractor shall furnish the quality procedures to be adopted for assuring quality from the receipt of material at site, during storage, erection, pre-commissioning to tests on completion and commissioning of the complete system/equipment.

16.03.00 For details of specific tests required on individual equipment refer to respective section of this specification.

17.00.00 TRAINING OF OWNER'S PERSONNEL

The Contractor shall extend all possible assistance and co-operation to the Purchaser regarding the transfer of technology and developing expertise in the area of engineering operation and maintenance of the Plant.

Number of man-days of training as mentioned below shall be included in his Tender.

17.01.00 Training at Contractor's Premises

The Contractor shall conduct training of sixty (60) engineers of the Owner on engineering, operation and maintenance of the Plant at the Contractor's or Associates or Sub-contractor's premises where adequate training facilities are available during the design and manufacturing stage of the Contractor.

The total man-months for training of engineers shall be maximum sixty (60), having following indicative break-up :

Discipline	No. of Engineers	No. of Man-month
Operation	20 heads	20
Maintenance Boiler, Turbine, Mechanical	20 heads	20
Electrical Maintenance	8 heads	4
Control & Instrumentation	8 heads	4
Maintenance Planning	4 heads	2
	-----	-----

However, the details of the training programme will be discussed and finalised with the successful Bidder.

The training may also be arranged by the Contractor in any Plant where the equipment manufactured by the Contractor or his Associates is under installation, operation or testing to enable the trainees to become familiar with the equipment being furnished by the Contractor. All expenses inherently related to the training shall be borne by the Contractor and shall include but not limited to travel expenses (international and inland fares), lodging and per diem charges as well as medical insurance, instructors fee, programme and miscellaneous cost to be incurred during the training.

The training programme shall be adequate for the trainees to acquire the necessary expertise and competence in the area of engineering, operation and maintenance and as trainers for in-house technology transfer programme of the Purchaser.

The Contractor shall be responsible for the development of the Training Module and Programme Schedule which shall be submitted to the Purchaser for approval.

The components of the training modules shall include but not be limited to the training procedures/methodology, instructional materials such as audio visual materials, CDs and slides and manuals for each trainee.

Three (3) sets of the materials included in the training modules shall be handed over to the Purchaser upon completion of the training. An evaluation shall be jointly undertaken by the Contractor and the Purchaser's representative on the adequacy, appropriateness and relevance of the training and the programme effectiveness after the training. The training material shall be in English language only.

The content of the training programme shall include but not be limited to:

1. Coal fired thermal plant principles in management and practice for operators, technicians and maintenance personnel.
2. Plant operation and systems training for operators including simulator training as applicable.
3. Maintenance training programme covering electrical, mechanical and instrumentation and control.

Said training programme shall be submitted to the Purchaser for approval.

The timing of the training should be such that the participants will be conversant with sufficient know-how to participate in the pre-commissioning and commissioning tests of the Plant.

The Contractor shall provide qualified English speaking instructors and training

coordinator(s) during the tenure of the training programme.

17.02.00 **Operation and Maintenance Training at Site**

The Contractor shall provide a comprehensive training programme related to design application, plant management, operation and maintenance, including trouble shooting, of the Contractor's supplied system and equipment at the Site starting from Start of Commissioning and thereafter up to the Final Acceptance of the first Unit.

The following instructors shall be at the Site continuously during the training :

- a) One (1) for Steam Generator and Auxiliaries ;
- b) One (1) for Turbine Generator and Auxiliaries ;
- c) One (1) for Electrical Works ;
- d) One (1) for Instrumentation and Control (Boiler and Auxiliaries) ;
- e) One (1) for Instrumentation and Control (Turbine and Auxiliaries).

17.03.00 **On-the-Job Training**

During the period of pre-commissioning, commissioning and trial operation, the Purchaser shall provide operation and maintenance personnel to assist the Contractor in the operation and maintenance of his supply and work under the direction of the Contractor for the purpose of on-the-job training.

The Purchaser shall have the right to send to the Site his employees later intended to operate and maintain the equipment supplied under this Contract. The Contractor shall, without additional cost, use his site staff to instruct these employees on the operation and maintenance of the equipment. All instructions shall be in the English language.

17.04.00 For detail C&I training refer to Volume-VI, Section-9.

18.00.00 **DEVIATIONS**

The Bidder is required to submit with his proposal in the relevant schedules a detail list of any and all deviations taken by him clearly without any ambiguity. In the absence of such a list it will be understood and agreed that the Bidder's proposal is based on strict conformance to this specification and no post-contract negotiations would be allowed in this regard.

Unless otherwise specifically indicated in the deviation list, it will be construed and agreed that details indicated in documents & drawings furnished by the Bidder along with the offer is in-line with the specification requirement.

ANNEXURE-I

LIST OF STANDARDS FOR REFERENCE

- a) International Standards Organisation (ISO).
- b) International Electro-technical Commission (IEC).
- c) American Society of Mechanical Engineers (ASME).
- d) American National Standards Institute (ANSI).
- e) American Society for Testing and Materials (ASTM).
- f) American Institute of Steel Construction (AISC).
- g) American Welding Society (AWS).
- h) Architecture Institute of Japan (AIJ).
- i) National Fire Protection Association (NFPA).
- j) National Electrical Manufacturer's Association (NEMA).
- k) Japanese Electro-technical Committee (JEC).
- l) Institute of Electrical and Electronics Engineers (IEEE).
- m) Federal Occupational Safety and Health Regulations (OSHA).
- n) Instrument Society of America (ISA).
- o) National Electric Code (NEC).
- p) Heat Exchanger Institute (HEI).
- q) Tubular Exchanger Manufacturer's Association (TEMA).
- r) Hydraulic Institute (HIS).
- s) International Electro-Technical Commission (IEC) Publications.
- t) Power Test Code for Steam Turbines (PTC).
- u) Applicable German Standards (DIN).
- v) Applicable British Standards (BS).
- w) Applicable Japanese Standards (JIS).

- x) Electric Power Research Institute (EPRI).
- y) Standards of Manufacturer's Standardization Society (MSS).
- z) Bureau of Indian Standards Institution (BIS).
- aa) Indian Electricity Rules.
- bb) Indian Boiler Regulations (IBR).
- cc) Indian Explosives Act.
- dd) Indian Factories Act.
- ee) Tariff Advisory Committee (TAC) rules.
- ff) Emission regulation of Central Pollution Control Board (CPCB).
- gg) Pollution Control regulations of Dept. of Environment, Govt. of India
- hh) Central Board of Irrigation and Power (CBIP) Publications.
- ii) The Air Prevention and Control of Pollution Act.
- jj) The Environmental Protection Act
- kk) The Public Liability Insurance Act.
- ll) The Forest Conservation Act
- mm) The Wildlife protection Act.
- nn) The EIA Notification, 1994.
- oo) IS: 14665-Specification for Electric Traction Lift
- pp) Any other statutory Codes/Standards/Regulations

**TELANGANA STATE POWER GENERATION
CORPORATION LTD
TELANGANA STATE, INDIA**

**1x800 MW KOTHAGUDAM TPS STAGE-VII UNIT#12,
PALONCHA**

VOL. IIB/SECTION-C2

**TECHNICAL SPECIFICATION
(ELECTRICAL PORTION)**



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT,
NOIDA, U.P., INDIA**



TITLE:
**ELECTRICAL EQUIPMENT SPECIFICATION
FOR**

1X800 MW KOTHAGUDEM TPS

SPECIFICATION NO.
VOLUME NO. : **II-B**
SECTION: **C**
REV NO. : **00** DATE: 19/03/2015
SHEET: 1 OF 1

CONTENTS

SECTION	TITLE	NO OF SHEETS
C	SPECIFIC TECHNICAL REQUIREMENTS	1
C	ELECTRICAL SCOPE BETWEEN BHEL & VENDOR	1
C	ELECTRICAL LOAD DATA FORMAT	1
C	DATASHEET-A	1
C	CABLE SCHEDULE FORMAT	1
D	QUALITY PLAN (FOR MOTORS BELOW 55 KW)	2
D	QUALITY PLAN (FOR MOTORS ABOVE & 55 KW)	9
D	SECTION II: TECHNICAL SPECIFICATION FOR AC & DC MOTORS	14
D	SECTION IV: TECHNICAL SPECIFICATION FOR CABLES	17



TECHNICAL SPECIFICATION FOR
CRANES & HOISTS
(ELECTRICAL PORTION)

SPECIFICATION NO.
VOLUME II B
SECTION-C
REV 0 DATE 19.03.2015
PAGE 1 OF 2

SPECIFIC TECHNICAL REQUIREMENTS: ELECTRICAL

1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:

- a) Services and equipment as per “Electrical Scope between BHEL and Vendor”.
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Electrical load requirement for Cranes.
- e) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- f) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer/BHEL approval without any commercial and delivery implications to BHEL
- g) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL.
- h) Motor shall meet minimum requirement of motor specification.
- i) Vendor to clearly indicate equipment locations and local routing lengths in their cable listing furnished to BHEL.
- j) Cable BOQ worked out based on routing of cable listing provided by the vendor for “both end equipment in vendor’s scope” shall be binding to the vendor with +10 % margin to take care of slight variation in routing length & wastages.

2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:

Refer “Electrical Scope between BHEL and Vendor”.

3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID

- 3.1 The electrical specification without any deviation from the technical/quality assurance requirements stipulated shall be deemed to be complied by the bidder in case bidder furnishes the overall compliance of package technical specification in the form of compliance certificate/No deviation certificate.
- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.



TECHNICAL SPECIFICATION FOR
CRANES & HOISTS
(ELECTRICAL PORTION)

SPECIFICATION NO.
VOLUME II B
SECTION-C
REV 0 DATE 19.03.2015
PAGE 2 OF 2

4.0 List of enclosures :

- a) Electrical scope between BHEL & vendor (Annexure –I)
- b) Technical specification for motors.
- c) Datasheets & quality plan for motors.
- d) Electrical Load data format (Annexure –II)
- e) BHEL cable listing format (Annexure –III)
- f) Electrical mandatory spares (As per spec.)

STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS)

PACKAGE: **ELECTRIC HOISTS**

SCOPE OF VENDOR: SUPPLY

PROJECT : 1X800 MW KOTHAGUDEM TPS

<u>S. NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&C</u>	<u>REMARKS</u>
1	Isolating Switch	Vendor	BHEL	BHEL will provide one number 415 V(3Ph,4W) supply feeder only up to isolating switches for cranes/ hoists. Any other voltage level (AC/DC) required will be derived by the vendor. Motor starter shall be part of crane/ hoist control panel.
2	Power cables, control cables, screened control cables and any special cables (if required) between equipment supplied by vendor.	Vendor	BHEL	Cable from supply feeder to isolating switch shall be in BHEL scope.
3	Cabling material (cable trays, accessories, cable tray supporting system, conduits etc).	Vendor	BHEL	
4	Equipment Earthing	BHEL	BHEL	All equipment metallic enclosures / frames, metal structure etc. shall be grounded at two points each to the nearest grounding points / risers provided by BHEL
5	Motors	Vendor	BHEL	
6	Cable glands and lugs for equipment supplied by vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power & control cables.
7	a) Input cable schedules (C & I) b) Cable interconnection details for above c) Cable block diagram	Vendor Vendor Vendor	- - -	Cable listing for Control and Instrumentation Cable in enclosed excel format shall be submitted by vendor during detailed engineering stage.
8	Equipment layout drawings	Vendor	-	
9	Electrical Equipment GA drawing	Vendor	-	For necessary interface review.



TITLE

LV MOTORS**DATA SHEET-A**

SPECIFICATION NO.

VOLUME II B

SECTION C


REV NO. 00 DATE 19.03.2015


SHEET 1 OF 1

- 1.0 Design ambient temperature : 50 °C
- 2.0 Maximum acceptable kW rating of LV motor : <175 KW
- 3.0 Installation (Indoors/ Outdoors) : As required
- 4.0 Degree Of Protection : IP55 - Outdoor
IP54 – Indoor
- 5.0 Details of supply system
- a) Rated voltage (with variation) : 415V ± 10%
 - b) Rated frequency (with variation) : 50 Hz (Variation: +3% TO –5%)
 - c) Combined voltage & freq. variation : 10% (sum of absolute values)
 - d) System fault level at rated voltage : 25 kA for 1 sec
 - e) Short time rating for terminal box : 25 kA for 0.25 sec
 - f) LV System grounding : Solidly
- 6.0 Class of insulation : Class 'F',with temp rise limited to class B.
- 7.0 Minimum voltage for starting : 85% of rated voltage
(As percentage of rated voltage)
- 8.0 Power cables data : Shall be given during Detailed engg.
- 9.0 Earth Conductor Size & Material : Shall be given during Detailed engg.
- 10.0 Space heater supply (30KW & ABOVE) : 240 V, 1Φ , 50 Hz
- 11.0 Rating up to which Single phase motor : Acceptable below 0.20 Kw
- 12.0 TYPE OF STARTER PROVIDED IN MCC : DOL
- 13.0 Locked rotor current
- a) Limit as percentage of FLC : 600%
 - b) Permissible tolerance, if any : ±20%
- 14.0 Additional tests : As per QP
- 15.0 Flame-proof motor
- a) Enclosure suitable (As per IS:2148) : As per requirement
 - b) Classification of Hazardous area : As per requirement
(As per IS: 5572 part-I)
 - c) Degree of protection : IP65
- 16.0 Makes : AS PER ANNEXURE- III
- 17.0 Terminal box : Suitable to rotate at 90 degrees
- 18.0 Paint shade : As per Annexure-II

All LT motors shall be controlled as follows:

- a) Up to 110kW: - Contactor operated.
- b) 110Kw to 175kW shall have ACB.

		CUSTOMER :			PROJECT			SPECIFICATION :				
		BIDDER/ VENDOR SYSTEM			TITLE			NUMBER :				
QUALITY PLAN		NUMBER PED-506-00-Q-006_REV-01			SPECIFICATION TITLE			SECTION VOLUME III				
SHEET 1 OF 2		ITEM AC ELECT. MOTORS BELOW 55KW (LV)			FORMAT OF RECORD			AGENCY				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	9	P	W	V	REMARKS
1	2	3	4	5	6	7	8	9	10			11
1.0	ASSEMBLY	1.WORKMANSHIP 2.DIMENSIONS 3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/COLOUR CODE 1.SHADE	MA	VISUAL	100%	MANUF'S SPEC	MANUF'S SPEC	-DO-	2	-	-	
			MA	-DO-	-DO-	MFG. DRG./ MFG. SPEC.	MFG. DRG./ MFG. SPEC.	-DO-	2	-	-	
			MA	VISUAL	100%	MFG.SPEC/ RELEVANT IS	MFG.SPEC/ RELEVANT IS	-DO-	2	-	-	
2.0	PAINTING		MA	VISUAL	SAMPLE	MANUF'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
3.0	TESTS	1.ROUTINE TEST INCLUDING SPECIAL TEST AS PER BHEL SPEC. 2.OVERALL DIMENSIONS & ORIENTATION	MA	-DO-	100%	IS-325/ BHEL SPEC/ DATA SHEET	SAME AS COL.7	TEST REPORT	2	1		NOTE -1 & NOTE-3
			MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPN. REPORT	2	1	-	NOTE -1 & NOTE-3
BHEL		PARTICULARS			BIDDER/VENDOR							
		NAME										
		SIGNATURE										

		QUALITY PLAN			CUSTOMER :		PROJECT TITLE		SPECIFICATION :		
BIDDER/ :		QUALITY PLAN			NUMBER :		SPECIFICATION :		TITLE :		
VENDOR SYSTEM		NUMBER PED-506-00-Q-006, REV-01			ITEM AC.ELECT. MOTORS BELOW 55KW (LV)		SECTION		VOLUME III		
SL. NO.	COMPONENT/OPERATION CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	7	8	9	10	11	AGENCY	REMARKS
					REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	P	W	V	
1	2	3	4	5	6	7	8	9	10	11	
	3.NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT	2	1	-	
	NOTES:										
	1. ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION. (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.										
	2. FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW . ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.										
	3. <u>Legends for Inspection agency</u>										
	1. BHEL/CUSTOMER										
	2. VENDOR (MOTOR MANUFACTURER)										
	3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)										
	P. PERFORM										
	W. WITNESS										
	V. VERIFY										
BHEL		PARTICULARS			BIDDER/VENDOR						
		NAME									
		SIGNATURE									
		DATE									
										BIDDER'S/VENDORS COMPANY SEAL	

VOLUME: V-A

SECTION-II

**TECHNICAL SPECIFICATION
FOR
A.C. & D.C. MOTORS**

CONTENT

CLAUSE NO.	DESCRIPTION
1.00.00	SCOPE
2.00.00	CODES & STANDARDS
3.00.00	SERVICE CONDITIONS
4.00.00	TYPE AND RATING
5.00.00	PERFORMANCE
6.00.00	SPECIFIC REQUIREMENTS
7.00.00	ACCESSORIES
8.00.00	TESTS
9.00.00	DRAWINGS, DATA & MANUALS
ATTACHMENT	
ANNEXURE-A	DESIGN DATA

VOLUME: V-A

SECTION-II

**TECHNICAL SPECIFICATION
FOR
A.C. & D.C. MOTORS**

- 1.00.00 **SCOPE**
- 1.01.00 This section covers the general requirements of the drive motors for power station auxiliary equipment.
- 1.02.00 Motors shall be furnished in accordance with both this general specification and the accompanying driven equipment specification.
- 1.03.00 In case of any discrepancy, the driven equipment specification shall govern.
- 2.00.00 **CODES & STANDARDS**
- 2.01.00 All motors shall conform to the latest applicable IS, IEC and CBIP Standards/ Publications except when otherwise stated herein or in the driven equipment specification.
- 2.02.00 Major standards, which shall be followed, are listed below other applicable Indian Standards for any component part even if not covered in the listed standards shall also be followed:
- i) IS-325
 - ii) IS-12615
 - iii) IEC-60034
- 3.00.00 **SERVICE CONDITIONS**
- 3.01.00 The motors will be installed in hot, humid and tropical atmosphere highly polluted at places with coal dust and/or fly ash.
- 3.02.00 Unless otherwise noted, electrical equipment/system design shall be based on the service conditions and auxiliary power supply given in the annexure to this specification.
- 3.03.00 For motor installed outdoor and exposed to direct sunrays, the effect of solar heat shall be considered in the determination of the design ambient temperature.
- 4.00.00 **TYPE AND RATING**
- 4.01.00 **A.C. Motors**
- 4.01.01 Motors shall be general purpose, constant speed, squirrel cage, three/single phase, induction type.

- 4.01.02 All motors shall be rated for continuous duty. They shall also be suitable for long period of inactivity.
- 4.01.03 LT motor & HT motor name-plate rating at 50°C shall have at least 15% margin and 10% margin respectively over the input power requirement of the driven equipment at rated duty point unless stated otherwise in driven equipment specification.
- 4.01.04 The motor characteristics shall match the requirements of the driven equipment so that adequate starting, accelerating, pull up, break down and full load torques are available for the intended service.
- 4.01.05 Motors efficiency class shall be IE1, IE2 as per latest version of IEC-60034.
- 4.02.00 **D.C. Motors**
- 4.02.01 D.C. motor provided for emergency service shall be shunt/compound wound type.
- 4.02.02 Motor shall be sized for operation with fixed resistance starter for maximum reliability.
- Starter panel complete with all accessories shall be included in the scope of supply.
- 5.00.00 **PERFORMANCE**
- 5.01.00 **Running Requirements**
- 5.01.01 Motor shall run continuously at rated output over the entire range of voltage and frequency variations as given in the annexure.
- 5.01.02 The motor shall be capable of operating satisfactorily at full load for 5 minutes without injurious heating with 75% rated voltage at motor terminals.
- 5.01.03 The motor shall be designed to withstand momentary overload of 60% of full load torque for 15 second without any damage.
- 5.02.00 **Starting Requirements**
- Motor shall be designed for direct online starting at full voltage. Breakaway starting current as percentage of full load current for various motor rating shall not exceed the given below-
- | | | |
|---------------------|---|---|
| Motors up to 1500kW | - | 600% subject to IS tolerance of plus 20%. |
| Motors above 1500kW | - | 450% not subject to any positive tolerance. |
- 5.02.01 The motor shall be capable of withstanding the stresses imposed if started at 110% rated voltage.

- 5.02.02 Motor shall start with rated load and accelerate to full speed with 80% rated voltage at motor terminals except mill motor. Mill motor shall start with rated load and accelerate to full speed at 85% of the rated voltage at the motor terminals.
- 5.02.03 a) Two hot starts in succession with motor initially at normal running temperature.
b) Pump motor subject to reverse rotation shall be designed to withstand the stresses encountered when starting with shaft rotating at 125% rated speed in reverse direction.
- 5.02.04 The motors shall be designed to withstand 120% of rated speed for 2 minutes without any mechanical damage.
- 5.03.00 **Stress During Bus Transfer**
- 5.03.01 The motor may be subjected to sudden application of 150% rated voltage during bus transfer, due to the phase difference between the incoming voltage and motor residual voltage.
- 5.03.02 The motor shall be designed to withstand any torsional and/or high current stresses, which may result, without experiencing any deterioration in the normal life and performance characteristics.
- 5.04.00 **Locked Rotor Withstand Time**
- 5.04.01 The locked rotor withstand time under hot condition at 110% rated voltage shall be more than motor starting time by at least 3 seconds for motors up to 20 seconds starting time and by 5 seconds for motor with more than 20 seconds starting time.
- 5.04.02 Starting time mentioned above is at minimum permissible voltage of 80% rated voltage.
- 5.04.03 Hot thermal withstand curve shall have a margin of at least 10% over the full load current of the motor to permit relay setting utilising motor rated capacity.
- 6.00.00 **SPECIFIC REQUIREMENTS**
- 6.01.00 **Enclosure**
- 6.01.01 All motor enclosures for outdoor, semi-outdoor & indoor application shall conform to the degree of protection IP-55 unless otherwise specified. Motor for outdoor or semi-outdoor service shall be of weather-proof construction with canopy.
- 6.01.02 For hazardous area approved type of increased safety enclosure shall be furnished.
- 6.02.00 **Cooling**
- 6.02.01 The motor shall be self ventilated type, either totally enclosed fan cooled IC 411(TEFC), totally enclosed tube ventilated IC 511(TETV) or closed air circuit air- cooled IC 611(CACA).

- 6.02.02 For large capacity motors not available with above type of cooling may be accepted with IC 81W or IC 91W, closed air circuit water cooled (CACW) subject to the approval of the owner.
- 6.03.00 **Winding and Insulation**
- 6.03.01 All insulated winding shall be of copper.
- 6.03.02 All motors shall have class F insulation but limited to class B temperature rise.
- 6.03.03 Windings shall be impregnated to make them non-hygroscopic and oil resistant.
- 6.04.00 **Tropical Protection**
- 6.04.01 All motors shall have fungus protection involving special treatment of insulation and metal against fungus, insects and corrosion.
- 6.04.02 All fittings and hardwares shall be corrosion resistant.
- 6.05.00 **Bearings**
- 6.05.01 Motor shall be provided with antifriction bearings, unless sleeve bearings are required by the motor application. Bearings shall be rated for minimum service life of 40,000Hrs.
- 6.05.02 Vertical shaft motors shall be provided with thrust and guide bearings. Thrust bearing of tilting pad type is preferred.
- 6.05.03 Bearings shall be provided with seals to prevent leakage of lubricant or entrance of foreign matters like dirt, water etc. into the bearing area.
- 6.05.04 Sleeve bearings shall be split type, ring oiled, with permanently aligned, close running shaft sleeves.
- 6.05.05 Grease lubricated bearings shall be pre-lubricated and shall have provisions for in-service positive lubrication with drains to guard against over lubrication. LT motors 15kW and above shall be provided with external greasing arrangement.
- 6.05.06 Oiled bearing shall have an integral self cooled oil reservoir with oil ring inspection ports, oil sight glass with oil level marked for standstill and running conditions and oil fill and drain plugs.
- 6.05.07 Forced lubricated or water cooled bearing shall not be used without prior approval of Owner.
- 6.05.08 Lubricant shall not deteriorate under all service conditions. The lubricant shall be limited to normally available types with IOC equivalent.
- 6.05.09 Bearings shall be insulated as required to prevent shaft current and resultant bearing damage.
- 6.06.00 **Noise & Vibration**

- 6.06.01 All HT motors shall be provided with vibration pads for mounting of vibration detectors. Vibration monitoring devices shall be provided on DE and NDE side in x&y direction with remote DCS monitoring, alarm and tripping.
- 6.06.02 The maximum double amplitude vibrations for HT motors upto 1500 rpm shall be 25 microns and 15 microns upto 3000 rpm. For 415V motors, maximum double amplitude vibrations upto 1500 rpm shall be 40 microns and 15 microns upto 3000 rpm.
- 6.06.03 The noise level shall not exceed 85db (A) at 1.5 meters from the motor.
- 6.07.00 **Motor Terminal Box**
- 6.07.01 Motor terminal box shall be detachable type and located in accordance with Indian Standards clearing the motor base- plate/ foundation
- 6.07.02 Terminal box shall be capable of being turned 360 Deg. in steps of 180 Deg. for HT motors and 90 Deg. for LT motors unless otherwise approved.
- 6.07.03 The terminal box shall be split type with removable cover with access to connections and shall have the same degree of protection as motor.
- 6.07.04 The terminal box shall have sufficient space inside for termination/connection of XLPE insulated armoured aluminium cables.
- 6.07.05 Terminals shall be stud or lead wire type, substantially constructed and thoroughly insulated from the frame.
- 6.07.06 The terminals shall be clearly identified by phase markings, with corresponding direction of rotation marked on the non-driving end of the motor.
- 6.07.07 The terminal box shall be capable of withstanding maximum system fault current for a duration of 0.25 sec.
- 6.07.08 For 11000V and 3300V motor, the terminal box shall be phase-segregated type. The neutral leads shall be brought out in a separate terminal box (not necessarily phase segregated type) with shorting links for star connection.
- 6.07.09 Motor terminal box shall be furnished with suitable cable lugs and double compression brass glands to match with cable used.
- 6.07.10 The gland plate for single core cable shall be non-magnetic type.
- 6.07.11 Minimum clearances to be provided between phase to phase and phase to earth shall be as under-

Voltage Rating of Motor	:	Minimum Ph-Ph & Ph-Earth clearance
0.415 kV	:	25 mm
3.3 kV	:	65 mm
11.0 kV	:	140 mm

Note: In case it is not possible to maintain these clearances, the live parts shall be totally insulated from earth and other Phases. Adequate clearances shall be provided for cable connections.

6.08.00 **Grounding**

6.08.01 The frame of each motor shall be provided with two separate and distinct grounding pads complete with tapped hole, GI bolts and washer.

6.08.02 The grounding connection shall be suitable for accommodation of ground conductors as follows:

Rating	Conductor Size
Above	Up to
-----	5.5 kW : 8 SWG GI Wires.
5.5 kW	22 kW : 25mm X 4mm GS Flat.
23 kW	55 kW : 40mm X 6mm GS Flat.
56kW	174kW : 50mm X 8mm GS Flat.
175kW	ABOVE : 75mm X 10mm GS Flat.

6.08.03 The cable terminal box shall have a separate grounding pad.

6.09.00 **Minimum Cable Size for LT & HT Motors shall as be as follows-**

a) For 415V, 3-Ph, LT Motors-

Rating	Cable Size
Above	Up to
-----	5.5 kW : 1R X 3C X 6 Sq.mm
5.5 kW	11 kW : 1R X 3C X 10 Sq.mm
11 kW	22 kW : 1R X 3C X 35 Sq.mm
22 kW	37.5 kW : 1R X 3C X 70 Sq.mm.
37.5kW	55 kW : 1R X 3C X 150 Sq.mm
55 kW	75 kW : 1R X 3C X 300 Sq.mm
75 kW	110kW : 2R X 3C X 150 Sq.mm
110 kW	175kW : 2R X 3C X 300 Sq.mm

b) For 3.3kV & 11kV, 3-Ph, HT Motors-

Rating	Cable Size
Above	Up to

175 kW	1000 kW	:	1R X 3C X 240 Sq.mm
1000 kW	2000 kW	:	2R X 3C X 240 Sq.mm
2000 kW	4500 kW	:	2R X 3C X 300 Sq.mm
4501 kW	10,000 kW	:	9R X 1C X 1000 Sq.mm.

Note: During detail engineering if higher cable size is required same shall be provided.

6.10.00 **Rating Plate**

In addition to the minimum information required by IS, the following information shall be shown on motor rating plate :

- a) Temperature rise in Deg.C under rated condition and method of measurement.
- b) Degree of protection.
- c) Bearing identification no. and recommended lubricant.
- d) Location of insulated bearings.

7.00.00 **ACCESSORIES**

7.01.00 **General**

Accessories shall be furnished, as listed below, or if otherwise required by driven equipment specification or application.

7.02.00 **Space Heater**

7.02.01 Motor of rating 30 kW and above shall be provided with space heaters, suitably located for easy removal or replacement.

7.02.02 The space heater shall be rated 240 V, 1 Phase, 50Hz and sized to maintain the motor internal temperature above dew point when the motor is idle.

7.02.03 Minimum Cable Size for space heater shall be as listed-

- i) For LT motors: 2.5 sq.mm, 2-Core copper cable complying with IS-1554(Part-1).
- ii) For HT motors: 6 sq.mm, 2 Core aluminium cable complying with IS-1554(Part-1).

7.03.00 **Temperature Detectors**

7.03.01 All 11000V and 3300V motors shall be provided with twelve (12) nos. simplex type winding temperature detectors, four (4) nos. per phase.

- 7.03.02 11000V and 3300V motor bearing shall be provided with duplex type temperature detectors.
- 7.03.03 The temperature detector mentioned above shall be resistance type, 3 wire, platinum wound, 100 Ohms at 0°C.
- 7.03.04 Leads of all simplex type motor winding RTDS and motor bearing RTDS shall be wired up to respective switchgear metering & protection compartment. From which one set of RTDS will be connected to numerical protection relay and another set shall be kept free for DDCMIS connectivity.
- 7.03.05 0.5 sq.mm annealed tinned copper conductor complying with IS-1554(Part-1). shall be used for RTD/BTD wiring.
- 7.04.00 **Indicator/Switch**
- 7.04.01 Dial type local indicator with alarm contacts shall be provided for the following:
- a) 11000 V and 3300V motor bearing temperature.
 - b) Hot and cold air temperature of the closed air circuit for CACA and CACW motor.
- 7.04.02 Flow switches shall be provided for monitoring cooling water flow of CACW motor and oil flow of forced lubrication bearing, if used. CACW motor shall be provided with water leakage detector with remote alarm and tripping.
- 7.04.03 Alarm switch contact rating shall be minimum 2.0 A at 220V D.C. and 10A at 240V A.C.
- 7.05.00 **Current Transformer for Differential Protection**
- 7.05.01 Motor 1000 kW and above shall be provided with three differential current transformers mounted over the neutral leads within the enclosure.
- 7.05.02 The arrangement shall be such as to permit easy access for C.T. testing and replacement. Current transformer characteristics shall match Owner's requirements to be intimated later.
- 7.06.00 **Accessory Terminal Box**
- 7.06.01 All accessory equipment such as space heater, temperature detector, current transformers etc., shall be wired to and terminated in terminal boxes, separate from and independent of motor (power) terminal box.
- 7.06.02 Accessory terminal box shall be complete with double compression brass glands and pressure type terminals to suit owner's cable connections.
- 7.07.00 **Drain Plug**
- Motor shall have drain plugs so located that they will drain the water, resulting from the condensation or other causes from all pockets of the motor casing.

7.08.00 **Lifting Provisions**

Motor weighing 25 Kg. or more shall be provided with eyebolt or other adequate provision of lifting.

7.09.00 **Dowel Pins**

The motor shall be designed to permit easy access for drilling holes through motor feet or mounting flange for installation of dowel pins after assembling the motor and driven equipment.

7.10.00 **Painting**

For paint shade finish, refer Section-X of Volume: II-A : Lead Specification.

8.00.00 **TESTS**

Routine and Type Tests are to be conducted in presence of customer's representative as per IS:325 and in addition, any special test called for in the driven equipment specification shall be performed and required copies of test certificates are to be furnished for approval. In addition, following tests shall have to be carried out on the motors in presence of OWNER's representative on 3.3kV/11kV motors.

- a. Impulse test by 1.2 / 50 micro sec. On sample coil of Stator winding insulation as type test as per IEC-60034, part -15 test voltages as under :

Voltage rating of motor	Impulse Test Voltage
3.3 kV	18 kV peak
11 kV	49 kV peak

- b. Tan delta, charging current and dielectric loss measurements on each phase of motor stator winding as routine test.
- c. Polarization Index Test as per IS: 7816 as routine test
- d. Test for suitability of IPW- 55(Weather proof) as per IS 4691 as type test. Type test certificate for first numeral shall be acceptable in lieu to test, provided the test motor is identical to motor being supplied. Second numeral test shall be carried out on one motor of each type and rating.
- e. Fault Withstand Test for main terminal box as type test. Type test certificate shall be acceptable, if the test is conducted on exactly identical terminal box.
- f. Test for noise level as routine test.
- g. Test for vibration as routine test.

- h. Tan delta measurement on coils.
- i. Surge withstand test for inter turn insulation.
- j. Test to diagnose rotor bar failure during manufacture.
- k. Over speed test as routine test.
- l. Temperature rise test.

Temperature rise under normal condition above ambient temperature shall be limited to-

Specified Design Ambient temperature	Thermometer Method	Resistance Method
50 deg.C	60 deg.C	70 deg.C
45 deg.C	65 deg.C	75 deg.C
40 deg.C	70 deg.C	80 deg.C

Tests indicated at (h), (i), (j) shall be carried out during manufacture of the coils and shall be furnished for verification.

9.00.00 **DRAWINGS, DATA & MANUALS**

9.01.00 Drawings, Data & Manuals shall be submitted in triplicate with the bid and in quantities and procedures as specified in General Conditions of Contract and/or elsewhere in the specification for approval and subsequent distribution after the issue of 'Letter of Intent'.

9.02.00 **To be Submitted with the bid**

- a) List of the motors
- b) Individual motor data sheet as per format of the proposal data sheets.
- c) Scheme & write-up on forced lubrication system, if any
- d) Type test report

9.03.00 **To be submitted for Owner / Purchaser's Approval and Distribution**

All relevant drawings and data pertaining to the equipment like GTP, GA drawing, foundation plan, QAP, etc. shall be submitted by the Bidder for approval of Owner/Owner's consultant. Also refer clause no. 1.19.02(u) of Section-I of Volume – V-A: Technical Specifications for Electrical Equipment & Accessories.

ANNEXURE-A

DESIGN DATA

1.0 AUXILIARY POWER SUPPLY

Supply	Description	Consumer
H.V. Supply	11000 V, 3Ø, 3W, 50 Hz, Non-effectively earthed Fault level 44 kA symm. for 1 sec.	Motors 1500 kW & above
M.V. Supply	3300 V, 3Ø, 3W, 50 Hz, Non-effectively earthed Fault level 40 kA symm. for 1 sec.	Motors 175 kW and Up to less than 1500 kW.
L.V. Supply (i)	415V, 3Ø, 3W, 50 Hz effectively earthed Fault level 50 kA symm. for 1 sec.	Motors above 0.2kW and below 175kW.
(ii)	240V AC/415V AC 240V, 1Ø, 2W, 50 Hz effectively earthed	Motors upto 0.2kW. Lighting, Space heat- ing , A.C supply for Contr- ol & protective devices.
D.C. Supply	220V, 2W, unearthed Fault level 25* kA. for 1 sec.	D.C. alarm, control & protective devices

* Indicative only, the actual value will be decided by the Bidder, after substantiating the same by calculation.

Note-

- 415V or 3.3 kV may be adopted by the bidder for the drives in the range of 160-210 kW.
- 3.3 kV AC supply for CHP conveyor motors of rating above 160 kW is to be used.
- The voltage rating of the drives indicated above is for basic guideline. Minor variations can be accepted on case to case basis based on techno-economic considerations of the various sub-systems.
- Voltage rating for special purpose motors viz, VFD and screw compressors, shall be as per manufacturer's standard. All the motors ratings on Stacker/ reclaimer shall be 415V ac supply only.

2.0 RANGE OF VARIATION

A.C. Supply :

Voltage	:	± 10%
Frequency	:	+3% to -5%
Combined Volt + frequency	:	10% (absolute sum)

During starting of large motor, the voltage may drop to 80% of the rated voltage for a period of 60 seconds. All electrical equipment while running shall successfully ride over such period without affecting system performance.

D.C. Supply :

Voltage	:	187 to 242 Volt
---------	---	-----------------

SECTION-IV

**TECHNICAL SPECIFICATION
FOR
CABLES**

- 1.00.00 **SCOPE OF SUPPLY**
- 1.01.00 Power and Control Cables shall cover the requirement of entire Plant including the switchyard.
- Other cables including special cables, if any, which may be necessary as per proven engineering practice for satisfactory and trouble free operation of the entire cable system of the plant shall also be within the scope of supply. These shall include all such cables for electrical integral with mechanical equipment systems and subsystems.
- 1.02.00 Cable shall be furnished in accordance with this specification and the following annexures :
- a) 11kV & 3.3 kV Power cables : Annexure - A
 - b) 1100V Power Cables : Annexure – B
 - c) Control Cables : Annexure – C
 - d) Fire Survival Cables : Annexure – D
 - e) Flexible Trailing cable : Annexure – E
- 1.03.00 All relevant drawings, data and instruction manuals
- 2.00.00 **CODES & STANDARDS**
- 2.01.00 All cable and materials shall be designed, manufactured and tested in accordance with the latest applicable Indian Standards (IS) and IEC except where modified and/or supplemented by this specification.
- 2.02.00 Cable and material conforming to any other standard which ensures equal or better quality, may be accepted. In such case, copies of the English version of the standard adopted shall be submitted along with the bid.
- 2.03.00 The electrical installation shall meet the requirements of Indian Electricity Rules as amended upto date and relevant IS Code of Practice. In addition, other rules and regulations applicable to the work shall be followed.
- 3.00.00 **DESIGN CRITERIA**
- 3.01.00 Cables will be generally laid on ladder type trays or drawn through rigid PVC/GI /HDPE pipe/conduits. Cable tunnels shall be avoided as far as possible, except at locations where overhead trays are not possible, with prior approval of the Owner.

- 3.02.00 For continuous operation at specified rating, maximum conductor temperature shall be limited to the permissible value as per relevant standard and/or this specification which one is more stringent.
- 3.03.00 The insulation and sheath materials shall be resistant to oil, acid and alkali and shall be tough enough to withstand mechanical stresses during handling.
- 3.04.00 Armouring shall be single round wire of galvanized steel for multicore cables and aluminum for single core cable for power and control cables. For fire survival control cable, the armouring over inner sheath shall consist of single layer of wire / round galvanised steel wire as per IS 3975 amended upto date. For Fire survival power cable, Single core cables to be used in A.C. system, the armouring over inner sheath shall consist of single layer of round copper wire, for multi-core cables to be used in A.C. system and single core cables in D.C. System, the armouring over inner sheath shall consist of single layer of round galvanised steel wire.
- 3.05.00 The outer sheath shall have flame retardant low smoke halogen evolution (FRLSH) characteristics or fire survival characteristics as applicable and shall meet the requirements of additional tests specified for the purpose.
- 3.06.00 Core identification for multicore cable shall be provided by colour coding.
- 3.07.00 HT cables shall be manufactured by triple extrusion dry cured (CCV) process using pressurized nitrogen.

4.00.00 **SPECIFIC REQUIREMENTS**

4.01.00 **General Description**

All Cables shall be furnished in strict compliance with ratings and requirements and sizes as given in Annexures to this Specification.

4.02.00 **Drum Length and Tolerance**

The cables shall be supplied in non-returnable packing steel drum for 11 kV & 3.3 kV power cables, wooden drums for 1100V power and control cables, each containing minimum 500 meters length of larger sizes of cable unless specifically asked for. For smaller sizes of cables, each drum shall contain 1000 meters length of cable. Allowable tolerance on individual drum length is $\pm 5\%$.

4.03.00 **Non-Standard Length**

Non-standard lengths upto 5% of the total ordered quantity may be accepted. However the Contractor will be required to obtain approval before packing the Cables on drums. Non-standard lengths shall not be less than 100 metres in any case.

4.04.00 **Cable identification**

Cable identification shall be provided by embossing on every meter on the outer sheath the following :

- a) TSGENCO
- b) Manufacturer's name or trade mark
- c) Voltage grade
- d) Year of manufacture
- e) Type of insulation, e.g. XLPE/PVC/HR85/IE2 etc.
- f) No. of core and size of cables.
- g) Type of improved fire performance, e.g. FR/FRLSH/FS
- h) IS number

4.05.00 **Packing**

4.05.01 Cables shall be supplied in non returnable drums. The drums shall be of heavy construction. All wooden parts shall be manufactured from seasoned wood. All ferrous parts used shall be treated with suitable rust preventive finish or coating to avoid rusting during transit or storage. Wooden cable drum shall be treated by immersing in copper-nitrate solution.

4.05.02 Cable shall be wound and packed on drums in such a manner that it will be properly sealed and firmly secured to the drum. The ends of each length shall be sealed before shipment.

4.05.03 The cable drums should carry the following details in printed form:

- a) TSGENCO
- b) Manufacturer's name or trade make
- c) Type of cable & voltage grade
- d) Year of manufacture
- e) Type of insulation e.g. XLPE/HRPVC/IE2
- f) No. of core and size of cables
- g) Cable code e.g. FRLSH/FS
- h) Length of cable on drum
- i) No. of length on drum, if more than one
- j) Direction of rotation, by arrow
- k) Approx. gross mass.

- l) IS/IEC number and ISI mark

4.06.00 **Joints and Terminations**

Materials of construction for a joint/termination shall perfectly match with the dielectric chemical and physical characteristics of the associated cables. The material and design concepts shall incorporate a high degree of operating compatibility between the cable and joints. The protective outer covering (jacket) used on the joints/terminations shall have the same qualities as that of the cable outer sheath in terms of ambient/operating temperature withstand capability and resistance to hazardous environments and corrosive elements. Straight through joints and terminations for HT cables shall be heat shrinkable type.

4.07.00 **Selection Criteria**

- 4.07.01 a) HT and LT power cables shall be selected on the basis of current carrying capacity, short circuit rating and permissible voltage drop.
- b) While sizing power cables, following aspects shall be reckoned:
- i) Ground/Ambient Air temperature
 - ii) Depth of Laying.
 - iii) Power Cables touching each other.
- c) Cables, for circuit breaker controlled feeders, shall withstand the short circuit current for the fault clearing time 0.16 Sec. for outgoing feeder, 0.5 Sec. for Tie feeder and 1.0 Sec. for Incomer.
- d) HT cables shall be sized based on the following considerations:
- Rated current of the equipment and ground/ambient temperature.
 - Touching/spacing of cable.
 - Laying on multi-tier racks, trench
 - Depth of laying.
- The voltage drop of the cable , during motor starting condition , shall be limited to 15% and during full load running condition shall be limited to 3 % rated voltage. For BFP motor, the voltage drop during motor starting condition shall be limited to 20% and for Mill motor shall be limited to 10%. Other outgoing feeder / transformer feeder shall be limited to 3% rated voltage.
- Short circuits withstand capability
- e) For fuse/MCCB/Breaker protected circuits the conductor size shall depend upon full load current subject to voltage drop limited to 3% during running of all feeders and 15% during starting for motor feeders. In addition, transformer regulation shall also be considered for loads fed from 415V PMCC. Incase of other out going line feeder voltage drop shall be limited to 3%.

- f) For loads fed from local panels, the total running voltage drop in cable from 415V PMCC to local panel and from local panel to individual motor shall be limited to 3% at full load motor current while the same during starting shall be limited to 15%.
- g) As per national electric code (NEC) current rating capacity of motor feeder/cables should be 125% of full load current.
- h) For welding receptacle, 3% running drop shall only be considered.

The minimum sizes of L.T cable to be chosen are as below:

AL - 16 mm² (3 core) & 16mm² (2 core) Cu - 2.5 mm²

4.07.02 Apart from above, consideration shall also be given to limit the cable to some standard sizes instead of using too many types.

4.07.03 The standard cable sizes, amp capacities, derating factors. as given in IS/IEC will be generally followed.

4.07.04 a) For breaker protected circuits minimum size of the cable shall be as follows:

1100V Power Cable : 240 Sq mm XLPE AL

3300V Power Cable : 185 Sq mm XLPE AL

11000V Power Cable : 240 Sq mm XLPE AL

b) For motor circuits the selection of size will be made ensuring that the cable shall withstand a short circuit fault directly following a second hot start.

4.07.05 For fuse/MCCB protected circuit, the conductor size will depend on full load current subject to voltage drop not exceeding 3%. For practical purposes, the minimum size chosen is as below :

a) Aluminium : 6 Sq mm.

b) Copper : 2.5 Sq mm.

4.07.06 All control cables shall be 2.5 Sq mm copper cable.

4.07.07 Multicore control cables will generally have spare conductor (s) in accordance with the following chart :

Conductors required	Cables
1 or 2	1-3/C
3 or 4	1-5/C
5 or 6	1-7/C
7 or 8	1-9/C

- | | | |
|--|----------|-----------------------------|
| | 9 or 10 | 1-12/C |
| | Above 10 | Two or more of above cables |
- 4.07.08 Separate cables for each type of following services/functions as applicable shall be used for each feeder. Same multicore cable using different services shall not be acceptable.
- a) Power.
 - b) Control, interlock and indication.
 - c) Metering and measuring.
 - d) Alarm and annunciation.
 - e) C.T. Cables.
 - f) V.T. Cables.
- 4.08.00 **Cable Identification**
- Cable identification shall be provided by embossing on the outer sheath the following :
- a) Manufacturer's name or trade mark
 - b) Manufacturer's name or trade mark
 - c) Voltage grade
 - d) Year of manufacture
 - e) Type of insulation, e.g. XLPE, HRPVC & IE2 etc.
 - f) No. of core & size of cables
 - g) Type of outer sheath e.g. FRLSH, FS etc.
- 4.09.00 Selected sizes of power and control cables are given in Annexure-G.
- 4.10.00 Fire Survival Cables shall be used for important auxiliaries / area as recommended in Standard Technical Specification by CEA for the following services. The fire survival time of these cables shall not be less than 3 hours at 750 deg. C.
- i. DC emergency lube oil pump
 - ii. DC hydrogen seal pump
 - iii. Turbine lube oil pump/barring gear
 - iv. DC emergency lighting for main building and service building
 - v. DC cables for battery to charger & DC distribution boards

- vi. Jacking oil pump
- vii. Emergency turbine trip in control room
- viii. Boiler Turbine : Generator inter trip which include the interconnection between
 - Boiler master fuel trip and turbine trip relays
 - Generator trip relays & turbine trip relays
 - Generator trip relays & generator breaker
 - Generator trip relays & field breaker
 - Generator trip relays & unit auxiliary transformer breaker
 - Incomer cables for DG board, emergency board, DC lighting board etc.

5.00.00 **TESTS**

5.01.00 **Shop Tests**

The Cables shall be subject to shop tests in accordance relevant IS/IEC standards to prove the design and general qualities of the Cables as below:

- 5.01.01 Routine tests on each drum of cables.
- 5.01.02 Acceptance Tests on 1 drum out of every 10 drums chosen at random for acceptance of the lot for every size.
- 5.01.03 Type test on each type and size of cable, inclusive of measurement of armour DC resistance of power cables on one drum out of every 10 drums of cable.

5.02.00 **Additional Tests**

Following additional acceptance tests shall also be performed on each type of cables having outer sheath with improved fire performance (category C1, Type FR/ Category C2, Type FRLSH)

- 5.02.01 Oxygen index test (both C1 & C2)

The Oxygen index shall not be less than 29.
- 5.02.02 Temperature Index Test (both C1 & C2)

The measured value of temperature index shall be 21 at a temperature of 250°C for FRLS cables and 350°C for FS cables
- 5.02.03 Flame Retardance test on single cable and on bunched cables (both C1 & C2)

After the test, there should be no visible damages on the test specimen within 300mm from its upper end.

After burning has ceased, the cables should be wiped clean and the charred or affected portion should not have reached a height exceeding 2.5 meter above the bottom edge of the burner, measured at the front and rear of the cable assembly. 3 Hours fire rating test shall be carried out for FS cable as per IEC-331

5.02.04 Halogen acid gas evolution test (for Category C2)

The level of HCL evolved shall not exceed 20 per cent by weight. HCL evolved shall not be exceed 2% for FS cable.

5.02.05 Smoke density test (for Category C2)

The cables shall meet the requirements of light transmission of minimum 40% after the test. Minimum transmission shall be 80% for FS cable.

5.02.06 Test for specific optical density of smoke

The cables shall meet the requirements of IS/IEC.

5.02.07 Test for rodent & termite repulsion property

The test shall be carried out to note the presence of rodent and termite repelling chemical in PVC compound. Normal procedure is that a few chippings of the PVC compound are slowly ignited in a porcelain dish or crucible in a muffle furnace at about 600°C. The resulting ignited ash is boiled with a little ammonium acetate solution (10%). A drop of aqueous sodium sulphide solution is placed on a thick filter paper and it is allowed to soak. The spot is touched with a drop of above extract. A black spot indicates the presence of anti-termite & rodent compound.

Flammability test shall be carried on finished cables as per following standards-

- a) Swedish Chimney test – SS: 424-14-75
- b) IEEE std.383 – 1974 latest
- c) IEC std. 332-1, 332-3 and IEC 331

6.00.00 **DRAWINGS, DATA & MANUALS**

6.01.00 Drawings, Data and Manuals shall be submitted with the bid and for approval/ reference and subsequent distribution after the issue of Letter of Intent in quantities and procedures as specified in General condition of contract and/or

6.02.00 **To be submitted with the Bid**

- a) Manufacturer's catalogues giving cable construction details and characteristics.

- b) Cable current ratings for different types of installation, inclusive of derating factors for ambient temperature, grouping etc.
- c) Write-up on Manufacturer's recommended method of splicing, jointing, termination etc. of the cables.
- d) Type test reports on 11 KV & 3.3 KV Power, LT FRLSH Power & control, FS power and control cables.
- e) Filled-up proposal particulars.

6.03.00 To be submitted for Owner/Purchaser's Approval and Distribution

All relevant drawings and data pertaining to the equipment like GTP, QAP, etc. shall be submitted by the Bidder for the approval of Owner/Owner's consultant. Also refer clause no. 1.19.02(u) of Section-I of Volume – V-A: Technical Specifications for Electrical Equipment & Accessories.

ANNEXURE-A

**RATINGS AND REQUIREMENTS
HV POWER CABLES (11 KV & 3.3 KV)**

- 1.0 11000/11000V & 3300/3300V grade 90°C continuous rating under normal condition and 250°C rating under short circuit condition heavy duty XLPE power cable suitable for use in 11000V/3300V non-effectively earthed system conforming to following requirement and in line with IS-7098, IS-8130, IS-5831 & IS-3975, manufactured by Triple Extrusion Dry Cure (CCV) process using pressurized Nitrogen.
- 1.1 Conductor : Stranded and compacted aluminium conductor of grade H2 & class 2 for all sizes, generally conforming to IS: 8130.
- 1.2 Conductor Screen : Extruded semi-conducting compound.
- 1.3 Insulation : Extruded cross linked polyethylene (XLPE) conforming to IS: 7098 (Part-2)
- 1.4 Insulation Screen : Extruded semi-conducting compound with a layer of non-magnetic metallic tape. For single core armoured cables, the armouring shall constitute the metallic part of screening. The semi-conducting tape shall be easily strippable.
- 1.5 Core Identification : By coloured strips applied on (For three core cables) cores.
- 1.6 Inner Sheath : Extruded HRPVC/FRLS compound conforming to type ST2 of IS: 5831 for three core cables. Single core cables shall have inner sheath. Filler material shall also be of type ST2 PVC.
- 1.7 Armour : Galvanised single round steel wire armour for twin and multicore cables.

Non-magnetic hard drawn aluminum single round wire conforming to H4 of IS-8130 latest for single core cables
- 1.8 Overall Sheath : Extruded FRLSH HRPVC compound conforming to type ST2 of IS: 5831.
- 1.9 Drum : Steel Drum

ANNEXURE-B

**RATINGS AND REQUIREMENTS
LV POWER CABLES [1.1KV (XLPE TYPE)]**

- 1.0 1100 V grade, 90°C continuous rating under normal condition and 250°C under short circuit condition rating, XLPE heavy duty, power cable conforming to following requirement and in line with IS 7098 Part-I. IS 8130 & IS 5831 and IS 3975.
- 1.1 Conductor : Stranded and compacted plain aluminium of grade H2 and class 2 stranded, high conductivity annealed plain copper for cable sizes upto 2.5 mm² conforming to IS:8130.
- 1.2 Insulation : Extruded cross-linked polyethylene (XLPE) conforming to IS: 7098 (Part-1)
- 1.3 Core Identification : By color coding
- 1.4 Inner Sheath : Extruded HRPVC FRLS compound conforming to type ST2 of IS: 5831 for multicore cable. Single core cables shall have no inner sheath. Filler shall be of same material as of inner sheath i.e. ST2
- 1.5 Armour : Galvanized single round steel wire armour for twin and multicore cables.

Non-magnetic hard drawn aluminum single round wire conforming to H4 of IS-8130 latest for single core cables
- 1.6 Overall Sheath : Extruded FRLSH HRPVC compound conforming to type ST2 of IS: 5831.
- 1.7 Drum : Conforming to IS-10418 (Wooden drum)

ANNEXURE-C

**RATINGS AND REQUIREMENTS
CONTROL CABLES**

- 1.0 1100 V grade 85°C continuous rating under normal condition and 160°C under short circuit condition rating HRPVC Control cable (YWY) conforming to following requirement and in line with IS:1554, IS:8130, IS:5831 and IS:3975.
- 1.1 Conductor : Stranded, non-compacted & circular, high conductivity annealed plain copper, generally conforming to IS: 8130.
- 1.2 Insulation : Extruded HRPVC type-C compound conforming to IS: 5831. The minimum volume resistivity of insulation shall be 3.5×10^{14} ohm-cm at 27°C and 3.5×10^{11} OHM-CM at 85°C.
- 1.3 Core Identification : By color coding and numbering at interval of 100mm or less
- 1.4 Inner sheath : Extruded HRPVC compound conforming to type ST2 FRLS of IS: 5831 for multicore cables. Single core cables shall have no inner sheath. Filler shall be of same material as of inner sheath i.e. ST2.
- 1.5 Armour : Galvanised single round steel wire for twin and multicore cables.
- 1.6 Overall sheath : Extruded FRLSH HRPVC compound conforming to type ST2 of IS: 5831.
- 1.7 Drum : Conforming to IS: 10418 (Wooden drum)

ANNEXURE-D

**RATINGS AND REQUIREMENTS
(1.1KV GRADE COPPER CONDUCTOR FS POWER CABLES)**

1100 V, copper conductor, heat resisting insulation, extruded inner sheath of low smoke and very low halogen content fire resisting material, single layer of copper wire armour for single core/ single layer of round galvanised steel wire for multicore, outer sheath of low smoke and very low halogen content fire resistant material, suitable for minimum temperature of 750 deg.C for 3 hours. The cables shall be in compliance with IEC-60331, Part 11.

**RATINGS AND REQUIREMENTS
(1.1KV GRADE COPPER CONDUCTOR FS CONTROL CABLES)**

1100 V, copper conductor, heat resisting insulation, extruded inner sheath of low smoke and very low halogen content fire resisting material, single layer of copper wire armour for single core/ single layer of round galvanised steel wire for multicore, outer sheath of low smoke and very low halogen content fire resistant material, suitable for minimum temperature of 750 deg.C for 3 hours. The cables shall be in compliance with IEC-60331, Part 11.

ANNEXURE-E

**RATINGS AND REQUIREMENTS
FLEXIBLE TRAILING CABLES**

- i) 3300 V Unearthed Grade
- Flexible trailing cable, annealed plain copper conductor, Class-5 of IS-8130, insulated with EPR, conductor and insulation shielded with EPR, cores screened with ATC wire braiding, cores laid up, HD CSP inner sheathed, proof cotton taped and FRLS HD CSP sheathed overall, conforming to IS:9968. Alternatively PCP sheathing may be acceptable.
- ii) 1100 V Grade
- 1100 V Grade trailing cable shall be plain copper of Class-5 of IS-8130, heat resistant elastomeric compound based on EPR insulation, inner sheath of heat resistant elastomeric compound PCP sheath, nylon cord reinforcement and heat resistant, oil resistant and flame retardant heavy duty elastomeric compound FRLS CSP outer sheath.

ANNEXURE-F

CABLE SIZES

Following sizes are given as a general guideline. Standard sizes as per IEC/IS shall be adopted.

Sl. No.	Cable Size	Conductor	Insulation
1.0	H. T. CABLES (11kV)		
1.1	1 core 1000 sq.mm	AL	XLPE (FRLS)
1.1	1 core 630 Sq.mm	AL	XLPE (FRLS)
1.2	3 core 400 Sq.mm	AL	XLPE (FRLS)
1.3	3 core 240 Sq.mm	AL	XLPE (FRLS)
1.4	1 core 70 Sq.mm	AL	XLPE (FRLS)
1.0	H. T. CABLES (3.3kV)		
1.1	1 core 630 Sq.mm	AL	XLPE (FRLS)
1.2	3 core 300 Sq.mm	AL	XLPE (FRLS)
1.3	3 core 240 Sq.mm	AL	XLPE (FRLS)
1.4	3 core 185 Sq.mm	AL	XLPE (FRLS)
1.5	1 core 70 Sq.mm	AL	XLPE (FRLS)
2.0	L. T. POWER CABLES		
2.1	3 core 2.5 Sq.mm	CU	XLPE (FRLS)
2.2	2 core 16 Sq.mm	AL	XLPE (FRLS)
2.3	3 core 16 Sq.mm	AL	XLPE (FRLS)
2.4	4 core 16 Sq.mm	AL	XLPE (FRLS)
2.5	2 core 35 Sq.mm	AL	XLPE (FRLS)
2.6	3 core 35 Sq.mm	AL	XLPE (FRLS)
2.7	4 core 35 Sq.mm	AL	XLPE (FRLS)
2.8	3 core 70 Sq.mm	AL	XLPE (FRLS)

Sl. No.	Cable Size	Conductor	Insulation
2.9	3.1/2 core 70 Sq.mm	AL	XLPE (FRLS)
2.10	3 core 95 Sq.mm	AL	XLPE (FRLS)
2.11	3.1/2 core 95 Sq.mm	AL	XLPE (FRLS)
2.12	3 core 185 Sq.mm	AL	XLPE (FRLS)
2.13	3.1/2 core 185 Sq.mm	AL	XLPE (FRLS)
2.14	3 core 240 Sq.mm	AL	XLPE (FRLS)
2.15	3.1/2 core 240 Sq.mm	AL	XLPE (FRLS)
2.16	3 core 300 Sq.mm	AL	XLPE (FRLS)
2.17	3.1/2 core 300 Sq.mm	AL	XLPE (FRLS)
2.18	1 core 630 Sq.mm	AL	XLPE (FRLS)
3.0	CONTROL CABLE		
3.1	2 core 2.5 Sq.mm	CU	HRPVC (FRLS)
3.2	3 core 2.5 Sq.mm	CU	HRPVC (FRLS)
3.3	5 core 2.5 Sq.mm	CU	HRPVC (FRLS)
3.4	7 core 2.5 Sq.mm	CU	HRPVC (FRLS)
3.5	9 core 2.5 Sq.mm	CU	HRPVC (FRLS)
3.6	12 core 2.5 Sq.mm	CU	HRPVC (FRLS)
3.7	20 core 2.5 Sq.mm	CU	HRPVC (FRLS)
4.0	FS POWER CABLES		
4.1	3 core 2.5 Sq.mm	CU	EPR
4.2	2 core 16 Sq.mm	CU	EPR
4.3	3 core 16 Sq.mm	CU	EPR
4.4	4 core 16 Sq.mm	CU	EPR
4.5	2 core 35 Sq.mm	CU	EPR

Sl. No.	Cable Size	Conductor	Insulation
4.6	3 core 35 Sq.mm	CU	EPR
4.7	4 core 35 Sq.mm	CU	EPR
4.8	3 core 95 Sq.mm	CU	EPR
4.9	3.1/2 core 95 Sq.mm	CU	EPR
5.0	FS CONTROL CABLE		
5.1	2 core 2.5 Sq.mm	CU	EPR
5.2	3 core 2.5 Sq.mm	CU	EPR
5.3	5 core 2.5 Sq.mm	CU	EPR
5.4	7 core 2.5 Sq.mm	CU	EPR
5.5	9 core 2.5 Sq.mm	CU	EPR
5.6	12 core 2.5 Sq.mm	CU	EPR



TITLE

**1X800 MW KOTHAGUDEM TPS
ELECTRIC HOISTS
CUSTOMER SPECIFICATION**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME: II B

REV 00

Section C 3

30.07. 2015

**VOLUME - IIB
SECTION – C3
ANNEXURES**



TITLE

TECHNICAL SPECIFICATION FOR
ELECTRIC HOISTS
1X800 MW KOTHAGUDEM TPS

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME II B

SECTION C

REV 00

DATE 30-07-15

SHEET 1 OF 1

**ANNEXURE I
SCOPE OF ELECTRIC HOISTS**

Sl. No	Area / Equipment description	Qty. (nos.)	Capacity (T)	Lift (m)	Travel (m)	Path
1	Vacuum Pumps	1	5T	9	17.0	Straight
2	Vacuum Pumps	1	3T	9	17.0	Straight
3	Elevator M/C room (TG hall & Service building)	2	3T	9	7	Curved
4	CW BFV	1	15T	15	20.0	Straight
5	DMCW Pumps	1	5T	9	29.0	Straight
6	Lube Oil Unloading (Hazardous Type)	1	1T	9	4.0	Straight
7	ESP Control Room	1	10T	9	5.0	Straight
8	Make-up Pump House	2	3T	6	23.0	Straight
9	Drip Pump	1	5T	9	6.0	Straight
10	Boiler MCC	1	10T	32	5.0	Straight



TECHNICAL SPECIFICATION FOR
FOR
ELECTRIC HOISTS
1X800 MW KOTHAGUDEM

DOC. NO. PE-TS-410-563-A201

REV. 0

DATE 30/07/2015

Annexure II

PAINING SPECIFICATION

Surface preparation: De greasing and Mechanical cleaning with wire brush or hand tool. (SA 1/ ST 2 / ST 3 as applicable)

Primer : Red oxide Zinc chromate as per IS: 2074 (Alkyd medium) - 1 coat, DFT35 μ per coat.

Intermediate : Red oxide Zinc chromate as per IS: 2074 (Alkyd medium) - 1 coat, DFT35 μ per coat

Finish Coat : Synthetic enamel (Alkyd medium) as per IS: 2932- 2 coats, DFT 25 μ per coat.

Total DFT : 120 μ

Electrical /Control Panel:

Surface preparation: Seven tank process

Primer : Zinc phosphate (Alkyd medium) - 2 coat Minimum DFT 25- 35 μ per coat.

Finish Coat : Synthetic enamel (Alkyd medium) as per IS: 2932- 3 coats, Minimum DFT 20-25 μ per coat.

Total DFT : 110 - 145 μ

Color Shade:

Sl. No	Item Description	Color Shade	Remarks
1	Structure	Smoke Gray shade 692 as per IS-5	
2	Bottom block assembly	Smoke Gray shade 692 as per IS-5	
3	Hooks	Lemon yellow shade 356 as per IS-5	With black zebra strip
4	End carriage sweep	Smoke Gray shade 692 as per IS-5	
5	Motors	Smoke Gray shade 692 as per IS-5	
6	Control Panels	Smoke Gray shade 692 as per IS-5	

SUB-VENDOR LIST – ELECTRIC HOISTS

ANNEXURE-III

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
1.	STEEL	SAIL		
		TISCO		
		JINDAL		
		ESSAR		
2.	HOOKS	STEEL FORGING & ENGG. CO.,	KOLKATA	
		SIMRITI FORGING		
		KARACHIWALA		UP TO 25T CAPACITY
3.	GEAR COUPLINGS	ALLIANCE		
		FLEX-TRANS (formerly known as HICLIFF)		
		SAHARA		
		NUTECH		
		OEM		
4.	WIRE ROPE	USHA MARTIN		
		FORT WILLIAMS		
		BHARAT WIRE ROPES		
5.	BEARINGS	SKF		
		FAG		
		TATA		
		NBC		
6.	MOTORS	SIEMENS		
		NGEF (up to 15KW)		
		CROMPTON		
		KIRLOSKAR		
		BHARAT BIJLI		
		MARATHON		
		ABB		
LHP				
7.	BRAKES	ELECTROMAG		
		SPEED-O- CONTROL		
		BCH		FOR DCEM BRAKES ONLY
		KAKKU		
8.	CONTACTOR	SIEMENS		
		L&T		
		SCHNEIDER (Earlier TELE MECHANIQUE)		
		BCH		
9.	OVER LOAD RELAYS	SIEMENS		
		L&T		
		ABB		
		SCHNEIDER (Earlier TELE MACHANIQUE)		
10.	HRC FUSES	SIEMENS		
		L&T		
		ENGLISH ELECTRIC		
		GE POWER		
		EATON (BUSSMANN)		
11.	ISOLATING SWITCH	ABB		
		SIEMENS		

SUB-VENDOR LIST – ELECTRIC HOISTS

ANNEXURE-III

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		L&T		
		CONTROL & SWITCH GEAR		
		ABB		
12.	SWITCH FUSE UNITS	SIEMENS		
		L&T		
		CONTROL & SWITCH GEAR	-	
		ABB		
13.	TIME DELAY RELAYS	SIEMENS		
		L&T		
		ABB		
		BCH		
		SCHNEIDER (Earlier TELE MACHANIQUE)		
14.	TRANSFORMERS	INDCOIL		
		LOGICSTAT		
		KAPPA		
		AUTOMATIC ELECTRIC		
		PRECISE ELECTRICALS		
		SILKAAN ELECTRIC MFG. CO. LTD.		
		SOUTHERN ELECTRIC		
		NEC		
15.	CABLE LUGS (HEAVY DUTY)	DOWELLS		
		UML ENGINEERS	KOLKATA	
		JAINSON		
16.	PVC POWER CABLES	APAR INDUSTRIES LTD.	MUMBAI	
		CORDS CABLE INDUSTRIES LTD.	NEW DELHI	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		GOYOLENE FIBRES (INDIA) PVT.LTD	MUMBAI	
		GOVIND CABLE INDUSTRIES	KOLKATA	
		GUPTA POWER INFRASTRUCTURE LIMITED	BHUBNESWAR	
		HAVELLS INDIA LIMITED	NOIDA	
		KEI INDUSTRIES LTD.	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	
		MANSFIELD CABLES COMPANY LTD.	NOIDA	
		NICCO CORPORATION LTD.	KOLKATA	
		PARAMOUNT COMMUNICATIONS LTD.	NEW DELHI	
		POLYCAB WIRES PVT. LTD.	MUMBAI	
		RADIANT CORPORATION PRIVATE LIMITED	HYDERABAD	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD.	VADODARA	

SUB-VENDOR LIST – ELECTRIC HOISTS

ANNEXURE-III

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		SRIRAM CABLES PVT. LTD.	NEW DELHI	
		SCOT INNOVATION WIRES AND CABLES PVT. LTD.	SOLAN	
		SAM CABLES & CONDUCTORS (P) LTD	UDHAM SINGH NAGAR	
		THERMO CABLES LTD	HYDERABAD	
		ADVANCE CABLE TECHNOLOGIES (P) LTD	BANGALORE	
		APAR INDUSTRIES LTD., CMI LTD	MUMBAI	
		CMI LIMITED	FARIDABAD	
		CORDS CABLE INDUSTRIES LTD	NEW DELHI	
		CRYSTAL CABLE INDUSTRIES LTD	KOLKATA	
		DELTON CABLES LTD	NEW DELHI	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		ELKAY TELELINKS LTD	NEW DELHI	
		GEMSCAB INDUSTRIES LTD	NEW DELHI	
		GOVIND CABLE INDUSTRIES	KOLKATA	
		GUPTA POWER INFRASTRUCTURE LIMITED	BHUBNESWAR	
		HAVELLS INDIA LIMITED	NOIDA	
		INCOM CABLES (P) LTD	NEW DELHI	
		KEI INDUSTRIES LTD	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
17.	PVC CONTROL CABLES	KEC INTERNATIONAL LIMITED	MUMBAI	
		MANSFIELD CABLES COMPANY LTD	NOIDA	
		NICCO CORPORATION LTD	KOLKATA	
		PARAMOUNT COMMUNICATIONS LTD	NEW DELHI	
		POLYCAB WIRES PVT. LTD	MUMBAI	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD	VADODARA	
		SPECIAL CABLES PVT. LTD	NEW DELHI	
		SCOT INNOVATION WIRES AND CABLES PVT. LTD	SOLAN	
		SAM CABLES & CONDUCTORS (P) LTD	UDHAM SINGH NAGAR	
		SPM POWER & TELECOM PVT. LTD	HYDERABAD	
		TORRENT CABLES LTD	AHMEDABAD	
		THERMO CABLES LTD	HYDERABAD	
		TIRUPATI PLASTOMATICS PVT. LTD	JAIPUR	
		UNIVERSAL CABLES LTD	SATNA	
18.	TRAILING CABLES	NICCO	KOLKATA	
		UNIVERSAL	SATNA	

SUB-VENDOR LIST – ELECTRIC HOISTS

ANNEXURE-III

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		INCAB		
		ICL	NEW DELHI	
		APAR INDUSTRIES LTD	MUMBAI	
		CMI LTD	FARIDABAD	
		KEI INDUSTRIES LTD	NEW DELHI	
		SUYOG ELECTRICALS LTD	VADODARA	
19.	XLPE POWER CABLES	APAR INDUSTRIES LTD	MUMBAI	
		CORDS CABLE INDUSTRIES LTD	NEW DELHI	
		CRYSTAL CABLE INDUSTRIES LTD	KOLKATA	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		GEMSCAB INDUSTRIES LTD	NEW DELHI	
		GOVIND CABLE INDUSTRIES	KOLKATA	
		GUPTA POWER INFRASTRUCTURE LIMITED	BHUBNESWAR	
		HAVELLS INDIA LIMITED	NOIDA	
		KEI INDUSTRIES LTD	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	
		MANSFIELD CABLES COMPANY LTD	NOIDA	
		PARAMOUNT COMMUNICATIONS LTD	NEW DELHI	
		POLYCAB WIRES PVT. LTD	MUMBAI	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD	VADODARA	
		SPECIAL CABLES PVT. LTD	NEW DELHI	
		SCOT INNOVATION WIRES AND CABLES PVT. LTD	SOLAN	
		SRIRAM CABLES PVT. LTD	NEW DELHI	
		TORRENT CABLES LTD	AHMEDABAD	
THERMO CABLES LTD	HYDERABAD			
TIRUPATI PLASTOMATICS PVT. LTD	JAIPUR			
20.	XLPE CONTROL CABLES	APAR INDUSTRIES LTD	MUMBAI	
		CABLE CORPORATION OF INDIA LTD	MUMBAI	
		CRYSTAL CABLE INDUSTRIES LTD	KOLKATA	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		GEMSCAB INDUSTRIES LTD	NEW DELHI	
		HAVELLS INDIA LIMITED	NOIDA	
		KEI INDUSTRIES LTD	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	
PARAMOUNT COMMUNICATIONS	NEW DELHI			

SUB-VENDOR LIST – ELECTRIC HOISTS

ANNEXURE-III

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		LTD		
		POLYCAB WIRES PVT. LTD	MUMBAI	
		RADIANT CORPORATION PRIVATE LIMITED	HYDERABAD	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD	VADODARA	
		SRIRAM CABLES PVT. LTD	NEW DELHI	
		TORRENT CABLES LTD	AHMEDABAD	
		UNIVERSAL CABLES LTD	SATNA	
21.	CABLE GLAND	COMMET		
		SUNIL&CO		
		ARUP ENGINEERING		
		JAINSON		
		DOWELL		
22.	PUSH BUTTONS	SIEMENS		
		L&T		
		BCH		
		SCHNEIDER		
23.	LIMIT SWITCHES	SPEED-O-CONTROL		
		ELECTROMAG		
24.	PENDENT PUSH BUTTON STATION	OEM		
25.	INDICATING LAMPS	TECKNIC		
		BCH		
		SIEMENS		
		STANDARD		
26.	MCB	MDS		
		INDO COPP		
		STANDARD		
		SIEMENS		
		L&T		
		ABB		
		SCHNEIDER		
27.	PANELS	OEM		
		RITTAL		
		PYROTECH		
28.	RESISTANCE BOXES	ENAPROS		
		OEM		
		SAFEX FIRE SERVICES LTD		
		UNITED FIRE EQUIPMENTS PVT. LTD		
		ZENITH FIRE SERVICES (INDIA) PVT LTD		
29.	VVVF	YASKAWA		
		ABB		
		SIEMENS		
		SCHNIEDER		
		FUJI ELECTRIC		

SUB-VENDOR LIST – ELECTRIC HOISTS

ANNEXURE-III

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		MITSUBISHI ELECTRIC		
30.	SHROUDED DSL	SUSHEEL		
		STROMAG		
31.	LOAD CELL	IPA		
		SARTORIUS		
32.	GEAR BOX	OEM		* = Applicable for Geared Motors only
		ELECON ENGINEERS		
		SHANTI GEARS		
		PBL*		
		NAW*		
		NORD*		
		SEW*		
BONGFILIOLI*				

NOTE:

1. THE SUB VENDOR LIST ABOVE IS INDICATIVE ONLY AND IS SUBJECT TO BHEL AND CUSTOMER APPROVAL DURING DETAILED ENGINEERING STAGE WITHOUT ANY COMMERCIAL & DELIVERY IMPLICATION TO BHEL.

BIDDER TO PROPOSE SUB VENDOR WITHIN 4 WEEKS OF PLACEMENT OF LOI. THEREAFTER NO REQUEST FOR ADDITIONAL SUB-VENDOR SHALL BE ENTERTAINED.

2. DEALERS ARE NOT ACCEPTABLE FOR ANY ITEM OF THE PACKAGE. BIDDER SHALL PROCURE ALL ITEMS INCLUDING PLATES, STRUCTURAL, FLANGES; COUNTER FLANGES ETC. FROM APPROVED SUB VENDOR ONLY.

3. THE INSPECTION CATEGORY WILL BE INTIMATED AFTER AWARD OF CONTRACT BY BHEL/CUSTOMER. HOWEVER THE SAME WILL BE ADHERED BY THE BIDDER WITHOUT ANY COMMERCIAL AND DELIVERY IMPLICATION TO BHEL/ CUSTOMER.



TITLE TECHNICAL SPECIFICATION FOR WIRE ROPE ELECTRICAL HOIST 1X800 MW KOTHAGUDEM TPS, REV	SPECIFICATION NO. PE-TS-410-563-A201	
	VOLUME II B	
	SECTION C3	
	00	DATE 30-07-15
	SHEET 1	OF 2

ANNEXURE-IV

Master drawing list and submission schedule

SI. No.	SI-NO	BHEL DRG.NO	DRAWING TITLE	CATEGORY	SUBMISSION SCHEDULE - WEEK NUMBER FROM DATE OF PO	Remarks
ELECTRIC HOISTS (EH)						
1	563	PE-V0-410-563-A201	Manufacturing Quality Plan with Sub vendor list	APPROVAL	2	
2	563	PE-V0-410-563-A202	GA Drawing for Electric Hoist, DSL arrangement and painting details.	APPROVAL	3	
3	563	PE-V0-410-563-A219	Schematic Circuit Diagram	APPROVAL	3	
4	563	PE-V0-410-563-A210	Mechanism Sizing Calculation	APPROVAL	3	
5	563	PE-V0-410-563-A218	Detailed BOM/BOQ for crane	INFORMATION	4	
6	563	PE-V0-410-563-A206	O & M Manual	INFORMATION	6	
7	563	PE-V0-410-563-A207	Mandatory spare parts list	APPROVAL	4	
8	563	PE-V0-410-563-A208	Erection procedure	INFORMATION	6	
NOTE:	1	VENDOR SHALL RESUBMIT THE REVISED DRAWINGS WITHIN 7 DAYS OF RECEIPT OF COMMENTS.				
	2	INCOMPLETE DRAWINGS/DOCUMENTS SHALL NOT BE TREATED AS SUBMITTED.				
	3	MANUFACTURING SHALL BE STARTED ON RECEIPT OF CAT II APPROVED DRAWINGS.				

Note:

Bidder to note that BHEL reserves the right for drawing/document submission through web based Document Management System. Bidder would be provided access to the DMS for drawing/document approval and adequate training for the same. Detailed methodology would be finalized during the kick-off meeting. Bidder to ensure following at their end.

- Internet explorer version – Minimum Internet Explorer 7.
- Internet speed – 2 mbps (Minimum preferred).
- Pop ups from our external DMS IP (124.124.36.198) should not be blocked.
- Vendor's internal proxy setting should not block DMS application's link (<http://124.124.36.198/wrenchwebaccess/login.aspx>).



**TECHNICAL SPECIFICATION
FOR
ELECTRIC HOISTS
1 X 800 MW KOTHAGUDEM**

DOC. NO. PE-DC-410-563-A201

REV. 0

DATE 30/07/2015

Mandatory Spares: (For each type and rating hoists)

ANNEXURE-V

Sl. no	Description	Quantity
1	Bearings for long travel wheels	2 sets
2	Bearings for gear boxes for each type of hoist	2 sets
3	Break liners for all the brakes	100% of total population of each type & size
4	Oil seals	100% of total population of each type, size rating
5	Brake springs for all brakes	100% of total population of each type, size rating
6	Wire ropes for hooks	100% installed on each crane and hoist
7	Solenoid coils for brakes (If applicable)	2 sets
8	Overload relay for motors	2 Nos.
9	Limit switches for hoists and travel mechanisms	2 sets
10	Spare motors for hoists	Total 2 nos. of hoisting motion
11	Long travel machinery	
11.1	i Gear wheel	1 set
11.2	ii. Internal clip	2 Nos.
11.3	iii. Pinion	1 No.
12	Trailing Cable	One set of full length of each size/type of cables as used for each type of Electrical Hoist
13	415 Volt Motor (Up to 30KW Rating)	
13.1	Driving End & Non-Driving End Bearing	3Set for each type and rating of Motor
13.2	Cooling Fan	2No. for each type and rating of Motor
13.3	Motor Terminal Block	5Nos. for each type and rating of Motor
13.4	Complete Set of Coupling	1Set for each Application
14	Control Panel	
14.1	Back-up panel mounted devices (Selector switches/ Push buttons/ Indicators etc.	5% of installed capacity
14.2	Lamps/ LEDs	100% of the total quantity
14.3	Blank Tiles	10% of installed capacity
14.4	MCBs	10% of each type & rating
14.5	Fuses/ Fuse holder	100% of each type & rating

Note:-

1. "One (1) Set" and "One (1) set of each type & size" is defined as 100% requirement for one hoist for the entire hoists of similar size & capacity. If the hoists are of same capacity, the total quantity for the hoists shall be 100% quantity required for one crane.
2. 100% of total population of each type, size and rating is defined as 100% requirement for one hoist.

ANNEXURE VI


DISTRIBUTION SCHEDULE

S. No	Description	TSGENCO										M/S DCPL, KOLKATA			Equipment Vendor	Remarks	
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/ KTPS	SE/ Civil KTPS	SE/E&M / KTPS	DE Constr. KTPS	Kolkata	HYD	KTPS	Kolkata	HYD			KTPS
A	Letter Of Intent or Contract Documents	1	1	1	S	1	2	2	1	1	1	1	1	1	1	2	
B	Vendor Drawings																
1.	Preliminary	1	1	1	2	1	1	2	2	12	1	1	-	-	S		
2.	Return preliminary with comments	-	-	1	2	1	1	1	1	S	1	1	-	-	1		
3.	Final and any revision thereof																
	a. Civil	1	1	6+1T	1	1	6+1T	1	1	2+1T	1	1	1	1	S		
	b. E&M	1	1	1	6+1T	1	1	6+1T	1	2+1T	1	1	1	1	S		
C.	Design Drawings																
1.	Preliminary																
	a. Civil	1	1	2	1	1	2	1	1	4	1	1	1	1	S		
	b. E&M	1	1	1	2	1	1	2	1	4	1	1	1	1	S		
2.	Released for construction																
	a. Civil	1	1	2	1	1	6	1	1	1	1	1	2	2	S		
	b. E&M	1	1	1	1	2	1	6	1	1	1	1	2	2	S		
3.	Return marked 'As built'																
	a. Civil	-	-	1	-	-	1	-	1	1	1	1	S	1			
	b. E&M	-	-	-	1	-	-	1	-	1	1	1	S	1			
4.	As built drawings																
	a. Civil	-	-	1+1T	-	2+1T	5+1T	-	1	1+1T	-	-	1	1	S		
	b. E&M	-	-	1	2+1T	2+1T	-	5+1T	1+1T	1+1T	-	-	1	1	S		

S. No	Description	TSGENCO										M/S DCPL, KOLKATA			Equipment Vendor	Remarks	
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/ KTPS	SE/ Civil KTPS	SE/E&M / KTPS	DE Constr. KTPS	Kolkata	HYD	KTPS					
D	Progress Report Monthly																
1.	Equipment vendor	1	1	1	2	1	1	2	1	1	1	1	1	1	1	S	
2.	M/s DCPL, Kolkata	1	1	2	2	1	1	2	1	1	1	1	1	1	1	Nil	
E	Test & Inspection Reports																
1.	Equipment manufacturer																
a.	Civil	1	1	1	2	1	1	1	1	1	1	1	1	1	1	S	
b.	E&M	1	1	-	2	1	-	1	1	1	1	1	1	1	1	S	
2.	M/s DCPL, Kolkata	1	1	-	2	1	-	1	1	1	1	1	1	1	-	-	
F	Instruction Manuals/Data Books																
1.	Equipment manufacturer																
a.	Civil	1	1	1+1T	1	1	1	1	6+1T	1	1	1	2+1T	1	1	S	
b.	E&M	1	1	-	3+1T	1	-	6+1T	-	1	2	3+1T	1	1	S		
2.	M/s DCPL, Kolkata	1	1	-	10+1T	1	-	15+1T	-	1	-	S	1	1	Nil		
G	M/s DCPL, Kolkata Criteria	1	1	1	8+1T	1	1	2	1	1	1	1	1	1	S		
H	Design Calculations	1	1	1	8+1T	1	1	2	1	1	1	1	1	1	S		
I	Final consulting Engineering Report	1	1	1	10	1	1	2	1	1	1	S	1	1	Nil		

S – Source, T – Transparency & Soft Copy on CD,

TSGENCO : Telangana State Power Generation Corporation Limited
Director, Projects, Hyd : Director/ Projects, TSGENCO, Vidhut Soudha, Hyderabad – 500 082

	TITLE: TECHNICAL SPECIFICATION ELECTRIC HOISTS 1X800 MW KOTHAGUDEM TPS,	SPECIFICATION NO. PE-TS-410-563-A201	
		VOLUME - IIB	
		SECTION "D"	
		REV. 00	DATE: 30.07.15

SECTION - D

ELECTRIC HOISTS



TITLE **TECHNICAL SPECIFICATION FOR
WIRE ROPE ELECTRICAL HOIST
1X800 MW KOTHAGUDEM TPS**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME II - B

SECTION -D

REV 00

DATE 30.07.15

SHEET 1 OF 5

1.0.0 **INTENT OF SPECIFICATION**

This specification covers the design, engineering, manufacture, inspection and testing at manufacturer's works, properly packed and delivery to site for the steel wire rope electric hoist as specified in the Data Sheet A enclosed. The equipment specified shall include all accessories required for trouble free operation.

2.0.0 **Design Particulars**

The steel wire rope electric hoist covered in this specification shall be suitable for the lift as specified in Data Sheet - A. Equipment offered shall be conforming to specification requirements as per **IS: 3938 (latest edition)** and other specified Indian Standards.

3.0.0 **Technical Particulars**

3.1.0 Quantity:

The quantity of various steel wire electric hoist shall be as mentioned in Annexure A.

3.2.0 Type - Electrically operated with trolley.

3.3.0 Capacity / Lift: **As indicated in Annexure - A**

3.4.0 Applicable IS

DESCRIPTION

- | | |
|----------------|--|
| i) IS: 2266 | Specification for steel wire ropes for general engineering purposes. |
| ii) IS: 4029 | Guide testing induction motor. |
| iii) IS: 900 | Code of practice for installation and maintenance of induction motor. |
| iv) IS: 4237 | General requirement of switchgear and control gear for voltage motor exceeding 1000 Volts. |
| v) IS: 694 | Copper conductors PVC insulated cables for voltage up to 1000 Volts |
| vi) IS: 3043 | Code of practice for earthing. |
| vii) IS: 1822 | Motor starters for Voltages up to 650V. |
| viii) IS: 2147 | Degree of protection provided by enclosures for low voltage switch— gear and control gear. |
| ix) IS: 1554 | PVC insulated (Heavy-duty) electric cables for working voltages and including 1100 volts. |



TITLE **TECHNICAL SPECIFICATION FOR
WIRE ROPE ELECTRICAL HOIST
1X800 MW KOTHAGUDEM TPS**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME II - B

SECTION -D

REV 00

DATE 30.07.15

SHEET 2 OF 5

- x) IS: 325 Three phase induction motors.
- xi) IS: 15660 Point hook with shank.
- xii) IS 9968 Part I Flexible trailing cables

3.5.0 **Material of Construction**

- i) Frame — M.S.Plate-IS: 2062.
- ii) Wheels — Single flanged conform to IS: 3938
- iii) Gearbox — MS fabricated IS: 2062
- iv) Hook -- As per IS: 15560.

4.0.0 **Quality Plan & Inspection**

To ensure that the equipment and services are in accordance with the specification, the vendor shall follow/adopt BHEL's STANDARD QUALITY PLAN (enclosed herewith)/Customer approved QAP to control critical activities at all essential points. The enclosed standard quality plan should be duly signed and stamped as a token of acceptance and submitted by the bidder along with the offer.

Inspection shall be carried out by BHEL/customer representative as the case may be in line with the approved drawing / document. Any necessary requirement at any stage of inspection deemed necessary by Customer/BHEL shall be carried out without any commercial or technical implication.

5.0.0 **Name Plate**

All the electric hoists shall be provided with individual nameplate indicating minimum the following data's:

- Name of manufacturer
- Capacity (in tons)
- Lift (in meters)
- Serial No.

6.0.0 **Painting Procedure**

- 6.1.0 All surfaces to be painted shall be thoroughly cleaned of all grease, oil, loose mill



TITLE **TECHNICAL SPECIFICATION FOR
WIRE ROPE ELECTRICAL HOIST
1X800 MW KOTHAGUDEM TPS**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME II - B

SECTION -D

REV 00

DATE 30.07.15

SHEET 3 OF 5

scale, dust, rust and any other foreign matter. Mechanical cleaning by power tool and scrapping with steel wire brushes shall be adopted to clear the surfaces.

6.2.0 Machined and bearing surface shall be protected with varnish or thick coat of grease.

Also refer "Painting Requirements" in Volume IIB, Section C.

7.0.0 DESPATCH

All the Electric hoists shall be packed to avoid any damage during transits and storage at site.

8.0.0 POST CONTRACT DRAWINGS AND DOCUMENTS

The drawings / documents shall be submitted after placement of order as per Clause 3.00 of Section C.

9.0.0 INFORMATION TO BE FURNISHED WITH THE OFFER

As per Annexure II.

10.0.0 COLOUR SCHEME

Color scheme shall be intimated by the purchaser to vendor during the contract execution stage and the same shall be strictly followed.

11.0.0 GENERAL DESIGN FEATURE

Parts requiring replacement or lubrication shall be easily accessible & without dismounting type.

Equipment shall include the devices as required and comply with applicable standards/specification requirements.

Defects in material not acceptable/allowed. Rectification of any flaw is permissible only with the approval of Purchaser.

Hoist shall be rigid in construction and all movements shall be smooth and non-jerky. Design shall provide for easy maintenance of all parts, particularly the wheel bearings.

Design shall conform to IS: 3938 and other standards as specified.

Both hoists and trolleys are driven electrically. Wheels shall be single flanged type and to suit different monorail beam sizes and the shall be intimated to purchaser during of manufacturing stage.

Hook shall be swiveling type and fitted with a safety latch.



TITLE	TECHNICAL SPECIFICATION FOR		SPECIFICATION NO. PE-TS-410-563-A201
	WIRE ROPE ELECTRICAL HOIST		VOLUME II - B
	1X800 MW KOTHAGUDEM TPS		SECTION -D
	REV 00		DATE 30.07.15
	SHEET 4	OF 5	

Hoists shall be designed for minimum headroom above the highest position of hook and for closest hook approaches.

Hoist shall be designed with the following electrical features:

11.1.0 ELECTRICAL MOTOR DESIGN

Motor shall be squirrel cage induction type, and suitable for AC supply of 415V, 3 phase, 50 HZ, 40% CDF with IP—55 degree of protection. Motors shall be class 'F' insulated with temperature rise limited 70⁰ C & suitable for 150 starts/hr. Motors shall conform to IS-325 and tested in line with enclosed Quality Plan.

11.2.0 ELECTRICAL POWER

Hoist mounted heavy duty, electrical panel, direct on reversing type Air brake contactors, electrically interlocked for safety with necessary control gears such as control transformer, **MCB** (Control and Power), limit switches, thermostat, space heater, neutral **link**, ON/OFF 3 Phase door interlock switch, wrong connection preventor, overload relays with SPP features, indicating lamps, cable glands, lugs, terminals, cables etc. housed in totally enclosed IP— 55 degree of panel. Control voltage shall be 110V.

11.3.0 LIMIT SWITCH

Limit switches to prevent over hoisting , over lowering & over travelling shall be provided.

11.4.0 Brake

The hoist and cross traverse motors are fitted with an DC electro-magnetic disc type brake designed and built to arrest, and hold safely the full load capacity of load. The brakes shall be fail-safe type wherein failure of current immediately applies the brake.

11.5.0 PUSH BUTTON STATION

Pendent push button station shall be provided with minimum 5 nos. of glow type push buttons such as hoisting/lowering, cross traverse forward/reverse and emergency stop (mushroom head type). The contactors are operated by pendent push button station suspended from the hoist for easy operation and suspension is made on steel link chain. Necessary cable glands, lugs, terminals along with connecting cable of 12C—1.5 copper flexible cable shall be provided. Emergency stop push button shall



TITLE **TECHNICAL SPECIFICATION FOR
WIRE ROPE ELECTRICAL HOIST
1X800 MW KOTHAGUDEM TPS**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME II - B

SECTION -D

REV 00

DATE 30.07.15

SHEET 5 OF 5

be mushroom head (lockable)type. Pendent push button shall return to off position when released.

11.6.0 EARTHING

All electrical equipment (motor,panel,pendent) shall be provided with proper elements like bolts, washers ,nuts etc. for proper earthing at site.

11.7.0 POWER SUPPLY TO HOIST:

- i) Shrouded Bus Bar Conductor Type DSL complete with brackets and other fixing arrangements.
- ii) Isolator and cable from isolator at 1.5 m operating floor to DSL shall be supplied by the manufacturer.



TITLE

**1X800 MW KOTHAGUDEM TPS
ELECTRIC HOISTS**

SPECIFICATION NO. PE-TS-410-563-A201

VOLUME: III

REV 00

30.07.2015

VOLUME - III



TITLE:
**1X800 MW KOTHAGUEM TPS
TECHNICAL SPECIFICATION
COMPLIANCE CUM CONFIRMATION
CERTIFICATE**

SPEC. NO.: PE-TS-410-563-A201
VOLUME: III
SECTION:
REV. NO. 00
SHEET 1 OF 2

COMPLIANCE CUM CONFIRMATION CERTIFICATE

The bidder shall confirm compliance with following by signing / stamping this compliance certificate (every sheet) and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions, other than those mentioned under "exclusion and those resolved as per 'Schedule of Deviations', with regard to same.
- b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL / CUSTOMER approval & customer hold points for inspection / testing shall be marked in the QP at the contract stage. Inspection / testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. This is within the contracted price without any extra implications to BHEL after award of the contract.
- d) All drawings/ data-sheets / calculations etc. submitted along with the offer shall not be taken cognizance off.
- e) The offered materials shall be either equivalent or superior to those specified in the specification & shall meet the specified / intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre-bid discussions, otherwise BHEL / Customer's decision shall be binding on the bidder whenever the deficiency is pointed out.

For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.

- f) All sub vendors shall be subject to BHEL / CUSTOMER approval in the event of order.
- g) Guarantee for plant/equipment shall be as per relevant clause of GCC / SCC / Other Commercial Terms & Conditions
- h) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price and within purview of the tender specification even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities.
- i) Schedule of drawings submissions, comment incorporations & approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to BHEL's / Customer's / Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.



TITLE:
**1X800 MW KOTHAGUEDEM TPS
TECHNICAL SPECIFICATION
COMPLIANCE CUM CONFIRMATION
CERTIFICATE**

SPEC. NO.: PE-TS-410-563-A201

VOLUME: III

SECTION:

REV. NO. 00

SHEET 2 OF 2

- j) As built drawings shall be submitted as and when required during the project execution.
- k) The bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.
- l) Successful bidder shall furnish detailed erection manual for each of the equipment supplied under this contract at least 3 months before the scheduled erection of the concerned equipment / component or along with supply of concerned equipment / component whichever is earlier.
- m) Document approval by customer under Approval category or information category shall not absolve the vendor of their contractual obligations of completing the work as per specification requirement. Any deviation from specified requirement shall be reported by the vendor in writing and require written approval. Unless any change in specified requirement has been brought out by the vendor during detail engineering in writing while submitting the document to customer for approval, approved document (with implicit deviation) will not be cited as a reason for not following the specification requirement.
- n) In case vendor submits revised drawing after approval of the corresponding drawing, any delay in approval of revised drawing shall be to vendor's account and shall not be used as a reason for extension in contract completion.



PROJECT:- 1X800 MW KOTHAGUDAM TPP

PACKAGE:- ELECTRIC HOISTS

TENDER ENQUIRY REFERENCE:-

NAME OF VENDOR:-

SL NO	VOULME/SECTION	PAGE NO.	CLAUSE NO.	TECHNICAL SPECIFICATIO N/ TENDER DOCUMENT	COMPLETE DESCRIPTION OF DEVIATION	COST OF WITHDRAWAL OF DEVIATION	REFERENCE OF PRICE SCHEDULE ON WHICH COST OF WITHDRAWL OF DEVIATION IS APPLICABLE	NATURE OF COST OF WITHDRAWAL OF DEVIATION (POSITIVE/ NEGATIVE)	REASON FOR QUOTING DEVIATION
-------	----------------	----------	------------	---	-----------------------------------	---------------------------------	---	--	------------------------------

TECHNICAL DEVIATIONS

COMMERCIAL DEVIATIONS

PARTICULARS OF BIDDERS/ AUTHORISED REPRESENTATIVE

NAME	DESIGNATIONS	SIGN & DATE

NOTES:

- For self manufactured items of bidder, cost of withdrawal of deviation will be applicable on the basic price (i.e. excluding taxes, duties & freight) only.
- For directly dispatchable items, cost of withdrawal of deviation will be applicable on the basic price including taxes, duties & freight.
- All the bidders have to list out all their Technical & Commercial Deviations (if any) in detail in the above format.
- Any deviation not mentioned above and shown separately or found hidden in offer, will not be taken cognizance of.
- Bidder shall submit duly filled unpriced copy of above format indicating "quoted" in "cost of withdrawal of deviation" column of the schedule above along with their Techno-commercial offer, wherever applicable.
- Bidder shall furnish price copy of above format along with price bid.
- The final decision of acceptance/ rejection of the deviations quoted by the bidder shall be at discretion of the Purchaser.
- Bidders to note that any deviation (technical/commercial) not listed in above and asked after Part-I opening shall not be considered.
- For deviations w.r.t. Payment terms, Liquidated damages, Firm prices and submission of E1/ E2 forms before claiming 10% payment, if a bidder chooses not to give any cost of withdrawal of deviation loading as per Annexure-VIII of GCC. Rev-06 will apply. For any other deviation mentioned in un-priced copy of this format submitted with Part-I bid but not mentioned in priced copy
- Any deviation mentioned in priced copy of this format, but not mentioned in the un-priced copy, shall not be accepted.
- All techno-commercial terms and conditions of NIT shall be deemed to have been accepted by the bidder, other than those listed in unpriced copy of this format.
- Cost of withdrawal is to be given seperately for each deviation. In no event bidder should club cost of withdrawal of more than one deviation else cost of withdrawal of such deviations which have been clubbed together shall be considered as NIL.
- In case nature of cost of withdrawal (positive/negative) is not specified it shall be assumed as positive.
- In case of discrepancy in the nature of impact (positive/ negative), positive will be considered for evaluation and negative for ordering.



TITLE TECHNICAL SPECIFICATION FOR ELECTRIC HOISTS 1X800 MW KOTHAGUDEM TPP	SPECIFICATION NO. PE-TS-410-563-A201	
	VOLUME III	
	SECTION	
	REV 00	DATE 30-07-15
	SHEET 1	OF 1

DOCUMENTS TO BE FURNISHED WITH OFFER FOR TECHNICAL EVALUATION

- 1) Deviation schedule with reference to specific clauses of the specification along with reason for such deviation or No deviation in the format given under Vol.-III
- 2) SIGNED AND STAMPED COPY OF COMPLIANCE CUM CONFIRMATION CERTIFICATE.
- 3) Unpriced format, duly mentioned 'Quoted' against each Sl.no below each column.

NOTE:

i) NO OTHER DOCUMENTS OTHER THAN THOSE LISTED ABOVE ARE REQUIRED TO BE SUBMITTED FOR TECHNICAL EVALUATION. IN CASE ANY OTHER DOCUMENT IS FURNISHED, THE SAME WILL NOT BE TAKEN INTO CONSIDERATION FOR TECHNICAL EVALUATION.

ii) BIDDER TO CLEARLY MENTION "QUOTED" AGAINST EACH ITEM. IN CASE ANY ITEM IS NOT APPLICABLE THEN "NA" SHOULD BE CLEARLY MENTIONED AGAINST THE SAME.