


CLAUSE NO.	TECHNICAL REQUIREMENTS			
12.02.00	<p>installed by the Contractor. It is the assembly of sections and associated fittings forming a rigid structural system used to support the cable from the equipment or instrument enclosure upto the main cable trays (trunk route).</p>			
12.02.00	<p>The covers on the cable sub-trays shall be used for protection of cables in areas where damage may occur from falling objects, welding spark, corrosive environment, etc. & shall be electrically continuous and solidly grounded. The cable trays shall not have sharp edges, burrs or projections injurious to the insulation or outer sheath of the cables.</p>			
12.03.00	<p>The supporting arrangement of cable tray system shall be able to withstand the weight of the cable and cable tray system. The supporting interval shall not be more than the recommended span for the above loading for the type of cable tray selected. The tray shall not overhang by more than one meter from the support at the dead end. As far as practicable the cable sub-tray system shall be supported from one side only, in order to facilitate installation and maintenance of cables.</p>			
12.04.00	<p>The Bidder shall furnish and install the estimated quantities and sizes of sub trays/troughs including all required fittings and adaptors on as required basis.</p>			
VINDHYACHAL SUPER THERMAL POWER PROJECT STAGE-V (1X500 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATIONS SECTION-VI PART-B	SUB-SECTION-IIIC-07 INSTRUMENTATION AND POWER SUPPLY CABLE	PAGE 19 OF 19	

MOTORS

VINDHYACHAL SUPER THERMAL POWER PROJECT
STAGE-V (1X500 MW)
STEAM TURBINE GENERATOR PACKAGE

TECHNICAL SPECIFICATIONS
SECTION-VI
PART-B

INDUCTION MOTOR & SYNCHRONOUS MACHINE

TESTS/CHECKS	Visual	Dimensional	Make/Type/Rating/Tc/General	Physical Inspection	Mech/Chem. Properties	NDT /DP/PI/UT	Metallography	Electrical Characteristics	Welding/Brazing(WPS/PQR)	Heat Treatment	Magnetic Characteristics	Hydraulic/Leak/Pressure Test	Thermal Characteristics	Run out	Dynamic Balancing	All tests as per IS-325/IS-4722 / 9283	Vibration	Over speed	Tan delta, shaft voltage & polarisation index test	
TEMS/COMPONENTS																				
Plates for stator frame, end shield, spider etc.	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y										
Shaft	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Magnetic Material	Y	Y	Y	Y	Y	Y	Y	Y			Y									
Rotor Copper/Aluminium	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Stator copper	Y	Y	Y	Y	Y	Y	Y	Y		Y										
SC Ring	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Insulating Material	Y	Y	Y	Y	Y	Y	Y	Y												
Tubes for Cooler	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Sleeve Bearing	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Stator/Rotor, Exciter Coils	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Castings, stator frame, terminal box and bearing housing etc.	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Fabrication & machining of stator, rotor, terminal box	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Wound stator	Y	Y	Y	Y	Y	Y	Y	Y												
Wound Exciter	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Rotor complete	Y	Y	Y	Y	Y	Y	Y	Y		Y										
Exciter, Stator, Rotor, Terminal Box assembly	Y	Y	Y	Y	Y	Y	Y	Y		Y				Y						
Accessories, RTD, BTD,CT, Brushes, Diodes,Space heater, antifriction bearing, cable glands, lugs, gaskets etc.	Y	Y	Y	Y	Y	Y	Y	Y												
Motor (IS 325 / 4722/ 9283)	Y	Y	Y	Y	Y	Y	Y	Y								Y				Y1

Note: 1. This is an indicative list of tests/checks. The manufacture is to furnish a detailed Quality Plan indicating the practices & Procedure followed along with relevant supporting documents during QP finalization. However, No QP for LT motor up to 50KW.
 2. Makes of all major bought out items will be subject to NTPC approval.
 Y1 = for HT Motor / Machines only.



1X500 MW VINDHYACHAL STAGE-V STPP
SG PACKAGE

SPECIFIC TECHNICAL REQUIREMENTS (C&I)
FUEL OIL UNLOADING AND HANDLING SYSTEM

**CONTROL AND INSTRUMENTATION SPECIFICATION
FOR
FUEL OIL UNLOADING AND HANDLING SYSTEM**



**1X500 MW VINDHYACHAL STAGE-V STPP
SG PACKAGE**

**SPECIFIC TECHNICAL REQUIREMENTS (C&I)
FUEL OIL UNLOADING AND HANDLING SYSTEM**

Specific Technical Requirements (C&I):


- 1.0 FUEL OIL UNLOADING AND HANDLING SYSTEM shall be controlled from DCS (BHEL make & scope of supply).
- 2.0 All necessary instruments such as transmitters/gauges etc. shall be provided for safe, efficient and reliable operation and maintenance of the Fuel Oil Handling System.
- 3.0 Since FOHS comes under hazardous area. Instruments shall be provided with explosion proof enclosure suitable for hazardous areas described in National Electric Code (USA), Article 500, Class-I, Division-I or EN60079-14 or shall comply with the essential requirements of ATEX directives. All fittings, cable glands etc. shall be strictly as per NEC recommendation article, 500 to 503.
- 4.0 Ultrasonic type level transmitters shall be provided.
- 5.0 The quantity of instruments shall be as per tender P&ID and Design Memorandum/Philosophy as a minimum, for bidding purpose. However, bidder shall also include in his proposal all the instruments and devices, which are needed for the completeness of system/equipment, supplied by the bidder, even if the same is not specifically appearing in the P&ID and Design philosophy. During detail engineering if any additional instruments are required for safe & reliable operation of plant, bidder shall supply the same without any price implication.
- 6.0 Bidder to include all the instruments (PG, PT, LT etc.) required for the package along with fittings, accessories and valve manifold.
- 7.0 Since instruments are required for oil application. Instruments shall be suitable for oil application & to be provided with diaphragm seal.
- 8.0 The detailed specification of instruments etc. is enclosed in the subsequent clauses of this technical specification.
- 9.0 The make/model of various instruments/items/systems shall be subject to approval of owner/purchaser during detailed engineering stage. No commercial implication in this regard shall be acceptable.
- 10.0 In case of any conflict and repetition of clauses in the specification, the more stringent requirements among them are to be complied with.




**1X500 MW VINDHYACHAL STAGE-V STPP
SG PACKAGE**

**SPECIFIC TECHNICAL REQUIREMENTS (C&I)
FUEL OIL UNLOADING AND HANDLING SYSTEM**

- 11.0 Drawings/Documents and data to be furnished after the award of contract for BHEL & NTPC review:
- Field instruments data sheet.
 - Instrument schedule.
 - Drive List and Analog / Binary Input / output List (in BHEL format)
 - Recommended Control write-up and Control Scheme/Logic.
 - HMI mimics manuscripts (in BHEL format)
 - List of Recommended Alarms and SOEs with set points. (in BHEL format)
 - Any other document decided during detailed engineering.
- 12.0 All motor operated valves/electrical actuators shall be envisaged with integral starter.
- 13.0 Mandatory spares: The following mandatory spares shall be provided by the bidder as per the list enclosed under Section -C, Annexure -II


CLAUSE NO.	TECHNICAL REQUIREMENTS 												
MEASURING INSTRUMENTS													
1.00.00	MEASURING INSTRUMENTS												
1.01.00	<p>Measuring instruments/equipment and subsystems offered by the Bidder shall be from reputed experienced manufacturers of specified type and range of equipment, whose guaranteed and trouble free operation has been proven. Refer Sub-section-IV:11(Basic Design Criteria). Further, all instruments shall be of proven reliability, accuracy, and repeatability requiring a minimum of maintenance. They shall comply with the acceptable international standards and shall be subject to Employer's approval. All instrumentation equipment and accessories under this specification shall be furnished as per technical specifications, ranges, makes/numbers as approved by the Employer during detailed engineering.</p>												
1.02.00	<p>Every panel-mounted instrument requiring power supply shall be provided with a pair of easily replaceable glass cartridge fuses of suitable rating. Every instrument shall be provided with a grounding terminal and shall be suitably connected to the panel grounding bus.</p>												
1.03.00	<p>All local gauges as well as transmitters, sensors, and switches for parameters like pressure, temperature, level, flow etc. as required for the safe and efficient operation and maintenance as well as for operator and management information (including all computation) of equipment under the scope of specification shall be provided on as required basis within the quoted lump sum price. For bidding purpose, tentative minimum instruments have been indicated on the P&IDs. However, contractor shall supply any additional local gauges/switches/transmitters/sensors for reasons mentioned above without any additional cost to the Employer.</p>												
1.04.00	<p>The necessary root valves, impulse piping, drain cocks, gauge-zeroing cocks, valve manifolds and all the other accessories required for mounting/erection of these local instruments shall be furnished, even if not specifically asked for, on as required basis. The contacts of equipment mounted instruments, sensors; switches etc. for external connection including spare contacts shall be wired out in flexible/rigid conduits, independently to suitably located common junction boxes. The proposal shall include the necessary cables, flexible conduits, junction boxes and accessories for the above purpose. Double root valves shall be provided for all pressure tapping where the pressure exceeds 40 Kg./sq.cm.</p>												
1.05.00	<p>For all instruments envisaged for sea water applications, they shall be provided with wetted parts made of monel/Hastelloy C or any other material (if provenness experience of the proposed material for such applications is established by Contractor).</p>												
1.06.00	<p>All instruments shall be provided with durable epoxy coating for housings and all exposed surfaces of the instruments.</p>												
2.00.01	<p>SPECIFICATION FOR ELECTRONIC TRANSMITTER FOR PRESSURE, D.P., FLOW AND LEVEL</p> <table border="1" data-bbox="414 1556 1380 1780"> <thead> <tr> <th colspan="3">ELECTRONIC TRANSMITTERS</th> </tr> <tr> <th>Sl.No:</th> <th>Features</th> <th>Essential/Minimum Requirements</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>Type of Transmitter</td> <td>Microprocessor based 2 wire type, Hart protocol compatible.</td> </tr> <tr> <td>2.</td> <td>Accuracy</td> <td>± 0.1% of calibrated span (minimum)</td> </tr> </tbody> </table>	ELECTRONIC TRANSMITTERS			Sl.No:	Features	Essential/Minimum Requirements	1.	Type of Transmitter	Microprocessor based 2 wire type, Hart protocol compatible.	2.	Accuracy	± 0.1% of calibrated span (minimum)
ELECTRONIC TRANSMITTERS													
Sl.No:	Features	Essential/Minimum Requirements											
1.	Type of Transmitter	Microprocessor based 2 wire type, Hart protocol compatible.											
2.	Accuracy	± 0.1% of calibrated span (minimum)											
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2268-104-2	PART - B SUB-SECTION-IV C-4 (MEASURING INSTRUMENTATION)	PAGE 1 OF 15										




S


611

13

CLAUSE NO.	TECHNICAL REQUIREMENTS	
3.	Output signal range	4-20 mA DC (Analog) along with superimposed digital signal (based on HART protocol)
4.	Turn down ratio	10:1 for vacuum/very low pressure applications. 30:1 for other applications.
5.	Stability	± 0.1% of calibrated span for six months for Ranges up to and including 70 Kg/cm ² . ± 0.25% of calibrated span for six months for Ranges more than 70 Kg/cm ² (g).
6.	Zero and span drift	+/- 0.015% per deg. C at maximum span. +/-0.11% per deg. C at minimum span.
7.	Load impedance	500 ohm (min.)
8.	Housing	Weather proof as per IP-55 with durable corrosion resistant epoxy coating.
9.	Over Pressure	150% of maximum operating pressure
10.	Connection (Electrical)	Plug and socket type
11.	Process connection	1/2 inch NPT (F)
12.	Span and Zero	Continuous, tamper proof, Remote as well as adjustability manual from instrument with zero suppression and elevation facility.
13.	Accessories	-Diaphragm seal, pulsation dampeners, syphon etc. as required by service and operating condition. -2 valve manifold for absolute pressure transmitters (3-valve manifold for gauge/ vacuum pressure transmitters) and 5 valve manifold for DP/level/flow transmitters. -For hazardous area, explosions proof enclosure as described in NEC article 500.
14.	Diagnostics	Self Indicating feature
15.	Power supply	24V DC ± 10%
16.	Adjustment/calibration/maintenance	Centralised PC based system (In Employer's Scope). In addition total two (2) no. of hand- held type universal calibrators per unit, compatible with HART protocol, shall be provided.
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2
PART - B SUB-SECTION-IV C-4 (MEASURING INSTRUMENTATION)		

612



CLAUSE NO.	TECHNICAL REQUIREMENTS			
2.01.00	Notes			
	In case it becomes necessary to use a DP transmitter for pressure measurement, then a 3-valve manifold should be used in place of 2-valve manifold.			
	LVDT type is not acceptable.			
	Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application.			
	Ultrasonic Type level Transmitter			
	Sl. No	Features	Essential/Minimum requirements	
	1.	Type of Transmitter	Non contact Microprocessor based 2 wire type, HART protocol compatible Ultrasonic transmitter.	
	2.	Output signal	Galvanically isolated 4-20mA DC (Analog) along with superimposed digital signal (based on HART protocol).	
	3.	Sensor Accuracy	+/- 0.5% of calibrated span.	
	4.	Sensor Repeatability	3 mm or better.	
	5.	Power supply	24 V DC +/- 10%	
6.	Temperature compensation	To be provided within transducer.		
7.	Configuration	Sensor unit and Electronic units are to be separate. It shall be possible to mount the Electronic unit at a remote accessible location from the transducer. All cables and weather proof fittings to interconnect transducer to electronic unit shall be provided by Bidder.		
8.	Housing	Weather proof as per IP-55 with durable corrosion resistant epoxy coating.		
9.	Calibration	Through HART Communicator.		
10.	Zero and Span adjustment	Continuous, tamper proof, remote as well as manual adjustability from instrument. It shall be possible to calibrate the instrument without any level in the tank/sump etc		
11.	Sensor Material	Corrosion resistant material to suit individual application requirement.		
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-4 (MEASURING INSTRUMENTATION)	PAGE 3 OF 15	





Handwritten signature



613

3

CLAUSE NO.	TECHNICAL REQUIREMENTS																					
	12.	False signal tolerance	Transmitter shall be capable of ignoring false echoes from internal tank/sumps obstructions such as pipes, heating coils or agitator blades. Also transmitter shall have adjustable damping circuitry																			
	13.	Range	Range of transmitter shall be capable of covering the complete level span of tank taking care of blocking distance, frequency attenuation due to surface, obstructions, vapors etc																			
	14.	Display	Minimum 4 character display with integral keypad, access protected by user code.																			
	15.	Diagnostics	Loss of echo alarm etc																			
	16.	Load Impedance	500 ohms minimum																			
	17.	Electrical Connection	Plug and socket																			
	18.	Accessories	<ul style="list-style-type: none"> • All weather canopy for protection from direct sunlight and direct rain. • All mounting hardware and accessories required for erection and commissioning mounting fittings material shall be SS 316. • For hazardous areas, explosion proof enclosure as described in NEC article 500. 																			
3.00.00	TEMPERATURE ELEMENTS																					
3.01.00	Thermocouple																					
	<table border="1"> <thead> <tr> <th data-bbox="446 1243 510 1288">Sr. No.</th> <th data-bbox="510 1243 829 1288">Features</th> <th data-bbox="829 1243 1436 1288">Essential/Minimum Requirements</th> </tr> </thead> <tbody> <tr> <td data-bbox="446 1332 510 1377">1</td> <td data-bbox="510 1332 829 1377">Type of Thermocouple.</td> <td data-bbox="829 1332 1436 1377">: 16 AWG wire of Chromel-Alumel (Type K) or 24 AWG wire Pt-Rhodium Pt (Type R) depending on operating temperature Range (ungrounded type).</td> </tr> <tr> <td data-bbox="446 1444 510 1489">2</td> <td data-bbox="510 1444 829 1489">No. of element</td> <td data-bbox="829 1444 1436 1489">: Duplex</td> </tr> <tr> <td data-bbox="446 1500 510 1545">3</td> <td data-bbox="510 1500 829 1545">Housing/Head</td> <td data-bbox="829 1500 1436 1545">: IP-55/Diecast Aluminium. Plug in connectors are to be provided for external signal cable connection.</td> </tr> <tr> <td data-bbox="446 1579 510 1646">4</td> <td data-bbox="510 1579 829 1646">Sheathing of Thermocouple</td> <td data-bbox="829 1579 1436 1646">: Swaged type magnesium oxide insulation-</td> </tr> <tr> <td data-bbox="446 1657 510 1702">5</td> <td data-bbox="510 1657 829 1702">Calibration and accuracy</td> <td data-bbox="829 1657 1436 1702">: As per IEC-751/ANSI-C-96.1(special class) for T/C.</td> </tr> <tr> <td data-bbox="446 1713 510 1758">6</td> <td data-bbox="510 1713 829 1758">Characteristic</td> <td data-bbox="829 1713 1436 1758">: Linear with respect to temp, within $\pm 1/2$ percent of top range value.</td> </tr> </tbody> </table>	Sr. No.	Features	Essential/Minimum Requirements	1	Type of Thermocouple.	: 16 AWG wire of Chromel-Alumel (Type K) or 24 AWG wire Pt-Rhodium Pt (Type R) depending on operating temperature Range (ungrounded type).	2	No. of element	: Duplex	3	Housing/Head	: IP-55/Diecast Aluminium. Plug in connectors are to be provided for external signal cable connection.	4	Sheathing of Thermocouple	: Swaged type magnesium oxide insulation-	5	Calibration and accuracy	: As per IEC-751/ANSI-C-96.1(special class) for T/C.	6	Characteristic	: Linear with respect to temp, within $\pm 1/2$ percent of top range value.
Sr. No.	Features	Essential/Minimum Requirements																				
1	Type of Thermocouple.	: 16 AWG wire of Chromel-Alumel (Type K) or 24 AWG wire Pt-Rhodium Pt (Type R) depending on operating temperature Range (ungrounded type).																				
2	No. of element	: Duplex																				
3	Housing/Head	: IP-55/Diecast Aluminium. Plug in connectors are to be provided for external signal cable connection.																				
4	Sheathing of Thermocouple	: Swaged type magnesium oxide insulation-																				
5	Calibration and accuracy	: As per IEC-751/ANSI-C-96.1(special class) for T/C.																				
6	Characteristic	: Linear with respect to temp, within $\pm 1/2$ percent of top range value.																				
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	<div style="text-align: center;">  </div> PART - B SUB-SECTION - IV C-4 (MEASURING INSTRUMENTATION)																				

614

CLAUSE NO.	TECHNICAL REQUIREMENTS				
6.00.00	SPECIFICATIONS FOR PR. GAUGE, D.P. GAUGE, TEMP. GAUGE AND LEVEL GAUGE.				
	SI.No	FEATURES	ESSENTIAL/MINIMUM REQUIREMENTS		
			Pr. Gauge/ DP Gauge/ Draught gauges	Temperature Gauge	Level Gauge
	1	Sensing Element and material	Bourdon for high pressure, Diaphragm/ Bellow for low pr. Of 316 SS	Mercury in steel for below 450°C and inert gas actuated for above 450°C of SS bulb and capillary.	Tempered *toughened Borosilicate gauge glass steel armoured reflex or transparent type.
	2	Body material	Die-cast aluminium	Die-cast aluminium	Forged carbon steel/304 SS
	3	Dial size	150mm	150 mm	Tubular covering entire range
	4	End connection	1/2 inch NPT (M)	3/4" NPT (M)	Process connection as per ASME PTC and drain/vent 15 NB
	5	Accuracy	±1% of span	± 1% of span	± 2%
	6	Scale	Linear, 270° arc graduated in metric units	Linear, 270° arc graduated in °C	Linear vertical
	7	Range selection	Cover 125% of max. of scale	Cover 125% of max. of scale	Cover 125% of max. of scale
	8	Over range test	Test pr. for the assembly shall be 1.5 to the max. Design pr. at 38°C.		
	9	Housing	Weather and per IP-55	Weather and dust proof as per IP-55	CS/304 SS leak dust proof as proof
	10	Zero/span adjustment	Provided	Provided	--
	11	Identification	Engraved with service legend or laminated phenolic name plate		
	12	Accessories	Blow out disc, siphon, snubber, pulsation dampener, chemical seal (if required by process) gauge isolation valve	SS Thermowell	Gasket for all KEL-F shield for transparent type vent and drain valves. Steel/SS as per CS Alloy process Requirement
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-4 (MEASURING INSTRUMENTATION)	 PAGE 10 OF 15		

CLAUSE NO.	TECHNICAL REQUIREMENTS																																	
7.00.00	13	Material of Bourdon/ movement	316 SS / 304 SS	316 SS / 304 SS																														
	<p>Notes:-</p> <p>* Bicolour type level gauges will be provided for applications involving steam and water except for condensate and feed water services.</p> <p>Length of gauge glass shall not be more than 1400 mm. If the vessel is higher, multiple gauge glasses with 50 mm overlapping shall be provided.</p> <p>Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application.</p>																																	
PROCESS ACTUATED SWITCHES																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 25%;">FEATURES</th> <th colspan="4">ESSENTIAL / MINIMUM REQUIREMENTS</th> </tr> <tr> <th></th> <th style="width: 25%;">1</th> <th style="width: 25%;">2</th> <th style="width: 25%;">3</th> <th style="width: 25%;">4</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td>Pressure/ Draft Switches/ DP Switches</td> <td>Temperature switches</td> <td>Level switches</td> </tr> <tr> <td>Sensing Element</td> <td></td> <td>Piston actuated for high pressure and diaphragm or bellows for low pr./ vacuum</td> <td>Vapor pressure sensing, liquid filled bellow type with SS bulb and capillary (10 m minimum)</td> <td>Capacitance types for oil and dirty medium, water, condensate application. Float type switches for applications as decided by Employer during detailed engineering. Capacitance/ Conductivity/ Ultrasonic type for acid and alkali application. Radio-frequency/ Ultrasonic type for ash hopper, ash slurry application.</td> </tr> <tr> <td>Material</td> <td></td> <td>316 SS</td> <td>Bulb 316 SS/ capillary 304 SS</td> <td>316 SS</td> </tr> <tr> <td>End connection</td> <td></td> <td>½ inch NPT (F)</td> <td>½ inch NPT (F)</td> <td>Manufacturer standard</td> </tr> </tbody> </table>					FEATURES	ESSENTIAL / MINIMUM REQUIREMENTS					1	2	3	4			Pressure/ Draft Switches/ DP Switches	Temperature switches	Level switches	Sensing Element		Piston actuated for high pressure and diaphragm or bellows for low pr./ vacuum	Vapor pressure sensing, liquid filled bellow type with SS bulb and capillary (10 m minimum)	Capacitance types for oil and dirty medium, water, condensate application. Float type switches for applications as decided by Employer during detailed engineering. Capacitance/ Conductivity/ Ultrasonic type for acid and alkali application. Radio-frequency/ Ultrasonic type for ash hopper, ash slurry application.	Material		316 SS	Bulb 316 SS/ capillary 304 SS	316 SS	End connection		½ inch NPT (F)	½ inch NPT (F)	Manufacturer standard
FEATURES	ESSENTIAL / MINIMUM REQUIREMENTS																																	
	1	2	3	4																														
		Pressure/ Draft Switches/ DP Switches	Temperature switches	Level switches																														
Sensing Element		Piston actuated for high pressure and diaphragm or bellows for low pr./ vacuum	Vapor pressure sensing, liquid filled bellow type with SS bulb and capillary (10 m minimum)	Capacitance types for oil and dirty medium, water, condensate application. Float type switches for applications as decided by Employer during detailed engineering. Capacitance/ Conductivity/ Ultrasonic type for acid and alkali application. Radio-frequency/ Ultrasonic type for ash hopper, ash slurry application.																														
Material		316 SS	Bulb 316 SS/ capillary 304 SS	316 SS																														
End connection		½ inch NPT (F)	½ inch NPT (F)	Manufacturer standard																														
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-4 (MEASURING INSTRUMENTATION)	 PAGE 11 OF 15																															

Sm

621

3



**CHECK LIST FOR
PRESSURE / DIFFERENTIAL PRESSURE TRANSMITTER
(Mechanical Auxillary Packages)**

SPECIFICATION NO.:

VOLUME

SECTION

REV. NO.

DATE:

SHEET 3 OF 3

Data Sheet No.. PE-CL-999-145-1026-0

SL NO	TESTS/CHECKS	QUANTM OF CHECK	REFERENCE DOC. ACCEPTANCE NORMS	AGENCY			REMARKS
				M	C	B	
1.0	CHECKS FOR VISULA, MODEL TAG NO.	SEE NOTE-1 BELOW	APPROVED TECHINCAL REQUIREMENT/ DATA SHEET	P	W	V	MFR TO CARRY OUT ROUTINE TEST ON 100%. WHEN MATERIAL CORELATION ARE NOT AVAILABLE MFR'S COMPLIANCE TO BE PROVIDED
2.0	PROCESS CONNECTION	-do-		P	W	V	
3.0	ACCURACY	-do-		P	W	V	
4.0	REPEATEABILITY	-do-		P	W	V	
5.0	HYSTERISIS	-do-		P	W	V	
6.0	EFFECT OF TEMP VARIATION ON ACCURACY	-do-		P	W	V	
7.0	SPAN /ZERO ADJUSTMENT	ONE/TYPE		P	W	V	
8.0	EFFECT OF SUPPLY VOLTAGE VARIATION	ONE/TYPE		P	W	V	
9.0	HIGH PRESSURE TEST	SEE NOTE-1 BELOW		P	W	V	
10.0	BURN IN TEST	ONE/TYPE		P	W	V	
11.0	DEGREE OF PROTECTION	ONE/TYPE		P	W	V	

LEGEND:

M: MANUFACTURER/ SUB CONTRACTOR, C: CONTRACTOR/ NOMINATED INSP AGENCY, B: BHEL. P: PERFORM, W: WITNESS, V: VERIFICATION.

NOTE:

1. QUANTUM OF CHECK SHALL BE AS BELOW
100 % - BY MANUFACTURER
RANDOM FOR EACH TYPE - BY BHEL & CUSTOMER
2. MANUFACTURER TO MAINTAIN CALIBRATED INSTRUMENT HAVING BETTER ACCURACY THAN THE ITEM UNDER TEST. INSPECTING ENGINEER SHALL CHECK THE SAME.
3. IN CASE OF IMPORTED ITEMS CONTRACTORS SHALL REVIEW TC's AND NOT INSPECT.

CONTRACTOR TO PROVIDE COMPLIANCE CERTIFICATE FOR TESTS/CHECKS VERIFIED BY CONTRACTOR AND SUBMIT THE SAME ALONGWITH TEST CERTIFICATES TO BE VERIFIED BY BHEL.



**CHECK LIST FOR
PRESSURE / DIFFERENTIAL PRESSURE GAUGE
(Mechanical Auxiliary Packages)**

SPECIFICATION NO.:	
VOLUME	
SECTION	
REV. NO.	DATE:
SHEET 2	OF 2

Data Sheet No.: PE-CL-999-145-1026-0

SL NO	TESTS/CHECKS	QUANTM OF CHECK	REFERENCE DOC. ACCEPTANCE NORMS	AGENCY			REMARKS
				P	W	V	
1.0	CHECK FOR		APPROVED TECHNICAL REQUIREMENT/ DATA SHEET				MFR TO CARRY OUT ROUTINE TEST ON 100%. WHEN MATL CORELATION ARE NOT AVAILABLE MFR'S COMPLIANCE TO BE PROVIDED
	1.1 DIAL SIZE	100%		M	C	C	
	1.2 MODEL NO/TAG NO	100%		M	C	C	
	1.3 RANGE/SCALE	100%		M	C	C	
	1.4 END CONNECTION	100%		M	C	C	
	1.5 SWITCH CONTACT RATING & NOS	100%		M	C	C	
2.0	CALIBRATION						
	2.1 ACCURACY	100%		M	C	B	
	2.2 REPEATABILITY (FOR SWITCH)	100%		M	C	B	
	2.3 SET POINT ADJUSTMENT FOR SWITCH	100%		M	C	C	
3.0	OVER PRESSURE & LEAK TEST	100%		M	C	C	
4.0	OPERATION OF PR. RELIEF DEVICE	ONE PER TYPE		M	C	C	
5.0	REVIEW OF T.C. FOR MATERIAL OF--						
	5.1 SENSOR	FOR LOT		-	-	B	
	5.2 MOVEMENT			-	-	B	
	5.3 PROCESS CONNECTION		-	-	B		
	5.4 HOUSING		-	-	B		
6.0	REVIEW OF T.C. FOR DEGREE OF PROTECTION	TYPE TEST	-	-	B		
7.0	REVIEW OF T.C. FOR CONTACT RATING OF SWITCH	ONE PER TYPE	-	-	B		
8.0	ACCESSORIES AS APPLICABLE	100%	M	C	C		

LEGEND:

M: MANUFACTURER/ SUB CONTRACTOR, C: CONTRACTOR/ NOMINATED INSP AGENCY, B: BHEL. P: PERFORM, W: WITNESS, V: VERIFICATION.

NOTE:

CONTRACTOR TO PROVIDE COMPLIANCE CERTIFICATE FOR TESTS/CHECKS VERIFIED BY CONTRACTOR AND SUBMIT THE SAME ALONGWITH TEST CERTIFICATES TO BE VERIFIED BY BHEL.



SUB-SECTION-III:E9

ELECTRICAL ACTUATORS WITH INTEGRAL STARTERS





VINDHYACHAL STPP -V (1X500MW)
STEAM GENERATOR WITH
ELECTROSTATIC PRECIPITATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
BID DOCUMENT NO.: CS-2260-101-2

482

CLAUSE NO.	TECHNICAL REQUIREMENTS	
1.00.00	ELECTRIC ACTUATORS WITH INTEGRAL STARTERS	
1.01.00	TYPE:	
1.01.01	The actuators shall have integral starters along with over load relays with built in SPP (Single Phasing Preventer). A 415, 3 phase 3 wire power supply shall be given to the actuator from vendor's/employer's switch board as applicable through a switch fuse unit. Control voltage of the motor starter shall be 110 V AC / 24 V DC, derived suitably from 415V power supply.	
1.01.02	In case supplier's standard control voltage for Open/Close contactors is 110V AC, the same is acceptable if suitable Opto Isolation circuit is provided with coupling relays for 24 V DC command inputs.	
1.02.00	INTERFACES:	
1.02.01	<p>Open/Close command termination logic with position & torque Limit Switches, positioner circuit shall be suitably built in the PCB inside the actuator.</p> <p>(a) For Binary Drive (both ON-OFF and INCHING type) :- Open/Close command & status thereof and disturbance monitoring signal (common contact for Overload; Thermostat, control supply failure, L/R selector switch at local & other protections operated) shall be provided.</p> <p>Interface with the control system shall be through hardware signal only. Inter posing relays provided (with coil burden 2.5 VA) in the actuator shall be energized to initiate opening and closing, by 24V DC signal from the external control system.</p> <p>(b) For Modulating Drive:- the command to actuator shall be in form of 4-20mA signal. The necessary positioning circuit and motor protection shall be provided</p> <p>(c) Open/close command termination logic shall be suitably built inside actuator.</p>	
1.03.00	<p>RATING :</p> <p>(a) Supply Voltage & frequency: 415V +/- 10%, 3 Phase, 3 Wire 50HZ +/-5%.</p> <p>(b) Sizing:-</p> <p>Open/Close at rated speed against designed differential pressure at 90% of rated voltage.</p> <p>For isolating service:- Three successive open-close operations or 15 mins, whichever is higher. For regulating service 150 starts per hour or required cycles, whichever is higher.</p>	
1.04.00	<p>CONSTRUCTION:</p> <p>(a) Enclosure:</p> <p>Totally enclosed weatherproof minimum IP-55 degree of protection.</p>	
<p>VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION-VI BID DOCUMENT NO.: CS-2260-101-2</p>	<p>PART-B SUB-SECTION III: E9 ELECTRIC ACTUATORS WITH INTEGRAL STARTERS</p> <p>Power Sector Marketing 1/10/09</p> <p>PAGE 1 OF 3</p>

CLAUSE NO.	TECHNICAL REQUIREMENTS	एनटीपीसी NTPC
1.05.00	<p>(b) Gear Train :</p> <p>Metal (Fibre gears are not acceptable)) self-locking to prevent drift under torque switch (where ever applicable) spring pressure when motor is de-energized.</p> <p>(c) Manual.Wheel:</p> <p>Shall disengage automatically during motor operation.</p> <p>MOTOR :</p> <p>(a) Type :</p> <p>Squirrel cage induction motor suitable for Direct On Line (DOL)starting.</p> <p>(b) Enclosure:</p> <p>Totally enclosed, self ventilated IP-55 degree of protection.</p> <p>(c) Insulation</p> <p>Class B or better. Temperature rise 70 Deg C. over 50 Deg C ambient</p> <p>(d) Bearings:</p> <p>Double shielded, grease lubricated antifriction.</p> <p>(e) Earth Terminals:</p> <p>Two</p> <p>(f) Protection:</p> <p>Single Phasing Protection, Over heating protection through Thermostat and wrong phase sequence protection shall be provided over and above other protection features standard to bidder's design Suitable means shall be provided to diagnose the type of fault locally.</p>	
1.06.00	<p>POSITION/TORQUE SWITCHES:</p>	
1.06.01	<p>Four nos. (2 each in open and close position) position limit switches and two nos. (one in open and other in close direction) torque switches each having two nos. NO and two nos. NC contacts shall be provided. A single shaft shall actuate all contacts of limit switches at each position.</p> <p>Limit switch and disturbance signals shall be available to DCS even when the power supply to the actuators is not available.</p> <p>Torque switches shall be bypassed in both the end positions with the other end Limit switches.</p>	
<p>VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION-VI BID DOCUMENT NO.: CS-2260-101-2</p>	<p>PART-B SUB-SECTION-III:E9 ELECTRIC ACTUATORS WITH INTEGRAL STARTERS</p> 

	SPECIFICATION FOR MOTORISED VALVE ACTUATOR		SPECIFICATION NO.:		
			VOLUME		
			SECTION		
			REV. NO.	DATE:	
			SHEET	1	OF 3
Data Sheet A & B					
DATA SHEET-A (TO BE FILLED BY PURCHASER)			DATA SHEET-B (TO BE FILLED-UP BY BIDDER)		
GENERAL*	* PROJECT	1X500 MW VINDHYACHAL STAGE-V			
	OFFER REFERENCE				
	* TAG NO. SERVICE				
	* DUTY	<input type="checkbox"/> ON / OFF		<input type="checkbox"/> INCHING	
	* LINE SIZE (inlet/outlet): MATERIAL				
	* VALVE TYPE	<input type="checkbox"/> GLOBE <input type="checkbox"/> GATE <input type="checkbox"/> REG. GLOBE		<input type="checkbox"/> BUTTERFLY	
	* OPENING / CLOSING TIME				
	* WORKING PRESSURE				
	AMBIENT CONDITION	SHALL BE SUITABLE FOR CONTINUOUS OPERATION UNDER AN AMBIENT TEMP. OF 0-55 DEG C AND RELATIVE HUMIDITY OF 0-95%			
	VALVE SEAT TEST PRESS	BIDDER TO SPECIFY			
	REQUIRED VALVE TORQUE	BIDDER TO SPECIFY			
	ACTUATOR RATED TORQUE	BIDDER TO SPECIFY			
CONSTRUCTION AND SIZING	CONSTRUCTION	TOTALLY ENCLOSED, WEATHER PROOF, IP:55			
	MECHANICAL POSITION INDICATOR	TO BE PROVIDED FOR 0-100% TRAVEL			
	BEARINGS	DOUBLE SHIELDED, GREASE LUBRICATED ANTI-FRICTION.			
	GEAR TRAIN FOR LIMIT SWITCH/TORQUE SWITCH OPERATION	METAL (NOT FIBRE GEARS). SELF-LOCKING TO PREVENT DRIFT UNDER TORQUE SWITCH SPRING PRESSURE WHEN MOTOR IS DE-ENERGIZED.			
	SIZING	OPEN/CLOSE AT RATED SPEED AGAINST DESIGNED DIFFERENTIAL PRESSURE AT 90% OF RATED VOLTAGE. FOR ISOLATING SERVICE THREE SUCCESSIVE OPEN-CLOSE OPERATIONS OR 15 MINS. WHICHEVER IS HIGHER. FOR INCHING(REGULATING) SERVICE 150 STARTS/HR MINIMUM			
HANDWHEEL	* REQUIRED	<input checked="" type="checkbox"/> YES		<input type="checkbox"/> NO	
	* ORIENTATION	<input type="checkbox"/> TOP MOUNTED		<input type="checkbox"/> SIDE MOUNTED	
	TO DISENGAGE AUTOMATICALLY DURING MOTOR OPERATION.				
ELECTRIC ACTUATOR	ACTUATOR MAKE/MODEL	BIDDER TO SPECIFY			
	MOTOR MAKE / MODEL / TYPE / RATING (KW)	BIDDER TO SPECIFY			
	MOTOR TYPE	SQUIRREL CAGE INDUCTION MOTOR, STARTING CURRENT LIMITED TO SIX TIMES THE RATED CURRENT.			
	ACTUATOR APPLICABLE WIRING DIAGRAM	<input checked="" type="checkbox"/> ENCLOSED (BIDDER TO CONFIRM) A: <input type="checkbox"/> DRG. NO. 3-V-MISC-24227 R00 B: <input type="checkbox"/> DRG. NO. 3-V-MISC-24550 R00 C: <input checked="" type="checkbox"/> DRG. NO. 3-V-MISC-24283 R00 D: <input type="checkbox"/> DRG. NO. 4-V-MISC-90271 R11			
	COLOUR SHADE	<input checked="" type="checkbox"/> BLUE (RAL 5012) ENAMEL		<input type="checkbox"/>	
	SHAFT RPM	BIDDER TO SPECIFY			
	OLR SET VALUE	BIDDER TO SPECIFY			
	STARTING / FULL LOAD CURRENT	BIDDER TO SPECIFY			
	NO. OF REV FOR FULL TRAVEL	BIDDER TO SPECIFY			
	@ PWR SUPP TO MTR / STARTER	415 VAC±10%,3PH,50Hz±5%,3 wire , 10 % (ABSOLUTE) COMBINED VOLTAGE & FREQUENCY VARIATIONS			
	@ CONTROL VOLTAGE REQUIREMENT	TO BE DERIVED FROM THE POWER SUPPLY TO THE STARTER <input type="checkbox"/> 230 V AC <input checked="" type="checkbox"/> 110 V AC			
	@ ENCLOSURE CLASS OF MOTOR	<input type="checkbox"/> IP 65 <input checked="" type="checkbox"/> IP 67 FOR OUTDOOR <input type="checkbox"/> FLAME PROOF <input checked="" type="checkbox"/> IP 55 FOR INDOOR, TOTALLY ENCL, SELF VENTILATED.			
	@ INSULATION CLASS	<input type="checkbox"/> CLASS-B <input checked="" type="checkbox"/> CLASS-F WITH TEMPERATURE RISE LIMITED TO CLASS-B			



**SPECIFICATION
FOR
MOTORISED VALVE ACTUATOR**


SPECIFICATION NO.:	
VOLUME	
SECTION	
REV. NO.	DATE:
SHEET 2	OF 3

Data Sheet A & B

DATA SHEET-A
(TO BE FILLED BY PURCHASER)

DATA SHEET-B
(TO BE FILLED-UP BY BIDDER)

	@ WINDING TEMP PROTECTION	<input type="checkbox"/> THERMOSTAT (3 Nos., 1 IN EACH PHASE)	
	SINGLE PHASE / WRONG PHASE SEQUENCE PROTECTION	<input type="checkbox"/>	
		REQUIRED	
INTEGRAL STARTER	INTEGRAL STARTER	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	TYPE OF SWITCHING DEVICE	<input checked="" type="checkbox"/> CONTACTORS <input type="checkbox"/> THYRISTORS	
	TYPE	<input checked="" type="checkbox"/> CONVENTIONAL <input type="checkbox"/> SMART (NON-INTRUSIVE)	
	IF SMART		
	a) SERIAL LINK INTERFACE	<input type="checkbox"/> INTEGRAL <input type="checkbox"/> FIELD MOUNTED	
	b) SERIAL LINK PROTOCOL	<input type="checkbox"/> FOUNDATION FIELD-BUS <input type="checkbox"/> PROFI-BUS <input type="checkbox"/> TCP/IP <input type="checkbox"/>	
	c) SERIAL LINK MEDIA	<input type="checkbox"/> TWISTED PAIR Cu-CBL <input type="checkbox"/> CO-AXIAL Cu-CBL <input type="checkbox"/> OFC	
	d) HAND HELD PROGRAMMER	<input type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	e) MASTER STATION	<input type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	f) MASTER STN INTRFACE WITH DCS	<input type="checkbox"/> MODBUS <input type="checkbox"/> TCP/IP	
	g) DETAILS OF SPECIAL CABLE	<input type="checkbox"/> ENCLOSED <input type="checkbox"/> NOT REQUIRED	
	STEP DOWN CONT. TRANSFORMER	<input checked="" type="checkbox"/> REQUIRED	
	OPEN / CLOSE PB	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	STOP PB	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	INDICATING LAMPS	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	LOCAL REMOTE S/S	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
STATUS CONTACTS FOR MONITORING	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED		
INTEGRAL STARTER DISTURBED SIGNAL	REQUIRED (O/L RELAY OPERATED, THERMOSTAT OPERATED, CONT./POWER SUPPLY FAILED, S/S IN LOCAL, TORQUE SWITCH OPTD. MID WAY)		
INTERPOSING RELAY (Applicable for integral Starter)	INTERPOSING RELAYS	REQUIRED	
	INTERPOSING RELAY (QUANTITY)	<input checked="" type="checkbox"/> 2 NOs. <input type="checkbox"/> 3 NOs.	
	DRIVING VOLTAGE	<input type="checkbox"/> 20.5 - 24V DC <input checked="" type="checkbox"/> 24 V DC	
	DRIVING CURRENT	<input type="checkbox"/> 125mA MAX <input type="checkbox"/> _____ mA MAX	
	LOAD RESISTANCE	<input type="checkbox"/> > 192 ohms - <25 k ohms <input type="checkbox"/> > _____ ohms - < _____ ohms	
	COIL BURDEN	2.5 VA	
TORQUE SWITCH (Not Applicable for Smart Actuator)	MECHANICAL LATCHING DEVICE	REQUIRED(REFER NOTE-5)	
	MFR & MODEL NO.	BIDDER TO SPECIFY	
	OPEN / CLOSE	<input checked="" type="checkbox"/> 1 No. <input type="checkbox"/> 2Nos. / <input checked="" type="checkbox"/> 1 No. <input type="checkbox"/> 2Nos	
	CONTACT TYPE	2 NO + 2 NC	
	RATING	5A 240V AC AND 0.5A 220V DC	
	ENCLOSURE	IP 55	
	CALIBRATED KNOBS(OPEN&CLOSE TS)	REQUIRED FOR SETTING DESIRED TORQUE	
ACCURACY	+3% OF SET VALUE		
LIMIT SWITCH (Not Applicable for Smart Actuator)	MFR & MODEL NO.	BIDDER TO SPECIFY	
	OPEN : INT : CLOSE	<input type="checkbox"/> 1 No. <input checked="" type="checkbox"/> 2 Nos. 2 Nos. (ADJ.) <input type="checkbox"/> 1 No. <input checked="" type="checkbox"/> 2Nos.	
	CONTACT TYPE	2 NO + 2 NC	
	RATING (AC / DC)	5A ,240V AC AND 0.5A,220V DC	
	ENCLOSURE CLASS	IP 55	

	SPECIFICATION FOR MOTORISED VALVE ACTUATOR	SPECIFICATION NO.:	
		VOLUME	
		SECTION	
		REV. NO.	DATE:
		SHEET	3 OF 3
Data Sheet A & B			
DATA SHEET-A (TO BE FILLED BY PURCHASER)		DATA SHEET-B (TO BE FILLED-UP BY BIDDER)	

POSITION TRANSMITTER	POSITION TRANSMITTER (For inching duty)	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED	
	MFR & MODEL NO.	BIDDER TO SPECIFY	
	TYPE	<input type="checkbox"/> ELECTRONIC (2 WIRE) R/I CONVERTER <input checked="" type="checkbox"/> ELECTRONIC (2 WIRE) CONTACTLESS	
	SUPPLY	<input checked="" type="checkbox"/> 24V DC <input type="checkbox"/>	
	OUTPUT	<input checked="" type="checkbox"/> 4-20mA	
	ACCURACY	± 1% FS	
SPACE HEATER	@SPACE HEATER	REQUIRED	
	@ POWER SUPPLY		
	@ RATING		
TERMINAL BOX	MOTOR TERMINAL BOX	REQUIRED	
	ACTUATOR TERMINAL BOX	REQUIRED	
	ENCL CLASS MTR T.B. / ACTUATOR T.B.	<input type="checkbox"/> IP 65 <input checked="" type="checkbox"/> IP-67..... <input type="checkbox"/> IP65 <input checked="" type="checkbox"/> IP-67.....	
	@ EARTHING TERMINAL	REQUIRED	
	PLUG & SOCKET(9 PIN) (ADDITIONAL 1 NO. FOR PoT)	<input checked="" type="checkbox"/> REQUIRED <input type="checkbox"/> NOT REQUIRED <input checked="" type="checkbox"/> 1 NO. <input checked="" type="checkbox"/> 1 NO. ADDITIONAL FOR PoT	
CABLE GLANDS	@ POWER CABLE GLAND	SIZE: _____	
	@ SPACE HEATER CABLE GLAND	SIZE: _____	
	OTHER CONTROL CABLE GLANDS-1	<input type="checkbox"/> 1No. for BFV of CW PUMP(Cable size 2Px1.5mm2)	
	OTHER CONTROL CABLE GLANDS-2	QUANTITY & SIZE : _____	
WEIGHT	TOTAL WEIGHT (ACTUATOR + ACCESSORIES)	BIDDER TO SPECIFY _____ Kg.	

- NOTES:**
1. SCOPE: DESIGN, MANUFACTURE, INSPECTION, TESTING AND DELIVERY TO SITE OF ELECTRIC ACTUATOR FOR INCHING OR OPEN / CLOSE DUTY.
 2. CODES & STANDARDS: DESIGN AND MATERIALS USED SHALL COMPLY WITH THE RELEVANT LATEST NATIONAL AND INTERNATIONAL STANDARD. AS A MINIMUM, THE FOLLOWING STANDARDS SHALL BE COMPLIED WITH: IS-8334, IS-2147, IS-2148, IS-325, IS-2958, IS-4891 AND IS-4722
 3. TEMPERATURE RISE SHALL BE RESTRICTED TO 70 DEG. C FOR AMBIENT TEMPERATURE OF 50 DEG C.
 4. CABLE GLANDS OF DOUBLE COMPRESSION TYPE, BRASS MATERIAL SHALL BE PROVIDED.
 5. THE TORQUE SWITCHES SHALL BE PROVIDED WITH MECHANICAL LATCHING DEVICE TO PREVENT OPERATION WHEN UNSEATING FROM THE END POSITIONS. THE LATCHING DEVICE SHALL UNLATCH AS SOON AS THE VALVE LEAVES THE END POSITION. IF SUCH PROVISION IS NOT POSSIBLE, THE TORQUE SWITCHES SHALL BE BYPASSED BY END-POSITION LIMIT SWITCHES WHICH OPENS ON VALVE LEAVING END POSITION. THESE LIMIT SWITCHES ARE ADDITIONAL TO THE NUMBER OF LIMIT SWITCHES SPECIFIED ELSEWHERE.
 6. THE MOTOR SHALL BE SUITABLE FOR DIRECT ON LINE STARTING.

	PREPARED BY	CHECKED BY	APPROVED BY	VENDOR COMPANY SEAL
	NAME			NAME
	SIGNATURE			SIGNATURE
DATE				DATE
NOTES* = TO BE FILLED BY MPL (LEAD AGENCY). @= TO BE FILLED BY ES				

ALL DIMENSIONS ARE IN MILLIMETRES. FOR TOLERANCES OF UNBALANCED DIMENSIONS DURING MANUFACTURE REFER RELEVANT QCP / QP.

3-V-MISC-24283 ON ENCL 002


CONTACT DEVELOPMENT DIAGRAM

OTS	1-2	OPEN AT OVER TORQUE DURING OPENING TRAVEL
OTS	3-4	CLOSE AT OVER TORQUE DURING OPENING TRAVEL
CTS	5-6	OPEN AT OVER TORQUE DURING CLOSING TRAVEL
CTS	7-8	CLOSE AT OVER TORQUE DURING CLOSING TRAVEL
OLS-1	9-10	OPEN AT OVER TORQUE DURING CLOSING TRAVEL
OLS-1	11-12	CLOSE AT OVER TORQUE DURING CLOSING TRAVEL
OLS-1	13-14	OPEN AT OVER TORQUE DURING CLOSING TRAVEL
OLS-1	15-16	CLOSE AT OVER TORQUE DURING CLOSING TRAVEL
OLS-2	17-18	OPEN AT OVER TORQUE DURING CLOSING TRAVEL
OLS-2	19-20	CLOSE AT OVER TORQUE DURING CLOSING TRAVEL
CLS-1	21-22	OPEN AT OVER TORQUE DURING CLOSING TRAVEL
CLS-1	23-24	CLOSE AT OVER TORQUE DURING CLOSING TRAVEL

SWITCH NO.	TERMINAL	VALVE POSITION
1	1	FULL OPEN
1	2	INTERMEDIATE
1	3	FULL CLOSE

- - - - - INDICATES CONTACT CLOSED
 - - - - - INDICATES CONTACT OPEN

CONTACT RATING: 5A AT 250V AC & 0.5A AT 220V DC



SETTING PROCEDURE OF POSITION LIMIT AND TORQUE SWITCH

VALVES	OPEN		CLOSE	
	MAIN	BACK UP	MAIN	BACK UP
GATE VALVE OF 100 mm AND ABOVE IN 1500 CL AND ABOVE RATINGS	OLS	OTS *	CLS	CTS
ALL OTHER GATE & GLOBE VALVES	OLS	OTS *	CLS	CTS

- CLS NOT TO BE CONNECTED IN TRIP CIRCUIT
 * - BYPASS OTS FOR INITIAL 5% OF TRAVEL (FOR GATE VALVES ONLY)

ELECTRICAL VALVE ACTUATORS (AC) WITH INTEGRAL STARTERS
FOR NTPC PROJECTS
(DRAWN FOR INTERMEDIATE POSITION OF VALVES)

TYPE OF PRODUCT OR NAME OF CUSTOMER/PROJECT	BHARAT HEAVY ELECTRICALS LTD., UNIT: HIGH PRESSURE BOILER PLANT, TIRUCHIRAPPALLI-60004.		
DRN	N.P.ESWAR	SIGN	N.P.
CHD	D.DHAKARAN	DATE	17.03.05
APPD	K.ARUNACHALAM	VAR	-
APPR		K.A.	17.03.05
WEIGHT (KG)	-		
SCALE	MKS		
DEPT	TL	CODE	U 01
REV	DATE	ALTERED	CEB & APPD
WIRING DIAGRAM (TERMINAL PLAN) FOR ACTUATOR WITH INTEGRAL STARTER WITH PLUG & SOCKET FOR NTPC PROJECTS			
DRAWING NO. 3-V-MISC-24283			
REV 0			

- NOTE:-
- ALL TORQUE AND LIMIT SWITCHES (OTS,CTS,OLS1&2, CLS1&2) ARE WITH 2NO+2NC CONTACTS '1NO+1NC' IS TERMINATED IN TBS 1-24, REMAINING CONTACTS ARE FOR INTERNAL USE.
 - ANY SPARE CONTACTS WHICH ARE NOT USED INTERNALLY ARE TO BE TERMINATED IN TBS 25-32
 - CTS - TORQUE SWITCHES FOR CW ROTATION (CLOSE)
 - OTS - TORQUE SWITCHES FOR CCW ROTATION (OPEN)
 - OLS-1, OLS-2 - LIMITSWITCHES FOR POSITION OPEN
 - CLS-1, CLS-2 - LIMITSWITCHES FOR POSITION CLOSE
 - EPT - ELECTRONIC POSITION TRANSMITTER (CONTACTLESS TYPE, FOR INCHING DUTY)
 - R1-R2-POTENTIOMETER 2 x 100 OHMS (FOR ON-OFF DUTY)
 - FOR COMMANDS & EPT EITHER INTERNALLY GENERATED 24 VDC OR EXTERNAL SUPPLY OF 24VDC CAN BE USED
 - M - MOTOR 3φ 415V 50 Hz AC SUPPLY
 - TORQUE SWITCH BYPASS WITH LIMITSWITCH BOTH ON OPEN & CLOSE DIRECTION TO BE DONE INTERNALLY.

Size A3



PROCESS CONNECTION AND PIPING



VINDHYACHAL STPP -V (1X500MW)
STEAM GENERATOR WITH
ELECTROSTATIC PRECIPITATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
BID DOCUMENT NO.: CS-2260-101-2



638

CLAUSE NO.	TECHNICAL REQUIREMENTS	
PROCESS CONNECTION AND PIPING		
1.00.00	PROCESS CONNECTION PIPING	
1.01.00	<p>The Contractor shall provide, install and test all required material for completeness of Impulse Piping System and Air Piping System as per the requirements of this Sub-section enclosed installation drawings and source connection drawings on as required basis for the connection of instruments and control equipment to the process and make the system complete. The installation & source connection of various items shall generally as per installation drawings (drawing no. 0000-999-POI-A-022 to 034) and source connection drawings (drawing nos. 0000-999-POI-A-035), however, the Contractor shall furnish during detailed engineering all relevant drawings, material and tech. specifications of various items service wise for Employer's approval.</p>	
1.01.01	<p>All materials supplied under this Sub-section shall be suitable for intended service, process, operating conditions and type of instruments used and shall fully conform to the requirements of this specification. The material offered by the Bidder shall be from reputed, experienced manufacturer whose guaranteed and trouble free operation has been proven at least for two years in not less than two pulverized coal fired utility stations.</p>	
1.02.00	IMPULSE PIPING, TUBING, FITTINGS, VALVES AND VALVE MANIFOLDS	
1.02.01	<p>All impulse pipe shall be of seamless type conforming to ANSI B36.10 for schedule numbers, sizes and dimensions etc. The material of the impulse pipe shall be same as that of main process pipe. For various applications specification of impulse pipe materials and associated fittings and valves shall be as given in Table PCP. For protection against sea environment all impulse pipes fittings etc. shall be provided with durable epoxy coating with poly urethane finish.</p>	
1.02.02	<p>Stainless steel tube shall be provided inside enclosures & racks from tee connection to valve manifold and then to instrument. For high pressure/temperature applications (piping class A, B, C & D of the table no. PCP) the material shall be ASTM A 213 TP 316H and for other applications material shall be ASTM A 213 TP 316L. The wall thickness of the tube shall be in accordance with the ANSI B31.1 standard.</p>	
1.02.03	<p>All fittings shall be forged steel and shall conform to ANSI B16.11. The material of forged tube fittings for shaped application (e.g. Tee, elbow etc.) shall be ASTM A 182 Gr. 316 H for high pressure/ temperature applications (as defined above) and ASTM A 182 Gr. 316L for other applications. The material for bar stock tube fitting (for straight application) shall be 316 SS. Metal thickness in the fittings shall be adequate to provide actual bursting strength equal to or greater than those of the impulse pipe or SS tube, with which they are to be used.</p>	
1.02.04	<p>The source shut-off (primary process root valve) and blow down valve shall be of 1/2 inch size globe valve type for all applications except for air and flue gas service wherein no source shut-off valves are to be provided. The disc and seat ring materials of carbon steel and alloy steel valves be ASTM A-105 and ASTM A-182, Gr. F22, hard faced with stellite (minimum hardness - 350 BHN.) The surface finish of 16 RMS or greater is required in the area of stem packing. The valve design shall be such that the seats can be reconditioned and stem and disc may be replaced without removing the valve body from the line.</p>	
1.02.05	<p>The valve manifolds shall be of 316 stainless steel with pressure rating suitable for intended application. 2 valve manifold and 3 valve manifold shall be used for pressure measurements using pressure transmitters/ pressure switches and diff. pressure transmitter/ switches respectively. 5-valve manifold shall be used for remaining applications like DP, SG and level measurements.</p>	
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-6 (PROCESS CONNECTION & PIPING)  PAGE 1 OF 6

SM

639



3

CLAUSE NO.	TECHNICAL REQUIREMENTS	
1.02.06	For Pr./D.P gauges in fluid application two-way globe valve on each impulse line to the instrument and in A/F application two-way gate valve on each impulse line to the instrument shall be provided near the instrument. These shall be in addition to the three ways gauge cock provided along with the pressure /D.P gauges.	
2.00.00	AIR SUPPLY PIPING	
2.01.00	All pneumatic piping, fittings, valves, air filter cum regulator and other accessories required for instrument air for the various pneumatic devices/ instruments shall be provided.	
2.01.01	This will include as a minimum air supply to pneumatically operated control valves, actuators, instruments, continuous and intermittent purging requirements of etc.	
2.02.00	For individual supply line and control signal line to control valve, 1/4-inch size light drawn tempered copper tubing conforming to ASTM B75 shall be used. The thickness of cu-tubing shall not be less than 0.065 inch and shall be PVC coated. The fittings to be used with copper tubes shall be of cast brass, screwed type.	
2.03.00	All other air supply lines of 1/2 inch to 2 inch shall be of mild steel hot dipped galvanized inside and outside as per IS-1239, heavy duty with threaded ends. The threads shall be as per ASA B.2.1. Fittings material shall be of forged carbon steel A234 Gr. WPB galvanized inside and outside, screwed as per ASA B2.1. Dimensions of fittings shall be as per ASA B16.11 of rating 3000 lbs.	
2.04.00	For air supply to various devices mentioned above, the bidder shall provide 2 inch size GI pipe header with isolation valve from the instrument air and service air terminal points. In the boiler area the 2 inch head shall be provided upto top most elevation of boiler floor and from this 2 inch header, 1 inch sub-header shall be branched off at each floor with isolation valve. From this 1 inch sub-header, branch line of 1/2 inch, with isolation valve shall be provided upto various devices. Similar system is to be followed for service air required for intermittent purging in the Local Instrument Enclosures (LIEs) etc.	
2.05.00	All instrument air filters cum regulator set with mounting accessories shall be provided for each pneumatic device requiring air supply. The filter regulators shall be suitable for 10-kg/sq.cm max. Inlet pressure. The filter shall be of size 5 microns and of material sintered bronze. The air set shall have 2-inch size pressure gauge and built in filter housing blowdown valve. The end connection shall be as per the requirement to be finalized during detailed engineering.	
2.06.00	All the isolation valves in the air supply line shall be gate valves as per ASTM B62 inside screw rising stem, screwed female ends as per ASA B2.1. Valve bonnet shall be union type & trim material shall be stainless steel, body rating 150 pounds ASA. The valve sizes shall be 1/2 inch to 2 inch.	
2.07.00	<p>Purge Air Connection for Air and Flue gas Applications</p> <p>The continuous purging with instrument air shall be done, for all air and flue gas measurements excepting instrument air and service air instruments, at the process source connection end. Necessary arrangements required for continuous purging shall be provided inside all the Air and Flue gas enclosures as per enclosed drawing no. 0000-999-POI-A-034.</p> <p>For intermittent purging with service air, necessary arrangements inside all the air and Flue gas enclosures shall be provided. The SS three way valve provided in the SS tubing shall be used for isolating the transmitter & connecting the service air quick disconnect line.</p>	
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-6 (PROCESS CONNECTION & PIPING) PAGE 2 OF 6



Signature

640



7

CLAUSE NO.	TECHNICAL REQUIREMENTS 	
	<p>Purging arrangement is not required for Instrument air and service air measurement applications.</p>	
3.00.00	INSTALLATION AND ROUTING	
3.01.00	Instrument Piping System	
3.01.01	For steam and liquid measurements, the impulse pipe should preferably slope downward from source connection to instrument and instrument shall be installed below the source point. If due to any reason instrument is installed above the source point, the impulse pipe should slope upwards continuously and a 'pigtail' should be provided at the instrument to assure water seal for temperature protection. For vacuum measurements instrument shall be installed above source point and impulse pipe should slope upwards.	
3.01.02	Impulse piping for air and flue gas shall slope upwards and instrument shall be installed above source point. If this requirement cannot be met special venting or drain provision shall be provided with vent & drain lines along with isolation valves and other accessories including drainpipes. This drain is to be connected to plant drain through open funnel also.	
3.01.03	All impulse piping shall be installed to permit free movement due to thermal expansion. Wherever required expansion loops shall be provided.	
3.01.04	Special accessories such as condensing pots/ reservoirs shall be provided and installed wherever required. In any case condensing pots shall be provided for all level measurements in steam and water services, all flow measurement in steam services and flow measurements water services above 120 Deg.C. For drum/ separator level measurement required balancing chamber shall be provided.	
3.01.05	Color coding of all impulse pipes shall be done by the bidder in line with the colour coding being followed for the parent pipes.	
3.02.00	Instrument Air & Service Air Piping/ Tubing System	
3.02.01	Instrument air & service air headers and their branches with all associated fittings & accessories shall be provided for giving supply to all consumers, as per the requirements. Air piping shall be installed always with a slope of over 1/20 to prevent accumulation of water within the pipe.	
3.02.02	Single and multi tubes shall run with the minimum number of changes in direction. Suitable identification tags shall be provided for easy checkup and for connections.	
4.00.00	PIPING/TUBING SUPPORT	
4.01.00	Impulse piping and sample piping shall be supported at an interval not exceeding 1.5 meters. Each pipe shall be supported individually using slotted angle mounted clamps with necessary fixtures. Tubing shall run in proper perforated trays with proper cover. Tubing shall be supported inside the trays by aluminium supports. Hangers and other fixtures required for support of piping and trays shall be provided, either by welding or by bolting on walls, ceilings and structures. Hanger clamps and other fastening hardware shall be of corrosion resistant metals and hot-dip galvanized.	
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	 PART - B SUB-SECTION-IV C-5 (PROCESS CONNECTION & PIPING)
		PAGE 3 OF 6

641

CLAUSE NO.	TECHNICAL REQUIREMENTS 		
5.00.00	SHOP AND SITE TESTS		
5.01.00	General Requirements		
5.01.01	The equipment and work performed as per this Sub-section shall be subject to shop and site test as per requirements of Sub-section-Q (Quality Assurance & Inspection) other applicable clauses of this Sub-section and Employer approved quality assurance plan.		
5.01.02	Hydrostatic and pneumatic tests shall be performed on all pipes, tubing and systems and shall conform to ANSI B31.1.		
5.02.00	Hydrostatic Testing		
5.02.01	All instrument piping/ tubing shall be hydrostatically tested upon completion of erection. The test pressure shall be 1.5 times the maximum process pressure. The test shall be performed either with the testing of associated process piping or without the associated process piping (by closing the root valve). In both the cases the instrument shall be isolated by closing the shut-off valve.		
5.03.00	Air Testing		
5.03.01	All air headers & branch pipes shall be air tested by pressure decay method as per ANSI B31.1. Flexible hoses and short signal tubing shall be tested at normal pressure for leakage. Long signal tubing shall be tested by charging each tube with air at 2 kg/ sq. cm. through a bubbler sight glass. The boiler draft and vacuum piping shall be air tested by the same method as long signal tubing.		
6.00.00	<p>LOCAL INSTRUMENT ENCLOSURE AND RACKS</p> <p>Transmitters, switches, devices, temperature transmitters etc. (except for all fuel oil applications which shall be mounted close to be tapping points) mounted in the field shall be suitably grouped together and mounted (i) local instruments enclosure in case of open areas of the plant like boiler area, etc. and (ii) In local instrument racks in case of covered areas. Gauges are to be mounted on a channel or a frame or a rack (Gauges shall not be mounted directly on process pipe). These local instrument enclosures and racks shall be furnished as per the actual requirements finalized during detailed engineering stage. The exact grouping of instruments in a particular instrument enclosure/instrument rack shall be as finalized during detailed engineering stage subject to Employer's approval.</p> <p>For mounting of PT/DPT/LT/FT, LIEs / LIRs shall be of three types depending on the number of transmitters located in it as elaborated in the typical GA of the LIE/LIR, drawing no. 0000-999-POI-A-064 (Sh Nos. 1 to 3 of 5).</p> <p>These dimensions and number of instruments indicated therein are only indicative and the exact dimensions along with the number of instruments shall be as finalized during detailed engineering stage without any price repercussions.</p> <p>The internal layout shall be such that the impulse piping/ blow down lines are accessible from back side of the enclosure / rack and the transmitters etc. are accessible from front side for easy maintenance. Bulkheads, especially designed to provide isolation from process line vibration shall be installed on instrument enclosures/racks to meet the process sensing line connection requirement.</p> <p>Vibration dampeners shall be installed for each enclosure / rack.</p>		
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-6 (PROCESS CONNECTION & PIPING)	 PAGE 4 OF 6

642

CLAUSE NO.	TECHNICAL REQUIREMENTS 		
	<p>The enclosures shall be constructed of 3 mm sheet plate and shall be of modular construction with one or more modules and two end assemblies bolted together to form an enclosure. Double inter locking doors shall be provided. The doors shall be the three-point locking type constructed of not less than 1.6 mm thick steel. Doors shall have concealed quick removal type pinned hinges and locking handles. Door locks shall accept the same key.</p> <p>Gaskets shall be used between all mating sections to achieve protection class of IP-55.</p> <p>The instrument racks shall be free standing type constructed of suitable 5 mm thick channel frame of steel and shall be provided with a canopy to protect the equipment mounted in racks from falling objects, water etc. The canopy shall not be less than 3 mm thick steel, and extended beyond the ends of the rack. Bulk heads, especially designed to provide isolation from process line vibration shall be provided. Exact fabrication details shall be as finalized during detailed engineering stage. The junction box for racks also shall conform to IP 55 protection class.</p> <p>Enclosures/racks shall be reinforced as required to ensure true surface and to provide adequate support for instruments and equipment mounted therein. Centre posts or any member which would reduce access shall not be provided.</p> <p>Each transmitter enclosure housing instruments requiring purge air for continuous air purging, shall be provided with common purge air header, redundant air filter regulators of sufficient capacity, required pressure gauges, valves, fittings, SS tubing and individual purge meters for each purge line etc. as required and indicated in Instrument Installation drawings enclosed herewith.</p> <p>A 15 mm NB service air header shall be furnished in each instrument enclosure housing air & flue gas and coal mill instruments. The header shall be furnished complete with a pressure regulating valve, pressure gauge, and quick disconnect connections. A hose for connecting each header to the draft instrument line four-way valves shall be furnished. The hose shall be self-storing nylon tubing having a burst pressure of 15 kg/sq. cm. The size of the hose shall be 1/2" minimum. The service air header shall originate at a bulkhead penetration or fitting located on one of the bulkhead plates.</p> <p>The contractor shall prepare the piping drawings and the general arrangement layout drawings for each of the enclosures and racks. Special attention shall be given in the piping layout to avoid air traps in liquid filled piping or water pockets in piping intended to be dry. Drawings shall indicate the arrangement of all equipment, piping, valves and fittings within the enclosure/racks and shall be subject to Employer's approval.</p> <p>All liquid filled blow down lines, except those measuring vacuum shall be connected to a two inch header which is extended through one end of the enclosure and turned downward for directing the blow down into a drain. The material of the blow down header shall be carbon steel as per ASTM A 106 Gr. C.</p> <p>The Contractor shall submit to the Employer with his proposal a copy of his welding procedure specification together with proof of his compliance with the latest applicable welding ANSI code. Prior to any welding being performed, the Contractor shall submit the qualifications of the craftsmen who will perform the work.</p>		
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV C-6 (PROCESS CONNECTION & PIPING)	 PAGE 5 OF 6

643

7.00.00 TABLE PCP

System/Line Description	Piping Class	Impulse Material	Pipe Schedule (Size)	Materials Fitting/Valve Body	Valve for Material	Stem Rating Piping/Fittings	Pr. Class of Valve
Main Steam/ Upstream of HP bypass and Auxiliary Steam Pressure reducing valve, Drum Level	A	ASTM-A335 Gr.P-91/22 (Note-2)	XXS (1/2 inch)	(1/2 (Note-3)	(Note-3)	9000 lb	3000 SPL
BFP disch, superheater attempertor, spray to PRDS, Phosphate dozing pp disch, BCW pump	B	ASTM-A106 Gr. C	160 (1/2 inch)	ASTM-A105	ASTM-A-182 Gr.F6a	6000 lb	2500
Reheater attempertor	C	ASTM-A106 Gr. C	160 (1/2 inch)	ASTM-A105	-do-	6000 lb	1500
Hot Reheat/ down stream of Aux. Steam press. Reducing valve upto desuper heater/ Flash tank drain manifold, HP heater level.	D	ASTM-A335 Gr. P-91/22 (Note-2)	160 (1/2 inch)	ASTM-A182 Gr.F-22	(Note-3)	3000 lb	900
Cold reheat upto Tee-off for HP Bypass / Extraction steam to HPH	E	ASTM-A335 Gr.P-22	80 (1/2 inch)	ASTM-A182 Gr.F-22	ASTM-A-182 Gr.F6a	3000 lb	800
Cold reheat down steam of Tee-off (HP Bypass)	F	ASTM-A106 Gr. C	80 (1/2 inch)	ASTM-A105	-do-	3000 lb	800
BFP suction, Condensate System/ Extraction to LPH/ Ext-4 to BFPT, Deaerator/ auxiliary steam, service air, inst air, ECW pump, ACW pump and other low pr water services	G	ASTM-A106 Gr. B	80 (1/2 inch)	ASTM-A105	-do-	3000 lb	800
Air/ Flue gas outside furnace	M	ASTM-A106 Gr. B/C	80 (3/4 inch)	ASTM-A105	-do-	3000 lb	800
Air/ Flue gas inside furnace	N	ASTM-A335 Gr.P22	80 (3/4 inch)	ASTM-A182 Gr. F-22	-do-	3000 lb	800

NOTE:

- 1 Rating of piping/fittings/valves etc. is subjected to the final design pressure & temperature during the detailed engineering.
- 2 In case temperature is more than 540 deg C, the material shall be P-91 only.
- 3 Material shall be compatible with that of the impulse pipe material and design parameter.
- 4 Separator related impulse piping material shall be as per main process pipe/tank material



STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC. NO.:CS-2280-101-2	PART - B SUB-SECTION-IV I-8 (PROCESS CONNECTION & PIPING)	PAGE 6 OF 6
---	---	---	-------------



TYPE TEST REQUIREMENTS





VINDHYACHAL STPP -V (1X500MW)
STEAM GENERATOR WITH
ELECTROSTATIC PRECIPITATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
BID DOCUMENT NO.: CS-2260-101-2

667

CLAUSE NO.	TECHNICAL REQUIREMENTS 	
1.00.00	<p style="text-align: center;">TYPE TEST REQUIREMENTS</p> <p>TYPE TEST REQUIREMENTS</p> <p>General Requirements</p> <p>The Contractor shall furnish the type test reports of all type tests as per relevant standards and codes as well as other specific tests indicated in this specification. A list of such tests are given for various equipment in table titled 'TYPE TEST REQUIREMENT FOR C&I SYSTEMS' at the end of this chapter and under the item 'Special Requirement for Solid State Equipments/Systems'. If the bidder proposes a different standard/code from that indicated at table 3.00.00, the same is acceptable provided the equivalence of the proposed standard is established by the bidder. For the balance equipment instrument, type tests may be conducted as per manufactures standard or if required by relevant standard.</p> <p>(a) Out of the tests listed, the Bidder/ sub-vendor/ manufacturer is required to conduct certain type tests specifically for this contract (and witnessed by Employer or his authorized representative) even if the same had been conducted earlier, as clearly indicated subsequently against such tests.</p> <p>(b) For the rest, submission of type test results and certificate shall be acceptable provided.</p> <p>i. The same has been carried out by the Bidder/ sub-vendor on exactly the same model /rating of equipment. (For control valves, this shall be same size, type & design).</p> <p>ii. There has been no change in the components from the offered equipment & tested equipment.</p> <p>iii. The test has been carried out as per the latest standards along with amendments as on the date of Bid opening.</p> <p>(c) In case the approved equipment is different from the one on which the type test had been conducted earlier or any of the above grounds, then the tests have to be repeated and the cost of such tests shall be borne by the Bidder/ sub-vendor within the quoted price and no extra cost will be payable by the Employer on this account.</p> <p>As mentioned against certain items, the test certificates for some of the items shall be reviewed and approved by the main Bidder or his authorized representative and the balance have to be approved by the Employer.</p> <p>The schedule of conduction of type tests/ submission of reports shall be submitted and finalized during pre-award discussion.</p> <p>For the type tests to be conducted, Contractor shall submit detailed test procedure for approval by Employer. This shall clearly specify test setup, instruments to be used, procedure, acceptance norms (wherever applicable), recording of different parameters, interval of recording precautions to be taken etc. for the tests to be carried out.</p> <p>The Bidder shall indicate in the relevant BPS schedule, the cost of the type test for each item only for which type tests are to be conducted specifically for this project. The cost shall only</p>	
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	<div style="text-align: center;">  </div> PART - B SUB-SECTION-IV.CS TYPE TESTS REQUIREMENTS
		PAGE 1 OF 6

668

CLAUSE NO.	TECHNICAL REQUIREMENTS																													
2.00.00	<p>be payable after the respective type tests are conducted in presence of authorized representative of Employer. If a test is waived off, then the cost shall not be payable.</p> <p>SPECIAL REQUIREMENT FOR SOLID STATE EQUIPMENTS/ SYSTEMS</p> <p>The minimum type test reports, over and above the requirements of above clause, which are to be submitted for each of the major C&I systems shall be as indicated below:</p> <p>i) Surge Withstand Capability (SWC) for Solid State Equipments/ Systems</p> <p>All solid state systems/ equipments shall be able to withstand the electrical noise and surges as encountered in actual service conditions and inherent in a power plant. All the solid state systems/ equipments shall be provided with all required protections that needs the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Hence, all front end cards which receive external signals like Analog input & output modules, Binary input & output modules etc. including power supply, data highway, data links shall be provided with protections that meets the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Complete details of the features incorporated in electronics systems to meet this requirement, the relevant tests carried out, the test certificates etc. shall be submitted along with the proposal. As an alternative to above, suitable class of EN 61000-4-12 which is equivalent to ANSI 37.90.1/ IEEE-472 may also be adopted for SWC test.</p> <p>ii) Dry Heat test as per IEC-68-2-2 or equivalent.</p> <p>iii) Damp Heat test as per IEC-68-2-3 or equivalent.</p> <p>iv) Vibration test as per IEC-68-2-6 or equivalent.</p> <p>v) Electrostatic discharge tests as per EN 61000-4-2 or equivalent.</p> <p>vi) Radio frequency immunity test as per EN 61000-4-6 or equivalent.</p> <p>vii) Electromagnetic Field immunity as per EN 61000-4-3 or equivalent.</p> <p>Test listed at item no. v, vi, vii, above are applicable for electronic cards only as defined under item (i) above.</p>																													
3.00.00	<p>TYPE TEST REQUIREMENT FOR C&I SYSTEMS</p> <table border="1" data-bbox="475 1406 1444 1780"> <thead> <tr> <th>Sl. No</th> <th>Item</th> <th>Test Requirement</th> <th>Standard</th> <th>Test To Be Specifically Conducted</th> <th>NTPC's Approval Req. On Test Certificate</th> </tr> <tr> <th>Col 1</th> <th>Col 2</th> <th>Col 3</th> <th>Col 4</th> <th>Col 5</th> <th>Col 6</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Elect. Metering instruments</td> <td>As per standard (col 4)</td> <td>IS-1248</td> <td>No</td> <td>Yes</td> </tr> <tr> <td>2</td> <td>Thermocouple</td> <td>Degree of protection test</td> <td>IS-2147</td> <td>No</td> <td>No</td> </tr> </tbody> </table>					Sl. No	Item	Test Requirement	Standard	Test To Be Specifically Conducted	NTPC's Approval Req. On Test Certificate	Col 1	Col 2	Col 3	Col 4	Col 5	Col 6	1	Elect. Metering instruments	As per standard (col 4)	IS-1248	No	Yes	2	Thermocouple	Degree of protection test	IS-2147	No	No	
Sl. No	Item	Test Requirement	Standard	Test To Be Specifically Conducted	NTPC's Approval Req. On Test Certificate																									
Col 1	Col 2	Col 3	Col 4	Col 5	Col 6																									
1	Elect. Metering instruments	As per standard (col 4)	IS-1248	No	Yes																									
2	Thermocouple	Degree of protection test	IS-2147	No	No																									
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2		PART - B SUB-SECTION-IV:C9 TYPE TESTS REQUIREMENTS		PAGE 2 OF 6																								


660


CLAUSE NO.	TECHNICAL REQUIREMENTS					
	3	RTD	As per standard (col 4)	IEC-60751	No	No
	4	Electronic transmitter	As per standard (col 4)	BS-6447 / IEC-60770	No	Yes
	5	E/P converter	As per standard (col 4)	Mfr. standard	No	Yes
	6 Instrumentation Cables Twisted & Shielded					
		-Conductor	Resistance test	VDE-0815	No	Yes
			Diameter test	IS-10810	No	Yes
			Tin Coating test (Persulphate test)	IS-8130	No	Yes
		-Insulation	Loss of mass	VDE 0472	No	Yes
			Ageing in air ovens**	VDE 0472	No	Yes
			Tensile strength and elongation test before and after ageing**	VDE 0472	No	Yes
			Heat shock	VDE 0472	No	Yes
			Hot deformation	VDE 0472	No	Yes
			Shrinkage	VDE 0472	No	Yes
			Bleeding & blooming	IS-10810	No	Yes
		-Inner sheath***	Loss of mass	VDE 0472	No	Yes
			Heat shock	VDE 0472	No	Yes
			Cold bend/ cold impact test	VDE 0472	No	Yes
			Hot deformation	VDE 0472	No	Yes
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2	PART - B SUB-SECTION-IV:C9 TYPE TESTS REQUIREMENTS	PAGE 3 OF 6			

5

670

7

CLAUSE NO.	TECHNICAL REQUIREMENTS					
		Shrinkage	VDE 0472	No	Yes	
	-Outer sheath	Loss of mass	VDE 0472	No	Yes	
		Ageing in air ovens**	VDE 0472	No	Yes	
		Tensile strength and elongation test before and after ageing**	VDE 0472	No	Yes	
		Heat shock	VDE 0472	No	Yes	
		Hot deformation	VDE 0472	No	Yes	
		Shrinkage	VDE 0472	No	Yes	
		Bleeding & blooming	IS-10810	No	Yes	
		Colour fastness to water	IS-5831	No	Yes	
		Cold bend/ cold impact test	VDE-0472	No	Yes	
		Oxygen index test	ASTMD-2863	No	Yes	
		Smoke Density Test	ASTMD-2843	No	Yes	
		Acid gas generation test	IEC-60754-1	No	Yes	
	-fillers	Oxygen index test	ASTMD-2863	No	Yes	
		Acid gas generation test	IEC-60754-1	No	Yes	
	-AL-MYLAR shield	Continuity test		No	Yes	
		Shield thickness		No	Yes	
		Overlap test		No	Yes	
	-Over all cable	Flammability Test	IEEE 383	No	Yes	




VINDHYACHAL STPP-V (1X500 MW)
STEAM GENERATOR WITH ELECTROSTATIC
PRECIPITATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
BID DOC NO.: CS-2260-101-2



PART - B
SUB-SECTION-IV:C9
TYPE TESTS
REQUIREMENTS

PAGE 4 OF 6

671

CLAUSE NO.	TECHNICAL REQUIREMENTS				
		Swedish Chimney Test	SEN 4241475	No	Yes
		Noise interference	IEEE Transactions	No	Yes
		Dimensional checks	IS 10810	No	Yes
		Cross talk	VDE-0472	No	Yes
		Mutual capacitance	VDE-0472	No	Yes
		HV test	VDE-0815	No	Yes
		Drain wire continuity		No	Yes
* For Drain wire only					
**These tests shall be carried out as per VDE0207 Part 6 & ASTM-D-2116 for TEFLON insulated & outer sheathed cables					
***Applicable for armoured cables only					
7	DC Power Supply System The Type Test reports for offered rectifier module and the controller module irrespective of the rectifier bank shall be acceptable				
		Degree of Protection	IS-13947 or equivalent	No	Yes
		Dry Heat Test	IEC-68-2-2 or equivalent	No	Yes
		Damp Heat test	IEC-68-2-3 or equivalent	No	Yes
		Vibration test	IEC68-2-6 or equivalent	No	Yes
		Electromagnetic field immunity	EN 61000-4-3 or equivalent	No	Yes
		Radio frequency immunity test	EN-61000-4-3 or equivalent	No	Yes
		Electrostatic discharge test	EN 61000-4-2 or equivalent	No	Yes
					
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2		PART - B SUB-SECTION-IV:C9 TYPE TESTS REQUIREMENTS	
				PAGE 5 OF 6	

672

CLAUSE NO.	TECHNICAL REQUIREMENTS					
		Surge Withstand Capability(SWC)	ANSI 37.90.1/ IEEE-472,EN 61000-4-12	No	Yes	
8	Battery	As per standard	IS-10918	No	Yes	
9	Voltage Stabiliser	Over Load Test	Approved procedure	No	Yes	
		Temp rise test without redundant fans	Approved procedure	No	Yes	
		Input voltage variation test	Approved procedure	No	Yes	
10	DDCMIS					
	BMS	Safety requirements	VDE0116 Sec 8.7	No	Yes	
11	Conductivity Type Level Switch	Degree of protection test	IS-2147	No	No	
12	Local Gauges	Degree of protection test	IS-2147	No	No	
13	Process actuated Switches	Degree of protection test	IS-2147	No	No	
14	Control Valves	CV test	ISA 75.02	No	Yes	
15	PLCs	As per standard	IEC 1131	No	No	
16	LIE / LIR	Degree of protection test	IS-2147	No	Yes	
17	Flue gas O2 analyser, other Flue Gas analysers	Degree of protection test	IS-2147	No	Yes	
18	Flow Nozzle Orifice plates	Calibration	ASME PTC BS 1042	No	Yes	
<p>Note:</p> <p>Type Tests are to be conducted only for the items, which are being supplied as a part of this Package.</p>						
VINDHYACHAL STPP-V (1X500 MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI BID DOC NO.: CS-2260-101-2		PART - B SUB-SECTION-IV:C9 TYPE TESTS REQUIREMENTS		 PAGE 6 OF 6

673

CLAUSE NO.	SCOPE OF SUPPLY & SERVICES			एनटीपीसी NTPC
8.02.00	Microprocessor Based Electronic Positioners employing HART protocol are to be provided with all the Control valves and all control dampers being provided by the contractor.			
8.03.00	Universal Hart Calibrator to be provided – One number per generating unit			
9.00.00	CONTROL AND INSTRUMENTATION FOR PLANT AUXILIARY SYSTEMS			
9.01.00	Instrumentation and Control System with interlocks, protection and annunciation of the mechanical common auxiliary systems as mentioned below shall be provided. All necessary equipments/system for control, monitoring and operations of the plants as well as the incomers and bus couplers shall be provided.			
9.02.00	For certain plants, facility for control from DDCMIS shall be provided as mentioned below:			
	SI No	Auxiliary Plant	Control System	Connectivity/operation
	01	Fuel Oil Pressurization/ Heating System (FOPH) & Fuel oil unloading system	Independent control system in SG-C&I based Hardware. I/O count for Fuel oil unloading system is 200 binary and 20 analogs.	Dual two way Ethernet connectivity to station LAN for information and control. Local operation of Fuel oil Handling System through GIU.
	02	Mill Reject System (Unitised System)	SG C&I Based Control System from Control Room	Graphical interface unit (GIU) based local operation apart from CCR.
	03	Air Compressor System including Air-Compressors of Mill Reject System	If the controller is integral to compressor, then Microprocessor/ PLC based control system along with suitable operator interface as per vendor's practice for individual Air compressors control. If the controller for individual compressors is not integral to compressor then control shall be through SG-C&I For both the cases, over all Control shall be through SG-C&I	Dual two way Ethernet Connectivity to SG-C&I for information and overall Control of Air Compressors. (Applicable only for compressors with integral controllers)
	04	LP Dosing and Oxygenated treatment	Control from BOP-C&I under Station C&I package(in Employer's scope).	
	05	Equipment Cooling Water System	Control from BOP-C&I under Station C&I Package	
VINDHYACHAL STPP-V(1X500MW) STEAM GENERATOR WITH ELECTROSTATIC PRECIPITATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI BID DOC. NO.: CS-2260-101-2		PART-A SUB-SECTION III-C CONTROL AND INST. SYSTEM Power Sector Marketing 7 OF 8

CLAUSE NO.	SCOPE OF SUPPLY & SERVICES					
	SI no	Item name	Unit	DDCMIS BASED		Remarks
	2.3	Programming station	Nos.	1 in CER, One in Programmer Room		If system documentation facility is not part of this station, separate workstations shall be provided for the same.
	2.4	Information Work Stations (only for Alternative 2)	Nos.	2	1*	* The function of Information Workstations can be merged with each of the OWS.
	2.5	Large Video Screens(LVS)	Nos.	NIL	NIL	
	2.6	Work Station for LVS	Nos.	3	NIL	Including that for flame camera.
	2.7	Suitable redundant interfaces and redundant links for connectivity between Unit LAN, stationwide LAN, and DDCMIS sub systems, unit / station PLCs, PC stations, PADO, Remote Service Centre as applicable.	sets	1	1	Each set will include components for respective remote I/O & FGs.
	2.8	Control System Programming device including EPROM Writer/eraser etc. (if applicable.)	Nos.	2	1	This item is not required in case not applicable.
	2.9	Data Communication System		As required basis	As required basis	
	2.10	Remote Service centre hardware		As required basis		
	2.11	Graphical Interface Unit (10")	Nos	1 no for local operation of Mill Reject system (unitised part)	1 no in Fuel Oil Unloading station for local operation	
	3	Printers				
	3.1	Laser jet colour printer (A4 size)			1	




VINDHYAHAL STPP-V (1X500 MW)
STEAM GENERATOR WITH ELECTROSTATIC
PRECIPITATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
BID DOC. NO.: CS-2260-102-2

PART 5
SUB-SECTION III G
APPENDIX - I

PAGE 9 OF 10

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



FOR TENDER PURPOSE ONLY

NTPC Ltd
(A GOVERNMENT OF INDIA ENTERPRISE)
ENGINEERING DIVISION



PROJECT		TYPICAL THERMAL POWER PROJECT TG PACKAGE	
TITLE DISTRIBUTED DIGITAL CONTROL, MONITORING AND INFORMATION SYSTEM (DDCMS) CONFIGURATION DIAGRAM			
REV. NO.	SCALE	DRG. NO.	REV. NO.
A	N.T.S.	0000-110-POI-A-001	A
DATE		SH-1 OF 1	

- NOTES:-**
- FOR CONTRACT QUANTITIES, REFER SUBSECTION DDCCMS SECTION VI PART-A OF TECHNICAL SPEC.
 - CONTROL SYSTEM CABINETS REFER DRG. NO. 0000-110-POI-A-008 FOR FUNCTIONAL GROUPING.
 - HARDWIRED SIGNAL EXCHANGE (TYP.).
 - THE SKETCH IS ONLY INDICATIVE. FOR DETAILED PROGRAMMER STATION REQUIREMENT, REFER SUBSECTION DDCCMS.
 - THE REMOTE I/O CABINET SHALL BE APPLICABLE IF MENTIONED IN PART-A OF TECHNICAL SPECIFICATIONS.

REV. NO.	DESCRIPTION	DATE	APPD	ARCH.	CLEAR BY
A	FIRST ISSUE	31/05/08			
	DRAWN DESIGN CHD.				
	M	E	C	C&I	

LIST OF MATERIALS

ITEM NO.	DESCRIPTION
1.	49 X 408 MM U.S. BLACK PIPE
2.	M322 TO 3/4" REDUCING INSERT
3.	M152(7) U.S. CAP
4.	3/4" SW GLOBE VALVE/DIAPHRAGM VALVE
5.	3/4" NPS PIPE
6.	3/4" NPS SW 3/4" NPT(U) CS/AS NIPPLE
7.	3/4" SW EQUAL TEE
8.	3/4" NPS SCH 80 CARBON/ALLOY STEEL NIPPLE
9.	3/4" NPT(F) CS/AS CAP
10.	3/4" SW CS/AS EQUAL CROSS
11.	1/2" TUBE ADAPTER
12.	3 VALVE MANIFOLD
13.	3/4" PIPE UNION
14.	2 VALVE MANIFOLD
15.	3/4" SW 4 WAY VALVE
16.	QUICK DISCONNECT FITTING
17.	3/4" 30MM/1/2" SW BRANCH TEE
18.	1/2" NB SEAMLESS CI PIPE
19.	1/2" NPT (F) CI FITTING
20.	SS TUBE
21.	FLEXIBLE HOSE WITH ONE END SOCKET WELDED (PIPE SIDE) & OTHER END WITH SURTABLE FITTING.
22.	3/4" x 1/2" S.S. TUBE UNION

NOTES:-

1. SEE NOTES UNDER DRG. NO.0000-110-PO-A-022.
2. IMPULSE LINE O'HAN CONNECTIONS SHALL BE DONE AS PER TECHNICAL SPECIFICATIONS
3. THE SLOPE IN THE HORIZONTAL OF THE IMPULSE PIPE SHALL BE APPROX. 30 mm/m.
4. THE EXACT ORIENTATION OF THE TRANSMITTERS WITH RESPECT TO VALVE MANIFOLDS ETC. WILL BE FINALISED DURING DETAILED ENGINEERING KEEPING IN VIEW THE MANUFACTURER'S RECOMMENDATIONS.
5. COMMON INSTRUMENT AIR HEADER (1700) USING REDUNDANT AIR FILTER REGULATORS WILL BE MADE IN EACH TRANSMITTER ENCLOSURE REQUIRING PURGE AIR. PURGE AIR FOR EACH INSTRUMENT LINE SHALL BE TAPPED FROM THIS HEADER USING INDIVIDUAL PURGE REGULATOR AS SHOWN IN DRG. NO. 0000-110-PO-A-034 TYPICALLY.

FOR TENDER PURPOSE ONLY


एन टी सी लिमिटेड
NTPC LIMITED
 (A GOVERNMENT OF INDIA ENTERPRISE)
 ENGINEERING DIVISION

PROJECT TYPICAL THERMAL POWER PROJECT
(TG PACKAGE)

TITLE INSTRUMENT INSTALLATION DIAGRAM
 (PRESSURE MEASUREMENT USING PRESS / DP TRANSMITTERS
 (INST./SERVICE, DIRTY AIR/FLUE GAS))

REV. NO.	A
SCALE	A3
SIZE	A3
DRG. NO.	0000-110-POI-A-023

CAD FILE NAME: D:\MORTH KARANPURA_3680MM\0000-110-POI-A-023RA.DWG



This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



**TECHNICAL SPECIFICATION FOR
FUEL OIL HANDLING SYSTEM
1X500MW VINDHAYACHAL STPP, STAGE- V**

SPECIFICATION NO. PE-TS-389-166-A001

VOLUME II-B

SECTION 'D'

REVISION 00

DATE:

SECTION-D



TITLE	TECHNICAL SPECIFICATION FOR TANKS		SPECIFICATION NO. PE-TS-389-166-A001	
			VOLUME II B	
			SECTION D	
			REV 00	DATE
			SHEET 1 OF 9	

1.0 SCOPE

This specification covers design, fabrication, assembly, inspection, and testing at manufacturer's work for shop fabricated tanks only; delivery, erection and testing at site. For site fabricated tanks it includes design, delivery of materials to site, fabrication, erection and testing at site.

2.0 CODES & STANDARDS

The design, fabrication & assembly, erection & performance of steel tanks shall comply with all latest statutory regulations and safety codes applicable in the locality where the tanks are to be installed. Tanks shall conform to the latest applicable Indian/British/ USA standards. The vendor shall not be construed to be relieved of his responsibility by virtue of this specification. The tank in general shall conform to the latest editions ,as is applicable, out of the following standards.

- 1 IS-800 Code of practice for use of steel in general building construction
- 2 IS-803 Code of practice for design, fabrication and erection of vertical mild steel cylindrical welded oil storage tank.
- 3 IS-804 Specification for rectangular pressed steel tanks
- 4 IS-805 Code of practice for use of steel in gravity water tank.
- 5 IS-816 Code of practice for metal arc welding for general construction in MS.
- 6 IS-817 Code of practice for training and testing for metal arc welder.
- 7 IS-2825 Code of practice for unfired pressure vessel
- 8 BS-2594 Specification for carbon steel welded horizontal cylindrical storage tank
- 9 BS-2654 Specification for vertical steel welded storage tanks with butt welded shells for the petroleum industry
- 10 Indian explosive act and statutory requirements of chief controller of explosives, **Nagpur** (For oil storage tanks.)
- 11 Indian Boiler Regulations
- 12 Indian Factories Act
- 13 American code for oil tanks API 650
- 14 Material Specification as per IS/ or approved equal



TITLE

TECHNICAL SPECIFICATION
FOR TANKS

SPECIFICATION NO. PE-TS-389-166-A001

VOLUME II B

SECTION D

REV 00

DATE

SHEET 2 OF 9

3.0 DESIGN REQUIREMENT

3.1 General Requirement

- 3.1.1 All tanks will be mild steel tanks. The tanks will be of welded construction and will be designed to withstand satisfactorily the internal forces due to the liquid. These tanks have to hold as specified and external forces due to wind and seismic forces without deformation or undue strain. The plates will be cold rolled through plate bending machines by several no. of passes to the curvature.
- 3.1.2 All tanks will be designed for the capacities, dimensions and working conditions as specified in DATA SHEET -A. These tanks will be provided with all necessary connections as specified. The design of tanks will be such as to allow easy inspection, cleaning and repair. Due consideration will be given to wind loading and adequate stiffening will be provided to prevent failure of tank due to buckling when it is empty. A 2.0 mm corrosion allowance for shells, bottom and roofs above and beyond the required thickness shall be provided.
- 3.1.3 Vessel seams shall be so positioned that they do not pass through vessel connections. For vessels consisting of more than two sections, longitudinal seams shall be offset.
- 3.1.4 The inside seam should be ground smooth, suitable for application of corrosion resistant primer. Except where otherwise indicated in the specification, if the stiffening of shell and/or roof is necessary, tanks will be stiffened from outside.
- 3.1.5 Flange faces of all nozzles shall be machined and squared with the vessel centre line.
- 3.1.6 All roofs and supporting structures shall be designed to support dead load plus a uniform live load of not less than 150 kg/m^2 of projected area.
- 3.1.7 The tanks shall be designed to have all courses truly vertical. Adequate distance between vertical joints in adjacent courses shall be taken so that the distortion is reduced to minimum.
- 3.1.8 When removing temporary attachments from shell plates, care should be taken that parent plate is not damaged. Holes in plate work to assist in fabrication / erection should be avoided as far as possible. The location of holes and method of filling shall be indicated in the fabrication drawing. Any projection of metal shall be chipped and ground flush with the plate surface. The plate shall not be gouged or torn in process of removing lugs.
- 3.1.9 In the construction of shell, very care shall be taken to minimize distortion or lack of circularity due to welding or for any other reason.



TITLE	TECHNICAL SPECIFICATION FOR TANKS		SPECIFICATION NO. PE-TS-389-166-A001	
			VOLUME II B	
			SECTION D	
			REV 00	DATE
			SHEET 3 OF 9	

3.1.10 Alignment

- 3.1.10.1 Plates to be joined by butt welding shall be matched accurately. Misalignment in completed vertical joints shall not exceed 10% of the plate thickness or 1.5 mm for plates of 20 mm thick and under, whichever is larger.
- 3.1.10.2 In completed horizontal butt joints, the upper plate shall not project beyond the face of the lower plate at any point by more than 20% of the upper plate thickness with a maximum of 3 mm for plate thickness exceeding 8 mm except that for plate thickness 8 mm and under, the maximum shall be 1.5 mm.
- 3.1.10.3 Each tank shall be properly constructed ensuring perfect vertical alignment with 5 mm and tank circularity within 5 mm on diameter. Local bulging and / or depressions at any location of tank particularly shell shall not be permitted.

3.1.11 WELDING

- 3.1.11.1 Tanks and other attachments shall be welded as per IS-816 and the qualification of welder should be as specified in IS-7310
- 3.1.11.2 Welding sequence shall be so adopted that distortion due to welding shrinkage shall be minimum. Welding procedure specification shall be submitted for approval of BHEL giving details of material, welding position, sequence, type of electrode used, pre-heat & post weld requirement etc as per the code of construction. Brand name of electrodes to be used with proper classification (e.g. E 6013) shall be as per BHEL's approval.
- 3.1.11.3 Welding shall not be carried out when the surface is wet and during periods of rain and high winds unless the welder and the work are properly shielded which should meet the approval of the purchaser.
- 3.1.11.4 Inspection of all welds shall be carried out in accordance with the governing code of construction. All material used by the purchaser such as electrodes, gaskets, bolts, nuts etc shall be conforming to relevant standards of repute and approved by the purchaser prior to use.
- 3.1.12 Each tank shall be complete with access staircase, ladder and safety cage and fittings like drain connection, overflow connection, tank inlet and outlet covers, level gauge glass, fittings with isolation cocks and protection covers, tank vent connection etc all complete with needed accessories for the completeness of the tanks and as specified in data sheet -A.
- 3.1.13 All openings in tank plate shall be well reinforced in approved manner by adding pad plates of adequate size and / or structural sections.



TITLE	TECHNICAL SPECIFICATION FOR TANKS		SPECIFICATION NO. PE-TS-389-166-A001	
			VOLUME II B	
			SECTION D	
			REV 00	DATE
			SHEET 4 OF 9	

3.1.14 **STAIRCASE / ACCESS LADDER AND HAND RAILING**

- 3.1.14.1 All cylindrical vertical tanks shall be provided with spiral staircase and shall conform to the requirements specified in IS- 803 unless specified otherwise. All stair treads shall be 32 mm steel fabricated gratings. Each tread, if needed, shall be housed in individual steel fabricated frame which shall be adequately supported from the tank outer periphery. The staircase shall have minimum 750 mm clear width.
- 3.1.14.2 Access ladder, one (1) for each horizontal cylindrical / rectangular tank shall be provided for access to the tank roof. It shall be steel fabricated having minimum 450 mm width. Ladder stringers shall be heavy steel flats or angle section. All rungs shall be minimum 20 mm Dia rods spaced at not more than 30 mm center to center. All ladders shall have steel fabricated safety cage to the approved construction. Safety cage shall be provided about 2.5 m clear height of the ladder. Access ladder's stringers shall be widely spaced at top for free access to the tank roof.
- 3.1.14.3 All staircase and roofs of vertical cylindrical tanks shall be provided with pipe hand railings of 1070 mm effective height throughout. Handrails shall be constructed out of 32 mm medium class galvanized steel pipe conforming to IS- 1239: 1968. Handrail posts shall be arranged at spacing not greater than 1850 mm. Two (2) sets of pipes horizontal runners all along the length shall be provided. All welds joints in the handrails shall be ground flush to protect any person getting injured. Steel toe plates of 100 mm flats shall be used. Hand railing shall be fabricated installed in an approved manner as directed by purchaser in accordance with approved drawings.
- 3.1.15 Unless otherwise specified, for all flanged connections vendor shall furnish suitable counter flanges and necessary nuts, bolts and gaskets materials.
- 3.1.16 Unless otherwise specified bolts and nuts shall be hexagonal head conforming to IS-1367
- 3.1.17 Gaskets shall be 3 mm thick full face. CAF Gasket is not acceptable. On completion of hydraulic test / water fill test, contractor shall replace the gaskets used during testing at his own cost.
- 3.1.18 Float level indicators, gauge glass and level switches of approved make as specified in data sheet-A shall be provided.
- 3.1.19 During erection of tank, shell plates shall be suitably supported both for outside and inside to avoid buckling / collapsing of tank due to high speed wind, gust or severe storm, if any, occurring during erection.
- 3.1.20 The contractor shall furnish two (2) grounding pads for each vertical tank. Each pad shall be stainless steel plate 100 mm x 100 mm x 6 mm thick, with two 15 mm holes on 45 mm centers. Pads shall be edge welded to tank shell within 450 mm from the tank base. Two grounding lugs shall be provided for each horizontal tank.



TITLE

TECHNICAL SPECIFICATION
FOR TANKS

SPECIFICATION NO. PE-TS-389-166-A001

VOLUME II B

SECTION D

REV 00

DATE

SHEET 5 OF 9

3.2 VERTICAL CYLINDRICAL STORAGE TANKS

- 3.2.1 The vertical cylindrical storage (non- pressure) tanks shall be of mild steel welded construction and shall be designed in accordance with IS- 803. The vertical cylindrical storage tanks shall have slightly sloping bottom towards an adequately sized sump inside the tank to enable complete draining of the tank. The tank shall be designed for a wind pressure and seismic coefficient as specified. While worst of these two shall be increased as per IS.
- 3.2.2 Conical roof shall be self supported over the tank periphery. The roof shall have a slope of not less than 1 in 16 to ensure drainage of rainwater. Needed roof rafters and purlins adequately designed shall be provided.
- 3.2.3 All plates to be used for fabrication of tank shall be checked and all sides trimmed to make them square.
- 3.2.4 All bottom plates shall have lap weld joints on all sides with overlap not less than five times the plate thickness.
- 3.2.5 All shell course plates shall be taken during bending to prevent plate skewing. For butt weld joints, edges shall be prepared which shall be uniform and smooth throughout. To maintain needed root penetration gap at any butt weld joint, sufficient numbers of erection cleats shall be provided on all sides of outer periphery of each shell plate. Plates for tanks shall be straightened by pressing or by other non injurious methods.
- 3.2.6 Each shell course shall be of uniform width throughout longitudinal weld in plates. Make up for the course width shall not be permitted. Shell plates in each course width shall be so arranged that all vertical joints are staggered having a minimum of 600 mm stagger. Shell thickness could be reduced in upper courses depending on design requirements but in no case the plate thickness shall be less than 6 mm.
- 3.2.7 The tank height shall be completed by the provision of top curb/ angle which shall be butt welded to the adjacent tank plate courses. The outstanding leg of the curb angle shall be kept outside the tank periphery. All butt weld joints shall be full strength welds but for design of shell plate thickness adequate weld efficiency as recommended by applicable code(s) shall be used.
- 3.2.8 Tank roof shall be supported over steel fabricated central column(s). Adequately sized and spaced rafters and purlins shall be provided. All rafters shall have sliding bolted connections at one end and preferably on the tank periphery side. The roof supporting frame shall have needed tie rods or bracing sets.
- 3.2.9 Roof plates shall have lap joints with lap not less than 25 mm and lap weld over the top surface only. Roof plates shall have continuous fillet welds around the tank curb angle. No joint of roof plate over the supporting frame shall be made.
- 3.2.10 Needed openings for mounting various specified accessories shall be well reinforced in accordance with application codes and as approved. Manhole shall be bolted and hinged covered unless otherwise specified.



TITLE

TECHNICAL SPECIFICATION
FOR TANKS

SPECIFICATION NO. PE-TS-389-166-A001

VOLUME II B

SECTION D

REV 00

DATE

SHEET 6 OF 9

3.2.11 All inlet pipe nozzles located at the top of tanks shall be provided with internal piping up to 500 mm high above the tank's bottom inside with suitable weir plate at bottom. The inside piping shall be adequately supported and shall be provided with adequately sized vent connection at pipe top.

3.3.0 RECTANGULAR TANKS

3.3.1 Rectangular tanks shall be fabricated in steel material and shall be designed to withstand internal hydrostatic pressure. In addition these shall be checked for a wind pressure and seismic coefficient as specified where applicable. While worst of these two shall be considered, the permissible stress shall be increased as per IS when their effect considered with tank load.

3.3.2 Tank bottom and / or side plates shall be of minimum 6 mm thick plate. Corrosion margin of at least 2 mm shall be provided over the design thickness of bottom and / or side plates.

3.3.3 To support tank plates and to maintain required unsupported plate length, adequately sized and spaced steel structural closed frame shall be provided inside the tank. Longitudinal and / or vertical structural members to connect and adequately support these frames shall be provided at corners. Horizontal diagonal members / sway bracings at corner shall also be provided.

3.3.4 Tank plates cut to size shall be welded on these frames. Plate butt weld joints at other locations shall be eliminated to avoid warping of the plates at free joints. Adequate openings in the structural frames, particularly at the bottom shall be provided to ensure complete unrestricted drainage of tank at one point.

3.3.5 Complete assembled tank shall have at its bottom longitudinal steel fabricated bearer beams welded to it. The tank with bearer will rest over number of concrete blocks to be provided by purchaser. The tank shall be adequately bolted / welded to the concrete blocks. Needed inserts / anchor bolts shall be furnished by the bidders. Grouting of tank over concrete blocks in approved manner shall be included in bidder's scope of work, if erection is also awarded to the bidder.

3.3.6 Where rectangular tanks are flushed in dual compartments the inside partition plate shall be well reinforced to withstand hydrostatic test pressure completely on one side throughout the full height.

3.4 HORIZONTAL CYLINDRICAL TANK

3.4.1 The horizontal cylindrical tank with dished ends shall be of mild steel welded construction and shall be designed in accordance with BS- 2594. The tank shall be designed for a wind pressure and seismic coefficient as specified. While worst of these two shall be considered, the permissible stress shall be increased as per IS.

3.4.2 The shell and dished end plate thickness shall be chosen as per design requirement but in no case the dished end and shell plate thickness shall be less than 8 mm.



TITLE	TECHNICAL SPECIFICATION FOR TANKS	SPECIFICATION NO. PE-TS-389-166-A001 <hr/> VOLUME II B <hr/> SECTION D <hr/> REV 00 DATE <hr/> SHEET 7 OF 9
-------	--	--

3.4.3 All seams, longitudinal as well as circumferential, shall be butt welded. Longitudinal seams should not be situated in the lower third of a tank or on the top center line.

3.4.4 All tank shall be supplied with integral saddle support and shall be designed in accordance with BS- 2594.

4.0 TESTING AND INSPECTION AT MANUFACTURERER'S WORKS

4.1 General

4.1.1 The supplier shall provide inspection to establish and maintain quality of workmanship in his works and that of his subcontractors to ensure the mechanical accuracy of components, compliance with drawings identity and acceptability of all materials, parts and equipment. He shall conduct all tests required to ensure that the equipment and material furnished shall conform to requirements of the acceptable codes. All tests and test procedure proposed by manufacturer shall be submitted to the purchaser for their prior approval.

4.1.2 All materials used for manufacture of the equipment under this specification shall be of tested quality. Relevant test certificates shall be made available to the purchaser before the final shop inspection. In case the relevant correlating test certificates are not available , the supplier shall arrange to carry out the necessary tests required by codes at his own cost.

4.1.3 Alloy cast iron and cast steel components shall be tested for both physical and chemical properties in absence of purchaser's representatives. Test bears shall be either integral or taken from the same ladle of material as the casting they represent.

4.2 TESTING AND INSPECTION FOR TANKS

4.2.1 The scope of testing and inspection for pressure vessel covered in this specification shall generally comprise of the following:

i) Examination and approval of fabrication drawings to ensure that design, materials and fabrication details meet requirement of code and specifications. Purchaser will review these drawings for interface problems and conformity with the general arrangement drawings and accord their approval.

ii) Examination of materials of construction and identification with material test certificates.

iii) All the plates of thickness 50 mm or more shall be ultrasonically tested to ensure freedom from laminations.

iv) Ensuring the relevant weld procedure and welder qualification tests are in accordance with stipulated code requirements.

v) Inspection of dished end flanges and alloy steel bolting where required.



TITLE	TECHNICAL SPECIFICATION FOR TANKS		SPECIFICATION NO. PE-TS-389-166-A001	
			VOLUME II B	
			SECTION D	
			REV 00	DATE
			SHEET 8 OF 9	

vi) Inspection during fabrication at appropriate stages including fit ups .

vii) For all butt welds, the root run and final run shall be subjected to dye penetrant or magnetic particle inspection. For all fillet welds the final run shall be subjected to dye penetrant / magnetic particle examination.

viii) Examination of radiographs including radiographic techniques, supervision of other non - destructive tests and heat treatment procedure as required by codes and specifications.

ix) Examination of internal cleanliness before final closure.

x) Dimensional examination of completed vessel including axis marking, proof marking , match marking etc.

xi) Witnessing of hydrostatic, pneumatic or vacuum tests or special tests as required by the code and specification . In case of hydrostatic tests, the test pressure must be kept for a minimum of two hours.

xii) Witnessing cleanliness, preservation, packing and marking .

xiii) Stamping of vessel and issue of certificates.

4.2.2 NON - PRESSURE TANKS

The scope of testing and inspection for non pressure tanks covered in this specification will comprise of the following :

i) Identification of materials to manufacturer's test certificates.

ii) Inspection of plate edges after edge preparation and checking curvature against templates if shell plates sent after rolling .

iii) Checking of dimension and match marking .

iv) Bottom testing

a. After the bottom and bottom course of shell plates have been welded, the bottom shall be tested by pumping air beneath the bottom plates to a pressure just sufficient to lift them off the foundation and in any case not less than 100 mm water gauge. The pressure shall be held by construction of a temporary dam of clay or other suitable material around the tank periphery. Soap suds or other suitable material shall be applied to all joints for detection of leaks.

b. Fuel oil may be used instead of air and soap suds to test for leaks, subject to prior agreement and approval of purchaser.



TITLE

TECHNICAL SPECIFICATION
FOR TANKS

SPECIFICATION NO. PE-TS-389-166-A001

VOLUME II B

SECTION D

REV 00

DATE

SHEET 9 OF 9

c. Alternatively, the bottom seams may be tested by vacuum box method subject to prior agreement and approval of the purchaser. The vacuum box used shall comply with IS-803, 1976 (figure-24)

v) Shell testing

The shell of fixed roof non - pressure tanks shall be tested after completion of roof. Testing shall be done by filling the tank with water to the level of the top leg of the top curb angle and noting any leaks.

vi) Roof testing

The roof of the tank shall be tested by pumping air under the roof plates while the tank is still full of water. In the non - pressure tank , the roof shall be tested to a pressure of 75 mm of water gauge and in case of pressure roof tanks, to a pressure of one and a quarter times the pressure at which the pressure sides of the pressure / vacuum relief valve is designed to open. Soap suds or other suitable material shall be applied to all joints for detection of leaks.

vii) All field testing shall be performed prior to any painting or coating application.

4.3 REPAIR OF LEAKS

4.3.1 All leaks detected during testing shall be repaired to the satisfaction of the purchaser and on completion retested for leakage as per approved procedure.

4.3.2 In the joints between roof plates only, pin hole leaks may be repaired by mechanical caulking. However, where there is any indication of considerable porosity , the leaks shall be sealed by laying down an additional layer of weld over the porous sections.

4.3.3 In all other joints, whether between shell plates or bottom plates or both, leak shall be repaired only welding and if necessary, after first cutting out the defective part.

4.3.4 When the tank is filled with water for testing , defects in the shell joints shall be repaired with the water level at least 300 mm below the joint being repaired.

4.3.5 No welding shall be done on any tank unless all lines connecting thereto have been completely blanked off. No repairs shall attempted on tanks while filled with oil, nor any tanks which have contained oil until the tanks have been emptied, cleaned and freed from gas in a safe manner. No repair shall be attempted on a tank which has contained oil except in a manner approved in writing by the purchaser, and in absence of the purchaser's inspector.

1X 500 MW VINDHAYACHAL STPP, STAGE-V

VOLUME III
TECHNICAL SPECIFICATION
FOR
FUEL OIL UNLOADING & STORAGE SYSTEM

SPECIFICATION NO. PE-TS-389-166-A001



BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI, NOIDA- INDIA



TITLE:
**TECHNICAL SPECIFICATION
3X660 MW NABINAGAR STPP BIHAR
COMPLIANCE CUM CONFIRMATION
CERTIFICATE**

SPEC. NO.: PE-TS-389-166-A001
VOLUME: III
SECTION:
REV. NO. 0 DATE 04-04-2014
SHEET 1 OF 2

COMPLIANCE CUM CONFIRMATION CERTIFICATE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate (every sheet) and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions other than those mentioned under "exclusion" and those resolved as per 'Schedule of Deviations', if applicable, with regard to same.
- b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'.
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/ CUSTOMER approval & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. This shall be within the contracted price with no extra implications to BHEL after award of the contract.
- d) All drawings/ data-sheets/ calculations etc. submitted along with the offer shall be considered for reference only, same shall be subject to BHEL/ CUSTOMER approval in the event of order.
- e) The offered materials shall be either equivalent or superior to those specified in the specification & shall meet the specified/ intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre - bid discussions, otherwise BHEL/ Customer's decision shall be binding on the bidder whenever the deficiency is pointed out.


For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.
- f) The commissioning spares shall be supplied on 'As Required Basis' & prices for same included in the base price itself.
- g) All sub vendors shall be subject to BHEL/ CUSTOMER approval in the event of order.
- h) **Guarantee for plant/equipment shall be as per relevant clause of GCC /SCC /Other Commercial Terms & Conditions.**
- i) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities. This clause will apply in case during site commissioning additional requirements emerges due to customer and/ or consultant's comments. No extra claims shall be put on this account.
- j) Schedule of drawings submissions, comment incorporations & approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to BHEL's/ Customer's/ Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.



TITLE:
**TECHNICAL SPECIFICATION
3X660 MW NABINAGAR STPP BIHAR
COMPLIANCE CUM CONFIRMATION
CERTIFICATE**

SPEC. NO.: PE-TS-389-166-A001
VOLUME: **III**
SECTION:
REV. NO. **0** DATE 04-04-2014
SHEET **2** OF **2**

- k) As built drawings shall be submitted as and when required during the project execution.
- l) The bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.

	TITLE	SPECIFICATION NO. PE-TS-389-166-A001	
	TECHNICAL SPECIFICATION FOR FUEL OIL UNLOADING & STORAGE SYSTEM	VOLUME III	
		SECTION D	
		REV 00	DATE
		SHEET OF	

CHECK LIST TO BE SUBMITTED BY THE BIDDER

S.No.	ITEM DESCRIPTION	YES/NO
01	Schedules submitted duly filled up with bidder's signature & stamp. a) Technical Deviation Schedule b) List of special maintenance tools & tackles c) Electrical Load List	
02	Resolutions to pre-bid clarifications, if any, duly stamped and signed by the bidder, enclosed with the bid	
03	Copy of Electrical Equipment Specification for Fuel Oil Handling System and the sheet titled "Electrical Scope between Customer and Vendor" duly signed and stamped is enclosed.	
04	Manual Calculation for Aux. Steam Requirement in case the maximum steam required is more than 11 T/hr.	
05	Technical details of Oil/Condensate Hoses (In case this is not enclosed, the details shall be finalized during detail engineering without any commercial implication to customer)	
06	Un priced bid clearly indicating "Quoted" or "Not Quoted" against each item.	
07	The list of recommended Spares considered is also enclosed with the un priced bid.	

Pls. note that all schedules shall be submitted even though they may not be applicable. Under such circumstance, it shall be clearly mentioned across such schedules that these are not applicable. (e.g. in case there are no technical deviation, it shall be mentioned in the deviation schedule that "THERE ARE NO DEVIATIONS TO THE TECHNICAL SPECIFICATION")

SIGNATURE: _____

NAME : _____

DESIGNATION: _____

COMPANY: _____

DATE: _____

COMPANY SEAL

DEVIATION SHEET (COST OF WITHDRAWAL)



PROJECT:- 1x500 MW VINDHAYACHAL STPP, STAGE-V

PACKAGE:- FUEL OIL UNLOADING AND STORAGE SYSTEM

TENDER ENQUIRY REFERENCE:-

NAME OF VENDOR:-

SL NO	VOULME/ SECTION	PAGE NO.	CLAUSE NO.	TECHNICAL SPECIFICATION/ TENDER DOCUMENT	COMPLETE DESCRIPTION OF DEVIATION	COST OF WITHDRAWAL OF DEVIATION	REFERENCE OF PRICE SCHEDULE ON WHICH COST OF WITHDRAWAL OF DEVIATION IS APPLICABLE	NATURE OF COST OF WITHDRAWAL OF DEVIATION (POSITIVE/ NEGATIVE)	REASON FOR QUOTING DEVIATION
-------	-----------------	----------	------------	--	-----------------------------------	---------------------------------	--	--	------------------------------

TECHNICAL DEVIATIONS

COMMERCIAL DEVIATIONS

PARTICULARS OF BIDDERS/ AUTHORISED REPRESENTATIVE

NAME	DESIGNATIONS	SIGN & DATE

NOTES:

- For self manufactured items of bidder, cost of withdrawal of deviation will be applicable on the basic price (i.e. excluding taxes, duties & freight) only.
- For directly dispatchable items, cost of withdrawal of deviation will be applicable on the basic price including taxes, duties & freight.
- All the bidders have to list out all their Technical & Commercial Deviations (if any) in detail in the above format.
- Any deviation not mentioned above and shown separately or found hidden in offer, will not be taken cognizance of.
- Bidder shall submit duly filled unpriced copy of above format indicating "quoted" in "cost of withdrawal of deviation" column of the schedule above along with their Techno-commercial offer, wherever applicable.
- Bidder shall furnish price copy of above format along with price bid.
- The final decision of acceptance/ rejection of the deviations quoted by the bidder shall be at discretion of the Purchaser.
- Bidders to note that any deviation (technical/commercial) not listed in above and asked after Part-I opening shall not be considered.
- For deviations w.r.t. Payment terms, Liquidated damages, Firm prices and submission of E1/ E2 forms before claiming 10% payment, if a bidder chooses not to give any cost of withdrawal of deviation loading as per Annexure-VIII of GCC, Rev-06 will apply. For any other deviation mentioned in un-priced copy of this format submitted with Part-I bid but not mentioned in priced copy of this format submitted with Priced bid, the cost of withdrawal of deviation shall be taken as NIL.
- Any deviation mentioned in priced copy of this format, but not mentioned in the un-priced copy, shall not be accepted.
- All techno-commercial terms and conditions of NIT shall be deemed to have been accepted by the bidder, other than those listed in unpriced copy of this format.
- Cost of withdrawal is to be given separately for each deviation. In no event bidder should club cost of withdrawal of more than one deviation else cost of withdrawal of such deviations which have been clubbed together shall be considered as NIL.
- In case nature of cost of withdrawal (positive/negative) is not specified it shall be assumed as positive.
- In case of discrepancy in the nature of impact (positive/ negative), positive will be considered for evaluation and negative for ordering.


NTPC LTD.

1X500MW VINDHAYACHAL STPP, STAGE- V

**TECHNICAL SPECIFICATION
FOR
FUEL OIL UNLOADING & STORAGE SYSTEM
SPECIFICATION NO. : PE-TS-389-166-A001
DRAWINGS**


















































**BHARAT HEAVY ELECTRICALS LTD
POWER SECTOR PROJECT ENGINEERING MANAGEMENT
PPEI, NOIDA, INDIA**



- NOTES:**
1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 5. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 7. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.
 10. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL AUTHORITIES.












































































































































- LEGEND:**
1. MAIN ELECTRICAL PANEL
 2. SUBSTATION
 3. TRANSFORMER
 4. BUSBAR
 5. CABLE TRAY
 6. CONDUIT
 7. PIPE
 8. WALL
 9. FLOOR
 10. CEILING
 11. ROOF
 12. GROUND
 13. WATER
 14. SEWER
 15. RAINWATER
 16. AIR
 17. GAS
 18. OIL
 19. FUEL
 20. ASH
 21. SLUDGE
 22. WASTE
 23. DRAINAGE
 24. VENTILATION
 25. EXHAUST
 26. INTAKE
 27. OUTLET
 28. INLET
 29. VALVE
 30. FITTING
 31. FLANGE
 32. GASKET
 33. BOLT
 34. NUT
 35. WASHER
 36. RIVET
 37. WELD
 38. BRACKET
 39. HANGAR
 40. SUPPORT
 41. ANCHOR
 42. FOUNDATION
 43. PILING
 44. RETAINING WALL
 45. FENCE
 46. GATE
 47. ROAD
 48. DRIVEWAY
 49. PARKING
 50. WALKWAY
 51. STAIR
 52. ELEVATOR
 53. ESCAPE ROUTE
 54. FIRE EXTINGUISHER
 55. FIRE ALARM
 56. SMOKE DETECTOR
 57. TEMPERATURE SENSOR
 58. PRESSURE SENSOR
 59. FLOW METER
 60. LEVEL METER
 61. PH METER
 62. O2 METER
 63. CO METER
 64. H2 METER
 65. H2S METER
 66. NH3 METER
 67. CH4 METER
 68. C2H6 METER
 69. C2H4 METER
 70. C2H2 METER
 71. HCN METER
 72. HCL METER
 73. HF METER
 74. HNO3 METER
 75. H2SO4 METER
 76. H3PO4 METER
 77. H2O2 METER
 78. H2O METER
 79. CO2 METER
 80. SO2 METER
 81. NO2 METER
 82. NO METER
 83. O3 METER
 84. O2 METER
 85. N2 METER
 86. CH4 METER
 87. C2H6 METER
 88. C2H4 METER
 89. C2H2 METER
 90. HCN METER
 91. HCL METER
 92. HF METER
 93. HNO3 METER
 94. H2SO4 METER
 95. H3PO4 METER
 96. H2O2 METER
 97. H2O METER
 98. CO2 METER
 99. SO2 METER
 100. NO2 METER
 101. NO METER
 102. O3 METER
 103. O2 METER
 104. N2 METER
 105. CH4 METER
 106. C2H6 METER
 107. C2H4 METER
 108. C2H2 METER
 109. HCN METER
 110. HCL METER
 111. HF METER
 112. HNO3 METER
 113. H2SO4 METER
 114. H3PO4 METER
 115. H2O2 METER
 116. H2O METER
 117. CO2 METER
 118. SO2 METER
 119. NO2 METER
 120. NO METER
 121. O3 METER
 122. O2 METER
 123. N2 METER
 124. CH4 METER
 125. C2H6 METER
 126. C2H4 METER
 127. C2H2 METER
 128. HCN METER
 129. HCL METER
 130. HF METER
 131. HNO3 METER
 132. H2SO4 METER
 133. H3PO4 METER
 134. H2O2 METER
 135. H2O METER
 136. CO2 METER
 137. SO2 METER
 138. NO2 METER
 139. NO METER
 140. O3 METER
 141. O2 METER
 142. N2 METER
 143. CH4 METER
 144. C2H6 METER
 145. C2H4 METER
 146. C2H2 METER
 147. HCN METER
 148. HCL METER
 149. HF METER
 150. HNO3 METER
 151. H2SO4 METER
 152. H3PO4 METER
 153. H2O2 METER
 154. H2O METER
 155. CO2 METER
 156. SO2 METER
 157. NO2 METER
 158. NO METER
 159. O3 METER
 160. O2 METER
 161. N2 METER
 162. CH4 METER
 163. C2H6 METER
 164. C2H4 METER
 165. C2H2 METER
 166. HCN METER
 167. HCL METER
 168. HF METER
 169. HNO3 METER
 170. H2SO4 METER
 171. H3PO4 METER
 172. H2O2 METER
 173. H2O METER
 174. CO2 METER
 175. SO2 METER
 176. NO2 METER
 177. NO METER
 178. O3 METER
 179. O2 METER
 180. N2 METER
 181. CH4 METER
 182. C2H6 METER
 183. C2H4 METER
 184. C2H2 METER
 185. HCN METER
 186. HCL METER
 187. HF METER
 188. HNO3 METER
 189. H2SO4 METER
 190. H3PO4 METER
 191. H2O2 METER
 192. H2O METER
 193. CO2 METER
 194. SO2 METER
 195. NO2 METER
 196. NO METER
 197. O3 METER
 198. O2 METER
 199. N2 METER
 200. CH4 METER
 201. C2H6 METER
 202. C2H4 METER
 203. C2H2 METER
 204. HCN METER
 205. HCL METER
 206. HF METER
 207. HNO3 METER
 208. H2SO4 METER
 209. H3PO4 METER
 210. H2O2 METER
 211. H2O METER
 212. CO2 METER
 213. SO2 METER
 214. NO2 METER
 215. NO METER
 216. O3 METER
 217. O2 METER
 218. N2 METER
 219. CH4 METER
 220. C2H6 METER
 221. C2H4 METER
 222. C2H2 METER
 223. HCN METER
 224. HCL METER
 225. HF METER
 226. HNO3 METER
 227. H2SO4 METER
 228. H3PO4 METER
 229. H2O2 METER
 230. H2O METER
 231. CO2 METER
 232. SO2 METER
 233. NO2 METER
 234. NO METER
 235. O3 METER
 236. O2 METER
 237. N2 METER
 238. CH4 METER
 239. C2H6 METER
 240. C2H4 METER
 241. C2H2 METER
 242. HCN METER
 243. HCL METER
 244. HF METER
 245. HNO3 METER
 246. H2SO4 METER
 247. H3PO4 METER
 248. H2O2 METER
 249. H2O METER
 250. CO2 METER
 251. SO2 METER
 252. NO2 METER
 253. NO METER
 254. O3 METER
 255. O2 METER
 256. N2 METER
 257. CH4 METER
 258. C2H6 METER
 259. C2H4 METER
 260. C2H2 METER
 261. HCN METER
 262. HCL METER
 263. HF METER
 264. HNO3 METER
 265. H2SO4 METER
 266. H3PO4 METER
 267. H2O2 METER
 268. H2O METER
 269. CO2 METER
 270. SO2 METER
 271. NO2 METER
 272. NO METER
 273. O3 METER
 274. O2 METER
 275. N2 METER
 276. CH4 METER
 277. C2H6 METER
 278. C2H4 METER
 279. C2H2 METER
 280. HCN METER
 281. HCL METER
 282. HF METER
 283. HNO3 METER
 284. H2SO4 METER
 285. H3PO4 METER
 286. H2O2 METER
 287. H2O METER
 288. CO2 METER
 289. SO2 METER
 290. NO2 METER
 291. NO METER
 292. O3 METER
 293. O2 METER
 294. N2 METER
 295. CH4 METER
 296. C2H6 METER
 297. C2H4 METER
 298. C2H2 METER
 299. HCN METER
 300. HCL METER
 301. HF METER
 302. HNO3 METER
 303. H2SO4 METER
 304. H3PO4 METER
 305. H2O2 METER
 306. H2O METER
 307. CO2 METER
 308. SO2 METER
 309. NO2 METER
 310. NO METER
 311. O3 METER
 312. O2 METER
 313. N2 METER
 314. CH4 METER
 315. C2H6 METER
 316. C2H4 METER
 317. C2H2 METER
 318. HCN METER
 319. HCL METER
 320. HF METER
 321. HNO3 METER
 322. H2SO4 METER
 323. H3PO4 METER
 324. H2O2 METER
 325. H2O METER
 326. CO2 METER
 327. SO2 METER
 328. NO2 METER
 329. NO METER
 330. O3 METER
 331. O2 METER
 332. N2 METER
 333. CH4 METER
 334. C2H6 METER
 335. C2H4 METER
 336. C2H2 METER
 337. HCN METER
 338. HCL METER
 339. HF METER
 340. HNO3 METER
 341. H2SO4 METER
 342. H3PO4 METER
 343. H2O2 METER
 344. H2O METER
 345. CO2 METER
 346. SO2 METER
 347. NO2 METER
 348. NO METER
 349. O3 METER
 350. O2 METER
 351. N2 METER
 352. CH4 METER
 353. C2H6 METER
 354. C2H4 METER
 355. C2H2 METER
 356. HCN METER
 357. HCL METER
 358. HF METER
 359. HNO3 METER
 360. H2SO4 METER
 361. H3PO4 METER
 362. H2O2 METER
 363. H2O METER
 364. CO2 METER
 365. SO2 METER
 366. NO2 METER
 367. NO METER
 368. O3 METER
 369. O2 METER
 370. N2 METER
 371. CH4 METER
 372. C2H6 METER
 373. C2H4 METER
 374. C2H2 METER
 375. HCN METER
 376. HCL METER
 377. HF METER
 378. HNO3 METER
 379. H2SO4 METER
 380. H3PO4 METER
 381. H2O2 METER
 382. H2O METER
 383. CO2 METER
 384. SO2 METER
 385. NO2 METER
 386. NO METER
 387. O3 METER
 388. O2 METER
 389. N2 METER
 390. CH4 METER
 391. C2H6 METER
 392. C2H4 METER
 393. C2H2 METER
 394. HCN METER
 395. HCL METER
 396. HF METER
 397. HNO3 METER
 398. H2SO4 METER
 399. H3PO4 METER
 400. H2O2 METER
 401. H2O METER
 402. CO2 METER
 403. SO2 METER
 404. NO2 METER
 405. NO METER
 406. O3 METER
 407. O2 METER
 408. N2 METER
 409. CH4 METER
 410. C2H6 METER
 411. C2H4 METER
 412. C2H2 METER
 413. HCN METER
 414. HCL METER
 415. HF METER
 416. HNO3 METER
 417. H2SO4 METER
 418. H3PO4 METER
 419. H2O2 METER
 420. H2O METER
 421. CO2 METER
 422. SO2 METER
 423. NO2 METER
 424. NO METER
 425. O3 METER
 426. O2 METER
 427. N2 METER
 428. CH4 METER
 429. C2H6 METER
 430. C2H4 METER
 431. C2H2 METER
 432. HCN METER
 433. HCL METER
 434. HF METER
 435. HNO3 METER
 436. H2SO4 METER
 437. H3PO4 METER
 438. H2O2 METER
 439. H2O METER
 440. CO2 METER
 441. SO2 METER
 442. NO2 METER
 443. NO METER
 444. O3 METER
 445. O2 METER
 446. N2 METER
 447. CH4 METER
 448. C2H6 METER
 449. C2H4 METER
 450. C2H2 METER
 451. HCN METER
 452. HCL METER
 453. HF METER
 454. HNO3 METER
 455. H2SO4 METER
 456. H3PO4 METER
 457. H2O2 METER
 458. H2O METER
 459. CO2 METER
 460. SO2 METER
 461. NO2 METER
 462. NO METER
 463. O3 METER
 464. O2 METER
 465. N2 METER
 466. CH4 METER
 467. C2H6 METER
 468. C2H4 METER
 469. C2H2 METER
 470. HCN METER
 471. HCL METER
 472. HF METER
 473. HNO3 METER
 474. H2SO4 METER
 475. H3PO4 METER
 476. H2O2 METER
 477. H2O METER
 478. CO2 METER
 479. SO2 METER
 480. NO2 METER
 481. NO METER
 482. O3 METER
 483. O2 METER
 484. N2 METER
 485. CH4 METER
 486. C2H6 METER
 487. C2H4 METER
 488. C2H2 METER
 489. HCN METER
 490. HCL METER
 491. HF METER
 492. HNO3 METER
 493. H2SO4 METER
 494. H3PO4 METER
 495. H2O2 METER
 496. H2O METER
 497. CO2 METER
 498. SO2 METER
 499. NO2 METER
 500. NO METER
 501. O3 METER
 502. O2 METER
 503. N2 METER
 504. CH4 METER
 505. C2H6 METER
 506. C2H4 METER
 507. C2H2 METER
 508. HCN METER
 509. HCL METER
 510. HF METER
 511. HNO3 METER
 512. H2SO4 METER
 513. H3PO4 METER
 514. H2O2 METER
 515. H2O METER
 516. CO2 METER
 517. SO2 METER
 518. NO2 METER
 519. NO METER
 520. O3 METER
 521. O2 METER
 522. N2 METER
 523. CH4 METER
 524. C2H6 METER
 525. C2H4 METER
 526. C2H2 METER
 527. HCN METER
 528. HCL METER
 529. HF METER
 530. HNO3 METER
 531. H2SO4 METER
 532. H3PO4 METER
 533. H2O2 METER
 534. H2O METER
 535. CO2 METER
 536. SO2 METER
 537. NO2 METER
 538. NO METER
 539. O3 METER
 540. O2 METER
 541. N2 METER
 542. CH4 METER
 543. C2H6 METER
 544. C2H4 METER
 545. C2H2 METER
 546. HCN METER
 547. HCL METER
 548. HF METER
 549. HNO3 METER
 550. H2SO4 METER
 551. H3PO4 METER
 552. H2O2 METER
 553. H2O METER
 554. CO2 METER
 555. SO2 METER
 556. NO2 METER
 557. NO METER
 558. O3 METER
 559. O2 METER
 560. N2 METER
 561. CH4 METER
 562. C2H6 METER
 563. C2H4 METER
 564. C2H2 METER
 565. HCN METER
 566. HCL METER
 567. HF METER
 568. HNO3 METER
 569. H2SO4 METER
 570. H3PO4 METER
 571. H2O2 METER
 572. H2O METER
 573. CO2 METER
 574. SO2 METER
 575. NO2 METER
 576. NO METER
 577. O3 METER
 578. O2 METER
 579. N2 METER
 580. CH4 METER
 581. C2H6 METER
 582. C2H4 METER
 583. C2H2 METER
 584. HCN METER
 585. HCL METER
 586. HF METER
 587. HNO3 METER
 588. H2SO4 METER
 589. H3PO4 METER
 590. H2O2 METER
 591. H2O METER
 592. CO2 METER
 593. SO2 METER
 594. NO2 METER
 595. NO METER
 596. O3 METER
 597. O2 METER
 598. N2 METER
 599. CH4 METER
 600. C2H6 METER
 601. C2H4 METER
 602. C2H2 METER
 603. HCN METER
 604. HCL METER
 605. HF METER
 606. HNO3 METER
 607. H2SO4 METER
 608. H3PO4 METER
 609. H2O2 METER
 610. H2O METER
 611. CO2 METER
 612. SO2 METER
 613. NO2 METER
 614. NO METER
 615. O3 METER
 616. O2 METER
 617. N2 METER
 618. CH4 METER
 619. C2H6 METER
 620. C2H4 METER
 621. C2H2 METER
 622. HCN METER
 623. HCL METER
 624. HF METER
 625. HNO3 METER
 626. H2SO4 METER
 627. H3PO4 METER
 628. H2O2 METER
 629. H2O METER
 630. CO2 METER
 631. SO2 METER
 632. NO2 METER
 633. NO METER
 634. O3 METER
 635. O2 METER
 636. N2 METER
 637. CH4 METER
 638. C2H6 METER
 639. C2H4 METER
 640. C2H2 METER
 641. HCN METER
 642. HCL METER
 643. HF METER
 644. HNO3 METER
 645. H2SO4 METER
 646. H3PO4 METER
 647. H2O2 METER
 648. H2O METER
 649. CO2 METER
 650. SO2 METER
 651. NO2 METER
 652. NO METER
 653. O3 METER
 654. O2 METER
 655. N2 METER
 656. CH4 METER
 657. C2H6 METER
 658. C2H4 METER
 659. C2H2 METER
 660. HCN METER
 661. HCL METER
 662. HF METER
 663. HNO3 METER
 664. H2SO4 METER
 665. H3PO4 METER
 666. H2O2 METER
 667. H2O METER
 668. CO2 METER
 669. SO2 METER
 670. NO2 METER
 671. NO METER
 672. O3 METER
 673. O2 METER
 674. N2 METER
 675. CH4 METER
 676. C2H6 METER
 677. C2H4 METER
 678. C2H2 METER
 679. HCN METER
 680. HCL METER
 681. HF METER
 682. HNO3 METER
 683. H2SO4 METER
 684. H3PO4 METER
 685. H2O2 METER
 686. H2O METER
 687. CO2 METER
 688. SO2 METER
 689. NO2 METER
 690. NO METER
 691. O3 METER
 692. O2 METER
 693. N2 METER
 694. CH4 METER
 695. C2H6 METER
 696. C2H4 METER
 697. C2H2 METER
 698. HCN METER
 699. HCL METER
 700. HF METER
 701. HNO3 METER
 702. H2SO4 METER
 703. H3PO4 METER
 704. H2O2 METER
 705. H2O METER
 706. CO2 METER
 707. SO2 METER
 708. NO2 METER
 709. NO METER
 710. O3 METER
 711. O2 METER
 712. N2 METER
 713. CH4 METER
 714. C2H6 METER
 715. C2H4 METER
 716. C2H2 METER
 717. HCN METER
 718. HCL METER
 719. HF METER
 720. HNO3 METER
 721. H2SO4 METER
 722. H3PO4 METER
 723. H2O2 METER
 724. H2O METER
 725. CO2 METER
 726. SO2 METER
 727. NO2 METER
 728. NO METER
 729. O3 METER
 730. O2 METER
 731. N2 METER
 732. CH4 METER
 733. C2H6 METER
 734. C2H4 METER
 735. C2H2 METER
 736. HCN METER
 737. HCL METER
 738. HF METER
 739. HNO3 METER
 740. H2SO4 METER
 741. H3PO4 METER
 742. H2O2 METER
 743. H2O METER
 744. CO2 METER
 745. SO2 METER
 746. NO2 METER
 747. NO METER
 748. O3 METER
 749. O2 METER
 750. N2 METER
 751. CH4 METER
 752. C2H6 METER
 753. C2H4 METER
 754. C2H2 METER
 755. HCN METER
 756. HCL METER
 757. HF METER
 758. HNO3 METER
 759. H2SO4 METER
 760. H3PO4 METER
 761. H2O2 METER
 762. H2O METER
 763. CO2 METER
 764. SO2 METER
 765. NO2 METER
 766. NO METER
 767. O3 METER
 768. O2 METER
 769. N2 METER
 770. CH4 METER
 771. C2H6 METER
 772. C2H4 METER
 773. C2H2 METER
 774. HCN METER
 775. HCL METER
 776. HF METER
 777. HNO3 METER
 778. H2SO4 METER
 779. H3PO4 METER
 780. H2O2 METER
 781. H2O METER
 782. CO2 METER
 783. SO2 METER
 784. NO2 METER
 785. NO METER
 786. O3 METER
 787. O2 METER
 788. N2 METER
 789. CH4 METER
 790. C2H6 METER
 791. C2H4 METER
 792. C2H2 METER
 793. HCN METER
 794. HCL METER
 795. HF METER
 796. HNO3 METER
 797. H2SO4 METER
 798. H3PO4 METER
 799. H2O2 METER
 800. H2O METER
 801. CO2 METER
 802. SO2 METER
 803. NO2 METER
 804. NO METER
 805. O3 METER
 806. O2 METER
 807. N2 METER
 808. CH4 METER
 809. C2H6 METER
 810. C2H4 METER
 811. C2H2 METER
 812. HCN METER
 813. HCL METER
 814. HF METER
 815. HNO3 METER
 816. H2SO4 METER
 817. H3PO4 METER
 818. H2O2 METER
 819. H2O METER
 820. CO2 METER
 821. SO2 METER
 - 822




Annex-I



TYPICAL DETAIL - 'K'

Sl. NO.	NO. OF HOLES	SIZE (mm)	Y ₁ (mm)	Y ₂ (mm)	Y ₃ (mm)
1	40	100	10	150	40
2	40	100	10	150	40
3	40	100	10	150	40
4	150	250	10	150	150





REFERENCE


1. NTPC DRG. NO. 2240-898-103-4001, REV.2
2. NTPC DRG. NO. 2240-898-103-4001, REV.4

NOTES

1. DIMENSIONS ARE IN MET AND ELEVATIONS & COORDINATES ARE IN MET.
2. EL. (±0.00m) CORRESPONDS TO R.L. 281.0m.
3. TRESTLE WORK INCLUDING ITS FPN, IS BY OTHERS.
4. ALL WORK SHALL BE FINISHED ON BOTH SIDES OF 3000 MM PIPE ON CUSTOMER'S TRESTLE NUMBERED AT EVERY 3.0m-3.7m SPAC.

REV.	DATE	BY	CHKD.	APPD.	DESCRIPTION
B	12.02.05	BHA	RFB	PRC	SHUT DOWN DISCHARGED PIPING TERMINATED TO ASH SLURRY SUMP AS PER APPROVAL
0	15.02.05	AD	RFB	PRC	ISSUED FOR APPROVAL
					DESCRIPTION
NATIONAL THERMAL POWER CORPORATION LTD. VINDHYACHAL SUPER THERMAL POWER PROJECT STAGE-III (2x500 MW) FUEL OIL PACKAGE					
BHARAT HEAVY ELECTRICALS LTD. POWER SECTOR : PROJECT ENGINEERING MANAGEMENT NEW DELHI TECHNO ELECTRIC & ENGINEERING CO. LTD. DESIGNERS AND CONSTRUCTORS KOLKATA, INDIA					
PIPING LAYOUT OF FUEL OIL SYSTEM					
JOB NO.	06550	DRG. NO.	06550/DR6/2500	SHEET NO./REV.	1/1
DATE	12.02.05	SCALE	AS SHOWN	DATE	12.02.05
BY	BHA	CHKD.	RFB	APPD.	PRC
DATE	12.02.05	DATE	12.02.05	DATE	12.02.05
SCALE	AS SHOWN	SCALE	AS SHOWN	SCALE	AS SHOWN
SHEET NO. REV. / TOTAL SHEETS 1/1 / 1					
BHEL DRG. NO. : PE-VO-209-166-4509 NTPC DRG. NO. : 2240-108-09PE-PM-F-050					

SKETCH WITH LOCATION OF FUEL OIL FACILITY RELATED TO FOHS SYSTEM (STAGE-V)



* COORDINATE OF THE WALL(EXISTING) AND RELOCATED ROAD LOCATION IS MENTIONED AS PER THE SKETCH RECEIVED FROM NTPC-VINDHAYACHAL Dt. 13.03.2014.
 HOW EVER CONFIRMATION ON THE SAME FROM NTPC IS REQUIRED ON THE COORDINATE
 ** NTPC CONCURRENCE REQUIRED

NOTE:-
 1. FGL IS CONSIDERED SIMILAR TO SATGE-III; i.e. 280.5M
 2. LOCATION OF VARIOUS FACILITY ARE SHOWN AS PER THE DRAWING RECEIVED FROM THE NTPC AND SITE VISIT MOM DT. 07/03/2013.
 3. FEASIBILITY OF THE VARIOUS FACILITY LOCATIONS IS NEEDED TO BE WETTED BY NTPC VINDHAYACHAL SITE

Customer's Drawing No. EN

Job No. - 389
 Status - CONTRACT
 Distribution

Project - 1X500MW VINDHAYACHAL STPP(STAGE-V)
 Customer - NTPC LTD.

Dept. Code - BHARAT HEAVY ELECTRICALS LTD
 Power Sector - PROJECTS ENGINEERING MANAGEMENT
 Region - Noida

Rev. 01
 Date 21.03.14
 Appd. S. K. SHARMA
 Chd. S. K. SHARMA
 Ss. S. K. SHARMA

Signature and Date fields for various roles.

Scale and Drawing No. fields.

Sheet 1 of 1, Drawing No. PB-SK-389-166-A001

Department, Sign, Date, and Rev. 1 fields.

Size-A1 field.

Document revised as per the NTPC EDC comments and Vindhayachal Sketch


Sketch with Location of Fuel Oil Facility Related to FOHS System (Stage-V)

Copyright and Confidentiality notice.


Computer File Name: PE-SK-389-166-166-166

Page 272 of 275


Fold-4



SL. NO.	TANK DETAILS	LIGHT DIESEL OIL STORAGE TANK
1.	TANK DIA.(D)XHEIGHT(H), MTRS.	14.0x9.7
2.	LIQUID STORED LDO	13.7
3.	FOUNDATION ID, MTRS.	TO BE DECIDED BY CIVIL AS PER DESIGN
4.	FOUNDATION OD, MTRS.	50
5.	EMPTY WT. OF TANK , TONNES	1550 TONNES
6.	MAX. WATER FILLED WT OF TANK	



NOTES:-
 1) ALL ELEVATIONS MARKED ARE W.R.T. FINISHED GRADE LEVEL OF FOPH-III, WHICH CORRESPONDS TO MSL 280.5M



WATER DRAW-OFF SUMP
 (AS PER API 650, FIG. NO 3-18)

REFERENCE DWG. :-
 1) GENERAL LAYOUT PLAN 2260-999-P0C-F-001
 2) WRITE UP FOR FUEL OIL UNLOADING & STORAGE SYSTEM 2260-101-01-PE-PWM-W-002
 3) PIPING LAYOUT OF FUEL OIL SYSTEM (STAGE-III) 2240-108-09PE-PWM-F-050

DATE: 04.05.14	BY: HK	CHK: HK	DESC: DRAW OFF SUMP AND STAIRCASE DETAILS SHOWN AS COMMENTED BY NTPC
DATE: 21.03.14	BY: SS	CHK: SS	DESC: DOCUMENT REVIEWED AS PER NTPC DOC COMMENTS ON INDIVIDUAL SKETCH
DATE: 07.02.14	BY: JRD	CHK: JRD	DESC: DESIGN
PROJECT:- 1X500MW VINDHYACHAL STPS (STAGE-V)			
CUSTOMER:- NTPC LIMITED			
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: TITLE
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: FOUNDATION DRAWING OF LDO STORAGE TANK
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 002
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 001
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 003
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 004
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 005
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 006
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 007
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 008
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 009
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 010
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 011
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 012
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 013
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 014
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 015
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 016
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 017
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 018
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 019
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 020
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 021
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 022
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 023
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 024
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 025
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 026
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 027
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 028
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 029
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 030
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 031
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 032
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 033
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 034
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 035
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 036
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 037
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 038
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 039
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 040
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 041
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 042
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 043
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 044
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 045
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 046
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 047
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 048
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 049
DATE: 07-02-14	BY: JRD	CHK: JRD	DESC: SHEET NO. 050

PLAN ORIENTATION OF LDO TANK DYKE

**COORDINATES OF LDO STORAGE TANK IS TAKEN FROM SKETCH RECEIVED FROM NTPC VINDHYACHAL. SITE AND SAME IS SUBJECT TO NTPC CONCURRENCE
 *DETAILS OF PIPE SUPPORT PEDESTALS SHALL BE PROVIDED AFTER FINALIZATION OF PIPING LAYOUT.

Location of stair, Draw off sump details and other civil inputs shall be remain firm during Detailed Engineering Stage also.

NTPC LTD.

1X500MW VINDHAYACHAL STPP, STAGE- V

**TECHNICAL SPECIFICATION
FOR
FUEL OIL UNLOADING & STORAGE SYSTEM
SPECIFICATION NO. : PE-TS-389-166-A001
UNPRICED PRICE SCHEDULE**



**BHARAT HEAVY ELECTRICALS LTD
POWER SECTOR PROJECT ENGINEERING MANAGEMENT
PPEI, NOIDA, INDIA**

1X500MW VINDHAYACHAL STPP, STAGE-V - FUEL OIL UNLOADING & STORAGE SYSTEM															
SUGGESTIVE PRICE FORMAT															
S.No	Details of Works or Equipment/System	Quantity	Unit	Unit Ex-works price	Total Ex works price	ED	CST /VAT	FREIGHT	E&C Charges	Any other service	Any other taxes /duties	TOTAL	(percentage value of Total Price Supply)	Remarks	
1	2	3	4	5	6	7	8	9	10	11	12	5 to 12	13	14	15
1.1.0	Lumpsum prices														
1.1.1	Lumpsum firm price for design, engineering, manufacturing, inspection and testing at vendor's / sub-vendor's works, painting, forwarding, proper packing, shipment and delivery at project site, including freight, unloading, storage, handling and transportation at site, erection and commissioning, minor civil work as required and handing over to the customer in line with drawings / documents / test procedures to be approved by Customer / consultant, inclusive of all prevailing taxes, duties and other levies for Fuel Oil Unloading & Storage System with all accessories including electricals, control & instrumentation, start up & commissioning spares, mandatory spares as required for the total scope defined as per technical specification PE-TS-389-166-A001.	1	Lot												
1.2.0	Break - up of Prices given at 1.1.1 above.														
1.2.0.1	Lumpsum firm price for LDO Storage tank with all accessories	1	Lot										62-65% of the Total Ex-Works Supply price	70% of the Total quated package(excluding mandatory spares but including all taxes and freight)	
1.2.0.2	Lumpsum firm price for pipes & fittings	1	Lot										15-17% of the Total Ex-Works Supply price		
1.2.0.3	Lumpsum firm price for Valves	1	Lot										9-11% of the Total Ex-Works Supply price		
1.2.0.4	Lumpsum firm price for Instruments	1	Lot										1-2 % of the Total Ex-Works Supply price		
1.2.0.5	Lumpsum firm price for Paints	1	Lot												
1.2.0.6	Lump sum price of all flanges, counter flanges, nuts,boths, washers, structural steel to be used for pipe support etc.	1	Lot												
1.2.0.7	Lump sum price for facilitating approval from all statutory bodies.	1	Lot												
1.2.0.8	Lump sum price for minor civil and structural works	1	Lot												
1.2.0.9	Lump sum price for startup and commissioning spares	1	Lot												
1.2.0.10	Lump sum price for maintenance tools and tackles (bidder shall furnish list of tools and tackles in terms of numbers only in separate Annexure form).	1	Lot												
1.2.0.11	Lumpsum firm price of any other item not covered above but required for succesful completion of system in line with specification (Indicating NIL against this S.No. shall not absolve bidder of supplying necessary items to the satisfaction of the customer)	1	Lot												
1.3.0	Total of 1.2.0 (sum of 1.2.0.1 to 1.2.0.11)														
1.4.0	E&C Charges													30% of the Total quated package(excluding mandatory spares but including all taxes and freight)	
1.5.0	Lumpsum price for Mandatory Spare as per the technical specification(bidder to furnish unit rate for each and every item as applicable)	1	Lot										Actual Price		
1.6.0	Total of 1.3.0,1.4.0 & 1.5.0														
Notes:															
a)	Bidder to note that total price indicated above at 1.6.0 shall be considered for evaluation and hence should be complete in all respect for the full scope defined and considering all terms and conditions agreed including electrical and control & instrumentation. In case there is any mismatch between lumpsum and break up price , higher of the two will be considered for evaluation and order will be placed on lower price in case the bidder happens to be L1														
b)	Proportion of Quotion for supply and E&C is 70% and 30% respectively.Sum total of Cl. No. 1.2.0.1 upto 1.2.0.11 aill be 100% of Total main supply price.														
c)	Any item not included in the price quoted above and shown separately will not be taken cognizance of and the offer shall be liable for rejection.														
d)	Bidder shall furnish the price of all items as indicated in the price schedule. Bidder's offer shall liable to be rejected in case bidder does not furnish the same.														
e)	Bidders are requested to obtain clarifications in case of any doubt before filling the price schedule in the prebid clarification stage. It is requested not to make any assumption.														