

**BHARAT HEAVY ELECTRICALS LTD.
(TRANSMISSION BUSINESS GROUP)
GENERAL TERMS AND CONDITIONS FOR TENDER ENQUIRY**

This Format is to be submitted in original duly signed and stamped by bidder. Deviation, if any, is to be brought out clearly in Schedule of Commercial deviation giving clause wise deviation. Any condition / clarification / deviation mentioned elsewhere will not be accepted.

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
1.	<p>INSTRUCTION TO BIDDERS:</p> <p>a) Sealed quotations are invited for the items mentioned in the enquiry. Quotations should be typed and free from over writing and erasures. Corrections or additions must be clearly written both in words and figures and attested, otherwise offer shall be liable for rejection.</p> <p>b) The tenders are invited and evaluated online through e-Procurement System. The bidder shall submit his response through bid submission to the tender on e-Procurement platform at https://bheleps.buyjunction.in.</p> <p>Foreign and indigenous vendors participating through open tenders/limited tender (Through E-procurement system) will necessarily have to buy Class-III digital certificates (DSCs) issued by certifying agencies in India.</p> <p>Procedure of getting obtaining DCSs can be down loaded from <u>Important Links</u> on link http://www.bhel.com/tender/tender_home.php or may be obtain from concern executive through email request.</p> <p>Successful bidder shall be responsible for completion of the contract in all respects. Techno commercial offers shall be opened through the E-Procurement portal. However this tender may be finalized through online Reverse Auction. Bidders are request to quote their most competitive prices through the online e-procurement portal / system.</p> <p>In case of any difficulty in operating the E-Tendering System, please call up our developer's Help Desk m Junction Services Ltd. at 033-6601 1717 or BHEL representative. Please ensure the submission of your most competitive offer before the due date in the E-Tendering Portal to avoid last minute hustle.</p> <p>c) Bids are to be submitted in Two parts:</p> <ol style="list-style-type: none">i) Techno-commercial bid (Part-I): A copy of price bid (Part-II) "without prices" is also to be enclosed in Part-I bid.ii) Bidder to strictly ensure submitting the price bids in BHEL format.iii) Price bid (Part-II): To be submitted only in one copy separately. This should not contain any Technical or Commercial Terms. The rates should be quoted both in figures and words. In case of any difference between figures and words, the quoted rate in words shall prevail over figure. Further in case of difference between unit rate & total price, unit rate in words shall prevail over total price.

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
	<p>d) <u>For any Technical Clarification, please contact:</u> SHRI VIVEK KAPIL, Sr. MANAGER / TBEM BHARAT HEAVY ELECTRICALS LIMITED TRANSMISSION BUSINESS GROUP TOWER A, 5TH FLOOR, ADVANT NAVIS IT BUSINESS PARK, PLOT NO-7, SECTOR-142, EXPRESSWAY NOIDA, NOIDA-201305, DISTT- GAUTAM BUDH NAGAR, UP, INDIA Phone : 0120-06748539 / 9818080691 E-mail : vivekk@bhel.in</p> <p><u>For any Commercial Clarification, please contact:</u> SH. S.C. SHIVHARE, Sr. MGR.(TBMM) / SMT. ARCHANA KUMARI, Sr. ENGR. (TBMM) BHARAT HEAVY ELECTRICALS LIMITED TRANSMISSION BUSINESS GROUP TOWER A, 5TH FLOOR, ADVANT NAVIS IT BUSINESS PARK, PLOT NO-7, SECTOR-142, EXPRESSWAY NOIDA, NOIDA-201305, DISTT- GAUTAM BUDH NAGAR, UP, INDIA Phone : 0120-6748467 / 0120-6748471 Email: archanak@bhel.in / scshivhare@bhel.in</p> <p>e) Price bid should not contain any information / description / terms & condition other than given in Part-I of the bid except prices, otherwise bid is liable for rejection.</p> <p>f) Price bid submitted along with the bid shall remain valid up to validity of offer. Unsolicited Supplementary / Revised price bid submitted during validity period of offer, unless asked by BHEL, shall not be considered. With-drawl of quotation by the bidder, at any stage after its opening, may entail blacklisting of vendor.</p> <p>g) Authorized signatory should authenticate tender documents.</p>
2.	<p>PRICES:</p> <p><u>The Prices shall remain FIRM during contract period .</u></p> <p><u>Project Status:</u> This is a Mega Power Project where Deemed Export Benefits are available as per Foreign Trade Policy.</p> <p>However, vendor shall be solely responsible for obtaining deemed export benefits from the concerned authorities and in case of failure to receive such benefits, BHEL will not compensate them in any manner, whatsoever.</p> <p>CIF value of import content in the Ex-Work price is “NIL”. Custom Duties on import content are not applicable.</p> <p>A. The prices shall be quoted by the vendors considering following</p> <p>The prices are to be quoted on FOR (Destination) basis. The break-up of price shall be as under:-</p> <p>a) Ex-works Price: Ex- works price including packing & forwarding charges.</p>

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
	<p>b) Excise duty: ED exempted against PAC (Project Authority Certificate by NTPC and Mega Power Status Certificate issued by GOI).</p> <p>c) Sales Tax: ST / VAT / CST (against C-form) to be quoted as percentage in un-price and price bid. In case of interstate sale-in-transit supplier have to provide E1/E2 form.</p> <p>d) Entry tax / Octroi Charges: Any Entry tax / Octroi applicable at destination / destination state shall be paid extra on proof of such payment.</p> <p>e) Freight & Insurance: Freight and Transit Insurance for door delivery up to destination/store is to be quoted.</p> <p>f) Type Test charges: As per technical specification enclosed with this Enquiry.</p> <p>Note: i) The purchase order shall be placed on Ex – Works basis.</p> <p>“BHEL reserves the right to go for Reverse Auction (RA) instead of opening the sealed envelope price bid, submitted by the bidder. This will be decided after techno-commercial evaluation. All bidders to give their acceptance for participation in RA. Non-acceptance to participate in RA may result in non-consideration of their bids, in case BHEL decides to go for RA.</p> <p>In case BHEL decides to go for Reverse Auction, only those bidders who have given their acceptance to participate in RA will be allowed to participate in the Reverse Auction. Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit ‘online sealed bid’ in the Reverse Auction. Non-submission of ‘online sealed bid’ by the bidder will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.”</p> <p>(Further to above clause, please refer attached Annexure I for Terms & Conditions Of Reverse Auction Page 1 & 2)</p>
3.	<p><u>TERMS OF PAYMENT:</u></p> <p>100 % Payment with Taxes, Duties, Freight & Insurance within 60 days (45 Days for MSE vendor) from the date of receipt of complete invoice with following documents in 3 sets (Original + 2 copies):</p> <ul style="list-style-type: none"> - LR duly endorsed in the name of customer by BHEL site - Receipt of material on the attached format by BHEL site - Excise invoice (If Applicable) - Delivery Challan or Packing list (case wise) - Transit insurance certificate from under writers or Copy of Intimation of Transit Insurance duly endorsed by under writers - MICC - Guarantee Certificate - Copy of Performance Bank Guarantee. <p>[A.] Documents to be furnished by vendor immediately after dispatch:</p> <ul style="list-style-type: none"> - Copy of Invoice - Copy of LR - Copy of Delivery Challan / Packing List - Copy of Insurance Certificate - Copy of Guarantee Certificate

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
	<p>[B.] Following Documents to be sent by vendor to TBG, BHEL :</p> <ul style="list-style-type: none"> - LR duly endorsed in the name of customer by BHEL site - Receipt of material on the attached format by BHEL site - Excise invoice (If Applicable) - Delivery Challan / Packing list (case wise) - Transit insurance certificate from under writers or Copy of Intimation of Transit Insurance duly endorsed by under writers - Dispatch Clearance / MICC - Guarantee certificate - All Test & Inspection Reports
4.	<p>INTEREST LIABILITY: In case of any delay in payment due to any reason, BHEL shall not pay any interest on delayed payment.</p>
5.	<p>GUARANTEE : The equipment / material shall be guaranteed for 18 months from the date of delivery or 12 months from the date of commissioning, whichever is earlier. The defective material / component shall be replaced free of cost at site.</p>
6.	<p>PERFORMANCE BANK GUARANTEE: Bidder shall furnish along with first invoice Performance BG / deposit as per follows.</p> <p><u>Option A</u> BG for 10% of the total Ex-works PO value, valid for 18 months + 3 months claim period (i. e. Total 21 months) from the date of last delivery.</p> <p><u>Option B</u> Retention of 10% of the total Ex-works PO value by BHEL from the first bill in lieu of Performance Bank Guarantee, to be released after expiry of 24 months from the date of first delivery.</p> <p>The Bank guarantee shall be from State Bank of India / State bank of Hyderabad / State Bank of Travancore / State Bank of Mysore / Canara Bank / Bank of Baroda / Punjab National Bank / Deutsche Bank / HDFC Bank / Standard Chartered Bank / CITI Bank / ICICI Bank / IDBI Bank / HSBC / any other Nationalised Bank. The original BG should be sent by issuing Bank directly to AGM (Finance), TBG, BHEL.</p> <p>All the bank Guarantee shall be from a schedule bank In India acceptable to BHEL. The original BG should be sent by issuing bank directly to AGM (Finance) TBG BHEL. BANK Guarantee should be valid for lodging claim within two month after expiry of guarantee period.</p> <p>If no option is specified, by default option – A shall be considered for confirmation.</p>
7.	<p>FINAL ENGINEERING DOCUMENTATION: Final documentation as called in the specification is to be submitted within 3 months from the date of despatch of material. In case of default, the Performance BG is liable to be en-cashed.</p>
8.	<p>INSPECTION: BHEL and / or customer / third party may inspect the Equipment / Material before despatch. In the event BHEL / Customer waives off inspection, Test Reports and Results shall be submitted for Approval. Supplier shall obtain Approval on Test Reports and MDCC / MICC (Material Inspection Clearance Certificate)</p>

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
	before dispatch of equipment. Stage inspection during manufacturing may also be carried out. Material to be dispatched only after getting Dispatch Clearance from BHEL. Supplier shall send inspection call on prescribed format only, with an advance notice of 15 days. (New Format of Inspection Call attached with this Enquiry).
9.	DESPATCH DOCUMENTS: Following despatch documents are to be immediately sent to purchaser on despatch. - Copy of Invoice - Copy of LR - Copy of Delivery Challan / Packing List - Copy of Insurance Certificate - Copy of Guarantee Certificate
10.	DELIVERY PERIOD: Bidder to specify the delivery period in weeks from the date of PO in the Activity Schedule Format enclosed with enquiry. Time for conduction of type test, if required, is to be separately indicated. Note: LR date or Invoice date whichever is later shall be considered as delivery date.
11.	DELAYED DELIVERY: In case of delay in execution of order beyond the lot wise contractual delivery, an amount of ½ % of total Ex-Works Value per week or part there-of subject to maximum of 10% of total Ex-Works value of P.O. will be levied.
12.	VALIDITY: The offer shall be valid for 120 days from the due date of opening.
13.	ACCEPTANCE / REJECTION OF TENDER: BHEL reserves the right to reject in full or part, any or all tender without assigning any reason thereof. BHEL also reserves right to vary the quantities mentioned in the tender.
14.	EVALUATION: Comparative statement shall be prepared based on overall quantity basis unless otherwise indicated in the enquiry. Evaluation of offers shall be done on the basis of delivered cost to BHEL.
15.	DEVIATION: The bids having deviation(s) w.r.to tender are liable for rejection. However, BHEL, at its discretion, may load the prices for evaluation of offer as mentioned at Sl. No. - 24.
16.	ARBITRATION: All cases of disputes emanating from and relating to this contract shall be referred to the sole arbitrator appointed by Unit Head / GM, BHEL. The arbitrator may be an employee of BHEL whether serving or retired or any other person nominated by Unit Head/GM BHEL. The arbitration shall be in accordance with 'The Arbitration and Conciliation Act 1996' and the rules there under as amended from time to time. The arbitrator shall give a reasoned award. The decision of the arbitrator shall be final &

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
	binding upon both the parties. The venue of arbitration shall be Delhi.
17.	<u>LEGAL SETTLEMENT:</u> All disputes shall be subject to jurisdiction of court situated in Delhi/New Delhi only. Notwithstanding contained herein anything in this NIT, the original exclusive jurisdiction shall remain of the court at Delhi / New Delhi.
18.	<u>SUBCONTRACTING:</u> In case further subcontracting of BHEL order or part thereof is envisaged by supplier, the same can be done after written permission is obtained from BHEL. However it shall not absolve the supplier of the responsibility of fulfilling BHEL purchase order requirements.
19.	<u>RISK PURCHASE:</u> In case the successful bidder fails to supply or fails to comply with the terms & conditions of the purchase order, BHEL reserves the right to source such material/ component / equipment/ system from any other agency at the risk and cost of the successful bidder.
20.	<u>ADJUSTMENT OF RECOVERY:</u> Any amount payable by the supplier under any of the condition of this contract shall be liable to be adjusted against any amount payable to the supplier under any other works/contract awarded to him by any BHEL unit. This is without prejudice to any other action as may be deemed fit by BHEL.
21.	<u>FORCE MAJEURE CONDITION:</u> Force Majeure will mean: Circumstances beyond the control of contracting parties such as but not limited to act of God, natural catastrophes, fire, war, embargo, industrial dispute, riot, civil commotion, restrictions etc. Vendors willing to plead force majeure shall inform its effect on fulfilment of contract and shall not be held responsible for non performance in such circumstances.
22.	<u>DEMURRAGE / WHARFAGE:</u> For the reasons of delay in receipt of documents from suppliers or due to the same being found to be incomplete, and/or faulty, the suppliers shall be responsible to reimburse in all demurrages / wharfages, if any, paid by BHEL (for stated reasons).
23.	<u>SPECIAL CONDITION:</u> Procurement will be from manufacturers only. Manufacturers should submit offers directly. However in case of involvement of any representative the details of the same along with the copy of the agreement should be submitted in the first part of the offer. Principal manufactures must ensure that the nominated representative do not represent any other manufacture for the same item.
24.	LOADING CRITERIA FOR DEVIATIONS TAKEN BY BIDDER ON: 24.1 : TERMS OF PAYMENT:

Sr. No	ENQUIRY NO. 225E185 DATED 22/09/2015 DUE ON 16/10/2015
	<p>If a bidder asks for payment within specified no. of days from the date of receipt of invoice with complete documents as per "Terms of Payment" at sr. No. 3 above, loading to be done as follows:</p> <p>a) Base rate of SBI (as applicable on the date of techno commercial bid opening) + 6 % shall be considered for loading for the period of relaxation sought by the bidder.</p> <p>b) 60 days - No loading</p> <p>24.2 : <u>DELAYED DELIVERY / PENALTY DUE TO DELAYED DELIVERY:</u> Loading for not accepting this clause / accepting only on un delivered portion shall be the maximum amount specified in this clause.</p>
25.	<p>"MSE suppliers can avail the intended benefits only if they submit along with the offer, attested copies of either EM II certificate having deemed validity (five years from the date of issue of acknowledgement in EM II) or valid NSIC certificate or EM II certificate along with attested copy of a CA certificate (Format enclosed at Annexure -1 where deemed validity of EM II certificate of five years has expired) applicable for the relevant financial year (latest audited). Date to be reckoned for determining the deemed validity will be the date of bid opening (Part 1 in case of two part bid). Non submission of such documents will lead to consideration of their bid at par with other bidders. No benefit shall be applicable for this enquiry if any deficiency in the above required documents are not submitted before price bid opening. If the tender is to be submitted through e-procurement portal, then the above required documents are to be uploaded on the portal. Documents should be notarized or attested by a Gazetted officer. "</p>
26.	<p>"The Bidder along with its associate/ collaborators/ sub-contractors/ sub-vendors/ consultants/ service providers shall strictly adhere to BHEL Fraud Prevention Policy displayed on BHEL website http://www.bhel.com and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice."</p>
27.	<p><u>Pre Qualification Criteria</u> : - AS PER TECHNICAL SPECIFICATION.</p> <p>Only NTPC approved vendors are applicable.</p> <p>However, this being an Open Tender Enquiry, so vendor beyond the approved vendor list of NTPC should be approved in NTPC or associated with any NTPC projects. Vendor should submit the complete credentials (hard copy) along with supporting documents of NTPC approval letter or documentary evidence of associated works done in NTPC for further submission to NTPC for their approval.</p>
28.	<p>Offer of techno – commercially acceptable vendors shall be considered for Price Bid Opening / RA subject to their approval from Customer.</p>

Signature of Bidder
Seal

Terms & Conditions of Reverse Auction

Against this enquiry for the subject item/ system with detailed scope of supply as per enquiry specifications, BHEL may resort to “REVERSE AUCTION PROCEDURE” i.e., ON LINE BIDDING (THROUGH A SERVICE PROVIDER). The philosophy followed for reverse auction shall be English Reverse (No ties).

1. For the proposed reverse auction, technically and commercially acceptable bidders only shall be eligible to participate.
2. Those bidders who have given their acceptance for Reverse Auction (quoted against this tender enquiry) will have to necessarily submit ‘online sealed bid’ in the Reverse Auction. Non-submission of ‘online sealed bid’ by the bidder for any of the eligible items for which techno-commercially qualified, will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.
3. BHEL will engage the services of a service provider who will provide all necessary training and assistance before commencement of on line bidding on internet.
4. In case of reverse auction, BHEL will inform the bidders the details of Service Provider to enable them to contact & get trained.
5. Business rules like event date, time, bid decrement, extension etc. also will be communicated through service provider for compliance.
6. Bidders have to fax the Compliance form (annexure IV) before start of Reverse auction. Without this, the bidder will not be eligible to participate in the event.
7. In line with the NIT terms, BHEL will provide the calculation sheet (e.g., EXCEL sheet) which will help to arrive at “Total Cost to BHEL” like Packing & forwarding charges, Taxes and Duties, Freight charges, Insurance, Service Tax for Services and loading factors (for non-compliance to BHEL standard Commercial terms & conditions) for each of the bidder to enable them to fill-in the price and keep it ready for keying in during the Auction.
8. Reverse auction will be conducted on scheduled date & time.
9. At the end of Reverse Auction event, the lowest bidder value will be known on auction portal.

10. The lowest bidder has to fax/e-mail the duly signed and filled-in prescribed format for price breakup including that of line items, if required, (Annexure VII) as provided on case-to-case basis to Service provider within two working days of Auction without fail.
11. In case BHEL decides not to go for Reverse Auction procedure for this tender enquiry, the Price bids and price impacts, if any, already submitted and available with BHEL shall be opened as per BHEL's standard practice.
12. Bidders shall be required to read the "Terms and Conditions" section of the auctions site of Service provider, using the Login IDs and passwords given to them by the service provider before reverse auction event. Bidders should acquaint themselves of the 'Business Rules of Reverse Auction', which will be communicated before the Reverse Auction.
13. If the Bidder or any of his representatives are found to be involved in Price manipulation/ cartel formation of any kind, directly or indirectly by communicating with other bidders, action *as per extant BHEL guidelines*, shall be initiated by BHEL and the results of the RA scrapped/ aborted.
14. The Bidder shall not divulge either his Bids or any other exclusive details of BHEL to any other party.
15. In case BHEL decides to go for reverse auction, the H1 bidder (whose quote is highest in online sealed bid) may not be allowed to participate in further RA process.

SCHEDULE OF PRICE

(BIDDERS TO STRICTLY ENSURE SUBMITTING THE PRICE BIDS IN THIS FORMAT)

NOTE: THIS FORMAT IS TO BE SUBMITTED IN ORIGINAL ONLY, DULY FILLED IN. REPRODUCTION OF THIS FORMAT ON BIDDER'S LETTER HEAD OR ON OTHER PAPER IS NOT ACCEPTABLE.

TENDER ENQUIRY NO. : 225E185 DATED 22/09/2015

SL. NO.	DESCRIPTION OF ITEM	UNIT	QTY.	UNIT PRICE	TOTAL	UNIT	TOTAL	ED	CST / ST	TOTAL F.O.R.
				EX. WORKS (Rs.)	EX. WORKS (Rs.) (5 * 4)	FREIGHT & INSURANCE (Rs.)	Freight & insurance (Inclusive of Service Tax, if any) (Rs.) (7 * 4)			
1	2	3	4	5	6	7	8	9	10	11
1	2C x 2.5 sq mm PVC/Copper, Armoured Control cable	kM	19					ED exempted against PAC (Project Authority Certificate by NTPC and Mega Power Status Certificate issued by GOI. Project with Deemed Export Benefits as per Foreign Trade Policy		
2	5C x 2.5 sq mm PVC/Copper, Armoured Control cable	kM	68							
3	10C x 2.5 sq mm PVC/Copper, Armoured Control cable	kM	89.5							
4	14C x 2.5 sq mm PVC/Copper, Armoured Control cable	kM	10.5							
5	19C x 2.5 sq mm PVC/Copper, Armoured Control cable	kM	26.5							
6	4C x 10 sq mm PVC/Copper, Armoured Control cable	kM	11.5							
7	2C x 6 sq mm PVC/Aluminium, Armoured Aux. Power cable	kM	7							
8	4C x 6 sq mm PVC/Aluminium, Armoured Aux. Power cable	kM	10.5							
9	4C x 16 sq mm PVC/Aluminium, Armoured Aux. Power cable	kM	26.5							
10	3.5C x 70 sq mm PVC/Aluminium, Armoured Aux. Power cable	kM	38							
11	3.5C x 150 sq mm XLPE/Aluminium, Armoured Aux. Power cable	kM	0.5							
12	3.5C x 300 sq mm XLPE/Aluminium, Armoured Aux. Power cable	kM	1							
13	2C x 150 sq mm XLPE/Aluminium, Armoured Aux. Power cable	kM	0.5							
14	1C x 630 sq mm XLPE/Aluminium, Armoured Aux. Power cable	kM	12							
	TOTAL PRICE									

NOTE: 1. PLEASE NOTE THAT UNPRICED COPY OF PRICE BID (i.e. WITH ALL PRICES BLANKED) SHALL BE FURNISHED ALONG WITH TECHNO-COMMERCIAL BID.
 2. REQUIRED COPIES OF FORMAT BE MADE & DETAILS MAY BE ANNEXED.
 3. THE PRICES MUST BE QUOTED IN THE PRESCRIBED UNIT ONLY.
 4. SALES TAX RATE AS APPLICABLE FOR SPECIFIED DESTINATION SHALL BE QUOTED. IN CASE OF CST, RATE AGAINST 'C' FORM SHALL BE QUOTED.
 5. IN CASE OF VARIED ED SLAB RATES. CONFIRM YOUR OPTION FOR 'X' OR 'Y'. (STRIKE OFF WHICH IS NOT APPLICABLE)
 IF NO OPTION IS MENTIONED 'X' SHALL BE TAKEN.

6. THE VENDORS MUST INDICATE THE APPLICABLE TARIFF NOS. UNDER WHICH ED AND / OR CST WOULD BE PAID BY THEM TO THE TAX AUTHORITIES.
 7. IF A VENDOR SUBMITS AN OFFER WITH REDUCED ED AND OR CST APPLICABLE THAN NORMALLY PAID ON SUCH ITEMS. THEY SHOULD SUBMIT NECESSARY DOCUMENTARY PROOF FOR THE SAME.
 X THE MAXIMUM ED SLAB RATE BE CONSIDERED FOR PRICE COMPARISON. IN THE EVENT OF ORDER ED AT ACTUAL BE PAID.
 Y THE QUOTED ED RATE BE CONSIDERED FOR PRICE COMPARISON. IN THE EVENT OF ORDER ED AT ACTUAL RATE LIMITED TO QUOTED RATE BE PAID.

SIGNATURE & SEAL OF TENDERER

TRANSMISSION BUSSINESS GROUP
MATERIAL MANGEMENT
BHEL, NOIDA

ACTIVITY SCHEDULE

Please submit this format duly filled in along with offer. Time indicated will be used for calculating contractual delivery period.

ENQUIRY NO. 225E185

Dated: 22/09/2015

PROJECT: NTPC NORTH KARANPURA

ITEM: LT POWER AND CONTROL CABLES

VENDOR :

OFFER REF.

SL. NO.	ACTIVITY	ACTIVITY TIME IN WEEKS	REMARKS IF ANY
1.	Receipt of P.O		
2.	P.O Acceptance	ONE WEEK	Vendor must Submit Po acceptance with in one week
3.	Submission of documents necessary for getting manufacturing clearance like Drawings, data sheet etc.		Documents complete in all respect are to be Submitted. Delay in approval on account of incomplete / inadequate information shall be the responsibility of supplier
4.	Review and Approval of documents and issue of manufacturing clearance	BHEL ACTIVITY	Vendor must ensure to reply all queries expeditiously.
5.	Manufacturing Time		Manufacturing time be indicated considering all constrains & must include time required for internal inspections etc.
6	Raise inspection call	-VE 2 WEEKS TO SL NO 5	Call for inspection must be raised at least two weeks in advance in the prescribed format. Non availability of offered material for inspection to the inspector will be viewed very seriously & may result in financial implications. The date of inspection must be with in the period indicated in 5 above.
7	Inspection	BHEL	
8	Issue of MICC, MDCC & other documents like EDEC , Road permits etc	BHEL	Vendor must indicate requirement well in advance.
9	Dispatch	ONE WEEK	Vendor must ensure to dispatch with in one Week of receiving all documents required

Total time in vendor's scope:

Please mention constraints if any. For multiple lot delivery activity landmark for each lot should be mentioned. Multiple inspection calls for one lot are to be avoided & delay on this account shall be vendor's responsibility. Vendors to quote their Best Delivery Plan.

SIGNATURE AND SEAL

SCHEDULE OF COMMERCIAL DEVIATION

The following are the deviations / variations exception from the General Terms and Conditions:-

SL. NO.	CLAUSE NO. OF GENERAL TERMS & CONDITIONS	STATEMENT OF DEVIATION

Incase, this schedule is not submitted, it will be presumed that the equipment / material to be supplied under this contract is deemed to be in compliance with the General terms and Conditions.

If there is NIL deviation, even then the format to be filled as NIL DEVIATION.

NOTE: Continuation sheets of like size and format may be used as per the Bidder's requirement and shall be annexed to this schedule.

Place

Signature of the authorized representative of

Date

Bidder's Name

Designation

Company seal

SCHEDULE OF TECHNICAL DEVIATION

The following are the deviations / variations exception from the Technical Specifications:-

SL. NO.	CLAUSE NO. OF TECHNICAL SPECIFICATIONS	STATEMENT OF DEVIATION

Incase, this schedule is not submitted, it will be presumed that the equipment / material to be supplied under this contract is deemed to be in compliance with the Technical Specifications.

If there is NIL deviation, even then the format to be filled as NIL DEVIATION.

NOTE: Continuation sheets of like size and format may be used as per the Bidder's requirement and shall be annexed to this schedule.

Place

Signature of the authorized representative of

Date

Bidder's Name

Designation

Company seal

CHECKLIST**SCHEDULE OF INFORMATION TO BE FURNISHED WITH THE OFFER**

NOTE: This format is to be submitted in original only, duly filled in. Reproduction of this format on bidder's letter head or on other paper is not acceptable.

Put a tick mark on "YES" if the information is enclosed with the offer or put a tick mark on "NO" if the information is not enclosed or write "NOT APPLICABLE" if the information is not applicable.

1.	Technical offer with detailed schedule of equipment / material and spares enclosed.	YES / NO
2.	Guaranteed Technical Particulars as per Section – 4 enclosed.	YES / NO
3.	Schedule of deviation, if any, clause wise with respect to Technical Specification enclosed.	YES / NO
4.	Standard Manufacturing Quality Plan enclosed.	YES / NO
5.	GA Drawings with dimensions and weights & foundation / fixing details enclosed.	YES / NO
6.	Drawing and Data submission schedule enclosed.	YES / NO
7.	Type Test Reports enclosed.	YES / NO
8.	Bar Chart showing the schedule indicating time required for design, manufacture, test and inspection, transport, erection, site testing and commissioning enclosed.	YES / NO
9.	Makes of all components as per technical Specification enclosed.	YES / NO
10.	Schedule of commercial deviation exception from the General Terms and Conditions	YES / NO

The above checklist is verified for:-

Offer Ref. :
 Equipment :
 Submitted by : M/s
 Project Reference. :

Signed with Seal

Date



**BHARAT HEAVY ELECTRICALS LIMITED
TRANSMISSION BUSINESS GROUP
MATERIAL RECEIPT CERTIFICATE**

- a) Site:
- b) LR No. with date:
- c) Vehicle no.:
- d) Date of receipt of material at site:
- e) Material details (as mentioned below):

S.no.	Item Description	Type of Packages	Unit (MT/KM/NO.)	Qty as per packing list	Qty Received	Remarks

Other Remarks:

Signature with date: _____

Name & Designation: _____

(With Seal)

(Previous Format)



**BHARAT HEAVY ELECTRICALS LIMITED
TRANSMISSION BUSINESS GROUP
MATERIAL RECEIPT CERTIFICATE**

Date: _____

- ~~a)~~ Site Name :
- b) Site Address:
- ~~c)~~ PO no. with date:
- ~~d)~~ Supplier Name:
- ~~e)~~ Invoice no. with date:
- f) LR No with date:
- ~~g)~~ Transporter Name:
- h) Vehicle no.:
- i) Date of receipt of material at site:
- j) Destination: From ----- To -----
- k) Material details (as mentioned below):

S.no.	Item Description	Type of Packages	Unit (MT/KM/NO.)	Qty as per packing list	Qty Received	Qty Accepted	Remarks

Other Remarks:

Signature with date: _____

Name & Designation: _____

(With Seal)

Certificate by Chartered Accountant on letter head

This is to Certify that M/S
(hereinafter referred to as 'company') having its registered office at
..... is registered under MSMED Act 2006, (Entrepreneur
Memorandum No (Part-II) dtd:.....,
Category: (Micro/Small)). (Copy enclosed).

Further verified from the Books of Accounts that the investment of the company as per the latest audited financial year as per MSMED Act 2006 is as follows:

1. **For Manufacturing Enterprises:** Investment in plant and machinery (i.e. original cost excluding land and building and the items specified by the Ministry of Small Scale Industries vide its notification No.S.O.1722(E) dated October 5, 2006 :
Rs.....Lacs
2. **For Service Enterprises:** Investment in equipment (original cost excluding land and building and furniture, fittings and other items not directly related to the service rendered or as may be notified under the MSMED Act, 2006:
Rs.....Lacs

(Strike off whichever is not applicable)

The above investment of Rs.....Lacs is within permissible limit of Rs.....Lacs forMicro / Small (Strike off which is not applicable) Category under MSMED Act 2006.

Or

The company has been graduated from its original category (Micro/ Small) (Strike off which is not applicable) and the date of graduation of such enterprise from its original category is (dd/mm/yyyy) which is within the period of 3 years from the date of graduation of such enterprise from its original category as notified vide S.O. No. 3322(E) dated 01.11.2013 published in the gazette notification dated 04.11.2013 by Ministry of MSME.

Date:



(Signature)

Name -

Membership number -

Seal of Chartered Accountant

(ON RS.100/- NON - JUDICIAL STAMP PAPER)

PROFORMA FOR SECURITY-CUM-PERFORMANCE GUARANTEE

1. This deed of Guarantee made this _____ day of _____ 200 ____ by _____ Bank Ltd., _____ in favour of **Bharat Heavy Electricals Limited, Transmission Business Group, Tower-A, 5th Floor, Advant Navis IT Business Park, Plot-7, Sector-142, Expressway Noida, Noida-201305** having their registered office at **BHEL House, Siri Fort, New Delhi - 110 049.**
2. Whereas **M/s** _____ (here in after called the **Contractor / Seller**) have entered into a Contract bearing No. _____ dated _____ (herein after called the **Contract**) for supply / erection of **M/s Bharat Heavy Electricals Limited** (hereinafter called the **Company**).
3. And whereas the said Contract Inter-alia provides that the Contractor / Seller shall pay to the company a sum of Rs. _____ only, towards **Security deposit-Cum-Performance Guarantee** in the for and manner therein specified.
4. And whereas the Seller/Contractor have approached _____ Bank Limited (hereinafter referred to as the **Guarantor**) and at their request and in consideration of the arrangement arrived at between the **Contractor** and the **Guarantor**, the Guarantor has agreed to give the Guarantee as herein after mentioned in favour of the Company.

NOW THIS DEED WITNESSES AS FOLLOWS :

5. The Guarantor by the hand of Mr. _____ and its lawfully and fully constituted attorney and do hereby guarantee the due and faithful performance of the said contract and do hereby irrevocably undertake and promise to pay the Company without any demur merely on demand made by them a sum not exceeding Rs. _____ only in case the Company sustains any loss or damage by reason of any breach, default, by the Contractor / Seller of any of the terms conditions, stipulations or undertakings or any one of them contained in the said contract and the tender documents attached hereto and for payment of any moneys payable by the Contractor/ Seller to the Company under the terms and conditions of the said contract. The decision of the company regarding the breach, default, loss, damage or payment shall be conclusive and binding in the guarantor irrespective of the fact whether the contractor/seller admits or denies such claims or questions its correctness in any court, tribunal or arbitration proceedings or before any other authority.

(Contd....2.)

6. The company shall have the fullest liberty without effecting in any way the liability of the Guarantor under this Guarantee, from time to time to vary any of the terms and conditions of the contract or extend time by the Seller/Contractor or to postpone for any time and from time to time any of the powers exercisable by its against the Seller/Contractor and either to enforce or forbear from enforcing any of terms and conditions governing the contract or securities available to the Company and the guarantor shall not be released from it's liability under these presents by any exercise by the company of the liberty with reference to the matters aforesaid or by reason of time being given to the seller or any other forbearance, act or omission on the part of the company or any induigence by the company to the Seller/Contractor or of any other matter or thing whatsoever which under the law relating to sureties, would but for this provision have the effect of so releasing the Guarantor/contractor from its liability under this Guarantee.
7. This Guarantee shall remain in full force and effect and the Guarantor shall be liable under the same irrespective of any concession or time being granted by the company to the contractor in or for fulfilling the said contract and this Guarantee shall remain in full force irrespective of any change in terms, conditions, stipulations or any variations in the terms of contract irrespective of whether notice of such change and / or variation is given to the Guarantor or not and the claim to receive such notice of any change and or variation of the terms/or conditions of the contract is hereby specifically waived by the Guarantor.
8. The Guarantor here in contained shall not be determined prejudiced or effected by the liquidation or winding up or insolvency of or change in the constitution of the contractor but shall in all respects and for all purposes be binding and operative until all payments or all moneys due or that may hereafter become payable to the company are paid in respect of any liability or obligation of the contractor under the contract.
9. The Guarantor further agree that the Guarantee herein contained shall remain in full force and effect during the period that would be taken for the commencement of the contract till end of the contract and its claim satisfied or discharged and till the company certified that the terms and conditions of the contract have been fully and properly carried out by the seller and accordingly discharges this Guarantee, subject, however, that the company shall have no claim under this guarantee after _____ months from the date of completion of the guarantee has been served on the guarantor before the expiry of the said period in which case the same shall be enforceable against the Guarantor not with standing the fact that the same is enforced after expiry of said period.

The Guarantor undertake not to revoke this Guarantee during the period it is in force except with the previous consent of the company in writing and agree that any liquidation or winding up or insolvency or dissolution or any change in the constitution of the Seller or the guarantor shall not discharge the Guarantor's liability here under.

(3)

It shall not be necessary for the company to proceed against the seller before proceeding against the Guarantor and the Guarantee herein contained shall be enforceable against them not with standing any security which the company may have obtained or obtained from the seller shall at the time when proceedings are taken against the Guarantor here under be outstanding or unrealised.

The Guarantor hereby declares that it has power to execute this Guarantee and the executant has full powers to do so on its behalf under the power of attorney dated _____granted to him by the proper authorities of the Guarantor.

- 10. Not withstanding anything here in before contained, our liability under this Guarantee is restricted to Rs. _____(Rs. _____only) and will expire on _____ and unless a claim in writing is presented to us or an action or suit to enforce the claim is filed against us, within **three months** from the date, all our rights shall be forfeited and we shall be relieved and discharged from all our liabilities there under.

IN WITNESS whereof the _____(Bank) have hereunto set and subscribed their hands the day, month and year first above written.

**SIGNED FOR AND ON
BEHALF OF THE BANK**

WITNESSESS

Name and Address

Signature

1.

2.



BHARAT HEAVY ELECTRICALS LIMITED

TRANSMISSION BUSINESS ENGINEERING MANAGEMENT

DOCUMENT No.	TB 369 510 011	Rev 00	Prepared	Checked	Approved
TYPE OF DOC.	TECHNICAL SPECIFICATION	NAME	MLK	VK	RS
TITLE 1.1 kV Aux Power & Control Cables		SIGN	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
		DATE	11/09/15	11/8	11/8
		GROUP	TBEM	W.O. No	83011
CUSTOMER	NTPC Ltd.				
CONSULTANT	---				
PROJECT	400/220 KV SWITCHYARD PACKAGE AT NORTH KARANPURA SUPER THERMAL POWER PROJECT (3 X 660 MW)				

COPYRIGHT & CONFIDENTIAL
The information in this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. This must not be used directly or indirectly in any way detrimental to the interest of the Company.

<u>CONTENTS</u>		
Sec. No.	Description	No. of Sheets
1.	Scope, Specific Technical Requirement and Quantities	16
2.	Equipment Specification	05
3.	Project Details & General Technical Requirements	24
4.	Guaranteed Technical Particulars (To be furnished at Contract Stage)	19
5.	Checklist (To be furnished at Tender Stage)	04

--	--	--	--

Rev No.	Date	Altered	Checked	Approved	REVISION DETAILS				
Distribution			To		TBTS	O/C	TBMM	TBQM	TBCM
			Copies		-	1	-	-	1

Project: 400/220 kV Switchyard Package at **Bharat Heavy Electricals Limited**
North Karanpura Super Thermal Power Project (3 X 660 MW) Document No. TB 369 510 011
Customer: NTPC Ltd.
Technical Specification: 1.1 kV Aux Power & Control Cables

SECTION 1

SCOPE, SPECIFIC TECHNICAL REQUIREMENTS AND QUANTITIES

1.0 SCOPE

This Specification covers the requirements of design, manufacture, testing at manufacturer's Works, packing, supply, delivery at site of 1.1 kV Aux Power & Control Cables as listed under this specification. This section covers the specific technical requirements of 1.1 kV Aux Power & Control Cables. This constitutes minimum technical parameters for the above item as specified by the customer (NTPC). The offered equipment shall also comply with the General Specification for the project as detailed under section-3 of this specification.

In case of any conflict between the technical details mentioned in this section and the remaining sections of this document, then Section-1 shall prevail and is to be considered as binding requirement.

The specification comprise of following sections:

- Section-1: Scope, Specific Technical Requirements and Quantities.
- Section-2: Equipment Specification.
- Section-3: Project Details and General Technical Requirements.
- Section-4: Guaranteed Technical Particulars.
- Section-5: Checklist.

Note: The term 'Owner' appearing in this specification shall refer to NTPC, the term 'Purchaser' shall refer to BHEL and the term 'Contractor' shall refer to the successful Bidder.

1.1 THE EQUIPMENT IS REQUIRED FOR THE FOLLOWING PROJECT

Name of customer: NTPC Ltd.

Name of of the project: 400/220 kV Switchyard Package at North Karanpura Super Thermal Power Project (3 X 660 MW)

Refer Section - 3 for Project Details and General Specifications.

1.2 SPECIFIC TECHNICAL REQUIREMENTS

1.2.1 As per Annexure-1A (NTPC specification, 13 pages)

1.2.2 (a) Strip armouring method (a) mentioned in Table 5, Page-6 of IS: 1554 (Part 1) - 1988 shall not be accepted for any of the cables.

(b) Strip armouring method (a) mentioned in Table 6, Page-6 of IS: 7098 (Part 1) - 1988 shall not be accepted for any of the cables.

1.3 QUANTITIES

Sl. No.	Type of Control Cables	Quantity (kM)		
		400/220 kV Switchyard at North Karanpura STPP	220 kV Switchyard at Mine End	Total
1.1	2C x 2.5 sq mm PVC/Copper, Armoured	17.0	2.0	19
1.2	5C x 2.5 sq mm PVC/Copper, Armoured	60.0	8.0	68
1.3	10C x 2.5sqmm PVC/Copper, Armoured	80.0	9.5	89.5
1.4	14C x 2.5 sq mm PVC/Copper, Armoured	8.0	2.5	10.5
1.5	19C x 2.5 sq mm PVC/Copper, Armoured	25.0	1.5	26.5
1.6	4C x 10 sq mm PVC/Copper, Armoured	10.0	1.5	11.5
	Type of Aux Power Cables			
2.1	2C x 6 sq mm PVC/Aluminium, Armoured	6.0	1.0	7.0
2.2	4C x 6 sq mm PVC/Aluminium, Armoured	9	1.5	10.5
2.3	4C x 16 sq mm PVC/Aluminium, Armoured	25	1.5	26.5
2.4	3.5C x 70 sq mm PVC/Aluminium, Armoured	36	2.0	38.0
2.5	3.5C x 150 sq mm XLPE/Aluminium, Armoured	0.5	0.0	0.5
* 2.6	3.5C x 300 sq mm XLPE/Aluminium, Armoured	1.0	0.0	1.0
2.7	2C x 150 sq mm XLPE/Aluminium, Armoured	0.5	0.0	0.5
* 2.8	1C x 630 sq mm XLPE/Aluminium, Armoured	12	0.0	12

Note:-

The cable type, size and length requirement shall be as per tables below. *However, the length of each cable type procured may be subject to a change of +/- 30% before placement of order. Quantity variation on the total ordered quantity shall be +/- 20% at contract stage.*

The standard drum length for control cables shall not be less than 1000 metres & for power cables it shall not be less than 500m. Cut lengths for cable marked as (*) above shall be informed during detailed engineering stage. The length per drum shall be subjected to a maximum tolerance of +/- 5% of the standard drum length. *Some of the cable type might not be ordered at all at contract stage.*

The Employer shall have the option of rejecting cable drums with shorter lengths. For each size, the variance of total quantity, adding all the supplied drum lengths, from the ordered quantity, shall not exceed +/- 2%.

Manufacturing clearance shall be divided into single / two Lots.

Second lot shall be cleared for manufacturing based on progress of engineering and site requirements.

Project: 400/220 kV Switchyard Package at **Bharat Heavy Electricals Limited**
North Karanpura Super Thermal Power Project (3 X 660 MW) Document No. TB 369 510 011
Customer: NTPC Ltd.
Technical Specification: 1.1 kV Aux Power & Control Cables

1.4 TESTS

Cables shall conform to type tests including additional type tests as per technical specification and shall be subject to routine & acceptance tests in accordance with requirements stipulated under respective sections.

The reports for all type tests and additional type tests as per technical specification shall be furnished by the bidder along with equipment / material drawings.

The bidder will conduct the routine tests on each drum length. All the type and acceptance tests shall be conducted as per specification and relevant standards/ approved MQP. These tests will be witnessed by owner/purchaser/purchaser's representatives.

The prices for conducting all tests are deemed to be included in respective cable prices.

1.5 QUALITY PLAN

The manufacturer shall carry out contract works in accordance with sound quality management principles which shall include items such as controls which are necessary to ensure full compliance to all requirements of the specification & applicable international standards. These quality management requirement shall apply to all activities during design, procurement, manufacturing, inspection, testing, packaging, shipping, inland transportation, storage, site erection & commissioning. Manufacturer shall submit detailed Quality Plan for BHEL / customer's approval.

6.0 PROVEN-MAKE CRITERIA FOR LT POWER AND CONTROL CABLES

6.1 Sub-Qualifying Requirements for LT Control Cables:

Bidder should have manufactured and supplied prior to the date of Techno-Commercial bid opening (28.11.2013).


- a. At least 300 km of PVC insulated, PVC sheathed stranded copper conductor 1.1 kV grade cables in one single contract
- b. At least one (1) km of Flame retardant low smoke cables.


6.2 Sub-Qualifying Requirement for LT Power Cables


Bidder should have manufactured and supplied prior to the date of Techno-Commercial bid opening (28.11.2013).


- a. At least 100 Kms of aluminium conductor, XLPE insulated, PVC sheathed power cables of 1.1 kV or higher grade in one single contract.
- b. At least 100 km of aluminium conductor, PVC insulated, PVC sheathed power cables of 1.1 kV or higher grade in one single contract.
- c. At least one (1) km of flame retardant low smoke cables.
- d. 1.1 kV or higher grade power cable of minimum 630 sq.mm. Conductor size.

ANNEXURE - I A

CLAUSE NO.	TECHNICAL REQUIREMENTS																								
1.00.00	CODES & STANDARDS																								
1.01.00	<p>All standards, specifications and codes of practice referred to herein shall be the latest editions including all applicable official amendments and revisions as on date of opening of bid. In case of conflict between this specification and those (IS : codes, standards, etc.) referred to herein, the former shall prevail. All the cables shall conform to the requirements of the following standards and codes:</p> <table border="0" data-bbox="371 577 1353 1601"> <tr> <td data-bbox="371 577 502 607">IS :1554 - I</td> <td data-bbox="608 577 1353 651">PVC insulated (heavy duty) electric cables for working voltages upto and including 1100V.</td> </tr> <tr> <td data-bbox="371 701 475 730">IS : 3961</td> <td data-bbox="608 701 1050 730">Recommended current ratings for cables</td> </tr> <tr> <td data-bbox="371 779 475 808">IS : 3975</td> <td data-bbox="608 779 1353 853">Low carbon galvanised steel wires, formed wires and tapes for armouring of cables.</td> </tr> <tr> <td data-bbox="371 902 475 931">IS : 5831</td> <td data-bbox="608 902 1110 931">PVC insulation and sheath of electrical cables.</td> </tr> <tr> <td data-bbox="371 981 552 1010">IS:7098 (Part -I)</td> <td data-bbox="608 981 1353 1055">Cross linked polyethylene insulated PVC sheathed cables for working voltages upto and including 1100V.</td> </tr> <tr> <td data-bbox="371 1104 475 1133">IS : 8130</td> <td data-bbox="608 1104 1257 1133">Conductors for insulated electrical cables and flexible cords.</td> </tr> <tr> <td data-bbox="371 1182 488 1211">IS : 10418</td> <td data-bbox="608 1182 1059 1211">Specification for drums for electric cables.</td> </tr> <tr> <td data-bbox="371 1261 488 1290">IS : 10810</td> <td data-bbox="608 1261 906 1290">Methods of tests for cables.</td> </tr> <tr> <td data-bbox="371 1339 539 1368">ASTM-D -2843</td> <td data-bbox="608 1339 1353 1413">Standard test method for density of smoke from the burning or decomposition of plastics.</td> </tr> <tr> <td data-bbox="371 1462 539 1514">IEC-754 (Part-I)</td> <td data-bbox="608 1462 1267 1491">Tests on gases evolved during combustion of electric cables.</td> </tr> <tr> <td data-bbox="411 1541 507 1570">IEC-332</td> <td data-bbox="608 1541 1310 1601">Tests on electric cables under fire conditions. Part-3: Tests on bunched wires or cables (Category-B).</td> </tr> </table>			IS :1554 - I	PVC insulated (heavy duty) electric cables for working voltages upto and including 1100V.	IS : 3961	Recommended current ratings for cables	IS : 3975	Low carbon galvanised steel wires, formed wires and tapes for armouring of cables.	IS : 5831	PVC insulation and sheath of electrical cables.	IS:7098 (Part -I)	Cross linked polyethylene insulated PVC sheathed cables for working voltages upto and including 1100V.	IS : 8130	Conductors for insulated electrical cables and flexible cords.	IS : 10418	Specification for drums for electric cables.	IS : 10810	Methods of tests for cables.	ASTM-D -2843	Standard test method for density of smoke from the burning or decomposition of plastics.	IEC-754 (Part-I)	Tests on gases evolved during combustion of electric cables.	IEC-332	Tests on electric cables under fire conditions. Part-3: Tests on bunched wires or cables (Category-B).
IS :1554 - I	PVC insulated (heavy duty) electric cables for working voltages upto and including 1100V.																								
IS : 3961	Recommended current ratings for cables																								
IS : 3975	Low carbon galvanised steel wires, formed wires and tapes for armouring of cables.																								
IS : 5831	PVC insulation and sheath of electrical cables.																								
IS:7098 (Part -I)	Cross linked polyethylene insulated PVC sheathed cables for working voltages upto and including 1100V.																								
IS : 8130	Conductors for insulated electrical cables and flexible cords.																								
IS : 10418	Specification for drums for electric cables.																								
IS : 10810	Methods of tests for cables.																								
ASTM-D -2843	Standard test method for density of smoke from the burning or decomposition of plastics.																								
IEC-754 (Part-I)	Tests on gases evolved during combustion of electric cables.																								
IEC-332	Tests on electric cables under fire conditions. Part-3: Tests on bunched wires or cables (Category-B).																								
2.00.00	TECHNICAL REQUIREMENTS																								
2.01.00	The cables shall be suitable for laying on racks, in ducts, trenches, conduits and under ground buried installation with chances of flooding by water.																								
2.02.00	All cables including EPR cables shall be flame retardant, low smoke (FRLS) type designed to withstand all mechanical, electrical and thermal stresses developed under steady state and transient operating conditions as specified elsewhere in this specification.																								
<p align="center">NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p align="center">TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p align="center">SUB-SECTION-B-20 LT POWER CABLES</p>	<p align="center">PAGE 1 OF 13</p>																						

CLAUSE NO.	TECHNICAL REQUIREMENTS																
2.03.00	Aluminium conductor used in power cables shall have tensile strength of more than 100 N/ sq.mm. Conductors shall be stranded.																
2.04.00	XLPE insulation shall be suitable for a continuous conductor temperature of 90 deg. C and short circuit conductor temperature of 250 deg C. PVC insulation shall be suitable for continuous conductor temperature of 70 deg C and short circuit conductor temperature of 160 deg. C.																
2.05.00	The cable cores shall be laid up with fillers between the cores wherever necessary. It shall not stick to insulation and inner sheath. All the cables, other than single core unarmoured cables, shall have distinct extruded PVC inner sheath of black colour as per IS : 5831.																
2.06.00	<p>For single core armoured cables, armouring shall be of aluminium wires/ formed wires. For multicore armoured cables, armouring shall be of galvanised steel as follows :</p> <table border="1" data-bbox="368 779 1370 1193"> <thead> <tr> <th data-bbox="368 779 863 846">Calculated nominal dia. of cable under armour</th> <th data-bbox="863 779 1370 846">Size and Type of armour</th> </tr> </thead> <tbody> <tr> <td data-bbox="368 869 863 913">Upto 13 mm</td> <td data-bbox="863 869 1370 913">1.4mm dia GS wire</td> </tr> <tr> <td data-bbox="368 925 863 969">Above 13 & upto 25mm</td> <td data-bbox="863 925 1370 969">0.8 mm thick GS formed wire / 1.6 mm dia GS wire</td> </tr> <tr> <td data-bbox="368 981 863 1025">Above 25 & upto 40 mm</td> <td data-bbox="863 981 1370 1025">0.8mm thick GS formed wire / 2.0mm dia GS wire</td> </tr> <tr> <td data-bbox="368 1037 863 1081">Above 40 & upto 55mm</td> <td data-bbox="863 1037 1370 1081">1.4 mm thick GS formed wire /2.5mm dia GS wire</td> </tr> <tr> <td data-bbox="368 1093 863 1137">Above 55 & upto 70 mm</td> <td data-bbox="863 1093 1370 1137">1.4mm thick GS formed wire / 3.15mm dia GS wire</td> </tr> <tr> <td data-bbox="368 1149 863 1193">Above 70mm</td> <td data-bbox="863 1149 1370 1193">1.4 mm thick GS formed wire / 4.0 mm dia GS wire</td> </tr> </tbody> </table>			Calculated nominal dia. of cable under armour	Size and Type of armour	Upto 13 mm	1.4mm dia GS wire	Above 13 & upto 25mm	0.8 mm thick GS formed wire / 1.6 mm dia GS wire	Above 25 & upto 40 mm	0.8mm thick GS formed wire / 2.0mm dia GS wire	Above 40 & upto 55mm	1.4 mm thick GS formed wire /2.5mm dia GS wire	Above 55 & upto 70 mm	1.4mm thick GS formed wire / 3.15mm dia GS wire	Above 70mm	1.4 mm thick GS formed wire / 4.0 mm dia GS wire
Calculated nominal dia. of cable under armour	Size and Type of armour																
Upto 13 mm	1.4mm dia GS wire																
Above 13 & upto 25mm	0.8 mm thick GS formed wire / 1.6 mm dia GS wire																
Above 25 & upto 40 mm	0.8mm thick GS formed wire / 2.0mm dia GS wire																
Above 40 & upto 55mm	1.4 mm thick GS formed wire /2.5mm dia GS wire																
Above 55 & upto 70 mm	1.4mm thick GS formed wire / 3.15mm dia GS wire																
Above 70mm	1.4 mm thick GS formed wire / 4.0 mm dia GS wire																
2.06.01	The aluminium used for armouring shall be of H4 grade as per IS: 8130 with maximum resistivity of 0.028264 ohm mm ² per meter at 20 deg C. The sizes of aluminium armouring shall be same as indicated above for galvanized steel.																
2.06.02	The gap between armour wires / formed wires shall not exceed one armour wire / formed wire space and there shall be no cross over / over-riding of armour wire / formed wire. The minimum area of coverage of armouring shall be 90%. The breaking load of armour joint shall not be less than 95% of that of armour wire / formed wire. Zinc rich paint shall be applied on armour joint surface of G.S.wire/ formed wire.																
2.07.00	<p>Outer sheath shall be of PVC as per IS: 5831 & black in colour. In addition to meeting all the requirements of Indian standards referred to, outer sheath of all the cables shall have the following FRLS properties.</p> <p>(a.) Oxygen index of min. 29 (as per IS 10810 Part-58).</p> <p>(b.) Acid gas emission of max. 20% (as per IEC-754-I).</p> <p>(c.) Smoke density rating shall not be more than 60 % (as per ASTM-D-2843).</p>																
2.08.00	Cores of the cables shall be identified by colouring of insulation. Following colour scheme shall be adopted:																
<p align="center">NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p align="center">TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p align="center">SUB-SECTION-B-20 LT POWER CABLES</p>	<p align="center">PAGE 2 OF 6</p>														

CLAUSE NO.	TECHNICAL REQUIREMENTS		
	<p>1 core - Red, Black, Yellow or Blue</p> <p>2 core - Red & Black</p> <p>3 core - Red, Yellow & Blue</p> <p>4 core - Red, Yellow, Blue and Black</p>		
2.09.00	For reduced neutral conductors, the core shall be black.		
2.10.00	<p>In addition to manufacturer's identification on cables as per IS, following marking shall also be provided over outer sheath.</p> <p>(a.) Cable size and voltage grade - To be embossed</p> <p>(b.) Word 'FRLS' at every 5 metre - To be embossed</p> <p>(c.) Sequential marking of length of the cable in metres at every one metre -To be embossed / printed</p> <p>The embossing shall be progressive, automatic, in line and marking shall be legible and indelible. For EPR cables identification shall be printed on outer sheath.</p>		
2.11.00	All cables shall meet the fire resistance requirement as per Category-B of IEC 332 Part-3.		
2.12.00	Allowable tolerances on the overall diameter of the cables shall be ± 2 mm maximum, over the declared value in the technical data sheets.		
2.13.00	In plant repairs to the cables shall not be accepted. Pimples, fish eye, blow holes etc. are not acceptable.		
2.14.00	Cable selection & sizing		
2.14.01	<p>Cables shall be sized based on the following considerations:</p> <p>(a) Rated current of the equipment</p> <p>(b) The voltage drop in the cable, during motor starting condition, shall be limited to 10% and during full load running condition, shall be limited to 3% of the rated voltage</p> <p>(c) Short circuit withstand capability</p> <p>This will depend on the feeder type. For a fuse protected circuit, cable should be sized to withstand the letout energy of the fuse. For breaker controlled feeder, cable shall be capable of withstanding the system fault current level for total breaker tripping time inclusive of relay pickup time.</p>		
2.14.02	<p>Derating Factors</p> <p>Derating factors for various conditions of installations including the following shall be considered while selecting the cable sizes:</p> <p>a) Variation in ambient temperature for cables laid in air</p> <p>b) Grouping of cables</p>		
<p>NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p>SUB-SECTION-B-20 LT POWER CABLES</p>	<p>PAGE 3 OF 6</p>

CLAUSE NO.	TECHNICAL REQUIREMENTS	
<p>2.14.03</p> <p>2.14.04</p> <p>2.14.05</p> <p>3.00.00</p> <p>3.01.00</p> <p>4.00.00</p> <p>5.00.00</p>	<p>c) Variation in ground temperature and soil resistivity for buried cables.</p> <p>Cable lengths shall be considered in such a way that straight through cable joints are avoided.</p> <p>Cables shall be armoured type if laid in switchyard area, CHP area or directly buried.</p> <p>All LT power cables of sizes more than 120 sq.mm. shall be XLPE insulated and preferable sizes are 1Cx150, 1Cx300, 1Cx630, 3Cx150 & 3Cx240 sq.mm.</p> <p>CONSTRUCTIONAL FEATURES</p> <p>1.1 KV Grade Power Cables</p> <p>(a) 1.1 KV grade XLPE power cables shall have compacted aluminium conductor, XLPE insulated, PVC inner-sheathed (as applicable), armoured/ unarmoured, PVC outer-sheathed conforming to IS:7098. (Part-I).</p> <p>(b) 1.1KV grade PVC power cables shall have aluminium conductor(compact type for sizes above 10 sq.mm), PVC Insulated, PVC inner sheathed (as applicable) armoured/ unarmoured, PVC outer-sheathed conforming to IS:1554 (Part-I).</p> <p>(c) 1.1 KV grade Trailing cables shall have tinned copper(class 5)conductor, insulated with heat resistant elastomeric compound based on Ethylene Propylene Rubber(EPR) suitable for withstanding 90 deg.C continuous conductor temperature and 250deg C during short circuit, inner-sheathed with heat resistant elastomeric compound, nylon cord reinforced, outer-sheathed with heat resistant, oil resistant and flame retardant heavy duty elastomeric compound conforming to IS 9968.</p> <p>CABLE DRUMS</p> <p>(a) Cables shall be supplied in non returnable wooden or steel drums of heavy construction. The surface of the drum and the outer most cable layer shall be covered with water proof cover. Both the ends of the cables shall be properly sealed with heat shrinkable PVC/ rubber caps secured by 'U' nails so as to eliminate ingress of water during transportation, storage and erection. Wood preservative anti-termite treatment shall be applied to the entire drum. Wooden drums shall comply with IS: 10418.</p> <p>(b) Each drum shall carry manufacturer's name, purchaser's name, address and contract number, item number and type, size and length of cable and net gross weight stencilled on both sides of the drum. A tag containing same information shall be attached to the leading end of the cable. An arrow and suitable accompanying wording shall be marked on one end of the reel indicating the direction in which it should be rolled.</p> <p>(c.) The standard drum length for power cables shall not be 1000 metres; however for cable sizes of 1C X 630mm², 3C X 150mm² and 3C X 240mm² (sizes if applicable) standarddrum length shall be 750 meters. The length per drum shall be subjected to a maximum tolerance of +/- 5% of the standard drum length. The Employer shall have the option of rejecting cable drums with shorter lengths.</p> <p>TESTS</p> <p>1.0 All equipments to be supplied shall be of type tested design. During detailed engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last ten years from the</p>	
<p>NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p>SUB-SECTION-B-20 LT POWER CABLES</p> <p>PAGE 4 OF 6</p>

date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.

2.0 However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client /owners representative and submit the reports for approval.


3.0 All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.

4.0 The type test reports once approved for any projects shall be treated as reference . For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.

5.01.00 **Type Tests**

5.01.01 The reports for the following type tests shall be submitted for one size each of LT XLPE and LT PVC Power cables. Size shall be decided by the employer during detailed engineering:

S.No.	Type test	Remarks
For Conductor		
1.	Resistance test	
2.	Tensile test	For circular non-compacted conductors only
3.	Wrapping test	For circular non-compacted only
For Armour Wires/ Formed Wires		
4.	Measurement of Dimensions	
5.	Tensile Test	
6.	Elongation test	
7.	Torsion test	For round wires only
8.	Wrapping test	For aluminium wires / formed wires only.
9.	Resistance test	
10(a)	Mass of zinc coating test	For GS Formed wires/wires only
10(b)	Uniformity of zinc coating	For GS Formed wires /wires only
11.	Adhesion test	For GS Formed wires/wires only


CLAUSE NO.	TECHNICAL REQUIREMENTS	
	<p style="text-align: center;">For PVC/XLPE insulation & PVC Sheath</p> <p>12. Test for thickness</p> <p>13. Tensile strength & elongation tests before ageing and after ageing</p> <p>14. Ageing in air oven</p> <p>15. Loss of mass test For PVC insulation and sheath only</p> <p>16. Hot deformation test For PVC insulation and sheath only</p> <p>17. Heat shock test For PVC insulation and sheath only</p> <p>18. Shrinkage test</p> <p>19. Thermal stability test For PVC insulation and sheath only</p> <p>20. Hot set test For XLPE insulation only</p> <p>21. Water absorption test For XLPE insulation only</p> <p>22. Oxygen index test For outer sheath only</p> <p>23. Smoke density test For outer sheath only</p> <p>24. Acid gas generation test For outer sheath only</p> <p style="text-align: center;">For completed cables</p> <p>25. Insulation resistance test (Volume resistivity method)</p> <p>26. High voltage test</p> <p>27. Flammability test as per IEC-332 Part-3 (Category-B)</p> <p>Indicative list of tests/checks, Routine and Acceptance tests shall be as per Quality Assurance & Inspection table of LT power cables enclosed.</p>	
<p style="text-align: center;">NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p style="text-align: center;">SUB-SECTION-B-20 LT POWER CABLES</p> <p style="text-align: right;">PAGE 6 OF 6</p>


SUB-SECTION – B-21


LT CONTROL CABLES

**NORTH KARANPURA STPP
(3 X 660 MW)
EPC PACKAGE**

**TECHNICAL SPECIFICATION
SECTION-VI, PART-B
BID DOC.NO.: CS-4410-001-2**


CLAUSE NO.	TECHNICAL REQUIREMENTS		
1.00.00	CODES & STANDARDS		
1.01.00	<p>All standards, specifications and codes of practice referred to herein shall be the latest editions including all applicable official amendments and revisions as on date of opening of bid. In case of conflict between this specification and those (IS : codes, standards, etc.) referred to herein, the former shall prevail. All the cables shall conform to the requirements of the following standards and codes:</p> <p>IS :1554 - I PVC insulated (heavy duty) electric cables for working voltages upto and including 1100V.</p> <p>IS : 3961 Recommended current ratings for cables</p> <p>IS : 3975 Low carbon galvanised steel wires, formed wires and tapes for armouring of cables.</p> <p>IS : 5831 PVC insulation and sheath of electrical cables.</p> <p>IS : 8130 Conductors for insulated electrical cables and flexible cords.</p> <p>IS : 10418 Specification for drums for electric cables.</p> <p>IS : 10810 Methods of tests for cables.</p> <p>ASTM-D -2843 Standard test method for density of smoke from the burning or decomposition of plastics.</p> <p>IEC-754 (Part-I) Tests on gases evolved during combustion of electric cables.</p> <p>IEC-332 Tests on electric cables under fire conditions. Part-3: Tests on bunched wires or cables (Category-B).</p>		
2.00.00	TECHNICAL REQUIREMENTS		
2.01.00	The cables shall be suitable for laying on racks, in ducts, trenches, conduits and under ground buried installation with chances of flooding by water.		
2.02.00	All cables including EPR cables shall be flame retardant, low smoke (FRLS) type designed to withstand all mechanical, electrical and thermal stresses develop under steady state and transient operating conditions as specified elsewhere in this specification.		
2.03.00	Conductor of control cables shall be made of stranded, plain annealed copper.		
2.04.00	PVC insulation shall be suitable for continuous conductor temperature of 70 deg C and short circuit conductor temperature of 160 deg. C.		
2.05.00	The cable cores shall be laid up with fillers between the cores wherever necessary. It shall not stick to insulation and inner sheath. All the cables, other than single core unarmoured cables, shall have distinct extruded PVC inner sheath of black colour as per IS: 5831.		
NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2	SUB-SECTION-B-21 LT CONTROL CABLES	PAGE 1 OF 6


CLAUSE NO.	TECHNICAL REQUIREMENTS															
2.06.00	<p>For multicore armoured cables, the armouring shall be of galvanised steel as follows:</p> <table border="0"> <tr> <td>Calculated nominal dia of cable under armour</td> <td>Size and Type of armour</td> </tr> <tr> <td>Upto 13 mm</td> <td>1.4mm dia GS wire</td> </tr> <tr> <td>Above 13 upto 25 mm</td> <td>0.8 mm thick GS formed wire / 1.6 mm dia GS wire</td> </tr> <tr> <td>Above 25 upto 40 mm</td> <td>0.8mm thick GS formed wire / 2.0mm dia GS wire</td> </tr> <tr> <td>Above 40 upto 55mm</td> <td>1.4 mm thick GS formed wire/2.5mm dia GS wire</td> </tr> <tr> <td>Above 55 upto 70 mm</td> <td>1.4mm thick GS formed wire / 3.15mm dia GS wire</td> </tr> <tr> <td>Above 70mm</td> <td>1.4 mm thick GS formed wire / 4.0 mm dia GS wire</td> </tr> </table> <p>The gap between armour wires / formed wires shall not exceed one armour wire / formed wire space and there shall be no cross over / over-riding of armour wire / formed wire. The minimum area of coverage of armouring shall be 90%. The breaking load of armour joint shall not be less than 95% of that of armour wire / formed wire. Zinc rich paint shall be applied on armour joint surface.</p>	Calculated nominal dia of cable under armour	Size and Type of armour	Upto 13 mm	1.4mm dia GS wire	Above 13 upto 25 mm	0.8 mm thick GS formed wire / 1.6 mm dia GS wire	Above 25 upto 40 mm	0.8mm thick GS formed wire / 2.0mm dia GS wire	Above 40 upto 55mm	1.4 mm thick GS formed wire/2.5mm dia GS wire	Above 55 upto 70 mm	1.4mm thick GS formed wire / 3.15mm dia GS wire	Above 70mm	1.4 mm thick GS formed wire / 4.0 mm dia GS wire	
Calculated nominal dia of cable under armour	Size and Type of armour															
Upto 13 mm	1.4mm dia GS wire															
Above 13 upto 25 mm	0.8 mm thick GS formed wire / 1.6 mm dia GS wire															
Above 25 upto 40 mm	0.8mm thick GS formed wire / 2.0mm dia GS wire															
Above 40 upto 55mm	1.4 mm thick GS formed wire/2.5mm dia GS wire															
Above 55 upto 70 mm	1.4mm thick GS formed wire / 3.15mm dia GS wire															
Above 70mm	1.4 mm thick GS formed wire / 4.0 mm dia GS wire															
2.07.00	<p>Outer sheath shall be of PVC as per IS: 5831 and grey in colour. In addition to meeting all the requirements of Indian Standards referred to, outer sheath of all the cables shall have the following FRLS properties.</p> <p>(a.) Oxygen index of min. 29. (As per IS 10810 Part-58)</p> <p>(b.) Acid gas emission of max. 20% (As per IEC-754-I)</p> <p>(c.) Smoke density rating shall not be more than 60% during Smoke Density Test as per ASTM-D-2843.</p>															
2.08.00	<p>Cores of the cables of upto 5 cores shall be identified by colouring of insulation. Following colour scheme shall be adopted.</p> <p>1 core - Red, Black, Yellow or Blue</p> <p>2 core - Red & Black</p> <p>3 core - Red, Yellow & Blue</p> <p>4 core - Red, Yellow, Blue and Black</p> <p>5 core - Red, Yellow, Blue, Black and Grey</p>															
2.09.00	<p>For cables having more than 5 cores, core identification shall be done by numbering the insulation of cores sequentially, starting by number 1 in the inner layer (e.g. say for 10 core cable, core numbering shall be from 1 to 10). The number shall be printed in Hindu-Arabic numerals on the outer surfaces of the cores. All the numbers shall be of the same colour, which shall contrast with the colour of insulation. The colour of insulation for all the cores shall be grey only. The numerals shall be legible and indelible. The numbers shall be repeated at regular intervals along the core, consecutive numbers being inverted in relation to each other. When the number is a single numeral, a dash shall be placed</p>															
<p>NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p>SUB-SECTION-B-21 LT CONTROL CABLES</p>	<p>PAGE 2 OF 6</p>													

CLAUSE NO.	TECHNICAL REQUIREMENTS													
<p>2.10.00</p>	<p>underneath it. If the number consists of two numerals, these shall be disposed one below the other and a dash placed below the lower numeral. The spacing between consecutive numbers shall not exceed 50 mm.</p> <p>In addition to manufacturer's identification on cables as per IS, following marking shall also be provided over outer sheath:</p> <p>(a.) Cable size and voltage grade - To be embossed</p> <p>(b.) Word 'FRLS' at every 5 metre - To be embossed</p> <p>(c.) Sequential marking of length of the cable in metres at every one metre - To be embossed / printed.</p> <p>The embossing / printing shall be progressive, automatic, in line and marking shall be legible and indelible. For EPR cables identification shall be printed on outer sheath.</p> <p>2.11.00 All cables shall meet the fire resistance requirement as per Category-B of IEC-332 Part-3.</p> <p>2.12.00 Allowable tolerances on the overall diameter of the cables shall be ± 2 mm maximum over the declared value in the technical data sheets.</p> <p>2.13.00 In plant repairs to the cables shall not be accepted. Pimples, fish eye, blow holes etc. are not acceptable.</p> <p>2.14.00 Cable selection & sizing</p> <p>Control cables shall be sized based on the following considerations:</p> <p>(a) The minimum conductor cross-section shall be 1.5 sq.mm.</p> <p>(b) The minimum number of spare cores in control cables shall be as follows:</p> <table border="1" data-bbox="371 1182 1069 1440"> <thead> <tr> <th>No. of cores in cable</th> <th>Min. No. of spare cores</th> </tr> </thead> <tbody> <tr> <td>2C, 3C</td> <td>NIL</td> </tr> <tr> <td>5C</td> <td>1</td> </tr> <tr> <td>7C-12C</td> <td>2</td> </tr> <tr> <td>14C & above</td> <td>3</td> </tr> </tbody> </table> <p>2.14.01 Cable lengths shall be considered in such a way that straight through cable joints are avoided.</p> <p>2.14.02 Cables shall be armoured type if laid in switchyard area, CHP area or directly buried.</p> <p>3.00.00 CONSTRUCTIONAL FEATURES</p> <p>3.01.00 1.1 KV Grade Control Cables shall have stranded copper conductor and shall be multicore PVC insulated, PVC inner sheathed, armoured / unarmoured, FRLS PVC outer sheathed conforming to IS: 1554. (Part-I).</p> <p>3.02.00 1.1 KV grade Trailing cables shall have tinned copper(class 5)conductor, insulated with heat resistant elastomeric compound based on Ethylene Propylene Rubber(EPR) suitable for withstanding 90 deg.C continuous conductor temperature and 250deg C during short circuit, inner-sheathed with heat resistant elastomeric compound, nylon cord reinforced, outer-sheathed with heat resistant, oil resistant and flame retardant heavy duty elastomeric compound conforming to IS 9968. Minimum conductor size shall be 2.5 sqmm.</p>			No. of cores in cable	Min. No. of spare cores	2C, 3C	NIL	5C	1	7C-12C	2	14C & above	3	
No. of cores in cable	Min. No. of spare cores													
2C, 3C	NIL													
5C	1													
7C-12C	2													
14C & above	3													
<p>NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p>SUB-SECTION-B-21 LT CONTROL CABLES</p>	<p>PAGE 3 OF 6</p>											

CLAUSE NO.	TECHNICAL REQUIREMENTS		
4.00.00	<p>CABLE DRUMS</p> <p>(a.) Cables shall be supplied in non returnable wooden or steel drums of heavy construction. The surface of the drum and the outer most cable layer shall be covered with water proof cover. Both the ends of the cables shall be properly sealed with heat shrinkable PVC/ rubber caps secured by 'U' nails so as to eliminate ingress of water during transportation, storage and erection. Wood preservative anti-termite treatment shall be applied to the entire drum. Wooden drums shall comply with IS: 10418.</p> <p>(b.) Each drum shall carry manufacturer's name, purchaser's name, address and contract number, item number and type, size and length of cable and net gross weight stenciled on both the sides of the drum. A tag containing same information shall be attached to the leading end of the cable. An arrow and suitable accompanying wording shall be marked on one end of the reel indicating the direction in which it should be rolled.</p> <p>(c.) The standard drum length for control cables shall not be less than 1000 metres. The length per drum shall be subjected to a maximum tolerance of +/- 5% of the standard drum length. The Employer shall have the option of rejecting cable drums with shorter lengths.</p>		
5.00.00	<p>TESTS</p> <p>All equipments to be supplied shall be of type tested design. During detailed engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last ten years from the date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.</p> <p>However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client /owners representative and submit the reports for approval.</p> <p>All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price</p> <p>The type test reports once approved for any projects shall be treated as reference . For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.</p>		
5.01.00	<p>TYPE TESTS</p>		
5.01.01	<p>The reports for the following type tests shall be submitted for one size of control cables. Size shall be decided by the employer during detailed engineering</p>		
<p>NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p>SUB-SECTION-B-21 LT CONTROL CABLES</p>	<p>PAGE 4 OF 6</p>



CLAUSE NO.	TECHNICAL REQUIREMENTS			
	S. No.	Type Test	Remarks	
		For Conductor		
	1.	Resistance test		
		For Armour Wires / Formed Wires (If applicable)		
	2.	Measurement of Dimensions		
	3.	Tensile Test		
	4.	Elongation test		
	5.	Torsion test	For round wire only	
	6.	Wrapping test	For aluminium wires / formed wires only.	
	7.	Resistance test		
	8(a).	Mass of zinc Coating test	For GS wires/formed wires only	
	8(b).	Uniformity of zinc coating	For GS wires/formed wires only	
	9.	Adhesion test	For GS wires/formed wires only	
		For PVC insulation & PVC Sheath		
	10.	Test for thickness		
	11.	Tensile strength and elongation test	before ageing and after ageing	
	12.	Ageing in air oven		
	13.	Loss of mass test	For PVC insulation and sheath only	
	14.	Hot deformation test	For PVC insulation and sheath only	
	15.	Heat shock test	For PVC insulation and sheath only	
	16.	Shrinkage test		
	17.	Thermal stability test	For PVC insulation and sheath only	
	18.	Oxygen index test	For outer sheath only	
	19.	Smoke density test	For outer sheath only	
<p align="center">NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE</p>	<p align="center">TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2</p>	<p align="center">SUB-SECTION-B-21 LT CONTROL CABLES</p>	<p align="center">PAGE 5 OF 6</p>	

CLAUSE NO.	TECHNICAL REQUIREMENTS				
5.02.00	S. No.	Type Test	Remarks		
	20.	Acid gas generation test	For outer sheath only		
	For completed cables				
	21.	Insulation resistance test(Volume resistivity method)			
	22.	High voltage test			
23.	Flammability test as per IEC-332 Part-3 (Category-B)				
	Indicative list of tests/checks, Routine and Acceptance tests shall be as per Quality Assurance & Inspection table of Control Cables enclosed.				
NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2	SUB-SECTION-B-21 LT CONTROL CABLES	PAGE 13 OF 13		

SECTION-2

2.0 SCOPE

This technical specification covers the requirement of design, manufacture, testing, packing and dispatch of 1.1 kV grade Auxiliary power and control cables (FRLS type). No deviation from the requirements specified in various clauses of this specification shall be allowed.

2.1 APPLICABLE STANDARDS

The auxiliary power and control cables shall conform to following latest Indian and International standards and their amendments.

IS 1554 (Part I)	PVC insulated (heavy duty) electric cables - For working voltage up to and including 1100V
IS 7098 (Part I)	XLPE insulated PVC sheathed cables - For working voltage up to and including 1100V
IS 5831	PVC insulation and sheath of electric cables.
IS 8130	Conductors for insulated electric cables and flexible cords.
IS 3975	Low Carbon Galvanized Steel Wires, Formed Wires and Tapes for Armouring of Cables - Specification
IS 10810	Method of tests for cables.
IEEE-383	Standard for type test of class IE electric cables, field splices, and connections for nuclear power generating stations.
ASTM-D2843	Standard test method for density of smoke from burning or decomposition of plastics.
ASTM-D2863	Standard test method for measuring minimum oxygen concentration to support candle - like combustion of plastics (oxygen index).
IEC: 60754 (Part-1 & 2)	Test on gases evolved during combustion of electric cables -
IEC: 60332 (Part I to 3)	Tests on electric and optical fibre cables under fire conditions
IS 3961 (Part II)	Recommended current rating for cables - PVC insulated and PVC sheathed heavy-duty cables.
IS 10418	Drums for electric cables.
SS 4241475	Swedish chimney test

2.2 CONSTRUCTIONAL FEATURES

- i) Cables shall be suitable for laying in racks, ducts, trenches, conduits and underground-buried installation with uncontrolled back fill and chances of flooding by water. They shall be designed to withstand all mechanical, electrical and thermal stresses under steady state and transient operating conditions.
- ii) The Aluminium/Copper wires used for manufacturing the cables shall be true circular in shape before stranding and shall be uniformly good quality, free from defects.
- iii) A distinct extruded inner sheath shall be provided in all armoured cable. The fillers and inner sheath shall be of non-hygroscopic, fire retardant material, softer than insulation & suitable for the operating temperature of the cable & compatible with the insulating material. The outer sheath shall be suitable for the operating temp. of the cable. For single core cable, inner sheath may not be provided.
- iv) Progressive sequential marking of the length of cable in meters at every one-meter shall be provided on the outer sheath of all cables.
- v) All power & control cables shall have an extruded outer sheath of PVC having following flame retardant & low smoke evolution properties.
Oxygen index - Minimum 29 (to ASTM D 2863).
Acid gas emission - Maximum 20% by weight (to IEC 754 – I).
Smoke density rating – Maximum 60% (to ASTM D 2843).
- vi) All cables shall be suitable for high ambient high humid tropical Indian climatic conditions.
- vii) The normal current rating of all PVC insulated cables shall be as per IS 3961.
- viii) All cables shall conform to type test and shall be subjected to routine and acceptance tests listed in the specification.
- ix) Allowable tolerance on the overall diameter of the cables shall be $\pm 2\text{mm}$.
- x) The minimum bending radius for the cables shall be equal to $12 \cdot D$, where D is the overall diameter of the cable for multicore cables and $15 \cdot D$ for single core cable.
- xi) Suitable chemicals shall be added to the outer sheath of all cables to protect from rodent, vermin and termite attack.
- xii) Repaired cables shall not be acceptable.
- xiii) Cores shall be identified as per IS 1554 (Part-I)/ IS 7098 Part-I for the cables upto five (5) cores and for cables with more than five (5) cores the identification of cores shall be done by printing legible Hindu Arabic numerals on all cores as per Clause 10.3 of IS 1554 (Part-1).
- xiv) Manufacturer's name, type of cable, number of cores, year of manufacture and sequential marking of length in metres at every one metre shall be permanently marked on the outer sheath throughout the entire length of cable.

2.3 CURRENT RATING FOR CONTROL and AUX. POWER CABLES

Technical Specification: 1.1 kV Aux Power & Control Cables

- 2.3.1 Normal current rating shall not be less than that covered by IS 3961. Vendor shall submit data in respect of all cables in the prescribed format.
- 2.3.2 PVC insulated cables shall be suitable for continuous conductor temperature of 70 °C and short circuit withstand temperature of 160 °C. Tables giving de-rating factors for various conditions of cable installation including the following, for all types of cables shall be furnished -
- Variation in ambient air temperature.
 - Variation in ground temperature.
 - Depth of laying.
 - Cables laid in the ground
 - Cables laid in trench
 - Cables laid in ducts
 - Soil resistivity.
 - Grouping of cables.

Overall derating factor for cable shall be 0.8 or less.

- 2.3.3 The value of short circuit withstand current ratings of all cables shall be indicated for a short circuit for 1 second duration and should also specify the maximum temperature during short circuit.
- 2.3.4 The following factors shall also be accounted for, while specifying the maximum short circuit withstand of the cables.
- 2.3.4.1 Deformation of the insulation, due to thermo-mechanical forces produced by the short circuit conditions, can reduce the effective thickness of insulation.
- 2.3.4.2 Conductor and core screens can be adversely affected with loss of screening effect. Likewise the thermal properties of the outer sheath material can be the limitation.
- 2.3.4.3 It is essential that the accessories, which are used in the cable system with mechanical and/or soldered connections, are suitable for the temperature adopted for the cables.
- 2.3.5 Formula for calculating short circuit current for different duration or curve showing short time current v/s time for different sizes of cables shall be furnished by vendor.

2.4 CABLE DRUMS

- 2.4.1 Cables shall be supplied in non-returnable wooden cable drum or steel drum of heavy construction. It shall be made of good quality wood, pressure impregnated against fungal and insect attack. Wood preservative shall be applied to the entire drum. The ends of the each length of cable shall be sealed before dispatch.
- 2.4.2 All Control and Power Cables shall be supplied in drum length of 1000 m, unless otherwise specified. For power cable with conductor cross sectional area 300sqmm and above may be supplied in 500m drums. Each drum shall contain one continuous length of cable. Owner shall have the option of rejecting cable drums with shorter lengths. The cable length per drum is allowed a tolerance of +5%. The tolerance allowed on total quantity of each size is +2%. Where

Technical Specification: 1.1 kV Aux Power & Control Cables

the ordered quantity is not multiple of 1000/500 m and the incremental quantity is very small, the same may be included in one of the drums. Otherwise, an additional length for the incremental quantity will be supplied.

- 2.4.3 A layer of water proof paper shall be applied to the surface of the drums and over the outer most cable layer.
- 2.4.4 A clear space of at least 40mm shall be left between the cables and the logging.
- 2.4.5 Each drum shall carry manufacturer's name, purchaser's name, address and contract number, item number and type, size and length of the cable, net and gross weight stenciled on both sides of drum. A tag containing the same information shall be attached to the leading end of the cable. An arrow and suitable accompanying wordings shall be marked on one end of the reel indicating the direction in which it should be rolled.
- 2.4.6 Packing shall be sturdy and adequate to protect the cables, from any injury due to mishandling or other conditions encountered during transportation, handling and storage. Both cable ends shall be sealed with PVC/Rubber caps so as to eliminate ingress of water during transportation and erection.

2.5 TESTS

All types and sizes of cables shall be subjected to following routine and acceptance tests and type tests.

2.5.1 Type and Acceptance test

The following test shall be performed on one length from each manufacturing series of same type and size of cable, covering at least 10% of all cable drums / test reports shall be submitted as per Section-5. The type and acceptance tests shall be witnessed by purchaser / purchaser's representatives.

- a) Annealing test (for Copper conductor), Tensile & Wrapping Tests (for Aluminium for conductor) as per IS 8130.
- b) Conductor resistance test as per IS 8130.
- c) Test for armouring wires/ formed wire (% Elongation, Tensile, Torsion/ winding, Resistance, Wt of Zinc coating, Dimension and uniformity of coating) as per IS 1554 (Part-I), IS 7098 (Part-I), IS 3975.
- d) Check for dimensions of insulation, sheath and conductor as per IS 1554 (Part-I), IS 7098 (Part-I).
- e) Physical tests for insulation and sheath as per IS 1554 (Part-I), IS 7098 (Part-I), IS 5831 as applicable.
- f) Insulation resistance test as per IS 1554 (Part-I), IS 7098 (Part-I), IS 5831 as applicable.
- g) High voltage test at room temperature as per IS 1554 (Part I), IS 7098 (Part-I) as applicable.
- h) High voltage test (water immersion test) as per clause 16.3 of IS 1554 (Part I).
- i) Flammability test as per clause 2.5 IEEE-383 / IEC 60332 part 3.

Technical Specification: 1.1 kV Aux Power & Control Cables

- j) Smoke density rating test as per ASTM-D2843.
- k) Oxygen index and Temperature index test as per ASTM-D2863.
- l) Acid gas generation test as per IEC: 60754
- m) Flammability test as per IS 1554 Part-I/ IS 7098 Part-1.
- n) Swedish chimney test F3 category as per SS 4241475

~~—Following special type tests shall be performed on one sample from each lot of the offered cables:~~

- ~~a) Hydraulic Stability Test~~
- ~~b) Ultraviolet Test as per DIN 53387~~

2.5.2 Routine tests

The following routine tests shall be conducted on full length of the cable. These shall be witnessed by purchaser / purchaser's representatives.

- a) High voltage test as per clause 16.2 of IS 1554 (Part I).
- b) Conductor resistance test as per clause 6.3 of IS 8130.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

SECTION- 3

PROJECT DETAILS AND GENERAL SPECIFICATIONS

3.0 GENERAL

This section stipulates the General Technical Requirements under the Contract and will form an integral part of the Technical Specification.

The provisions under this section are intended to supplement general requirements for the materials, equipment and services covered under other sections of tender documents and are not exclusive. However in case of conflict between the requirements specified in this section and requirements specified under other sections, the requirements specified under respective sections shall prevail.

3.1 PROJECT DETAILS

	Particular	Details
a)	Customer	NTPC Ltd.
b)	Engineer/Consultant/ Inspector	NTPC Ltd.
c)	Project Title	North Karanpura Super Thermal Power Project (3x660 MW) : 400/220kV Switchyard at NKSTPP end & 220kV Sub-station at Mine end
d)	Project Location	Place: Near Tandwa town District: Hazaribagh & Chatra State: Jharkhand
e)	Latitude & Longitude	400/220kV S/s at NKSTPP: North: 23°50' to 23°52' and East: 84°59' to 85°2' 220kV S/s at Chatti Bariatu & Kerandari-A mine: North: 23°52'35" and East: 85°05'25"
f)	Nearest Railway Station	Khalari Railway Station Ranchi-Garhwa section of Eastern Railways
g)	Distance of project location from the Railway station	40 Km (approx.)
h)	Nearest Major Town	Hazaribagh city
i)	Distance of the town from the project site	50 Km.
j)	Nearest commercial airport	Ranchi
k)	Distance of airport from the project site	150 Km
<u>SITE CONDITIONS</u> (for design purposes)		
a)	Design ambient temperature	50°C
b)	Maximum Relative humidity	95 %
c)	Height above mean sea level	Less than 1000 meters
d)	Pollution Severity	Heavily polluted (With Coal dust & Fly ash) and Highly Corrosive environment.
e)	Criteria for Wind Resistant design of structures and equipment	Standard Applicable - IS 875 (Part 3) 1987
f)	Basic Wind speed "Vb" at ten meters	39 m/ sec

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

	above the mean ground level.	
g)	Category of terrain	Cat -2
h)	Risk Coefficient "K1"	1.06

3.1.1 SYSTEM PARAMETERS:

Sl.No.	Parameters	400 kV	220 kV
1	Highest system voltage	420 kV rms	245 kVrms
2	Lightning Impulse voltage	±1425kVp	± 1050kVp
3	Switching impulse voltage	±1050kVp	-
4	Power frequency withstand for 1 min (rms)	630 kV(rms)	460 kV(rms)
5	Max. fault level (1 sec.)	50 kA	40kA
6	Minimum creepage distance	10500 mm	6125mm

3.1.2 AUXILIARY POWER:

Sl.No.	Nominal Connection Voltage	Variations in Voltage	Frequency	Phase	Neutral
1	415V	±10%	50 (+3% -5%)	3Phase , 4 Wire	Solidly Earthed
2	240V	±10%	50 (+3% -5%)	1 phase	Solidly Earthed

Combined variation of voltage and frequency shall be + 10%. Design fault level of 415V system shall be restricted to 50kA rms for 1 second.

The operational limits for variation of DC voltage are (+) 10% to (-) 15%.

3.1.3 The various minimum heights of the switchyard shall be as given below from plinth level:

Voltage	Equipment /1st Level	2nd Level	3rd Level	Peak
220kV	6000mm	12000mm	17000mm	8500mm
400kV	8000mm	16000mm	23000mm	8500mm

The minimum vertical distance from the bottom of the lowest porcelain part of the bushing, porcelain enclosures or support insulators to the bottom of the equipment structure, where it rests on the foundation pad shall be 2550mm.

The minimum height of intermediate gantry tower for 400kV wherever required shall be 25 m and the peak (s) shall be of 8.5 m.

3.1.4 The minimum clearances for 400kV & 220 kV switchyards shall be as given below:

	400kV	220kV
Phase to earth clearance	3500 mm	2100mm
Phase to phase clearance	4000 mm	2100mm
Section clearance	6500 mm	5000mm

3.2 INSTRUCTION TO BIDDERS:

The bidders shall submit the technical requirements, data and information as per the technical data sheets, provided in Section-4.

The bidders shall furnish catalogues, engineering data, technical information, design documents, drawings etc fully in conformity with the technical specification.

It is recognized that the bidders may have standardized on the use of certain components, materials, processes or procedures different than those specified herein. Alternate proposals offering similar

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

equipment based on the manufacturer's standard practice will also be considered provided such proposals meet the specified designs, standard and performance requirements and are acceptable to the Purchaser. Unless brought out clearly, the Bidder shall be deemed to conform to this specification scrupulously. All deviations from the specification shall be clearly brought out in the respective schedule of deviations. Any discrepancy between the specification and the catalogues or the bid, if not clearly brought out in the schedule, will not be considered as valid deviation.

Except for lighting fixtures, wherever a material or article is specified or defined by the name of a particular brand, Manufacturer or Vendor, the specific name mentioned shall be understood as establishing type, function and quality and not as limiting competition. For lighting fixtures, makes shall be as defined in Section-Lighting System.

Equipment furnished shall be complete in every respect with all mountings, fittings, fixtures and standard accessories normally provided with such equipment and/ or needed for erection, completion and safe operation of the equipment as required by applicable codes, though they may not have been specifically detailed in the Technical Specifications unless included in the list of exclusions. Materials and components not specifically stated in the specification but which are necessary for commissioning and satisfactory operation of the switchyard unless specifically excluded shall be deemed to be included in the scope of the specification and shall be supplied without any extra cost. All similar standard components/parts of similar standard equipment under supply shall be inter-changeable with one another.

The bidder shall supply type tested (including special tests as per tech. specification) equipment and materials. The test reports shall be furnished by the bidder along with equipment/ material drawings. In the event of any discrepancy in the test reports, (i.e., if any test report is not acceptable due to any design/ manufacturing changes or due to non-compliance with the Technical Specification and/ or applicable standard), the tests shall be carried out without any additional cost implication to the BHEL. BHEL reserves the right to get any or all type/tests conducted/repeated.

3.3 CODES AND STANDARDS

The supplier is required to follow local **statutory regulations** stipulated in the latest amended Electricity Supply Act 1948 and Indian **Electricity Rules 1956 (latest)**, and other local rules and regulations.

The equipment to be furnished under **this specification shall conform** to latest issue with all amendments of standards and/ or codes **specified under respective section heads**. The standards mentioned in the specification are not **mutually exclusive or complete** in them, but intended to complement each other. The supplier shall **also note that list** of standards presented in this specification is not complete. Whenever necessary **the list standards shall** be considered in conjunction with specific IS/IEC. When the specified requirements stipulated in the specifications exceed or differ than those required by the applicable standards, **the stipulation** of the specification shall take precedence.

Other internationally accepted standards which ensure **equivalent** or better performance that specified in the standards referred under section shall also be **acceptable**.

In case governing standards for the equivalent for the equipment is different from IS/ IEC, the salient points of difference shall be clearly brought out in additional information schedule along with English language version of standard of relevant extract of the same. The equipment conforming to standards other than IS/ IEC shall be subject to Purchaser's approval.

The full names of the codes and standards mentioned in abbreviations under various equipment heads are as follows:

BS British Standards
IEC/ CISPR International Electro-technical Commission

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

IS Bureau of Indian Standards
ISO International Organization for Standards
NEMA National Electric Manufacturers Association

3.4 SERVICES TO BE PERFORMED BY THE EQUIPMENT BEING FURNISHED

The 400 kV system is being designed to limit the power frequency over voltage of 1.5 p.u. and the switching surge over voltage to 2.5 p.u. In 400 kV system the initial value of temporary over voltage could be 2.0 p.u. for 1-2 cycles. All the equipment/materials covered in this specification shall perform all its function satisfactorily without undue strain, restriking etc. under such over voltage conditions. All equipment shall also perform satisfactorily under various other electrical, electromechanical and meteorological conditions of the site of installation. All equipment shall be able to withstand all external and internal mechanical, thermal and electromechanical forces due to various factors like wind load, temperature variation, ice & snow, (not applicable for this project) short circuit etc for the equipment .

The equipment shall also comply with the following:

- a) All equipments shall be suitable for hot line washing.
- b) To facilitate erection of equipment, all items to be assembled at site shall be "match marked".
- c) Piping, if any, between equipment control cabinet or operating mechanism to marshalling box of the equipment shall bear proper identification to facilitate the connection at site.
- d) All equipment shall be supplied with necessary inter-pole cabling, and its cost shall be included in the cost of equipment.

3.5 ENGINEERING DATA

3.5.1 Drawings

All drawings submitted by the supplier including those submitted at the time of bid shall be in sufficient detail to indicate the type, size, arrangement, material description, Bill of Materials, weight of each component, break-up for packing and shipment, the external connections, fixing arrangement required. The dimensions required for installation and interconnections with other equipment and materials, clearances and spaces required for installation and interconnections between various portions of equipment and any other information specifically requested in the specifications.

Each drawing submitted by the Contractor (including those of sub-vendors) shall bear a title block at the right hand bottom corner with clear mention of the name of the Employer, the system designation, the specifications title, the specification number, the name of the Project, drawing number and revisions. If standard catalogue pages are submitted, the applicable items shall be indicated therein. All titles, noting, markings and writings on the drawing shall be in English. All the dimensions should be in metric units.

After the approval of the drawings, further work by the Contractor shall be in strict accordance with these drawings and no deviation shall be permitted without the written approval of the Purchaser, if so required.

The review of these data by the purchaser will cover only general conformance of the data to the specification and documents, interfaces with the equipment provided under specification, external connections and of the dimensions which might affect plan layout. This review by the purchaser may not indicate a thorough review of the dimensions, quantities and details of the equipment, material, any devices or items indicated or the accuracy of the information submitted. This review and/or approval by the purchaser shall not be considered by the contractor, as limiting any of his responsibilities and liabilities for mistakes and deviations from the requirements, specified under these specifications and documents.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawings shall be at the Contractor's risk. The Contractor may make any changes in the design which are necessary to make the equipment conform to the provisions and intent of the Contract and such changes will again be subject to approval by the Purchaser. Approval of Contractor's drawing or work by the Purchaser shall not relieve the contractor of any of his responsibilities and liabilities under the Contract.

All engineering data submitted by the contractor after final process including review and approval by the purchaser shall form part of the contract document and the entire work performed under these specifications shall be performed in strict conformity, unless otherwise expressly requested by the purchaser in writing.

3.5.2 Approval Procedure

The following procedure for submission and review/approval of the drawings, data, reports, information, etc. shall be followed by Contractor:

- a. All data/information furnished by Vendor in the form of drawings, documents, Catalogues or in any other form for NTPC's information/interface and/or review and approval are referred by the general term "drawings".
- b. The 'Master drawings list' indicating titles, Drawing Number, Date of submission and approval etc. shall be finalised mutually between Contractor and Employer before the award of contract. This list shall be updated if required at suitable interval during detailed engineering.
- c. All drawings (including those of subvendor's) shall bear at the right hand bottom corner the 'title plate' with all relevant information duly filled in. The Contractor shall furnish this format to his subvendor along with his purchase order for subvendor's compliance.
- d. Contractor shall submit all the drawings in five (5) copies for review of Employer. Employer shall forward their comments within four (4) weeks of receipt of drawings.
- e. Upon review of each drawings, depending on the correctness and completeness of the drawings, the same will be categorised and approval accorded in one of the following categories:

CATEGORY I	Approved
CATEGORY II	Approved subject to incorporation of comments/modification as noted. Resubmit revised drawing incorporating the comments
CATEGORY III	Not approved. Resubmit revised drawings for Approval after incorporating comments/modifications as noted
CATEGORY IV	For information and records

- f. Contractor shall resubmit the drawings approved under Category II, III within one (1) week of receipt of comments on the drawings, incorporating all comments. Every revision of the drawing shall bear a revision index wherein such revisions shall be highlighted in the form of description or marked up in the drawing identifying the same with relevant revision number enclosed in a triangle (e.g 1.2.3. etc.).
- g. In case Contractor does not agree with any specific comment, he shall furnish the explanation for the same to Employer consideration. In all such cases Contractor shall necessarily enclose explanations along with the revised drawing (taking care of balance comments) to avoid any delay and/or duplication in review work.
- h. It is the responsibility of the Contractor to get all the drawings approved in the Category I or IV (as the case may be) and complete engineering activities within the agreed schedule. Any delay

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

arising out of submission and modification of drawings shall not alter the contract completion schedule.

- i. Contractor shall not make any changes in the portion of the drawing other than those commented. If changes are required to be made in the portions already approved, the Contractor shall resubmit the drawings identifying the changes (along with reasons for changes) for Employer's review and approval. **Drawings resubmitted shall show clearly the portions where the same are revised marking the relevant revision numbers and Employer shall review only such revised portion of documents.**
- j. Approval of drawings will not in any way relieve the Contractor of his obligations of furnishing the equipment in accordance with the specification and shall not prevent subsequent rejection if such equipment is later found to be defective.

3.5.3 Erection Drawings.

- a. Contractor shall furnish erection drawings for the guidance or commencement of erection or the first shipment, whichever is earlier. These shall generally comprise of fabrication/assembly drawings, various component/part details drawing, assembly, clearance data requirements, etc. The drawings shall contain details of components/ equipment with identification number, match marks, bill of materials, assembly procedures etc.
- b. For all major equipment apart from above details, assembly sequence and instructions with check-lists shall be furnished in the form of erection manuals.

3.5.4 Instruction Manual

- a. The Contractor shall submit to the Employer preliminary instruction manuals for all the equipments for review. The final instructions manuals incorporating Employer's comments and complete in all respect shall be submitted at least sixty (60) days before the first shipment of the equipment. The instruction manuals shall contain full details and drawings of all the equipments, the transportation, storage, installation, testing, operation and maintenance procedures, etc. separately for each component/equipment along with log record format. These instruction manuals shall be submitted in five (5) copies for approval.
- b. If after commissioning and initial operation of the plant, the instruction manuals require any modifications/additions/changes, the same shall be incorporated and the updated final instruction manuals shall be submitted.
- c. The operating and maintenance instructions together with drawings (other than shop drawings) of the equipment, as completed, shall have sufficient details to enable the Employer to maintain, dismantle, reassemble and adjust all parts of the equipment. They shall give a step by step procedure for all operations likely to be carried out during the life of the plant/equipment, including erection, testing, commissioning, operation, maintenance dismantling and repair. Each manual shall also include a complete set of approved drawings together with performance/rating curves of the equipment and test certificates, wherever applicable. The contract shall not be considered completed for purpose of taking over until such instructions and drawings have been supplied to the Employer.
- d. A separate section of the manual shall be for each size/type of equipment and shall contain a detailed description of construction and operation, together with all relevant pamphlets.
- e. The manuals shall include the following
 - a) List of spare parts along with their drawing and catalogues and procedure for ordering spares.
 - b) Lubrication Schedule including charts showing lubrication checking, testing and replacement procedure to be carried daily, weekly, monthly & at longer intervals to ensure trouble free operation.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

- f. Where applicable, fault location charts shall be included to facilitate finding the cause of mal-operation or break down.
- g. A collection of the manufacturer's standard leaflets will not accepted to be taken as a compliance of this clause. The manual shall be specifically compiled for the concerned project.

3.5.5 Final Submission of drawings and documents:

The Contractor shall furnish the following after approval of all drawings /documents and test reports:

- a. List of drawings bearing the Employer's and Contractor's drawing number.
- b. Two (2) bound sets alongwith 4 CD-ROMs of all drawing.
- c. All documents/designs in two (2) copies as noted above.
- d. Contractor shall also furnish six (6) bound sets of all as-built drawings including the list of all as-built drawings bearing drawing numbers. The Contractor shall also furnish two (2) sets of CD-ROMs/ DVD/Portable hard disk of all as-built drawings as decided by the Employer.
- e. The Contractor shall also furnish four (4) copies of instruction/ operations & maintenance manuals (after approval) for all the equipments.

3.5.6 TEST REPORTS

Two (2) copies of all test reports shall be supplied for approval before shipment of Equipment. The report shall indicate clearly the standard value specified for each test to facilitate checking of the reports. After final approval six (6) bound copies of all type and routine test reports shall be submitted to Employer.

3.6 MATERIAL /WORKMANSHIP

Where the specification does not contain references to workmanship, equipment, materials and components of the covered equipment, it is essential that the same must be new, of highest grade of the best quality of their kind, conforming to best engineering practice and suitable for the purpose for which they are intended and shall ensure satisfactory performance throughout the service life.

In case where the equipment, materials or components are indicated in the specification as "similar" to any special standard the purchaser shall decide upon the question of similarity. When required by the specification or when required by the purchaser the contractor shall submit, for approval, all the information concerning the materials or components to be used in manufacture. Machinery, equipment, materials and components supplied, installed or used without such approval shall run the risk of subsequent rejection, it being understood that the cost as well as the time delay associated with the rejection shall be borne by the Contractor.

The design of the Works shall be such that installation, future expansions, replacements and general maintenance may be undertaken with a minimum of time and expenses. Each component shall be designed to be consistent with its duty and suitable factors of safety subject to mutual agreements. All joints and fastenings shall be devised, constructed and documented so that the component parts shall be accurately positioned and restrained to fulfill their required function. In general, screw threads shall be standard metric threads. The use of other thread forms will only be permitted when prior approval has been obtained from the Purchaser.

Whenever possible, all similar part of the works shall be made to gauge and shall also be made interchangeable with similar parts. All spare parts shall also be interchangeable and shall be made of the same materials and workmanship as the corresponding parts of the equipment supplied under the specification. Where feasible, common component units shall be employed in different pieces of equipment in order to minimize spare parts stocking requirements. All equipment of the same type and rating shall be physically and electrically interchangeable.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

The equipment offered in the bid only shall be accepted for supply, with the minimum modifications as agreed/accepted.

3.7 PROVISIONS FOR EXPOSURE TO HOT AND HUMID CLIMATE

Outdoor equipment supplied under the specification shall be suitable for service and storage under tropical conditions of high temperature, high humidity, heavy rainfall and environment favorable to the growth of fungi and mildew. The indoor equipment located in non-air-conditioned areas shall also be of same type.

SPACE HEATERS

The heaters shall be suitable for continuous operation at 230 V as supply voltage. On –off switch and fuse shall be provided.

One or more adequately rated thermostatically connected heaters shall be supplied to prevent condensation in any compartment. The heaters shall be installed in the compartment and electrical connections shall be made sufficiently away from below the heaters to minimize deterioration of supply wire insulation. The heaters shall be suitable to maintain the compartment temperature to prevent condensation.

The heaters shall be suitably designed to prevent any contact between the heater wire and the air and shall consist of coiled resistance wire centered in a metal sheath and completely encased in a highly compacted powder of magnesium oxide or other material having equal heat conducting and electrical insulation properties or they shall consist of resistance wire wound on a ceramic and completely covered with a ceramic material to prevent any contact between the wire and the air. Alternatively, they shall consist of a resistance wire mounted into a tubular ceramic body built into an envelope of stainless steel or the resistance wire is wound on a tubular ceramic body and embedded in vitreous glaze. The surface temperature of the heaters shall be restricted to a value which will not shorten the life of the heater sheaths or that of insulated wire or other component in the compartments.

FUNGI STATIC VARNISH

Besides the space heaters, special moisture and fungus resistance varnish shall be applied on parts which may be subjected or predisposed to the formation of fungi due to the presence or deposit of nutrient substances. The varnish shall not be applied to any surface of part where the treatment will interfere with the operation or performance of the equipment. Such surfaces or parts shall be protected against the application of the varnish.

Ventilation opening

In order to ensure adequate ventilation, compartments shall have ventilation openings provided with fine wire mesh of brass to prevent the entry of insects and to reduce to a minimum the entry of dirt and dust. Outdoor compartment openings shall be provided with shutter type blinds.

Degree of Protection

The enclosure of the Control Cabinets, Junction boxes and Marshalling Boxes, panels etc. to be installed shall provide degree of protection as detailed here under:

- a. Installed outdoor: IP- 55
- b. Installed indoor in air conditioned area: IP-31
- c. Installed in covered area: IP-52
- d. Installed indoor in non air-conditioned area where possibility of entry of water is limited: IP-41.
- e. For LT Switchgear (AC & DC distribution Boards) : IP-52

The degree of protection shall be in accordance with IS: 13947 (Part –I) / IEC-947 (Part-I) / IS 12063/IEC 529. Type test report for degree of protection test, on each type of the box shall be submitted for approval.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

PRESERVATIVE SHOP COATING

All exposed metallic surfaces subject to corrosion shall be protected by shop application of suitable coatings. All surfaces which will not be easily accessible after the shop assembly, shall be treated beforehand and protected for the life of the equipment. All surfaces shall be thoroughly cleaned of all mill scales, oxides and other coatings and prepared in the shop. The surfaces that are to be finish-painted after installation or require corrosion protection until installation, shall be shop painted as per the requirements covered in the relevant part of the Technical Specification.

Transformers and other electrical equipments, if included shall be shop finished with one or more coats of primer and two coats of high grade resistance enamel. The finished colors shall be as per manufacturer's standards, to be selected and specified by the Employer at a later date.

Shop primer for all steel surfaces which will be exposed to operating temperature below 95 degrees Celsius shall be selected by the Contractor after obtaining specific approval of the Employer regarding the quality of primer proposed to be applied. Special high temperature primer shall be used on surfaces exposed to temperature higher than 95 degrees Celsius and such primer shall also be subject to the approval of the Employer.

3.8 RATING PLATES, NAME PLATES AND LABELS

- 3.8.1 Each equipment shall have permanently attached to it in a conspicuous position, a rating plate of non-corrosive material upon which shall be engraved manufacturer's name, equipment, type or serial number together with details of the ratings, service conditions under which the item of plant in question has been designed to operate, and such diagram plates as may be required by the Employer.
- 3.8.2 Such nameplates or labels shall be of white nonhygroscopic material with engraved black lettering or alternately, in the case of indoor circuit breakers, starters, etc. of transparent plastic material with suitably coloured lettering engraved on the back.
- 3.8.3 The rated current, extended current rating and rated thermal current shall be clearly indicated in the name plate in case of current transformer.
- 3.8.4 Rated voltage, voltage factor and intermediate voltage shall be clearly indicated on the nameplate in case of capacitor voltage transformer.
- 3.8.5 Each switch shall have a clear inscription identifying its function. Switches shall also have a clear inscription of each position indication.
- 3.8.6 All segregated phases of conductors or bus ducts, indoor or outdoor, shall be provided with coloured phase plates to clearly identify the phase of the system.
- 3.8.7 All such plates, instruction plates, etc. shall be bilingual with Hindi inscription first, followed by English. Alternatively, two separate plates one with Hindi and the other with English inscriptions may be provided.

3.9 GALVANISING:

- 3.9.1 The galvanised surface shall consist of a continuous film adhering to the steel. The finished surface shall be clean and smooth, and shall be free from defects like dissolved patches, base, spot, unevenness of coating, spelter which is loosely attached to the steel globules, spiky deposits, blistered surfaces, flaking or peeling off, etc. The presence of any of these defects shall render the material liable to rejection.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

3.9.2 All exposed ferrous parts shall be hot dip galvanised as per IS:2629 & IS:2633, Galvanising shall be uniform, smooth continuous and free from acid spots. Should the galvanising of the sample be found defective, the entire batch of steel shall have to be re-galvanised at Contractor's cost. The amount of zinc deposit shall be not less than 610 gms. per sq.m. of surface area and in addition, the thickness of zinc at any spot shall not be less than 85 microns. The Employer reserves the right to measure the thickness of zinc deposit by Elkometer or any other instrument acceptable to Employer and reject any component which shows thickness of zinc at any location less than 85 microns. The testing on the galvanised materials shall be carried out as per IS:2633.

3.9.3 The amount of zinc deposit over threaded portion of the bolts, nuts and screws shall not be less than 300 gms. per sq. meter of surface area. The amount of zinc deposit on washers shall not be less than 340 gms. per sq. meter of surface area. The threads having extra deposit of zinc shall be removed by die cutting after the completion of galvanising. The removal of extra zinc shall be carefully done so that threads shall have minimum deposits of zinc on them as specified.

3.10 PAINTING

Unless explicitly stated in relevant chapters of the specification, the painting of all electrical equipment shall be as follows:

Epoxy based with suitable additives. The thickness of finish coat shall be minimum 50 microns (minimum total DFT shall be 100 microns). However in case electrostatic process of painting is offered for any electrical equipment, minimum paint thickness of 50 microns shall be acceptable for finish coat. Paint shade shall be as per technical specification.

3.11 QUALITY ASSURANCE PROGRAMME

3.11.1 The Contractor shall adopt suitable quality assurance programme to ensure that the equipment and services under the scope of contract whether manufactured or performed within the Contractor's works or at his subcontractor's premises or at the Employer's site or at any other place of work are in accordance with the specifications. Such programmes shall be outlined by the Contractor and shall be finally accepted by the Employer/authorised representative after discussions before the award of the contract. The QA programme shall be generally in line with ISO-9001/IS- 14001.

A quality assurance programme of the contractor shall generally cover the following:

- i. His organisation structure for the management and implementation of the proposed quality assurance programme
- ii. Quality System Manual
- iii. Design Control System
- iv. Documentation Data Control System
- v. Qualification data for Bidder's key Personnel.
- vi. The procedure for purchase of materials, parts, components and selection of subcontractor's services including vendor analysis, source inspection, incoming raw-material inspection, verification of materials purchased etc.
- vii. System for shop manufacturing and site erection controls including process, fabrication and assembly.
- viii. Control of non-conforming items and system for corrective actions and resolution of deviations.
- ix. Inspection and test procedure both for manufacture and field activities.
- x. Control of calibration and testing of measuring testing equipments.
- xi. System for Quality Audits.
- xii. System for identification and appraisal of inspection status.
- xiii. System for authorising release of manufactured product to the Employer.
- xiv. System for handling storage and delivery.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

- xv. System for maintenance of records, and
- xvi. Furnishing quality plans for manufacturing and field activities detailing out the specific quality control procedure adopted for controlling the quality characteristics relevant to each item of equipment/component as per format enclosed as Annexure-I.

3.12 GENERAL REQUIREMENTS - QUALITY ASSURANCE

- 3.12.1 All materials, components and equipment covered under this specification shall be procured, manufactured, erected, commissioned and tested at all the stages, as per a comprehensive Quality Assurance Programme. An indicative programme of inspection/tests to be carried out by the contractor for some of the major items is given in the respective technical specification. This is, however, not intended to form a comprehensive programme as it is the contractor's responsibility to draw up and implement such programme duly approved by the Employer. The detailed Quality Plans for manufacturing and field activities should be drawn up by the Bidder and will be submitted to Employer for approval. Schedule of finalisation of such quality plans will be finalised before award.
- 3.12.2 Manufacturing Quality Plan will detail out for all the components and equipment, various tests/inspection, to be carried out as per the requirements of this specification and standards mentioned therein and quality practices and procedures followed by Contractor's/ Sub-contractor's/ sub-supplier's Quality Control Organisation, the relevant reference documents and standards, acceptance norms, inspection documents raised etc., during all stages of materials procurement, manufacture, assembly and final testing/performance testing. The Quality Plan shall be submitted on electronic media e.g. floppy or E-mail in addition to hard copy, for review. Once the same is finalised, hard copies shall be submitted for approval. After approval the same shall be submitted in compiled form on CD ROM.
- 3.12.3 Field Quality Plans will detail out for all the equipment, the quality practices and procedures etc. to be followed by the Contractor's site Quality Control Organisation, during various stages of site activities starting from receipt of materials/equipment at site.
- 3.12.4 The Bidder shall also furnish copies of the reference documents/plant standards/acceptance norms/tests and inspection procedure etc., as referred in Quality Plans along with Quality Plans. These Quality Plans and reference documents/standards etc. will be subject to Employer's approval without which manufacturer shall not proceed.
- 3.12.5 These approved documents shall form a part of the contract. In these approved Quality Plans, Employer shall identify customer hold points (CHP), i.e. test/checks which shall be carried out in presence of the Employer's Project Manager or his authorised representative and beyond which the work will not proceed without consent of Employer/Authorised representative in writing. All deviations to this specification, approved quality plans and applicable standards must be documented and referred to Employer along with technical justification for approval and dispositioning.
- 3.12.6 No material shall be despatched from the manufacturer's works before the same is accepted subsequent to pre-despatch final inspection including verification of records of all previous tests/inspections by Employer's Project Manager/Authorised representative and duly authorised for despatch by issuance of MDCC.
- 3.12.7 All material used for equipment manufacture including casting and forging etc. shall be of tested quality as per relevant codes/standards. Details of results of the tests conducted to determine the mechanical properties, chemical analysis and details of heat treatment procedure recommended and actually followed shall be recorded on certificates and time temperature chart. Tests shall be carried out as per applicable material standards and/or agreed details.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

- 3.12.8 All welding and brazing shall be carried out as per procedure drawn and qualified in accordance with requirements of ASME Section IX/BS-4870 or other International equivalent standard acceptable to the Employer.
- 3.12.9 All welding/brazing procedures shall be submitted to the Employer or its authorised representative for approval prior to carrying out the welding/brazing.
- 3.12.10 All brazers, welders and welding operators employed on any part of the contract either in Contractor's/his sub-contractor's works or at site or elsewhere shall be qualified as per ASME Section-IX or BS-4871 or other equivalent International Standards acceptable to the Employer.
- 3.12.11 Test results or qualification tests and specimen testing shall be furnished to the Employer for approval. However, where required by the Employer, tests shall be conducted in presence of Employer/authorised representative.
- 3.12.12 For all pressure parts and high pressure piping welding, the latest applicable requirements of the IBR (Indian Boiler Regulations) shall also be essentially complied with. Similarly, any other statutory requirements for the equipments/systems shall also be complied with. On all back-gauged welds MPI/LPI shall be carried before seal welding.
- 3.12.13 All the heat treatment results shall be recorded on time temperature charts and verified with recommended regimes.
- 3.12.14 No welding shall be carried out on cast iron components for repair.
- 3.12.15 Unless otherwise proven and specifically agreed with the Employer, welding of dissimilar materials and high alloy materials shall be carried out at shop only.
- 3.12.16 All non-destructive examination shall be performed in accordance with written procedures as per International Standards. The NDT operator shall be qualified as per SNT-TC-IA (of the American Society of non-destructive examination). NDT shall be recorded in a report which includes details of methods and equipment used, result/evaluation, job data and identification of personnel employed and details of co-relation of the test report with the job.

In general all plates of thickness greater than 40mm & for pressure parts plates of thickness equal to or greater than 25mm shall be ultrasonically tested otherwise as specified in respective equipment specification. All bar stock/Forging of diameter equal to or greater than 50mm shall be ultrasonically tested.

The Contractor shall list out all major items/ equipment/ components to be manufactured in house as well as procured from sub-contractors (BOI). All the subcontractor proposed by the Contractor for procurement of major bought out items including castings, forging, semi-finished and finished components/equipment etc., list of which shall be drawn up by the Contractor and finalised with the Employer, shall be subject to Employer's approval. The contractor's proposal shall include vendor's facilities established at the respective works, the process capability, process stabilization, QC systems followed, experience list, etc. along with his own technical evaluation for identified subcontractors enclosed and shall be submitted to the Employer for approval within the period agreed at the time of pre-awards discussion and identified in "DR" category prior to any procurement. Such vendor approval shall not relieve the contractor from any obligation, duty or responsibility under the contract.

- 3.12.17 For components/equipment procured by the contractors for the purpose of the contract, after obtaining the written approval of the Employer, the contractor's purchase specifications and inquiries shall call for quality plans to be submitted by the suppliers. The quality plans called for from the subcontractor shall set out, during the various stages of manufacture and installation, the quality practices and procedures followed by the vendor's quality control

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

organisation, the relevant reference documents/standards used, acceptance level, inspection of documentation raised, etc.

- 3.12.18 Employer reserves the right to carry out quality audit and quality surveillance of the systems and procedures of the Contractor's or their sub vendor's quality management and control activities. The contractor shall provide all necessary assistance to enable the Employer carry out such audit and surveillance.
- 3.12.19 The contractor shall carry out an inspection and testing programme during manufacture in his work and that of his sub-contractors and at site to ensure the mechanical accuracy of components, compliance with drawings, conformance to functional and performance requirements, identity and acceptability of all materials parts and equipment. Contractor shall carry out all tests/inspection required to establish that the items/equipments conform to requirements of the specification and the relevant codes/standards specified in the specification, in addition to carrying out tests as per the approved quality plan.
- 3.12.20 Quality audit/surveillance/approval of the results of the tests and inspection will not, however, prejudice the right of the Employer to reject the equipment if it does not comply with the specification when erected or does not give complete satisfaction in service and the above shall in no way limit the liabilities and responsibilities of the Contractor in ensuring complete conformance of the materials/equipment supplied to relevant specification, standard, data sheets, drawings, etc.
- 3.12.21 For all spares and replacement items, the quality requirements as agreed for the main equipment supply shall be applicable.
- 3.12.22 Repair/rectification procedures to be adopted to make the job acceptable shall be subject to the approval of the Employer/ authorised representative.

3.12.23 Environmental Stress Screening

All solid state electronic system / equipment / sub assembly shall be free from infant mortile components. For establishing the compliance to this requirement, the contractor / sub – contractor should meet the following.

1. The Contractor / Sub – contractor shall furnish the established procedure being followed for eliminating infant mortile components. The procedure followed by the Contractor / Sub – contractor should be substantiated along with the statistical figures to validate the procedure being followed. The necessary details as required under this clause shall be furnished at the stage of QP finalization.

Or

In case the Contractor / Sub – contractor do not have any established procedure to eliminate infant mortile components then two or 10% whichever is less, most densely populated Panels shall be tested for Elevated Temperature Cycle Test as per the following procedure.

Elevated Temperature Test Cycle

During the elevated temperature test which shall be for 48 hours, the ambient temperature shall be maintained at 50° C. The equipment shall be interconnected with devices and kept under energized conditions so as to repeatedly perform all operations it is expected to perform in actual service with load on various components being equal to those which will be experienced in actual service.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

During the elevated temperature test the cubicle doors shall be closed (or shall be in the position same as they are supposed to be in the field) and inside temperature in the zone of highest heat dissipating components / modules shall be monitored. The temperature rise inside the cubicle should not exceed 10° C above the ambient temperature at 50° C.

In case of any failure during the test cycle, the further course of action should be mutually discussed for demonstrating the intent of the above requirement.

Burn In Test Cycle

The test shall be conducted on all the panels fully assembled and wired including the panels having undergone the above mentioned elevated temperature test.

The period of Burn in Test Cycle shall be 120 hrs and process shall be similar to the elevated temperature test as above except that the temperature shall be reduced to the ambient temperature prevalent at that time.

During the above tests, the process I/O and other load on the system shall be simulated by simulated inputs and in the case of control systems, the process which is to be controlled shall also be simulated. Testing of individual components or modules shall not be acceptable.

During the Burn in Test the cubicle doors shall be closed (or shall be in the position same as they are supposed to be in the field) and inside temperature in the zone of highest heat dissipating components / modules shall be monitored. The temperature rise inside the cubicle should not exceed 10° C above the ambient temperature.

The Contractor / Sub-contractor shall carry out routine test on 100% item at contractor / sub-contractor's works. The quantum of check / test for routine & acceptance test by employer shall be generally as per criteria / sampling plan defined in referred standards. Wherever standards have not been mentioned quantum of check / test for routine / acceptance test shall be as agreed during detailed engineering stage.

3.13 QUALITY ASSURANCE DOCUMENTS

The Contractor shall be required to submit two hard copies and two sets on CDROM of the following Quality Assurance Documents as identified in respective quality plan with tick (✓) mark.

Each QA Documentation shall have a project specific Cover Sheet bearing name & identification number of equipment and including an index of its contents with page control on each document.

The QA Documentation file shall be progressively completed by the Supplier's sub-supplier to allow regular reviews by all parties during the manufacturing.

The final quality document will be compiled and issued at the final assembly place of equipment before dispatch. However CD-Rom may be issued not later than three weeks.

3.13.1 Typical contents of Quality Assurance Document are as below:-

- i) Quality Plan,
- ii) Material mill test reports on components as specified by the specification and approved Quality Plans.
- iii) Manufacturer / works test reports/results for testing required as per applicable codes and standard referred in the specification and approved Quality Plans.

- iv) Non-destructive examination results /reports including radiography interpretation reports. Sketches/drawings used for indicating the method of traceability of the radiographs to the location on the equipment.
- v) Heat Treatment Certificate/Record (Time- temperature Chart)
- vi) All the accepted Non-conformance Reports (Major/Minor) / deviation, including complete technical details / repair procedure).
- vii) CHP / Inspection reports duly signed by the Inspector of the Employer and Contractor for the agreed Customer Hold Points.
- viii) Certificate of Conformance (COC) whoever applicable.
- ix) MDCC

3.13.2 Similarly, the contractor shall be required to submit two hard copies and two sets on CD ROM of Quality Assurance Documents (in line with above) pertaining to field activities as per Approved Field Quality Plans and other agreed manuals/ procedures, prior to commissioning of individual system.

3.13.3 Before dispatch/ commissioning of any equipment, the Supplier shall make sure that the corresponding quality document or in the case of protracted phased deliveries, the applicable section of the quality document file is completed. The supplier will then notify the Inspector regarding the readiness of the quality document (or applicable section) for review.

- i) If the result of the review carried out by the Inspector of the Quality document (or applicable section) is satisfactory. The Inspector shall stamp the quality document (or applicable section) for release.
- ii) If the quality document is unsatisfactory, the Supplier shall endeavour to correct the incompleteness, thus allowing finalizing the quality document (or applicable section) by time compatible with the requirements as per contract documents. When it is done, the quality document (or applicable section) is stamped by the Inspector.
- i) If a decision is made for dispatch, whereas all outstanding actions cannot be readily cleared for the release of the quality document by that time, the supplier shall immediately, upon shipment of the equipment, send a copy of the quality document Review Status signed by the Supplier Representative to the Inspector and notify of the committed date for the completion of all outstanding actions & submission. The Inspector shall stamp the quality document for applicable section when it is effectively completed. The submission of QA documentation package shall not be later than 3 weeks after the dispatch of equipment.

3.14 TRANSMISSION OF QUALITY DOCUMENTS

As a general rule, two hard copies of the quality document and Two CD ROMs shall be issued to the Employer after the delivery date for the corresponding equipment. One set of quality document shall be forwarded to Corporate Quality Assurance Department and other set to respective Site.

For the particular case of phased deliveries, the complete quality document to the Employer shall be issued not later than 1 month after the date of the last delivery similarly as stated above.

3.15 INSPECTION, TESTING & INSPECTION CERTIFICATE

3.15.1 The word 'Inspector' shall mean the Project Manager and/or his authorised representative and/or an outside inspection agency acting on behalf of the Employer to inspect and examine the materials and workmanship of the works during its manufacture or erection.

3.15.2 The Project Manager or his duly authorised representative and/or an outside inspection agency acting on behalf of the Employer shall have access at all reasonable times to inspect

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

and examine the materials and workmanship of the works during its manufacture or erection and if part of the works is being manufactured or assembled on other premises or works, the Contractor shall obtain for the Project Manager and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Contractor's own premises or works.

- 3.15.3 The Contractor shall give the Project Manager/Inspector fifteen (15) days written notice of any material being ready for testing. Such tests shall be to the Contractor's account except for the expenses of the Inspector's. The Project Manager/Inspector, unless the witnessing of the tests is virtually waived, will attend such tests within fifteen (15) days of the date on which the equipment is noticed as being ready for test/inspection failing which the contractor may proceed with test which shall be deemed to have been made in the inspector's presence and he shall forthwith forward to the inspector duly certified copies of test reports in two (2) copies.
- 3.15.4 The Project Manager or Inspector shall within fifteen (15) days from the date of inspection as defined herein give notice in writing to the Contractor, or any objection to any drawings and all or any equipment and workmanship which is in his opinion not in accordance with the contract. The Contractor shall give due consideration to such objections and shall either make modifications that may be necessary to meet the said objections or shall inform in writing to the Project Manager/Inspector giving reasons therein, that no modifications are necessary to comply with the contract.
- 3.15.5 When the factory tests have been completed at the Contractor's or subcontractor's works, the Project Manager /Inspector shall issue a certificate to this effect fifteen (15) days after completion of tests but if the tests are not witnessed by the Project Manager /Inspectors, the certificate shall be issued within fifteen (15) days of the receipt of the Contractor's test certificate by the Project Manager /Inspector. Project Manager /Inspector to issue such a certificate shall not prevent the Contractor from proceeding with the works. The completion of these tests or the issue of the certificates shall not bind the Employer to accept the equipment should it, on further tests after erection be found not to comply with the contract.
- 3.15.6 In all cases where the contract provides for tests whether at the premises or works of the Contractor or any sub-contractor, the Contractor, except where otherwise specified shall provide free of charge such items as labour, material, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the Project Manager /Inspector or his authorised representatives to carry out effectively such tests on the equipment in accordance with the Contractor and shall give facilities to the Project Manager/Inspector or to his authorised representative to accomplish testing.
- 3.15.7 The inspection by Project Manager / Inspector and issue of Inspection Certificate thereon shall in no way limit the liabilities and responsibilities of the Contractor in respect of the agreed Quality Assurance Programme forming a part of the contract.
- 3.15.8 To facilitate advance planning of inspection in addition to giving inspection notice, the Contractor shall furnish quarterly inspection programme indicating schedule dates of inspection at Customer Hold Point and final inspection stages. Updated quarterly inspection plans will be made for each three consecutive months and shall be furnished before beginning of each calendar month.
- 3.15.9 All inspection, measuring and test equipments used by contractor shall be calibrated periodically depending on its use and criticality of the test/measurement to be done. The Contractor shall maintain all the relevant records of periodic calibration and instrument identification, and shall produce the same for inspection by NTPC. Wherever asked specifically, the contractor shall re-calibrate the measuring/test equipments in the presence of Project Manager / Inspector.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW) CUSTOMER: NTPC LTD.
--

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

3.16 PACKAGING & TRANSPORTATION

Items shall be packed & dispatched separately to respective sites i.e. to 400/220kV S/s at NKSTPP end & to 220kV S/s at Chatti Bariatu & Kerandari-A mine end.

3.16.1 Packing, Marking and shipping

The packing and shipping shall be carried out in accordance with the standard practice of Contractor and with the following additional requirements:

- a) The equipment shall be prepared in such a manner as to protect the equipment from damage or deterioration during shipping or storage. The shipments can be exposed to heavy rains, hot sun, high humidity and sudden extreme changes of temperature. The equipment shall be packed and shipped so as to protect it from all such conditions and any other abnormal conditions, generally expected during shipping & storage.
- b) The metallic containers, if any, shall be considered as the property of the Contractor and he will be allowed to remove them from site once the contents are unpacked, inspected, documented and placed in temporary storage or in final position.
- c) The equipment shall be shipped in such a manner as to facilitate unloading, handling and storage enroute and at the site. The Contractor shall provide lifting lugs and special lifting devices for proper handling and erection.
- d) The Contractor shall be liable for any damage or loss resulting due to careless, improper, poor or insufficient packing and handling.
- e) Spare parts and spare equipment shall be packed separately in containers adequate for long term storage, plainly marked "Spare Parts Only". They shall be crated individually or in kits to be used in one single renewal or overhaul operation. Other spare part kits shall not be disturbed when using one set or kit.
- f) The Contractor shall at all times protect and preserve from damage, loss, corrosion and all other forms of damage, all parts of the works.

3.16.2 Transportation

- a) The Contractor shall make a careful examination of access rail/roadways to the site in order to confirm the practical maximum transport weight and dimensions as well as a careful examination of the ports of disembarkation particularly with respect to the capacity of the cranes installed and access roads.
- b) All instruments and computer/microprocessor based equipment imported into India from overseas for the purpose of this contract shall be air freighted to the nearest possible point and further by rail/road taking due precautions as per manufacturer's recommendations. Employer shall have the right to decide the items that should be air freighted and Employer's decision shall be binding on Contractor.

3.16.3 Insurance

- a) The Contractor shall insure all shipments and works at his own expense for not less than the full replacement cost plus any additional cost for accelerated manufacturing of the replacement parts.
- b) Loss or the damage to equipment during shipping or transportation to the site(s) or otherwise

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

shall not constitute groups for claims for extension in time or for extra payment.

3.17 CLAMPS AND CONNECTORS INCLUDING TERMINAL CONNECTORS

- 3.17.1 The material of clamps and connectors shall be Aluminium alloy casting conforming to designation A6 of IS:617 for connecting to equipment terminals and conductors of aluminium. In case the terminals are of copper, the same clamps/connectors shall be used with 2mm thick bimetallic liner.
- 3.17.2 The material of clamps and connectors shall be Galvanised mild steel for connecting to shield wire.
- 3.17.3 Bolts, nuts and plain washers shall be hot dip galvanised mild steel for sizes M12 and above. For sizes below M12, they shall be electro-galvanised mild steel. The spring washers shall be electro-galvanised mild steel.
- 3.17.4 All castings shall be free from blow holes, surface blisters, cracks and cavities. All sharp edges and corners shall be rounded off to meet specified corona and radio interference requirements.
- 3.17.5 They shall have same current rating as that of the connected equipment. All current carrying parts shall be at least 10 mm thick. The connectors shall be manufactured to have minimum contact resistance.
- 3.17.6 Flexible connectors, braids or laminated strips shall be made up of copper/aluminium.
- 3.17.7 Current rating and size of terminal/conductor for which connector is suitable shall be put on a suitable sticker on each component which should last atleast till erection time.

3.18 BUSHINGS, HOLLOW COLUMN INSULATORS, SUPPORT INSULATORS, AND DISC INSULATORS

- 3.18.1 Bushings shall be manufactured and tested in accordance with IS: 2099 & IEC: 137 while hollow column insulators shall be manufactured and tested in accordance with IEC 233/IS 5284. The support insulators shall be manufactured and tested as per IS: / IEC 168/IEC 273. The insulators shall also conform to IEC 815 as applicable. Support insulators/ bushings/ hollow column insulators shall be designed to have ample insulation, mechanical strength and rigidity for the conditions under which they will be used.
- 3.18.2 Porcelain used shall be homogenous, free from laminations, cavities and other flaws or imperfections that might affect the mechanical or dielectric quality and shall be thoroughly vitrified, tough and impervious to moisture. Hollow porcelain should be in one integral piece in green & fired stage.
- 3.18.3 Glazing of the porcelain shall be uniform brown in colour, free from blisters, burns and other similar defects.
- 3.18.4 When operating at normal rated voltage there shall be no electric discharge between conductor and insulators which would cause corrosion or injury to conductors or when operating at normal rated voltage.
- 3.18.5 The design of the insulator shall be such that stresses due to expansion and contraction in any part of the insulator shall be lead to deterioration. All ferrous parts shall be hot dip galvanised.

- 3.18.6 Bushing porcelain shall be robust and capable of withstanding the internal pressures likely to occur in service. The design and location of clamps, the shape and the strength of the porcelain flange securing the bushing to the tank shall be such that there is no risk of fracture. All portions of the assembled porcelain enclosures and supports other than gaskets, which may in any way be exposed to the atmosphere shall be composed of completely non hygroscopic material such as metal or glazed porcelain.
- 3.18.7 All iron parts shall be hot dip galvanised and all joints shall be air tight. Surface of joints shall be trued, porcelain parts by grinding and metal parts by machining. Insulator/ bushing design shall be such as to ensure a uniform compressive pressure on the joints.
- 3.18.8 Insulator shall also meet requirement of IEC - 815 as applicable, having alternate long & short sheds.

3.19 CONTROL CABINETS, JUNCTION BOXES, TERMINAL BOXES & MARSHALLING BOXES FOR OUTDOOR EQUIPMENT.

- 3.19.1 All types of control cabinets, junction boxes, marshaling boxes, lighting panels, terminal boxes, operating mechanism boxes, Kiosks etc. shall generally conform to IS:5039, IS:8623 and IEC:439 as applicable.
- 3.19.2 **Mechanism Box/ Control Cabinet/ Kiosks:** A sheet steel (atleast 2.5 mm thick), dust and vermin proof M.Box/CCC/CMB shall be provided with proper lighting and thermostatically controlled space heaters. The degree of protection shall be IP 55. One dummy terminal block in between each trip wire terminal shall be provided. At least 20% spare terminals shall be provided on each panel. The gasket used shall be of neoprene rubber.

Painting of boxes shall be as follows,

- External surface : Chemical resistant epoxy zinc phosphate primer, MIO (Micaceous iron oxide) as intermediate paint followed by polyurethane finish paint (**RAL 5012 Blue**)
- Internal surface : Chemical resistant epoxy zinc phosphate primer followed by chemical & heat resistant **epoxy enamel white paint**.

- 3.19.3 **Junction Boxes:** The junction boxes shall be made of minimum 2 mm thick sheet steel. Gland plates shall be removable type and made of 3 mm thick sheet steel. The boxes shall be provided with detachable cover or hinged door with captive screws. Top of the box shall be arranged to slope towards the rear of the box. The box shall be **hot dip galvanised** and shall be provided with suitable neoprene gaskets to achieve requisite degree of protection. Adequate spacing shall be provided to terminate the external cables. The boxes shall be suitable for mounting on various types of steel structures. The terminal blocks provided shall be of 650 V grade, rated for 10 A for control cables. Suitable numbering for terminal blocks shall be done. In case of junction box for power cable, the box shall be rated for maximum current carrying capacity. Terminal blocks shall be of one piece, Klippon RSF-1 or ELMEX CSLT-1 type with insulating barriers.
- 3.19.4 The cabinets/boxes/kiosks/panels shall be free standing or wall mounting or pedestal mounting type. They shall have hinged doors with padlocking arrangement. All doors, removable covers and plates shall be gasketed all around with neoprene gaskets.
- 3.19.5 The degree of protection of of all the outdoor boxes shall not be less than IP 55 as per IS 2147.
- 3.19.6 The cable entry shall be from bottom, for which removable gasketed cable gland plates shall be provided.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)
CUSTOMER: NTPC LTD.

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

- 3.19.7 Suitable 240V, single phase, 50Hz ac heaters with thermostats controlled by switch and fuse shall be provided to maintain inside temperature 10deg. above the ambient.
- 3.19.8 The size of enclosure and the layout of equipment inside shall provide generous clearances. Each cabinet/box/kiosk/panel shall be provided with a 15A, 240V ac, 2 pole, 3 pin industrial grade receptacle with switch. For incoming supply, MCB of suitable rating shall be provided. Illumination of each compartment shall be with door operated incandescent lamp. All control switches shall be of rotary switch type.
- 3.19.9 Each cabinet/box/kiosk/panel shall be provided with two earthing pads to receive 75mmx12mm GS flat. The connection shall be bolted type with two bolts per pad. The hinged door shall be connected to body using flexible wire. The cabinets/boxes/kiosks/panels shall also be provided with danger plate, and internal wiring diagram pasted on inside of the door. The front label shall be on a 3mm thick plastic plate with white letters engraved on black background

3.20 TERMINAL BLOCKS

- 3.20.1 They shall be non-disconnecting stud type of extensible design equivalent to Elmex type CAT-M4.
- 3.20.2 The terminal blocks shall be of 650 V grade, and rated to continuously carry maximum expected current. The conducting part shall be tinned or silver plated.
- 3.20.3 They shall be of moulded, non-inflammable thermosetting plastic. The material shall not deteriorate with varied conditions of temperature and humidity. The terminal blocks shall be fully enclosed with removable covers of transparent, non deteriorating plastic material. Insulating barriers shall be provided between the terminal blocks so that the barriers do not hinder the wiring operation without removing the barriers.
- 3.20.4 The terminals shall be provided with marking tags for wiring identification.
- 3.20.5 Unless otherwise required (expected current rating) or specified, terminal blocks shall be suitable for connecting the following conductors on each side:
All CT & VT circuits - Min. four 2.5 sq.mm. copper flexible conductor
AC & DC power supply -Two 16 sq.mm. Aluminium conductor
Other control circuits - Min. two 2.5 sq.mm. copper flexible conductor.
- 3.20.6 The terminal blocks for CT and VT secondary leads shall be provided with test links and isolating facilities. CT secondary leads shall also be provided with short circuiting and earthing facilities.

3.21 Wiring

- 3.21.1 All wiring shall be carried out with 1100 V grade stranded copper wires. The minimum size of the stranded conductor used for internal wiring shall be as follows:
a) All circuits except CT circuits 2.5 sq.mm
b) CT circuits 4 sq. mm (minimum number of strands shall be 3 per conductor).
- 3.21.2 All internal wiring shall be securely supported, neatly arranged readily accessible and connected to equipment terminals and terminal blocks.
- 3.21.3 Wire terminations shall be made with solderless crimping type of tinned copper lugs which firmly grip the conductor and insulation. Insulated sleeves shall be provided at all the wire terminations. Engraved core identification plastic ferrules marked to correspond with the wiring diagram shall be fitted at both ends of each wire. Ferrules shall fit tightly on the wires

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

shall not fall off when the wires and shall not fall off when the wire is disconnected from terminal blocks.

- 3.21.4 All wires directly connected to trip circuit breaker shall be distinguished by the addition of a red coloured unlettered ferrule. Number 6 & 9 shall not be included for ferrules purposes.
- 3.21.5 All terminals including spare terminals of auxiliary equipment shall be wired upto terminal blocks. Each equipment shall have its own central control cabinet in which all contacts including spare contacts from all poles shall be wired out. Interpole cabling for all equipment's shall be carried out by the Contractor.

3.22 CABLE GLANDS AND LUGS

- 3.22.1 Cable glands shall be Double compression type, tinned/Nicked plated (coating thickness not less than 20 microns in case of tin and 10 to 15 microns in case of nickel) brass cable glands for all power and control cables. They shall provide dust and weather proof terminations. They shall comprise of heavy duty brass casting, machine finished and tinned to avoid corrosion and oxidation. Rubber components used in cable glands shall be neoprene and off tested quality. Required number of packing glands to close unused openings in gland plates shall also be provided.
- 3.22.2 The cable glands shall be tested as per BS:6121. The cable glands shall also be duly tested for dust proof and weather proof termination.
- 3.22.3 Cables lugs for power cables shall be tinned copper solder less crimping type conforming to IS:8309 and 8394 suitable for aluminum or copper conductor (as applicable). Cable lugs and ferrules for control cables shall be tinned copper type. The cable lugs for control cables shall be provided with insulating sleeve and shall suit the type of terminals provided on the equipments. The cable lugs shall suit the type of terminals provided. The cable lugs shall be of Dowell make or equivalent.

3.4 CONDUITS, PIPES AND ACCESSORIES

- 3.4.1 The bidder shall supply and install all rigid conduits, mild steel pipes, flexible conduits, hume pipes, etc. including all necessary sundry materials, such as tees, elbows, check nuts, bushing reduces, enlargers, wooden plugs, coupling caps, nipples, gland sealing fittings, pull boxes, etc.
- 3.4.2 Rigid conduits shall be flow-coat metal conduits of Nagarjuna Coated Tubes or equivalent make. The outer surface of the conduits shall be coated with hot-dip zinc and chromate conversion coatings. The inner surface shall have silicone epoxy ester coating for easy cable pulling. Mild steel pipes shall be hot-dip galvanised. All rigid conduits/ pipes shall be of a reputed make.
- 3.4.3 Flexible conduits shall be heat-resistant lead coated steel, water-leak, fire and rust proof, and be of PLICA make or equivalent.

3.5 MOTOR CONTROL CENTRE

- 3.5.1 The 415 Volt motor control centres (if provided separately) shall conform to the requirements for boxes/cabinets/kiosks. They shall be fixed type, shall be fully sectionalised and shall be equipped with load break switches. Motor feeders shall be provided with isolating switch fuse unit and Contractor with thermal overload relay and single phase protection. The motor Contractor shall have one normally open auxiliary contact for alarm purposes. The motor control circuit shall be independent from all other control circuits.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

3.5.2 Isolating Switches

The incoming power supply isolating switch operation handle shall be interlocked with the control cabinet door as to prevent opening of door when main switch is closed. Device for by passing the door interlock shall also be provided. Switch handle shall have provision for locking in both fully open and fully closed positions.

3.5.3 Fuses

All fuses shall be of the HRC cartridge type, conforming to IS: 2208 and suitable to mount on plug-in type of fuse bases. Fuses shall be provided with visible operation indicators to show that they have operated. All accessible live connections shall be adequately shrouded, and it shall be possible to change fuses with the circuit alive, without danger of contact with live conductor. Insulated fuse pulling handle shall be supplied with each control cabinet.

3.6 MOTORS

3.6.1 Motors shall be "Squirrel Cage" three phase induction motors of sufficient size capable of satisfactory operation for the application and duty as required for the driven equipment and shall conform to type tests and shall be subjected to routine tests as per applicable standards.

3.6.2 Enclosures

- a) For motors to be installed outdoor, the motor enclosure shall have degree of protection IP: 55. For motors to be installed indoor, i.e. inside a box, the motor enclosure shall be dust proof equivalent to IP: 54.
- b) Two independent earthing points shall be provided on opposite sides of the motor for bolted connection of earthing conductor.
- c) Motors shall have drain plugs so located that they will drain water resulting condensation or other causes from all pockets in the motor casing.

3.6.3 Operational Features :

- a) Continuous motor ratings (name plate rating) shall be at least suitable for the driven equipment at design duty operating point of driven equipment that will arise in service.
- b) Motors shall be capable of giving rated output without reduction in the expected life span when operated continuously in the given system.

3.6.4 Starting Requirements

- a) All induction motors shall be suitable for full voltage direct on-line starting. These shall be capable of starting and accelerating to the rated speed alongwith the driven equipment without exceeding the acceptable winding temperature even when the supply voltage drops.
- b) Motors shall be capable of withstanding the electrodynamic stresses and heating imposed if it is started at a voltage of 110% of the rated value.
- c) The locked rotor current shall not exceed six(6) times the rated full load current for all motors subject to tolerance given in IS:325.
- d) Motors when started with driven equipment imposing full starting torque and supply voltage conditions specified shall be capable of withstanding at least two successive starts from cold condition at room temperature and one start from hot condition without injurious heating of winding. The motors shall also be suitable for three equally spread starts per hour under the above referred supply condition.
- e) The locked rotor withstand time under hot condition at 110% of rated voltage shall be more than starting time with the driven equipment of minimum permissible voltage by a least two seconds or 15% of the accelerating time whichever is greater. In case it is not possible to meet the above requirement, the Contractor shall offer centrifugal type speed switch mounted on the motor shaft which shall remain closed for speeds lower

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification	TB-316-369-006
Section-3: Project Details and General Specification	

than 20% and open for speeds above 20% of the rated. The speed switch shall be capable of withstanding 120% of the rated speed in either directions of rotation.

- 3.6.5 The maximum permissible temperature rise over the ambient temperature shall be within the limits specified in IS: 325 (for 3 phase induction motors) after adjustment due to increased ambient temperature specified.
- 3.6.6 The double amplitude of motor vibration shall be within the limits specified in IS:729. Vibration shall also be within the limits specified by the relevant standard for the driven equipment when measured at the motor bearings.
- 3.6.7 All the induction motors shall be capable of running at 80% of rated voltage for a period of 5 minutes.

3.7 AUXILIARY SWITCH

The auxiliary switch shall conform of following type tests:

- a) Electrical endurance test - A minimum of 1000 operations for 2A. D.C. with a time constant greater than or equal to 20 milliseconds with a subsequent examination of mV drop/ visual defects/ temperature rise test.
- b) Mechanical endurance test - A minimum of 5000 operations with a subsequent checking of contact pressure test/ visual examination
- c) Heat run test on contacts
- d) IR/HV test, etc.

3.8 LAMPS AND SOCKETS

3.8.1 Lamps:

All incandescent lamps shall use a socket base as per IS-1258, except in the case of signal lamps.

3.8.2 Sockets

All sockets (convenience outlets) shall be suitable to accept both 5 Amp & 15 Amp pin round Standard Indian plugs. They shall be switched sockets with shutters.

3.8.3 Hand Lamp:

A 240 Volts, single Phase, 50 Hz AC plug point shall be provided in the interior of each cubicle with ON-OFF Switch for connection of hand lamps.

3.9 SWITCHES & FUSES:

Each control panel shall be provided with necessary arrangements for receiving, distributing, isolating and fusing of DC and AC supplies for various control, signaling, lighting and space heater circuits. The incoming and sub-circuits shall be separately provided with switch-fuse units. Selection of the main and sub-circuit fuse ratings shall be such as to ensure selective clearance of sub-circuit faults. Potential circuits for relaying and metering shall be protected by HRC fuses.

All fuses shall be of HRC cartridge type conforming to IS 9228 mounted on plug-in type fuse bases. Miniature circuit breakers with thermal Protection and alarm contacts will also be accepted. All accessible live connection to fuse bases shall be adequately shrouded. Fuses shall have operation indicators for indicating blown fuse condition. Fuse carrier base shall have imprints of the fuse rating and voltage.

All control switches shall be of rotary type. Toggle/piano switches shall not be accepted.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW) CUSTOMER: NTPC LTD.
--

Technical Specification

TB-316-369-006

Section-3: Project Details and General Specification

3.10 TYPE, ROUTINE & ACCEPTANCE TESTS:

All equipments to be supplied shall be of type tested design. During contract stage, bidder shall submit for Owner's approval the reports of all the type tests listed in this specification and carried out within last ten years from the date **28.11.2013**. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the tests should have been either conducted at an independent laboratory or should have been witnessed by a client.

However if contractor is not able to submit report of the type tests conducted within ten years from the date **28.11.2013** or in the case of type test reports are not found to be meeting the specification requirements, the bidder shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/ owners representative and submit the reports for approval.

All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.


3.11 CORONA AND RIV TESTS AND SEISMIC WITHSTAND TEST:


- a) The corona (for 400kV only) and RIV tests shall confirm to the requirements as per Annexure A.
- b) The seismic withstand test for 400kV shall conform to requirements as per Annexure B.


3.12 Enclosures:


1. ANNEXURE- A - CORONA AND RADIO INTERFERENCE VOLTAGE (RIV) TEST
2. ANNEXURE- B - SEISMIC WITHSTAND TEST
3. ANNEXURE- I – MQP (NTPC format)
4. ANNEXURE- II – QUALITY ASSURANCE FOR SWITCHYARD


SECTION - 4
GUARANTEED TECHNICAL PARTICULARS


CLAUSE NO.	Bidder's Name	
<p>SUB-SECTION - I</p> <p>TECHNICAL INFORMATION AND DATA</p> <p>TO BE SUBMITTED</p> <p>WITH THE PROPOSAL</p>		
1.00.00	Bidder shall give the details of his previous experience for the similar supplies made by him till this date.	
2.00.00	TECHNICAL LITERATURE	
2.01.00	The following technical particulars shall be submitted by the Bidder alongwith his proposal as separate appendices to the proposal:	
	a) Type test certificate for cables including those for FRLS properties.	
3.00.00	TECHNICAL DATA	
	The following technical data shall be submitted by the bidder for each type and size of the cable, alongwith his proposal:	
	1. Make	:
	2. Country of Manufacturer	:
	3. Type Designation	:
	4. Applicable Standard	:
	5. Cable size	:
	6. Rated voltage	:
	7. Continuous current rating for max. conductor temperature:	
	a. When laid in air at an ambient temp. of 50 °C	:
	b. When buried in soil having thermal resistivity of 150 °C Cm/W at a depth of 1000 mm in ground amb. Temp. of 40 °C.	:
	8. Short circuit withstand capacity and duration for	
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID
		PAGE 1 OF 19


CLAUSE NO.	Bidder's Name	
	a. Conductor :	
	b. Armour :	
	9. Conductor	
	a. Material :	
	b. Nominal cross section area in sq. mm. :	
	c. Max. D. C. resistance at 20 °C :	
10.	Insulation	
	a. Material :	
	b. Nominal thickness (in mm) :	
	c. Identification of cores :	
11.	Material and Type of filler material (if required) :	
12.	Material and Type of inner sheath (if required) :	
13.	Armour	
	a. Material & shape :	
14.	Outer sheath	
	a. Material :	
	b. Colour :	
15.	Overall dia. of cable (in mm) :	
16.	Weight per 1000 metre (in Kg.) :	
17.	Standard drum length offered :	
SUB-SECTION - II		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID
		PAGE 3 OF 10


CLAUSE NO.	Bidder's Name		
	<p>TECHNICAL INFORMATION & DATA TO BE SUBMITTED AFTER THE AWARD OF CONTRACT</p> <p>1.0 The following Technical Data, Drawings & Test certificates shall be submitted by successful bidder. The actual schedule of submission of these data/drawings/test reports shall be mutually discussed and agreed to between the Employer and successful bidder before the issue of Award of contract.</p> <p>1.1 Technical Particulars and Drawings</p> <p>a) Sectional drawings of cables</p> <p>b) Approx. weight of metallic and non metallic items of each cable size</p> <p style="padding-left: 40px;">- Metallic (Kgs/Km)</p> <p style="padding-left: 40px;">- Non Metallic (Kgs/Km)</p> <p>c) Rating factors for variation in ambient air temp</p> <p>d) Rating factors for variation in amb. ground temp</p> <p>e) Rating factors for variation in depth of laying in ground</p> <p>f) Rating factors for variation in thermal resistivity of soil</p> <p>g) Grouping factors for cables laid in open air racks</p> <p>h) Grouping factors for cables laid in built Up concrete trenches with restricted air circulation</p> <p>i) Grouping factors for cables laid in ground</p> <p>j) Particulars of cable drums</p> <p>k) Grouping factors for cables laid in ducts/pipes</p>		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID	PAGE 4 OF 10


CLAUSE NO.	Bidder's Name	
1.2	<p>Test Certificates</p> <p>Complete test reports including type tests, routine tests and acceptance tests.</p>	
1.3	<p>Instruction manual for storage for prolonged duration, unpacking, handling at site, erection, pre-commissioning test etc.</p>	
1.4	<p>Technical Data</p>	
1.4.1	<p>The following technical data shall be submitted by the contractor for each type and size of the cable for employer's approval.</p> <p>1. Make :</p> <p>2. Country of manufacturer :</p> <p>3. Type designation :</p> <p>4. Applicable standard :</p> <p>5. Cable size (No. of cores x mm²) :</p> <p>6. Rated voltage :</p> <p>7. Continuous current rating for maximum conductor temp. when laid in air at ambient of 50 °C</p> <p style="padding-left: 40px;">a) When metallic armour is earthed at one end (amps) :</p> <p style="padding-left: 40px;">b) For unarmoured Cables (Amps) :</p> <p>8. Continuous current rating for max. conductor temp. when buried in soil having thermal resistivity of 150 °C Cm/N at a depth of 1 mt. at ground ambient temp. of 40 ° C.</p> <p style="padding-left: 40px;">a) When armour is earthed at one end (Amps) :</p>	
<p>NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE</p>	<p>TECHNICAL DATA SHEETS SECTION - VI PART-G</p>	<p>DB17:LT POWER POST BID</p> <p>PAGE 5 OF 10</p>

CLAUSE NO.	Bidder's Name	
11.	<p>b) For unarmoured Cables (Amps) :</p> <p>9.Short circuit withstand capacity and duration for</p> <p>a) Conductor :</p> <p>b) Armour :</p> <p>10. Conductor</p> <p>a) Material :</p> <p>b) Grade :</p> <p>c) Nominal cross sectional area (Sq. mm)</p> <p>d) Number and diameter of wires Before compacting of conductor Strands</p> <p style="padding-left: 40px;">i) No. of wires (min.)</p> <p style="padding-left: 40px;">ii) Dia. Of each wire in mm (min.):</p> <p>e) Shape of conductor :</p> <p>f) Diameter over conductor (mm) :</p> <p style="padding-left: 40px;">i) Fictitious (as per IS 10462 (part-1-1983) :</p> <p style="padding-left: 40px;">ii) Approximate :</p> <p>g) Direction of lay of stranded layer :</p> <p>h) Conductor resistance (DC) at 20 °C ohm/Km (max) :</p> <p>Conductor resistance (AC)</p> <p>a) at 20 °C ohm/Km :</p> <p>b) at 90 °C in ohm/Km (for XLPE Cables) :</p> <p>c) at 70 °C. in ohms/KM (for PVC Cables) :</p>	
<p>NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE</p>	<p>TECHNICAL DATA SHEETS SECTION - VI PART-G</p>	<p>DB17:LT POWER POST BID</p> <p>PAGE 6 OF 10</p>

CLAUSE NO.	Bidder's Name	
12.	Reactance per phase at 50 Hz in ohm/km :	
13.	Capacitance at 50 hz in micro Farads/Km	
14.	<p>Insulation</p> <p>a) Material and Type of insulation :</p> <p>b) Nominal thickness of insulation (mm) :</p> <p>c) Tolerance on thickness of insulation (mm) :</p> <p>d) Filled or unfilled (for XLPE only)</p> <p>e) Type of curing (for XLPE only) :</p> <p>f) Min. volume resistivity at - 27 °C (Ohm-cm) :</p> <p style="padding-left: 20px;">- 70 °C (Ohm-cm) (for PVC only) :</p> <p style="padding-left: 20px;">- 90 °C (Ohm-cm (for XLPE only) :</p> <p>g) Identification of cores :</p>	
15.	<p>Inner sheath</p> <p>a) Material and Type :</p> <p>b) Diameter over the laid up cores (mm) :</p> <p style="padding-left: 20px;">i) Calculated (By fictitious Calculations as per IS 10462 (part-1) 1983) :</p> <p style="padding-left: 20px;">ii) Approximate :</p> <p>c) Thickness of inner sheath (Min) (mm) :</p> <p>d) Colour of inner sheath :</p> <p>c) Tolerance in thickness of Inner sheath (mm) :</p>	
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID PAGE 7 OF 10

CLAUSE NO.	Bidder's Name	
16.	Material and Type of filler :	
17.	Armour (in case of armoured cables) a) Material and Type of armour : b) Shape : c) Diameter of cable over inner-sheath (under armour) mm : i) Calculated : (By Fictitious calculations as per IS 10462 (part-1) 1983) ii) Approximate : d) Dimension of formed wire/wire in mm : e) No. of armour formed wires/wires : f) Approx. cross sectional area of armour (Sq. mm) : g) Max. Resistivity of armour formed wire/wire at 20°C (ohm/km) : h) Direction of lay of armour :	
18.	Voltage developed in the armour per 100 mt. run with armour earthed at one end, when cable is carrying (for single core cables only) a) Rated current (Volts) : b) Short circuit current (Volts) :	
19.	Outer sheath a) Material and Type : b) Diameter under the outer sheath (mm) : i) Calculated : (By fictitious Calculations as per IS 10462 (part-1) 1983)	
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID PAGE 8 OF 10

CLAUSE NO.	Bidder's Name	
	ii) Approximate : c) Nominal thickness of outer sheath (mm) : d) Tolerance on Nominal thickness of outer sheath (mm) : e) Colour of outer sheath : 20. Guaranteed value of min. oxygen index of outer sheath : 21. Max. acid gas generation by weight (%): 22. Maximum smoke density rating (%) : 23. a) Overall diameter of cable (mm) : b) Tolerance on overall diameter (mm) : 24. Weight per 1000 mtrs (Kg) : 25. Recommended min. installation radius (mm) : 26. Safe pulling force when pulled by pulling eye on the conductor (N) : 27. Cable Drums a) Type (Wooden/steel) : b) Dimensions (Approx) : i) Flange diameter (mm) : ii) Barrel diameter (mm) : iii) Traverse (mm) : 28. Weight of cable drum with cable (Kgs) :	
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID PAGE 9 OF 10

CLAUSE NO.	Bidder's Name		
29.	Max./standard length per drum for each size of cable (single length with tolerance) (m) (%) :		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB17:LT POWER POST BID	PAGE 10 OF 10



SUB-SECTION-DB18
LT CONTROL CABLES

**NORTH KARANPURA STPP
(3X660 MW)
EPC PACKAGE**

**TECHNICAL DATA SHEETS
SECTION-VI
PART - G
BID DOC NO:CS-4410-001-2**


CLAUSE NO.


Bidder's Name





TECHNICAL DATA SHEETS


SUB-SECTION	TITLE
I	TECHNICAL INFORMATION & DATA TO BE SUBMITTED WITH THE PROPOSAL
II	TECHNICAL INFORMATION AND DATA TO BE SUBMITTED AFTER THE AWARD OF CONTRACT


CLAUSE NO.	Bidder's Name	
	<p>SUB-SECTION - I</p> <p>TECHNICAL INFORMATION AND DATA</p> <p>TO BE SUBMITTED WITH THE PROPOSAL</p> <p>1.00.00 Bidder shall give the details of his previous experience for the similar supplies made by him till this date.</p> <p>2.00.00 TECHNICAL LITERATURE</p> <p>2.01.00 The following technical particulars shall be submitted by the Bidder alongwith his proposal as separate appendices to the proposal:</p> <p style="padding-left: 20px;">a) Type test certificates for cables including those for FRLS properties.</p> <p>3.00.00 TECHNICAL DATA</p> <p>The following technical data shall be submitted by the bidder for each type and size of the cable, alongwith his proposal:</p> <p>1. Make :</p> <p>2. Country of Manufacturer :</p> <p>3. Type Designation :</p> <p>4. Applicable Standard :</p> <p>5. Cable size :</p> <p>6. Rated voltage :</p> <p>7. Continuous current rating for max. conductor temperature:</p> <p style="padding-left: 20px;">a. When laid in air at an ambient temp. of 50 ° C :</p> <p style="padding-left: 20px;">b. When buried in soil having thermal resistivity of 150 ° C Cm/W at a depth of 1000 mm at ground amb. Temp. of 40 ° C. :</p> <p>8. Short circuit withstand capacity and duration for</p> <p style="padding-left: 20px;">a. Conductor :</p> <p style="padding-left: 20px;">b. Armour :</p>	
<p>NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE</p>	<p>TECHNICAL DATA SHEETS SECTION - VI PART-G</p>	<p>DB18: LT CONTROL CABLE</p> <p>PAGE 2 OF 9</p>

CLAUSE NO.	Bidder's Name		
	<p>9. Conductor</p> <p>a. Material :</p> <p>b. Nominal cross section area in sq. mm. :</p> <p>c. Maximum D. C. resistance at 20 ° C :</p> <p>10. Insulation</p> <p>a. Material :</p> <p>b. Nominal thickness (in mm) :</p> <p>c. Identification of cores :</p> <p>11. Material and Type of filler material :</p> <p>12. Material and Type of inner sheath material :</p> <p>13. Armour</p> <p>a. Material type :</p> <p>14. Outersheath</p> <p>a. Material :</p> <p>b. Colour :</p> <p>15. Overall dia. of cable (in mm) :</p> <p>16. Weight per 1000 metre (in Kg.) :</p> <p>17. Standard drum length offered :</p>		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB18: LT CONTROL CABLE	PAGE 3 OF 9

CLAUSE NO.	Bidder's Name		
1.2	Test Certificates Complete test reports including type tests, routine tests and acceptance tests.		
1.3	Instructional manual for storage for prolonged duration, unpacking, handling at site, erection, pre-commissioning test etc.		
1.4	Technical Data		
1.4.1	The following technical data shall be submitted by the contractor for each type and size of the cable for Employer's approval.		
1.	Make :		
2.	Country of manufacturer	:	
3.	Type designation	:	
4.	Applicable standard	:	
5.	Cable size (No. of cores x mm²)	:	
6.	Rated voltage	:	
7.	Continuous current rating for maximum conductor temp. when laid in air at ambient of 50 ° C a) When armour is earthed at one end (amps) : b) For unarmoured Cables (Amps) : 8. Continuous current rating for max. conductor temp. when buried in soil having thermal resistivity of 150 ° C Cm/N at a depth of 1 m at ground ambient temp. of 40 °C. a) When armour is earthed at one end (Amps) : b) For unarmoured Cables (Amps) :		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB18: LT CONTROL CABLE	PAGE 5 OF 9

CLAUSE NO.	Bidder's Name	
	<p>9. Conductor</p> <p>a) Material :</p> <p>b) Grade :</p> <p>c) Nominal cross sectional area (Sq. mm)</p> <p>d) Number and diameter of wires before compacting of conductor strands</p> <p style="padding-left: 40px;">i) No. of wires (min.) .</p> <p style="padding-left: 40px;">ii) Dia. of each wires in mm (min.) :</p> <p>e) Shape of conductor :</p> <p>f) Diameter over conductor (mm) :</p> <p style="padding-left: 40px;">i) Fictitious (as per IS 10462 (part-1)-1983) :</p> <p style="padding-left: 40px;">ii) Approximate :</p> <p>g) Direction of lay of stranded layer :</p> <p>h) Conductor resistance (DC) at 20 deg. C ohm/Km (max) :</p> <p>10. Conductor resistance (AC)</p> <p>a) at 20 deg. C ohm/Km :</p> <p>b) at 70 deg. C. in ohms/Km :</p> <p>11. Reactance per phase at 50 Hz in ohm/km :</p> <p>12. Capacitance at 50 Hz in micro Farads/Km</p> <p>13. Insulation</p> <p>a) Material and Type of insulation :</p> <p>b) Nominal thickness of insulation (mm) :</p>	
<p>NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE</p>	<p>TECHNICAL DATA SHEETS SECTION - VI PART-G</p>	<p>DB18: LT CONTROL CABLE PAGE 6 OF 9</p>

CLAUSE NO.	Bidder's Name		
14.	c) Tolerance on thickness of insulation (mm) :	
	e) Min. volume resistivity at 20 deg. C (Mega Ohm/Km) :	
	f) Identification of cores :	
	Innersheath		
	a) Material & Type :	
	b) Diameter over the laid up cores (mm) :	
	i) Calculated (By fictitious Calculations as per IS 10462 (part-1) 1983) :	
	ii) Approximate :	
	c) Thickness of innersheath (Min) (mm) :	
	d) Colour of sheath :	
	e) Tolerance in thickness of Inner sheath (mm) :	
	15.	Material and Type of filler :
	16.	Armour (in case of armoured cables)	
	a) Material and Type of armour :	
b) Shape :		
c) Diameter of cable over inner-sheath (under armour) mm :		
i) Calculated (By fictitious calculations as per IS 10462 (part-1) 1983) :		
ii) Approximate :		
d) Dimension of formed wire/wire in mm :		
e) No. of armour formed wires/wires :		
f) Approx. cross sectional area of armour (Sq. mm) :		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB18: LT CONTROL CABLE	PAGE 7 OF 9

CLAUSE NO.	Bidder's Name		
	g) Max. Resistivity of armour formed wire/wire at 20 deg. C (ohm/km) : h) Direction of lay of armour :		
17.	Outersheath a) Material and type : b) Diameter under the sheath (mm) : i) Calculated (By fictitious Calculations as per IS 10462 (part-1) 1983) : ii) Approximate : c) Nominal thickness of sheath (mm) : d) Tolerance on Nominal thickness of outer sheath (mm) : e) Colour of outer sheath :		
18.	Guaranteed value of min. oxygen index of outer sheath :		
19.	Max. acid gas generation by weight (%) :		
20.	Maximum Smoke Density rating (%) :		
21.	a) Approx. overall diameter of cable (mm) : b) Tolerance on overall diameter (mm) :		
22.	Weight per 1000 mtrs (Kg) with a tolerance of $\pm 10\%$:		
23.	Recommended min. installation radius (mm) :		
24.	Safe pulling force when pulled by pulling eye on the conductor (N) :		
25.	Cable Drums a) Type (Wooden/steel) : b) Dimensions (Approx) :		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION - VI PART-G	DB18: LT CONTROL CABLE	PAGE 8 OF 9

Project: 400/220 kV Switchyard Package at
 North Karanpura Super Thermal Power Project (3 X 660 MW)
 Customer: NTPC Ltd.
 Technical Specification: 1.1 kV Aux Power & Control Cables

Bharat Heavy Electricals Limited
 Document No. TB 369 510 011

SECTION-5

**CHECK LIST FOR INFORMATION TO BE FURNISHED WITH OFFER RETURN THIS
 CHECKLIST AS PART OF THE OFFER DULY SIGNED**

The offer may not be considered if the following information and this Checklist are not enclosed with the Offer.

BHEL ENQUIRY. NO:

BIDDER OFFER REFERENCE:

A)

(1)	(2)	(3)	(4)	(5)
S.No.	Parameters	Data	Yes / No	Remarks in case reply in Col (4) is <i>NO</i>
1.0	Applicable Standard	Latest IS -1554, 5831, 8130, 7098, 3975, 613, ASTM-D2843, ASTM-D2863, IEC60754, IEC60332, IS3961, IS 10418, SS4241475, NEMA WC-70, IEEE-383; For screened cables, standards mentioned in Annexure-1B, Section-1.		
2.0	Type	FRLS		
3.0	Construction feature for PVC Control and Aux Power cable			
3.1a	Material of Conductor for Control cables	Plain Annealed, High Conductivity, Stranded, untinned Copper, Grade EC		
3.1b	Material of Conductor for Screened Cable	High Conductivity, Annealed bare copper, Electrolytic grade, Strands: 7x0.3mm (nom)		
3.2	Material of Conductor for Power cables	Stranded Aluminium, Grade H2 /H4		
3.3	Conductor Insulation for Control and Power cables	As per Annexure-1A, Section-1		
3.4a	Conductor insulation for Screened Control Cable	PVC Type Y13 (Insulation Thickness suitable for 1.1kV Voltage class as per relevant standards)		
(1)	(2)	(3)	(4)	(5)

Project: 400/220 kV Switchyard Package at
North Karanpura Super Thermal Power Project (3 X 660 MW)
Customer: NTPC Ltd.

Bharat Heavy Electricals Limited
Document No. TB 369 510 011

Technical Specification: 1.1 kV Aux Power & Control Cables

S.No.	Parameters	Data	Yes / No	Remarks in case reply in Col (4) is NO
3.4b	Shielding for <i>Screened Control Cable</i>	Al- Mylar Tape a) Individual Pair Shielding: 28 Micron Thickness (Min.) b) Overall cable assembly Shielding : 55micron Thickness (min)		
3.4c	Drain Wire for <i>Screened Control Cable</i>	For individual & Overall Shield: 7 Strand, 20 AWG (0.51sq.mm) annealed Tin coated copper		
3.5	Inner sheath	Extruded PVC, Type ST-1		
3.6a	Armouring for Control Cables	Galvanised Steel Round wire /formed wire for multicore cables		
3.6b	Armouring for Screened Control Cable	Galvanised Steel Round wire		
3.7	Armouring for Aux Power Cables	Aluminium round wire for Single core And Galvanised Steel round wire/formed wire for Multi-core cables		
3.8a	Outer sheath for Control and Power cables	PVC extruded, FRLS, Type ST-2, Category C2		
3.8b	Outer sheath for <i>Screened Control Cable</i>	PVC extruded, FRLS, Compound YM1		
4.0	Construction feature for XLPE Aux Power cable			
4.1	Material of Conductor for Power cables	Stranded Aluminium, Grade H2 /H4		
4.2	Conductor Insulation	XLPE		
4.3	Inner sheath	Extruded PVC, Type-ST2		
(1)	(2)	(3)	(4)	(5)
S.No.	Parameters	Data	Yes / No	Remarks in case reply in

Project: 400/220 kV Switchyard Package at
North Karanpura Super Thermal Power Project (3 X 660 MW)
Customer: NTPC Ltd.

Bharat Heavy Electricals Limited
Document No. TB 369 510 011

Technical Specification: 1.1 kV Aux Power & Control Cables

				Col (4) is <i>NO</i>
4.4	Armouring for Aux Power Cables	Aluminium round wire for Single core And Galvanised Steel round wire/formed wire for Multi-core cables		
4.5	Outer sheath	PVC extruded, FRLS, Type ST-2, Category C2		
5.0	FRLS properties of Outer sheath			
5.1	Minimum Oxygen index	29		
5.2	Minimum Temperature index	250°C		
5.3	Acid gas emission	Max 20% by weight		
5.4	Smoke density rating	Max 60%		
6.0	Tolerance on overall diameter	± 2mm		
7.0	Chemicals added to outer sheath to protect from rodent, vermin and termite attack	Yes		
8.0	Drum lengths shall be 1000m for cables with conductor cross section area less than 300 sq mm	Yes		
9.0	Tolerance on total quantity	± 2%		
10.0	Minimum bending radius for multicore cables	12 x D		
(1)	(2)	(3)	(4)	(5)
S.No.	Parameters	Data	Yes / No	Remarks in case reply in Col (4) is <i>NO</i>
11.0	Core Identification	By colour coding as per IS		

Project: 400/220 kV Switchyard Package at
 North Karanpura Super Thermal Power Project (3 X 660 MW)
 Customer: NTPC Ltd.

Bharat Heavy Electricals Limited
 Document No. TB 369 510 011

Technical Specification: 1.1 kV Aux Power & Control Cables

		1554 (Part-1)/ IS 7098 Part-I for the cables upto five (5) cores; and for the cables with more than five (5) cores, by printing legible Hindu Arabic numerals on all cores as per Clause 10.3 of IS 1554 (Part-1).		
12.0	The fillers and inner sheaths shall be of non-hygroscopic, fire retardant material, shall be softer than insulation and outer sheath shall be suitable for the operating temperature of the cable	Yes		

B) TYPE TESTS

- i) Whether valid type test reports of all the tests as per relevant IS including additional tests mentioned in this specification, conducted earlier on identical material are available (test reports shall be of the tests conducted not earlier than 10 (ten) years prior to the date of bid opening). **(YES/NO)**
- ii) If valid type test reports are not available with bidder / test reports are not acceptable to BHEL/Customer, then above tests shall be conducted by the bidder free of cost either at third party lab or in presence of BHEL/NTPC representative and submit the reports for approval. **(YES)**

C)

(1)	(2)	(3)
S.No.	Description	Confirmation of Supplier
1.	Bidder to confirm that at all drawings / data sheets/QP/ valid type tests reports/ all relevant information shall be submitted to BHEL for organising approval of ultimate customer.	

Date:

Signature of the authorized representative of Bidder

Company Seal