

TENDER SPECIFICATION NO

Sl NO	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460	Package-E (Unit-1&2)
2	BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4)/1461	Package-F (Unit-3&4)

(Structural Works of Entire Plant including Fabrication, Erection, Alignment & Welding and Shot blasting/Painting of Steel Structures of Package-E and Package-F)

Package E: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; **Compressor Building; Raw Water Pump House** and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for **Unit# 1 & 2 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana**

Package F: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; **Permanent Store Building; Clarified Water Pump House** and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for **Unit# 3 & 4 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana**

TECHNICAL BID SPECIFICATION - VOLUME- IA

TENDER SPECIFICATIONS CONSISTS OF:

- **Notice Inviting Tender**
- **Volume 1 A - Technical Conditions of Contract,**
- **Volume 1 B - Special conditions of Contract,**
- **Volume 1 C - General conditions of Contract**
- **Volume 1 D - Forms & Procedures**
- **Volume 1 E - Technical Specification Sec C & D and Plot**

Plan



Bharat Heavy Electricals Limited
(A Government of India Undertaking)
Power Sector - Western Region
345-Kingsway, Nagpur-440001

Volume No	Description	Hosted in website bhel.com as files titled
NIL	Tender Specification Issue Details	(Part of <u>Vol-IA-1460-1461</u>)
NIL	Notice Inviting Tender	(Part of <u>Vol-IA-1460-1461</u>)
I-A	Technical Conditions of Contract	Vol-IA-1460-1461
I-B	Special Conditions of Contract	Vol-IBCD-1460-1461
I-C	General Conditions of Contract	(Part of <u>Vol-IBCD-1460-1461</u>)
I-D	Forms & Procedures	(Part of <u>Vol-IBCD-1460-1461</u>)
I-E	Volume 1 E – Technical Specification Section-C, Section D and Plot Plan	Vol-IE- 1460-1461
II	Price Bid Specification	Vol-II-1460-1461

TENDER SPECIFICATION

Sl NO	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460	Package-E (Unit-1&2)
2	BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4)/1461	Package-F (Unit-3&4)

Package E: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; **Compressor Building; Raw Water Pump House** and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for **Unit# 1 & 2 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana**

Package F: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; **Permanent Store Building; Clarified Water Pump House** and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for **Unit# 4 & 3 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana**

EARNEST MONEY DEPOSIT: Refer Notice Inviting Tender

LAST DATE FOR TENDER SUBMISSION: Refer Notice Inviting Tender

THESE TENDER SPECIFICATION DOCUMENTS CONTAINING VOLUME-IA AND VOLUME- II ARE ISSUED TO:

M/s.

.....

PLEASE NOTE:
THESE TENDER SPECS DOCUMENTS ARE NOT TRANSFERABLE.

For Bharat Heavy Electricals Limited

AGM (Purchase)
Place: Nagpur
Date:

1460
&
1461

NOTICE INVITING
TENDER

Bharat Heavy Electricals Limited



BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Ref: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460/ Pkg-F (U-3 & 4)/1461
Date: 19/05/2015

NOTICE INVITING TENDER (NIT)
NOTE: BIDDER MAY DOWNLOAD FROM WEB SITES
OR
PURCHASE TENDERS FROM THIS OFFICE ALSO

To

Dear Sir/Madam

Sub : NOTICE INVITING TENDER

Sealed offers in two part bid system are invited from reputed & experienced bidders (meeting [PRE QUALIFICATION CRITERIA](#) as mentioned in Annexure-I) for the subject job by the undersigned on the behalf of BHARAT HEAVY ELECTRICALS LIMITED as per the tender document. Following points relevant to the tender may please be noted and complied with.

1.0 Salient Features of NIT

Sl No	ISSUE	DESCRIPTION		
		Sl NO	Tender Specification Number	Unit Number & Project
i	TENDER NUMBER	1	BHE/PW/PUR/MANUT-STR Pkg-E(U-1&2) /1460	Package-E (Unit-1&2)
		2	BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4)/1461	Package-F (Unit-3&4)
ii	Broad Scope of job	Package E: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; Compressor Building; Raw Water Pump House and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for Unit# 1 & 2 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana.		

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

		<p>Package F: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; Permanent Store Building; Clarified Water Pump House and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for Unit# 4 & 3 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana.</p>	
iii	DETAILS OF TENDER DOCUMENT		
a	Volume-IA	<i>Technical Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc</i>	<i>Applicable</i>
b	Volume-IB	<i>Special Conditions of Contract (SCC)</i>	<i>Applicable</i>
c	Volume-IC	<i>General Conditions of Contract (GCC)</i>	<i>Applicable</i>
d	Volume-ID	<i>Forms and Procedures</i>	
e	Volume-II	<i>Price Schedule (Absolute value).</i>	<i>Applicable</i>
iv	Issue of Tender Documents	<p>1. Sale from BHEL PS Regional office at : Start : 21/05/2015 , Closes: 04/06/2015 , Time : 16.00 Hrs</p> <p>2. From BHEL website (www.bhel.com) Tender documents will be available for downloading from website till due date of submission</p>	<i>Applicable</i>
v	DUE DATE & TIME OF OFFER SUBMISSION	<p>Date : 05/06/2015, Time 15.00 Hrs Place : <u>BHEL PS Regional office at :Nagpur</u></p> <p>Tenders being submitted</p>	<i>Applicable</i>

BHEL PSWR**Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 7 of 101

		<p>through representative shall be submitted at dispatch section of PSWR HQ Office after making entry/registration at the reception. For any assistance on the matter kindly contact following officials:</p> <ul style="list-style-type: none"> • Pratish Gee Varghese / Sr Engineer (Purchase) • Neeraj Tiwari / Sr Engineer (Purchase) • Shivkesh Meena / Engineer (Purchase) 	
vi	OPENING OF TENDER	<p>1 hours after the latest due date and time of Offer submission</p> <p>Notes:</p> <p>(1) In case the due date of opening of tender becomes a non-working day, then the due date & time of offer submission and opening of tenders get extended to the next working day.</p> <p>(2) Bidder may depute representative to witness the opening of tender</p>	<i>Applicable</i>
vii	EMD AMOUNT	Rs 2,00,000/- (Rupees Two Lakhs Only)	<i>Applicable</i>
viii	COST OF TENDER	Rs 2000/- (Rupees Thousand Only)	<i>Applicable</i>
ix	LAST DATE FOR SEEKING CLARIFICATION	<p>Five days before the due date of offer submission.</p> <p>Along with soft version also, addressing to undersigned & to others as per contact address given below</p>	<i>Applicable</i>
x	SCHEDULE OF Pre Bid Discussion (PBD)	Date : 26/05/2015	<i>Applicable.</i>

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

xi	INTEGRITY PACT & DETAILS OF INDEPENDENT EXTERNAL MONITOR (IEM)	<p>Mrs. Pravin Tripathi, IA & AS (Retd.) D-243, Anupam Gardens, Lane IB, Neb Sarai, Sainik Farms, New Delhi – 110 068 Email: pravin.tripathi@gmail.com</p>	<i>Applicable</i>
xii	Latest updates	<p><u>Latest updates on the important dates, Amendments, Correspondences, Corrigenda, Clarifications, Changes, Errata, Modifications, Revisions, etc to Tender Specifications will be hosted in BHEL webpage (www.bhel.com -->Tender Notifications →View Corrigendums) and not in the newspapers. Bidders to <u>keep themselves updated with all such information</u></u></p>	

- 2.0 The offer shall be submitted as per the instructions of tender document and as detailed in this NIT. Bidders to note specifically that all pages of tender document, including these NIT pages of this particular tender together with subsequent correspondences shall be submitted by them, duly signed & stamped on each page, as part of offer. Rates/Price including discounts/rebates, if any, mentioned anywhere/in any form in the techno-commercial offer other than the Price Bid, shall not be entertained.
- 3.0 Unless specifically stated otherwise, bidder shall remit cost of tender and courier charges if applicable, in the form of Demand Draft drawn in favour of Bharat Heavy Electricals Ltd, payable at Power Sector Regional HQ at Nagpur issuing the Tender, along with techno-commercial offer. Bidder may also choose to deposit the Tender document cost by cash at the Cash Office as stated above against sl no iv of 1, on any working day; and in such case copy of Cash receipt is to be enclosed with the Techno Commercial offer. Sale of tender Documents shall not take place on National Holidays, holidays declared by Central or State Governments and BHEL PS HQ at Nagpur, Sundays and second/ last Saturdays

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

4.0 Unless specifically stated otherwise, bidder shall deposit EMD through Demand Draft/Pay Order in favour of Bharat Heavy Electricals Ltd, payable at Nagpur. For other details and for 'One Time EMD' please refer General Conditions of Contract.

5.0 **Procedure for Submission of Tenders:** The Tenderers must submit their Tenders to Officer inviting Tender, as detailed below:

- PART-I consisting of 'PART-I A (Techno Commercial Bid)' & 'PART-I B (EMD/COST of TENDER)' in two separate sealed and superscribed envelopes (ENVELOPE-I & ENVELOPE-II)
- PART-II (Price Bid) - in sealed and superscribed envelope (ENVELOPE-III)
- One set of tender documents shall be retained by the bidder for their reference

6.0 The contents for ENVELOPES and the superscription for each sealed cover/Envelope are as given below. **(All pages to be signed and stamped)**

Sl no	Description	Remarks
	Part-I A	
	<p><u>ENVELOPE - I superscribed as :</u> PART-I (TECHNO COMMERCIAL BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:</p> <p><u>CONTAINING THE FOLLOWING:-</u></p>	
i.	Covering letter/Offer forwarding letter of Tenderer.	
ii.	<p>Duly filled-in 'No Deviation Certificate' as per prescribed format to be placed after document under sl no (i) above.</p> <p><u>Note:</u> a. In case of any deviation, the same should be submitted separately for technical & commercial parts, indicating respective clauses of tender against which deviation is taken by bidder. The list of such deviation shall be placed after document under sl no (i) above. It shall be specifically noted that deviation</p>	

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	<p>recorded elsewhere shall not be entertained.</p> <p>b. BHEL reserves the right to accept/reject the deviations without assigning any reasons, and BHEL decision is final and binding.</p> <p>i). In case of acceptance of the deviations, appropriate loading shall be done by BHEL</p> <p>ii). In case of unacceptable deviations, BHEL reserves the right to reject the tender</p>	
iii.	<p>Supporting documents/ annexure/ schedules/ drawing etc as required in line with Pre-Qualification criteria.</p> <p>It shall be specifically noted that all documents as per above shall be indexed properly and credential certificates issued by clients shall distinctly bear the name of organization, contact ph no, FAX no, etc.</p>	
iv.	<p>All Amendments/Correspondences/Corrigenda/Clarifications/Changes/ Errata etc pertinent to this NIT.</p>	
v.	<p>Integrity Pact Agreement (Duly signed by the authorized signatory)</p>	<p>If applicable</p>
vi.	<p>Duly filled-in annexures, formats etc as required under this Tender Specification/NIT</p>	
vii.	<p>Notice inviting Tender (NIT)</p>	
viii.	<p>Volume – I A : <u>Technical</u> Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc</p>	
ix.	<p>Volume – I B : Special Conditions of Contract (SCC)</p>	
x.	<p>Volume – I C : General Conditions of Contract (GCC)</p>	
xi.	<p>Volume – I D : Forms & Procedures</p>	
xii.	<p>Volume – II (UNPRICED – without disclosing rates/price, but mentioning only ‘QUOTED’ or ‘UNQUOTED’ against each item</p>	
xiii.	<p>Any other details preferred by bidder with proper indexing.</p>	

PART-I B		
-----------------	--	--

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	<p>ENVELOPE – II superscribed as: PART-I (EMD/COST of TENDER) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:</p> <p>CONTAINING THE FOLLOWING:-</p>	
i.	<p>1. Earnest Money Deposit (EMD) in the form as indicated in this Tender</p> <p align="center">OR</p> <p>Documentary evidence for ‘One Time EMD’ with the Power Sector Region of BHEL floating the Tender</p> <p>2. Cost of Tender (Demand Draft or copy of Cash Receipt as the case may be)</p>	

	PART-II	
	PRICE BID consisting of the following shall be enclosed	
	<p>ENVELOPE-III superscribed as: PART-II (PRICE BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:</p> <p>CONTAINING THE FOLLOWING</p>	
i	Covering letter/Offer forwarding letter of Tenderer enclosed in Part-I	
ii	Volume II – PRICE BID (Duly Filled in Schedule of Rates – rate/price to be entered in words as well as figures)	

	OUTER COVER	
	<p>ENVELOPE-IV (MAIN ENVELOPE / OUTER ENVELOPE) superscribed as: TECHNO-COMMERCIAL BID, PRICE BID & EMD TENDER NO: NAME OF WORK: PROJECT:</p>	

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 12 of 101

	DUE DATE OF SUBMISSION:	
	CONTAINING THE FOLLOWING:	
i	<ul style="list-style-type: none">○ Envelopes I○ Envelopes II○ Envelopes III	

SPECIAL NOTE : All documents/ annexures submitted with the offer shall be properly annexed and placed in respective places of the offer as per enclosure list mentioned in the covering letter. BHEL shall not be responsible for any missing documents.

7.0 Deviation with respect to tender clauses and additional clauses/suggestions in Techno-commercial bid / Price bid shall NOT be considered by BHEL. Bidders are requested to positively comply with the same.

8.0 BHEL reserves the right to accept or reject any or all Offers without assigning any reasons thereof. BHEL also reserves the right to cancel the Tender wholly or partly without assigning any reason thereof. Also BHEL shall not entertain any correspondence from bidders in this matter (except for the refund of EMD).

9.0 Assessment of Capacity of Bidders:

Bidders capacity for executing the job under tender shall be assessed 'LOAD' wise and 'PERFORMANCE' wise as per the following:

I. **LOAD**: Load takes into consideration **ALL** the contracts of the Bidder under execution with BHEL Regions, irrespective of whether they are similar to the tendered scope or not. The 'Load' is the sum of the unit wise identified packages (refer Table-1) for contracts with BHEL Regions. The cut off month for reckoning 'Load' shall be the month, two (2) months preceding the month corresponding to the 'latest date of bid submission', in the following manner:

(Note: For example if latest bid submission is in Aug 2011, then the 'load' shall be calculated upto and inclusive of June 2011)

i). Total number of Packages
Total number of Packages in hand = P

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

.....
Where

- 'P' is the sum of all unit wise identified packages under execution with BHEL Regions as of the cut off month defined above, including packages yet to be commenced, excepting packages which are on HOLD due to reasons not attributable to Bidder..

II. **PERFORMANCE**: Here 'Monthly Performance' of the bidder for all the packages (**under execution/** executed during the 'Period of Assessment' in all the Power Sector Regions of BHEL) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced shall be taken into consideration. The 'Period of Assessment' shall be 6 months preceding the cut off month. The cut off month for reckoning 'Period of Assessment' shall be the month two (2) months preceding the month corresponding to the 'latest date of bid submission', in the following manner:

(Note: For example if 'latest date of bid submission' is in Aug 2011, then the 'performance' shall be assessed for a 6 month period upto and inclusive of June 2011, for all the unit wise identified packages (refer Table I)

i). Calculation of Overall 'Performance Rating' for 'similar Package/Packages' for the tendered scope under execution at Power Sector Regions for the 'Period of Assessment':

This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for all the similar Package/packages', divided by the total number of Package months for which evaluation should have been done, as per procedure below:

- a) $P_1, P_2, P_3, P_4, P_5, \dots, P_N$ etc be the packages (**under execution/** executed during the 'Period of Assessment' in all Regions) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced. Total number of similar packages for all Regions = **P_T** (ie $P_T = P_1 + P_2 + P_3 + P_4 + \dots + P_N$)
- b) Number of Months ' T_1 ' for which 'Monthly Performance Evaluation' as per relevant formats, should have been done in

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) / 1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) / 1461

	Similar Packages for all Regions → (under execution / executed during period of assessment)		P ₂	P ₃	P ₄	P ₅	..	P	Total No of similar packages for all Regions = P_T ie Sum (Σ) of columns (iii) to (ix)
	Number of Months for which 'Monthly Performance Evaluation' as per relevant formats should have been done in the 'period of assessment for correspon		T ₂	T ₃	T ₄	T ₅	..	T	Sum (Σ) of columns (iii) to (ix) = T_T

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	ding similar Package (as in row 1)								
	Monthly performance scores for the corresponding period (as in Row 2)	1, S ₁₋₁ , 2, S ₁₋₂ , 3, S ₁₋₃ , 4, S ₁₋₄ , ... T1	2-1, S ₂₋₂ , S ₂₋₃ , S ₂₋₄ , ... 2-T2	S ₃₋₁ , S ₃₋₂ , 2, S ₃₋₃ , 3, S ₃₋₄ , 4, S ₃₋₅ , ... S _{3-T3}	S ₄₋₁ , S ₄₋₂ , 2, S ₄₋₃ , 3, S ₄₋₄ , 4, S ₄₋₅ , ... S _{4-T4}	S ₅₋₁ , S ₅₋₂ , 2, S ₅₋₃ , 3, S ₅₋₄ , 4, S ₅₋₅ , ... S _{5-T5}	.	1, S _{N-2} , S _{N-3} , 4, S _{N-4} , ... S	----- -
	Sum of Monthly Performance scores of the corresponding Package for the corresponding period (as in row-3)		S ₂	S ₃	S ₄	S ₅	..	S	Sum (Σ) of columns (iii) to (ix) = S_T

ii) Calculation of Overall ‘Performance Rating’ (**R_{BHEL}**) in case ‘similar Package/Packages’ for the tendered scope ARE NOT AVAILABLE, during the ‘Period of Assessment’:

This shall be obtained by summing up the ‘Monthly Performance Evaluation’ scores obtained by the bidder in all Regions for ALL the packages, divided by the total number of Package months for which evaluation should have been done. ‘R_{BHEL}’ shall be calculated subject to availability of ‘performance scores’ for at least.6 ‘package months’ in the order of precedence below:

- a) Period of Assessment.
- b) 12 months preceding the cut-off month
- c) 24 months preceding the cut-off month

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

d) 36 months preceding the cut-off month

In case, R_{BHEL} cannot be calculated as above, then Bidder shall be treated as 'NEW VENDOR'. Further eligibility and qualification of this bidder shall be as per definition of 'NEW VENDOR' described in 'Explanatory Notes'

iii) Factor "L" assigned based on Overall Performance Rating (R_{BHEL}) at Power Sector Regions,:

Sl	Overall Performance Rating (R_{BHEL})	Corresponding value of 'L'
1	=60	NA
2	> 60 and ≤ 65	0.4
3	> 65 and ≤ 70	0.35
4	> 70 and ≤ 75	0.25
5	> 75 and < 80	0.2
6	≥ 80	NA

III. 'Assessment of Capacity of Bidder':

'Assessment of Capacity of Bidder' is based on the Maximum number of packages for which a vendor is eligible, considering the performance scores of similar packages, as below:

Max number of packages $P_{Max} = (R_{BHEL} - 60)$ divided by corresponding value of 'L'

i.e. $(R_{BHEL} - 60)/L$

Note:

- i. In case the value of P_{Max} results in a fraction, the value of P_{Max} is to be rounded off to next whole number
- ii. For $R_{BHEL} = 60$, $P_{Max} = '1'$
- iii. For $R_{BHEL} \geq 80$, there will be no upper limit on P_{Max}

The Bidder shall be considered 'Qualified' as per 'Assessment of Capacity of Bidder' for the subject Tender if $P \leq P_{Max}$
(where P is calculated as per clause 9.I)

IV. Explanatory note:

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
- a) Similar package means Boiler or ESP or Piping or Turbine or Civil or Structure or Electrical or CI, etc at the individual level irrespective of rating of Plant, and irrespective of whether the subject tender is a single package or as part of combined/composite packages. Normally Boiler, ESP, Piping, Turbine, Electrical, CI, Civil, Structure, etc is considered individual level of package. For example in case the tendered scope is a Boiler Vertical Package comprising of Boiler, ESP and Power Cycle Piping (i.e the 'identified packages as per Table-1 below), the 'PERFORMANCE' part against sl no II above, needs to be evaluated considering all the identified packages (ie Boiler, ESP and Power Cycle Piping) and finally the Bidder's capacity to execute the tendered scope is assessed in line with III above
- b) Identified Packages (Unit wise)

Table-1

	Civil	Electrical & CI	Mechanical
	i). Enabling works ii). Pile and Pile Caps iii). Civil Works including foundations iv). Structural Steel Fabrication & Erection v). Chimney vi). Cooling Tower vii). Others (Civil)	i). Electrical ii). CI iii). Others (Elec & CI)	i). Boiler & Aux (All types including CW Piping if applicable) ii). Power Cycle Piping/Critical Piping iii). LP Piping iv). ESP v). Steam Turbine Generator set & Aux vi). Gas Turbine Generator set & Aux vii). Hydro Turbine Generator set & Aux iii). Turbo Blower (including Steam Turbine) ix). Material Handling x). Material Management xi). Material Handling & Material Management xii). Others

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

			(Mechanical)
--	--	--	--------------

c) Bidders who have not been evaluated for at least six package months in the last 36 months in the online BHEL system for contractor performance evaluation in BHEL PS Regions, wef July'2010 shall be considered "NEW VENDOR".

A 'NEW VENDOR' shall be considered qualified subject to satisfying all other tender conditions

A 'NEW VENDOR' if awarded a job (of package/packages identified under this clause) shall be tagged as "FIRST TIMER" on the date of first LOI from BHEL.

The "FIRST TIMER" tag shall remain till execution of work for a period of not less than 09 months, from the commencement of work of first package

A Bidder shall not be eligible for the next job as long as the Bidder is tagged as "FIRST TIMER" excepting for the Tenders which have been opened on or before the date of the bidder being tagged as 'FIRST TIMER'.

After removal of 'FIRST TIMER' tag, the Bidder shall be considered 'QUALIFIED' for the future tenders subject to satisfying all other tender conditions including 'Capacity Evaluation of Bidders'.

d) In the unlikely event of all bidders shortlisted against Technical and Financial Qualification criteria not meeting the criteria on 'Assessment of Capacity of Bidders' detailed above, OR leads to a single tender response on applying the criteria of 'Assessment of Capacity of Bidders' or due to non-approval by Customer, then BHEL at its discretion reserves the right to consider the further processing of the Tender based on the **Overall Performance Rating 'RBHEL'** only, starting from the upper band.

e) 'Under execution' shall mean works in progress as per the following:

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 20 of 101

-
- i. up to Boiler Steam Blowing in case of Steam Generator and Auxiliaries
 - ii. upto Synchronisation in case of all other works excepting sl no (i) and (iii)
 - iii. Upto execution of at least 90% of anticipated contract value in case of Civil & Structures (unit wise), Enabling works and upto 90% of material unloading (in tonnage) as per the original contract in case of MM Package.

Note : BHEL at its discretion can extend (or reduce in exceptional cases in line with Contract conditions) the period defined against (i), (ii) and (iii) above, depending upon the balance scope of work to be completed.

- f) Performance evaluation in CL 9 above is applicable to Prime bidder and consortium partner (or Technical tie up partner) for their respective scope of work

10.0 Since the job shall be executed at site, bidders must visit site/ work area and study the job content, facilities available, availability of materials, prevailing site conditions including law & order situation, applicable wage structure, wage rules, etc before quoting for this tender. They may also consult this office before submitting their offers, for any clarifications regarding scope of work, facilities available at sites or on terms and conditions.

11.0 For any clarification on the tender document, the bidder may seek the same in writing or through e-mail, as per specified format, within the scheduled date for seeking clarification, from the office of the undersigned. BHEL shall not be responsible for receipt of queries after due date of seeking clarification due to postal delay or any other delays. Any clarification / query received after last date for seeking clarification may not be normally entertained by BHEL and no time extension will be given.

12.0 BHEL may decide holding of pre-bid discussion [PBD] with all intending bidders as per date indicated in the NIT. The bidder shall ensure participation for the same at the appointed time, date and place as may be decided by BHEL. Bidders shall plan their visit accordingly. The outcome of pre-bid discussion (PBD) shall also form part of tender.

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 21 of 101

-
- 13.0 In the event of any conflict between requirement of any clause of this specification/ documents/drawings/data sheets etc or requirements of different codes/standards specified, the same to be brought to the knowledge of BHEL in writing for clarification before due date of seeking clarification (whichever is applicable), otherwise, interpretation by BHEL shall prevail. Any typing error/missing pages/ other clerical errors in the tender documents, noticed must be pointed out before pre-bid meeting/submission of offer, else BHEL's interpretation shall prevail.
- 14.0 Unless specifically mentioned otherwise, bidder's quoted price shall deemed to be in compliance with tender including PBD.
- 15.0 Bidders shall submit Integrity Pact Agreement (Duly signed by authorized signatory who signs in the offer), **if applicable**, along with techno-commercial bid. This pact shall be considered as a preliminary qualification for further participation. **The names and other details of Independent External Monitor (IEM) for the subject tender is as given at point (1) above.**
- 16.0 The Bidder has to satisfy the Pre Qualifying Requirements stipulated for this Tender in order to be qualified. The Price Bids of only those bidders will be opened who will be qualified for the subject job on the basis of satisfying the Pre Qualification Criteria specified in this NIT as per Annexure-I (as applicable), past performance etc. and date of opening of price bids shall be intimated to only such bidders. BHEL reserves the right not to consider offers of parties under HOLD.
- 17.0** In case BHEL decides on a 'Public Opening', the date & time of opening of the sealed PRICE BID shall be intimated to the qualified bidders and in such a case, bidder may depute one authorised representative to witness the price bid opening. BHEL reserves the right to open 'in-camera' the 'PRICE BID' of any or all Unsuccessful/Disqualified bidders under intimation to the respective bidders.
- 18.0 Validity of the offer shall be for **six months** from the latest due date of offer submission (including extension, if any) unless specified otherwise.
- 19.0 BHEL reserves the right to decide the successful bidder on the basis of Reverse Auction process. In such case all qualified bidders will be intimated regarding procedure/ modality for Reverse Auction process prior to Reverse Auction and price will be decided as per the rules for Reverse Auction. .

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 22 of 101

-
- However, if reverse auction process is unsuccessful as defined in the RA rules/procedures, or for whatsoever reason, then the sealed 'PRICE BIDS' will be opened for deciding the successful bidder. BHEL's decision in this regard will be final and binding on bidder.
- 20.0 On submission of offer, further consideration will be subject to compliance to tender & qualifying requirement and customer's acceptance, as applicable.
- 21.0 In case the bidder is an "Indian Agent of Foreign Principals", 'Agency agreement has to be submitted along with Bid, detailing the role of the agent along with the terms of payment for agency commission in INR, along with supporting documents.
- 22.0 The bidders shall not enter into any undisclosed M.O.U. or any understanding amongst themselves with respect to tender.
- 23.0 Consortium Bidding (or Technical Tie up) shall be allowed only if specified in Pre Qualifying Requirement (PQR) criteria, and in such a case the following shall be complied with:
- 23.1 Prime Bidder and Consortium Partner or partners are required to enter into a consortium agreement with a validity period of six months initially. In case the consortium is awarded the contract, then the Consortium Agreement between the Prime Bidder and Consortium Partner or partners shall be extended till contractual completion period including extension periods if any applicable.
- 23.2 'Stand alone' bidder cannot become a **'Prime Bidder' or a 'Consortium bidder' or 'Technical Tie up bidder' in a consortium (or Technical Tie up) bidding.** Prime bidder shall neither be a consortium partner to other prime bidder nor take any other consortium partners. However, consortium partner may enter into consortium agreement with other prime bidders. In case of non compliance, consortium bids of such Prime bidders will be rejected.
- 23.3 Number of partners for a consortium Bidding (or Technical Tie up) shall be as specified in the PQR
- 23.4 Prime Bidder shall be as specified in the Pre Qualification Requirement, else the bidder who has the major share of work

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
- 23.5 In order to be qualified for the tender, Prime Bidder and Consortium partner or partners shall satisfy (i) the Technical 'Pre Qualifying Requirements' specified for the respective package, (ii) "Assessment of Capacity of Bidder" as specified in clause 9.0
 - 23.6 Prime Bidder shall comply with additional 'Technical' criteria of PQR as defined in 'Explanatory Notes for the PQR'
 - 23.7 Prime Bidder shall comply with all other Pre Qualifying criteria for the Tender unless otherwise specified
 - 23.8 In case customer approval is required, then Prime Bidder and Consortium Partner or partners shall have to be individually approved by Customer for being considered for the tender.
 - 23.9 Prime Bidder shall be responsible for the overall execution of the contract
 - 23.10 In case of award of job, Performance shall be evaluated for Prime Bidder and Consortium Partner or partners for their respective scope of work(s) as per prescribed formats
 - 23.11 In case the Consortium partner or partners back out, their SDs shall be encashed by BHEL. In such a case, other consortium partner or partners meeting the PQR have to be engaged by the Prime Bidder, and if not, the respective work will be withdrawn and executed on risk and cost basis of the Prime Bidder. The new consortium partner or partners shall submit fresh SDs as applicable.
 - 23.12 In case the prime Bidder withdraws, the whole contract shall be considered cancelled and short closed.
 - 23.13 After execution of work, the work experience shall be assigned to the Prime Bidder and the consortium partner or partners for their respective scope of work. After successful execution of two similar works with the same consortium partner or partners under direct orders of BHEL, the Prime Bidder shall be eligible for becoming a 'stand alone' bidder for similar works, subject to certification from BHEL about the active involvement of the Prime Bidder for satisfactory execution of the works.

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 24 of 101

-
- 23.14 The consortium partner shall submit SD equivalent to 2% of the total contract value in addition to the SD to be submitted by the prime Bidder for the total contract value. In case there are two consortium partners, then each partner shall submit SD equivalent to 1% of the total contract value in addition to the SD to be submitted by the prime Bidder for the total contract value.
- 23.15 In case of a Technical Tie up, all the clauses applicable for the Consortium partner shall be applicable for the Technical Tie up partner also
- 24.0 The bidder shall submit documents in support of possession of 'Qualifying Requirements' duly self certified and stamped by the authorized signatory, indexed and properly linked in the format for PQR. In case BHEL requires any other documents/proofs, these shall be submitted immediately.
- 25.0 The bidder may have to produce original document for verification if so decided by BHEL.
- 26.0 Order of Precedence
In the event of any ambiguity or conflict between the Tender Documents, the order of precedence shall be in the order below:
- a. Amendments/Clarifications/Corrigenda/Errata etc issued in respect of the tender documents by BHEL
 - b. Notice Inviting Tender (NIT)
 - c. Price Bid
 - d. Technical Conditions of Contract (TCC)—Volume-1A
 - e. Special Conditions of Contract (SCC) —Volume-1B
 - f. General Conditions of Contract (GCC) —Volume-1C
 - g. Forms and Procedures —Volume-1D

It may please be noted that guidelines/rules in respect of suspension of business dealings', 'Vendor evaluation format', 'Quality, Safety & HSE guidelines', etc may undergo change from time to time and the latest one shall be followed.

for BHARAT HEAVY ELECTRICALS LTD

AGM Pur

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 25 of 101

.....
Enclosure

01. Annexure-1: Pre Qualifying criteria.
02. Annexure-2: Check List.
03. Annexure-3: Integrity Pact
04. Annexure-4: Important Information.
- 05 Other Tender documents as per this NIT.

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

ANNEXURE - 1

PRE QUALIFYING CRITERIA

JOB	<p>Package E: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; Compressor Building; Raw Water Pump House and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for Unit# 1 & 2 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana</p> <p>Package F: All structural works of STG building; Mill & Bunker Bay; Interconnecting gallery ESP control room structure; CW Pump House; CW Treatment Str; Permanent Store Building; Clarified Water Pump House and sheds/access ways/ platforms etc within the battery limits of plant area up to final painting and handing over to civil/mechanical/electrical agencies for Unit# 3 & 4 (Common works like pipe/cable racks shall be divided equally) AT 4 X 270 MW Thermal Power Station, Manuguru, Distt-Khammam, Telangana</p>	
SI NO	Tender Specification Number	Unit Number & Project
1	BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460	Package-E (Unit-1&2)
2	BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4)/1461	Package-F (Unit-3&4)

SI No	PRE QUALIFICATION CRITERIA	Bidders claim in respect of fulfilling the PQR Criteria	
		Name and Description of qualifying criteria	Page no of supporting document. Bidder must fill up this column as per applicability

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

A	Submission of Integrity Pact duly signed (if applicable) (Note: To be submitted by Prime Bidder & Consortium/Technical Tie up partner jointly in case Consortium bidding is permitted, otherwise by the sole bidder)	APPLICABLE	
B	<p>Technical Bidders shall essentially meet all the Qualifying Requirements (i.e. B.1, B.2 and B.3) as under, in last seven years as on latest date of bid submission.</p> <p>B.1: Bidder should have Executed <u>Fabrication</u> and <u>Erection</u> OF Structural Steel of atleast 4450 MT each, within a period of twelve consecutive months against one or cumulative of two concurrently running contracts in Power / industrial projects.</p> <p style="text-align: center;">AND</p> <p>B.2: Bidder should have Executed Fabrication and Erection of Mill Bunker Structure of one unit of 100 MW capacity or above.</p> <p>Note: The above experience of “B.1” and “B.2” can be in a same project or in different Projects</p> <p style="text-align: center;">AND</p> <p>B.3: Bidder should have Executed Structural works in Power/ Industrial projects as below:</p> <p>B.3.1) Executed One similar work</p>	APPLICABLE	

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	<p>of value not less than Rs. 2584 Lakhs against single work order.</p> <p>OR</p> <p>B.3.2) Executed Two similar works each of value not less than Rs. 1615 Lakhs against maximum two work orders.</p> <p>OR</p> <p>B.3.3) Executed Three similar works each of value not less than Rs. 1292 Lakhs against maximum three work orders.</p> <p>Note: Industrial projects shall mean projects in sectors like Power /Petro / Chemical/Refinery / Oil and Gas/ Cement /Aviation / Ports /any other sector involving civil works for setting-up factory</p>		
C-1	<p><u>Financial TURNOVER</u></p> <p>Bidders must have achieved an average annual financial turnover (audited) of Rs 3230 Lakhs or more over last three Financial Years (FY) i.e. 2012-2013, 2013-14, 2014-15 OR 2011-2012, 2012-2013, 2013-14 if Annual Accounts for FY 2014-15 are not audited.</p>	APPLICABLE	
C-2	<p><u>NETWORTH</u> (only in case of Companies)</p> <p>Net worth of the Bidder based on the latest Audited Accounts as</p>	APPLICABLE	

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	furnished for 'C-1' above should be positive.		
C-3	PROFIT Bidder must have earned cash profit in any one of the three Financial Years as applicable in the last three Financial Years defined in 'C-1' above based on latest Audited Accounts.	APPLICABLE	
D	Assessment of Capacity of Bidder to execute the work as per sl no 9 of NIT (if applicable)	APPLICABLE	By BHEL
E	Approval of Customer (if applicable) Note: Names of bidders (including consortium/Technical Tie up partners in case consortium bidding is permitted) who stand qualified after compliance of criteria A to D shall be forwarded to customer for their approval.	APPLICABLE	BY BHEL
F	Price Bid Opening Note: Price Bids of only those bidders shall be opened who stand qualified after compliance of criteria A to E		BY BHEL
F	Technical Tie up criteria (if applicable)	Not applicable	
<p align="center"><u>Explanatory Notes for the PQR (unless otherwise specified in the PQR):</u></p> <p align="center">1. Bidder to submit Audited Balance Sheet and Profit and Loss Account for the respective years as indicated against C-1 above along with all annexures</p>			

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
2. In case audited Financial statements have not been submitted for all the three years as indicated against C-1 above, then the applicable audited statements submitted by the bidders against the requisite three years, will be averaged for three years i.e total divided by three.
 3. C-2:-NETWORTH : Shall be calculated based on the latest Audited Accounts as furnished for C-1 above. Net worth = Paid up share capital + Reserves. (Net worth is required to be evaluated in case of companies)
 4. C-3:- PROFIT : shall be NET profit (PAT + Non cash expenditure viz depreciation) earned during any one of the three financial years as in C-1 above
 5. ~~‘Additional’ Criteria in respect of ‘Technical’ criteria of PQR (as in ‘B’ above) for Civil, Electrical, CI, unless otherwise specified :~~
 1. ~~Bidder should have executed similar work of any one of the following:~~
 - a. ~~One (1) work of value not less than Rs XXX~~
 - ~~_____ OR~~
 - b. ~~Two (2) works of not less than Rs YYY~~
 - ~~_____ OR~~
 - c. ~~Three (3) works of not less than Rs ZZZ~~

~~(Value XXX, YYY, ZZZ shall be as indicated by BHEL~~
 2. ~~‘Similar’ work for criteria 5 above means~~
 - a. ~~Civil or Structures or Civil & Structures or Chimney respectively as applicable to the tendered scope in respect of ‘CIVIL’ Works~~
 - b. ~~Electrical works in respect of ‘ELECTRICAL’~~
 - c. ~~CI works in respect of ‘CI’ Works~~
 - d. ~~Material Handling and/or Management works in respect of ‘MM’ works~~
 6. Time period for achievement of the ‘Technical’ criteria of PQR (as in ‘B’ above) will be the last 7 years ending on the ‘latest date’ of Bid submission
 7. ‘EXECUTED’ means the Vendor should have achieved the criteria

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

specified in the Technical criteria of PQR (as in 'B' above) even if the Contract has not been completed or closed, Unless otherwise specified, for the purpose of 'Technical' criteria of PQR (as in 'B' above), the word 'EXECUTED' means:

- ~~1. "BOILER LIGHT UP" in respect of Boiler & Aux and ESP~~
- ~~2. Term 'Commissioning' indicated in PQR refers to 'assistance to commissioning' / 'commissioning'~~
- ~~3. "SYNCHRONISATION" in respect of STG/GTG and 'SPINNING' in case of HTG~~
- ~~4. "STEAM BLOWING COMPLETION" in respect of at least Main Steam Line of Power Cycle Piping~~
- ~~5. "HYDRAULIC TEST" of the system in respect of Structures, Pressure parts/IBR Piping~~
- ~~6. "CHARGING" in respect of power Transformers, Bus ducts, HT/LT switchgears.~~
- ~~7. "Completion of RCC Shell and liner (steel or brick as per tendered scope) up to the HEIGHT specified using slip form" in case of RCC Chimney.~~
8. Achievement of physical Quantities as per respective PQRs in respect of Civil & Structures and Piling Works
9. 'Readiness for coal Filling" in respect of Bunker Structure Work.
- ~~8. Boiler means HRSG or WHRB or any other types of Steam Generator.~~
- ~~9. Critical/Power Cycle piping means Main Steam, Hot Reheat, Cold Reheat, HP Bypass, LP Bypass lines~~
- ~~10. For the purpose of evaluation of the PQR, one MW shall be considered equivalent to 3.5TPH where ever rating of HRSG/BOILER is mentioned in MW. Similarly, where ever rating of Gas Turbine is mentioned in terms of Frame size, ISO rating in terms of MW shall be considered for evaluation.~~
11. In case the experience/PO/WO certificate enclosed by bidders do not have separate break up prices for the E&C portion of Electrical and CI Works, (i.e. the certificates enclosed are for composite order for supply and erection of Electrical & CI and other works if any), then value of Erection and Commissioning for the

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	<p>Electrical & CI portion shall be considered as 15% of the supply & erection of Electrical & CI, unless otherwise specifically indicated in the PQR.</p> <p>12. Scope for capital overhaul of STG shall cover Bearing Inspection work and overhauling of all cylinders of the Turbine unless otherwise specifically indicated in the PQR.</p> <p>13. In case the tendered scope is not a Pulverised Fuel Boiler, experience of Oil/Gas Fired Boilers also can be considered unless otherwise specifically indicated in the PQR</p> <p>14. The value of work (Experience submitted against PQR B) shall be updated as per the PVC indices for "All India Avg. Consumer Price Index for Industrial Workers" with base month as date of execution (completion of contract/work) and indexed upto two months prior to bid opening month.</p>
--	---

BIDDER SHALL SUBMIT ABOVE PRE-QUALIFICATION CRITERIA FORMAT, DULY FILLED-IN, SPECIFYING RESPECTIVE ANNEXURE NUMBER AGAINST EACH CRITERIA AND FURNISH RELEVANT DOCUMENT IN THE RESPECTIVE ANNEXURES IN THEIR OFFER.

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Bidder's Response to BHEL TECHNICAL PQR (WHICHEVER IS APPLICABLE)

PQR No	Pre-Qualifying Requirement	Credentials (Detailed Work Order, Completion Certificate and TDS Certificates) based on which bidder is claiming PQR	Reference of the documents	Page No
B.1	Bidder should have Executed Structural Steel of atleast 4450 MT quantities each for Fabrication and Erection within a period of twelve consecutive months against one or cumulative of two concurrently running contracts in Power / industrial projects.			
B.2	Bidder should have Executed Fabrication and Erection of Mill Bunker Structure of one unit of 100 MW capacity or above.			
B.3:	Bidder should have Executed Structural work in Power/ Industrial projects as below:			
B.3.1	Executed One similar work of value not less than Rs. 2584 Lakhs against single work order.			

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) / 1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) / 1461

Bidder's Response to BHEL TECHNICAL PQR (WHICHEVER IS APPLICABLE)

PQR No	Pre-Qualifying Requirement	Credentials (Detailed Work Order, Completion Certificate and TDS Certificates) based on which bidder is claiming PQR	Reference of the documents	Page No
B .3.2	Executed Two similar works each of value not less than Rs. 1615 Lakhs against maximum two work orders.			
B.3.3	Executed Three similar works each of value not less than Rs. 1292 Lakhs against maximum three work orders.			

NOTE:

BIDDERS MUST CLEARLY INDICATE IN THE TABLE ABOVE, HOW THEY ARE SATISFYING TECHNICAL PQR ALONG WITH THE REFERENCE OF THE SUPPORTING DOCUMENTS AND THE PAGE NUMBER IN WHICH THE REFERRED DOCUMENTS ARE ANNEXED IN THE BID DOCUMENT.

BHEL WILL NOT CONSIDER ANY OTHER DOCUMENT OTHER THAN THOSE SPECIFIED BY THE BIDDERS IN THE TABLE ABOVE FOR EVALUATION OF TECHNICAL PQR.

BIDDER MAY ATTACH SEPERATE SHEET IF NECESSARY

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

	with proper supporting documents referenced in the specified format		
7	Audited profit and Loss Account for the last three years	Applicable /Not Applicable	YES/NO
8	Copy of PAN Card	Applicable /Not Applicable	YES/NO
9	Whether all pages of the Tender documents including annexures, appendices etc are read understood and signed	Applicable /Not Applicable	YES/NO
10	Integrity Pact	Applicable /Not Applicable	YES/NO
11	Declaration by Authorised Signatory	Applicable /Not Applicable	YES/NO
12	No Deviation Certificate	Applicable /Not Applicable	YES/NO
13	Declaration confirming knowledge about Site Conditions	Applicable /Not Applicable	YES/NO
14	Declaration for relation in BHEL	Applicable /Not Applicable	YES/NO
15	Non Disclosure Certificate	Applicable /Not Applicable	YES/NO
16	Bank Account Details for E-Payment	Applicable /Not Applicable	YES/NO

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 37 of 101

17	Capacity Evaluation of Bidder for current Tender	Applicable /Not Applicable	YES/NO
18	Tie Ups/Consortium Agreement are submitted as per format	Applicable /Not Applicable	-----
19	Power of Attorney for Submission of Tender/Signing Contract Agreement	Applicable /Not Applicable	YES/NO
20	Analysis of Unit rates	Applicable /Not Applicable	YES/NO

NOTE : STRIKE OFF 'YES' OR 'NO', AS APPLICABLE. TENDER NOT ACCOMPANIED BY THE PRESCRIBED **ABOVE APPLICABLE DOCUMENTS** ARE LIABLE TO BE SUMMARILY REJECTED.

DATE :

AUTHORISED SIGNATORY

(With Name, Designation and Company seal)

**BHEL PSWR
Notice Inviting Tender (NIT)**

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 38 of 101

Annexure-3

INTEGRITY PACT

Between

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at “BHEL House” Siri Fort, New Delhi – 110049 (India) hereinafter referred to as “The Principal”, which expression unless repugnant to the context of meaning hereof shall include its successors or assigns of the ONE PART

And

_____, (description of the party along with address), hereinafter referred to as “The Bidder/ Contractor” which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

Preamble

The Principal intends to award, under laid-down organizational procedures, contract/s for

_____. The Principal values full compliance with all relevant laws of the land, rules and regulations and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1 - Commitments of the Principal

- 1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:-

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
- 1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for itself or third person, any material or immaterial benefit which the person is not legally entitled to.
 - 1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.
 - 1.1.3 The Principal will exclude from the process all known prejudiced persons.
 - 1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions.

Section 2 – Commitments of the Bidder(s)/ Contractor(s)

- 2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the tender process and during the contract execution.
 - 2.1.1 the Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal’s employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he / she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.
 - 2.1.2 The bidder(s)/ Contractors(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
- 2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant IPC/PC Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
 - 2.1.4 The Bidders (s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.
 - 2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.

Section 3 – Disqualification from tender process and execution from future contracts

If the Bidder(s)/Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s)/ Contractor(s) from the tender process or take action as per separate “Guidelines on for Suspension of Business Dealings with Suppliers/ Contractors” framed by the Principal.

Section 4 – Compensation for Damages

- 4.1 If the Principal has disqualified the Bidder from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent to Earnest Money Deposit/ Bid Security.
- 4.2 If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to Section 3, the Principal shall be entitled to demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/ Performance Bank Guarantee, whichever is higher.

Section 5 – Previous Transgression

- 5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-

BHEL PSWR

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

.....
corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.

- 5.2 If the Bidder makes incorrect statement on his subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason.

Section 6 – Equal treatment of all Bidders/ Contractors/ Sub-Contractors

- 6.1 The Bidder(s)/ Contractor(s) undertake(s) to obtain from his sub-contractors a commitment consistent with this Integrity Pact and report Compliance to the Principal. This commitment shall be taken only from those sub-contractors whose contract value is more than 20% of Bidder’s/ Contractor’s contract value with the Principal. The Bidder(s)/Contractor(s) shall continue to remain responsible for any default by his Sub-contractor(s).
- 6.2 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors.
- 6.3 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

Section -7 Criminal Charges against violating Bidders/ Contractors/ Sub-contractors

If the Principal obtains knowledge of conduct of a Bidder. Contractor or Sub-contractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

Section – 8 Independent External Monitor(s)

- 8.1 The Principal appoints competent and credible Independent External Monitor for this Pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- 8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 42 of 101

-
- 8.3 The Bidder(s)/ Contractors(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s)/ Contractor(s). The Bidder(s)/Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s)/ Contractor(s)/ Sib-contractor(s) with confidentiality.
- 8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meeting could have an impact on the contractual relations between the Principal and the Contractor. The parties offer to the Monitor the option to participate in such meetings.
- 8.5 As soon as the Monitor notices, or believes to notice, a violation of this agreement, he will so inform the Management of the Principal and request the Management to discontinue or take corrective action, or heal the situation, or to take other relevant action. The Monitor can in this regard submit non-binding recommendations. Beyond this, the Monitor has no right to demand from the parties that they act in a specific manner, refrain from action or tolerate action.
- 8.6 The Monitor will submit a written report to the CMD, BHEL within 8 to 10 weeks from the date of reference or intimation to him by the Principal and, should the occasion arise, submit proposals for correcting problematic situations.
- 8.7 The CMD, BHEL shall decide the compensation to be paid to the Monitor and its terms and conditions.
- 8.8 If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant IPC/PC Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.9 The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.

BHEL PSWR
Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Page 43 of 101

.....
8.10 The word 'Monitor' would include both singular and plural.

Section 9 – Pact Duration

- 9.1 This Pact begins and shall be binding on and from the submission of bid(s) by bidder(s). It expires for the Contractor 12 months after the last payment under the respective contract and for all other Bidders 6 months after the contract has been awarded.
- 9.2 If any claim is made/ lodged during this time, the same shall be binding and continue to be valid despite the lapse of this pact as specified as above, unless it is discharged/ determined by the CMD, BHEL.

Section 10 – Other Provisions

- 10.1 This agreement is subject to Indian Laws and jurisdiction shall be registered office of the Principal, i.e. New Delhi.
- 10.2 Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- 10.3 If the contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- 10.4 Should one or several provisions of this agreement turn out to be invalid, the reminder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 10.5 Only those Bidders/ Contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

For & On Behalf of the Principal
of the Bidder/ Contractor
(Office Seal)
(Office Seal)

For & On Behalf

IMPORTANT INFORMATION

Sealed Tenders shall be submitted at following address to AGM /Purchase BHEL PSWR NAGPUR:

BHEL PSWR, SRIMOHINI COMPLEX , 345 KINGSWAY, NAGPUR 440001, INDIA

All correspondences regarding this tender shall be addressed to AGM / PURCHASE BHEL PSWR at above address. Bidders may also opt to correspond with following BHEL officials regarding this tender through email at following email ids . However please be informed that sealed tenders shall necessarily be submitted in original at above address:

AGM Purchase, Email id: ska@bhhelpswr.co.in. Ph: +91 – 712 – 3048633

Sr Engineer Purchase, Email: pgv@bhhelpswr.co.in, Ph: +91 – 712 – 3048713

Sr Engineer Purchase, Email: nktiwari@bhhelpswr.co.in Ph: +91-712-3048651

Engineer Purchase, Email id: svm@bhhelpswr.co.in , Ph: +91 – 712 – 3048715

- 1. The offers of the bidders who are on the banned list as also the offer of the bidders, who engage the services of the banned firms, shall be rejected. The list of banned firms is available on BHEL web site (www.bhel.com ---> Tender Notification -> List of Banned Firms)**
- 2. Refer Chapter XII of Volume IB Special Conditions of Contract regarding Suspension of Business Dealings: The abridged version of extant 'Guidelines for suspension of business dealings with suppliers/ contractors' has now been uploaded on www.bhel.com on "supplier registration page" at the following link: http://www.bhel.com/vender_registration/pdf/Suspension-of-Business-Dealings-with-Supplier-issued-Sept13_abridged.pdf**
- 3. All Statutory Requirements as applicable for this project shall be complied with.**
- 4. Please take note of following Revised Tender Clauses:**
 - i. Notice Inviting Tender: Sl No 9
 - ii. General conditions of Contract: Clause No 1.15.13 (New), Clause No 2.8.3, 2.8.4 and 2.8.5

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

5. Following Notes are added to Form F- 15 of Volume I D 'Forms & procedures'

- i. It is only indicative and shall be as per the online format issued by BHEL time to time.
- ii. No request will be entertained after specified date of the current month w.r.t the changes requested in the scores of immediate previous month.

6. MODALITY FOR AWARD OF VARIOUS CIVIL & STRUCTURAL PKGS AT SUBJECT PROJECT:

6.1

Following 9 packages of civil and structural job is envisaged under the project:

- a. **Package A:** Boiler island Unit#1&3
- b. **Package B:** Boiler island Unit#2&4
- c. **Package C:**Power House island Unit#1&2
- d. **Package D:** Power House island Unit#3&4
- e. **Package E:**Structure power house Unit#1&2
- f. **Package F:** Structure power house Unit#3&4
- g. **Package G:** Clarified water Tank Unit#1,2,3 & 4
- h. **Package H:** CW Reservoir and Pump house
- i. **Package I:** BOP Civil

} One Combined tender
} One Combined tender
} One Combined tender

Subject tender is for **Package E and Package F** at sl no e and f respectively. Successful tenderer of any of the package above shall not be considered for other packages i.e any bidder who has been awarded any of the package above (listed at Sl No 6.1 a to i), shall not considered in the tender for other packages except for the specific case indicated in Sl No 6.2 v below. In case more than one package is tendered simultaneously, then BHEL reserves the right to open the price bids of any tender in any order.

6.2:

Subject tender is a combined tender for Package-E and Package-F at 4X 270 MW BHADRADRI, MANUGURU TPS, TELANGANA.

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
- i Tender specification (Volume IA Technical Specification and Vol-II-Price Bid Specification) is common for both Packages i.e. **Package-E and Package-F**.
 - ii **Package-E and Package-F** shall be awarded to separate agencies.
 - iii **Bidder has to submit their Price for Package-E only as indicated in the Vol-II-Price Bid Specification.**
 - iv L-1 Bidder shall be considered for award of **Package-E**.
 - v For award of **Package-F**, next bidder in the order of their price competitiveness (i.e L-2, then L-3 and hence forth) shall be given an option to match their price/rate, with the Awarded/Finalized price/rate of **Package-E**. In case none of the bidders agree to match the Awarded PRICE/RATE of **Package-E**, then BHEL may consider awarding the **Package-F**, to L-1 bidder or opt any other suitable method to finalize Package-F.
- vi Pictorial depiction of modality in Sl No 6.2 above is as below:

Sl No	Name of the Package	To be awarded to:
1	Package E	To L-1 bidder of subject tender
2	Package F	To the next bidder (in the order of their price competitiveness) matching L-1 awarded rate/price

7. PRICE VARIATION CLAUSE

Revision in Price Variation Compensation Clause no. 2.17 of Vol I C GCC:

Clause No. 2.17 of Vol IC GCC is revised as below:-

2.17 PRICE VARIATION COMPENSATION (During Original Contract Period and Extension if any)

2.17.1 In order to take care of variation in Total Minimum Per Day Wages of all categories of workers/labors, Price Variation Formula as described herein shall be applicable

2.17.2 20 % component of Contract Value shall be permitted to be adjusted for variation in Total Minimum per Day Wage of 'UNSKILLED LABOUR/WORKERS' during execution of work. The remaining 80% shall be treated as fixed component

2.17.3 Payment/recovery due to variation labor index during execution of work shall be determined on the basis of the following notional formula:

$$P = 20 \% \times R \times \frac{(X_N - X_0)}{X_0}$$

X₀

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

.....
Where

P = Amount to be paid/recovered due to variation in Total Minimum Per Day Wage of 'UNSKILLED LABOUR/WORKERS'

R = Value of work done for the billing month (Excluding Taxes and Duties if payable extra)

XN = Revised Total Minimum per Day Wage of 'UNSKILLED LABOUR/WORKERS' for the billing month under consideration

Xo = Total Minimum per Day Wage of 'UNSKILLED LABOUR/WORKERS' as on the Base date.

2.17.4 Base date shall be calendar month of the latest date of submission of Tender

2.17.5 Total Minimum Per Day Wage of 'UNSKILLED LABOUR/WORKERS' applicable for the billing month and the base month shall be as per the authorized notification/circulars issued by the Principle Employer (BHEL's Customer) regarding prevailing (billing Month or base month) minimum total per day labor wage of UNSKILLED LABOUR/WORKERS applicable in the project

2.17.6 PVC shall not be payable for the ORC amount, Supplementary/Additional Items, Extra works

2.17.7 The contractor will be required to raise the bills for price variation payments on a monthly basis along with the running bills irrespective of the fact whether any increase/decrease in the Total Minimum Per Day Wage of 'UNSKILLED LABOUR/WORKERS' has taken place or not. In case there is delay in publication/issuance of authorized notification/circulars (final figure), the PVC bill shall be deferred till the issuance of the same

2.17.8 PVC shall be applicable for the entire original contract period plus the extended period. The total amount of PVC shall not exceed 5 % of the cumulatively executed contract value. Executed contract value for this purpose is exclusive of PVC, ORC, Supplementary/Additional Items and Extra works. However the Total Quantum of Price Variation amount payable/recoverable during delayed/extended period shall be regulated as follows

- i) For the portion of backlog attributable to the contractor, the PVC will be based on the average of the Total Minimum Per Day Wage of 'UNSKILLED LABOUR/WORKERS' for the period of the original contract period
- ii) For the period of Force Majeure, the PVC will be limited to Total Minimum Per Day Wage of 'UNSKILLED LABOUR/WORKERS' applicable at the beginning of the force majeure period.

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
 BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

- iii) For the portion of backlog attributable to BHEL, the PVC will be as per the Total Minimum Per Day Wage of 'UNSKILLED LABOUR/WORKERS' applicable for the respective months

2.17.9 Additional PVC during Contract Extension Period

- i) In order to take care of variation in cost of execution of work on either side, due to variation in the index of LABOUR, HIGH SPEED DIESEL OIL, WELDING ROD, CEMENT, STEEL, MATERIALS, Additional Price Variation Formula as described herein shall be applicable during contract extension period. **Additional PVC shall be applicable only during the extended period of contract (if any)** after the schedule completion date for the portion of work delayed / backlog for the reasons not attributable to Contractor
- ii) 65 % component of **Executed Value (during extended period)** shall be permitted to be adjusted for variation in various relevant indices during extended contract period. The remaining 35% shall be treated as fixed component.
- iii) The basis for calculation of price variation in each category, their component, Base Index, shall be as under:

No	CATEGORY	Base Index	Component K
01	LABOUR (ALL CATEGORIES)	MONTHLY AVERAGE CONSUMER PRICE INDEX NUMBERS FOR INDUSTRIAL WORKERS' for WARRANGAL CENTRE of TELANGANA State published by Labour Bureau, Ministry of Labour and Employment, Government of India. (Website: labourbureau.nic.in)	45
02	HIGH SPEED DIESEL OIL	Name of Commodity: HSD OIL. Type : INDIVIDUAL COMMODITY (See Note below)	5
03	WELDING ROD	Name of Commodity : WELDING ROD Type: INDIVIDUAL COMMODITY (See Note below)	15

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

Note:

As per the 'MONTHLY WHOLE SALE PRICE INDEX' for the respective Commodity and Type, published by Office of Economic Adviser, Ministry of Commerce and Industry, Government of India. (Website : www.eaindustry.nic.in). Revisions in the index or commodity will be re adjusted accordingly

- iv) Payment/recovery due to variation in index shall be determined on the basis of the following notional formula without any initial absorption, in respect of the identified components viz LABOUR, HIGH SPEED DIESEL OIL, WELDING ROD, CEMENT, STEEL, MATERIALS

$$P = K \times R \times \frac{(X_N - X_o)}{X_o}$$

Where

P = Amount to be paid/recovered due to variation in the Index for Labor, High Speed Diesel Oil, Welding Rod, Cement, Steel and Materials

K = Percentage component applicable for Labor, High Speed Diesel Oil, Welding Rod, Cement, Steel and Materials

R = Value of work done for the billing month during extended period (Excluding Taxes and Duties if payable extra)

XN = Revised Index No for Labor, High Speed Diesel Oil, Welding Rod, Cement, Steel and Materials for the billing month under consideration

Xo = Index no for Labor, High Speed Diesel Oil, Welding Rod, Cement, Steel and Materials as on the Base date

- v) Base date shall be the calendar month of the schedule completion date of the contract. Schedule Completion date shall be the actual start date plus contract period as defined in Chapter VI 'Vol IA TCC'
- vi) Additional PVC shall not be payable for the ORC amount, Supplementary/Additional Items, Extra works
- vii) The contractor shall furnish necessary monthly bulletins for the necessary indices from the relevant websites along with his Bills
- viii) The contractor will be required to raise the bills for additional price variation payments on a monthly basis during extended period along with the running bills irrespective of the fact whether any increase/decrease in the index for relevant categories has taken place or not. In case there is delay in publication of bulletins (final figure), the provisional values as published can be considered for

.....
payments and arrears shall be paid/recovered on getting the final values

ix) Total quantum of Additional Price Variation amount payable/recoverable shall be regulated as follows:

- a) For the portion of backlog attributable to the contractor and for the portion of backlog due to force majeure condition during contract period, Additional PVC shall not be paid.
- b) For the period of force Majeure during extended contract period, Additional PVC will be as per the indices applicable at the beginning of the force majeure period (during extended period).
- c) void
- d) The total amount of additional PVC shall not exceed 20% of the cumulatively executed contract value during the extended contract period. Executed contract value for this purpose is exclusive of PVC, ORC, Supplementary/Additional Items and Extra works.

8. QUANTITY VARIATION

Revision in QUANTITY VARIATION Clause no. 2.14 of Vol I C GCC:

Clause No. 2.14 of Vol IC GCC is revised as below:-

Rates for individual items shall remain firm for any variation in the respective quantity up to plus (+) 30 % and minus (-) 100 %.

For any variation in individual item quantities beyond plus (+) 30 %, the item rate of that item shall be increased by 5 % i.e. payment for the quantities executed beyond 130 % of the tendered quantity shall be made @ of 105 % of the awarded rate of that particular item. Contractor shall not be eligible for any other compensation on this account

For any variation in individual item quantity on negative side or in case any item is not operated at all, there will be no revision in the item rates during entire contract period and extended period if any.

However In case the finally executed contract value reduces below 85 % of the ordered total value due to quantity variation, the contractor will be eligible for compensation @ 15% of the difference between the 85% of the ordered value and the actual executed value. For this purpose executed contract value shall also include items quantities which are paid @ 105 % of ordered rate due to variation beyond plus (+) 30%.

9. OVER RUN COMPENSATION

Over Run Compensation Clause no. 2.12 of Vol I C GCC shall not be Applicable

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

10. Acceptance of Bank Guarantee (BG)

Revision in Acceptance of Bank Guarantee (BG) Clause no. 1.10.3 (V) of Vol I C GCC:

Clause No. 1.10.3 (V) of Vol IC GCC is revised as below:-

“Bank Guarantee issued by:

- a. Any of the BHEL consortium bank listed below :

State Bank of India
ABN Amro Bank N.V.
Bank of Baroda
Canara Bank
Citi Bank N.A.
Corporation Bank
Deutsche Bank
HDFC Bank Ltd.
The Hongkong and Shanghai Banking Corporation Ltd.
ICICI Bank Ltd.
IDBI Ltd.
Punjab National Bank
Standard Chartered Bank
State Bank of Travancore
State Bank of Hyderabad
Syndicate Bank

- b. Any public sector Bank (other than consortium banks) with a clause in the text of Bank Guarantee that it is enforceable at Nagpur, Maharashtra
- c. Any private sector banks, with a clause in the text of Bank Guarantee that it is enforceable by being presented at any branch of the bank

Note: “Bank Guarantees issued by Co-operative Banks are not acceptable”.

11. Broad Terms & Conditions of Reverse Auction

In continuation to Clause 19.0 of NIT (Notice Inviting Tender) following are the broad terms and conditions of Reverse Auction is given in Annexure V of NIT:

- 11.1. Against this enquiry for the subject item/ system with detailed scope of supply as per enquiry specifications, BHEL may resort to “REVERSE AUCTION PROCEDURE” i.e., ON LINE

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

.....
BIDDING (THROUGH A SERVICE PROVIDER). The philosophy followed for reverse auction shall be English Reverse (No ties).

- 11.2. BHEL reserves the right to go for Reverse Auction (RA) instead of opening the sealed envelope price bid, submitted by the bidder. This will be decided after techno-commercial evaluation. All bidders to give their acceptance for participation in RA. Non-acceptance to participate in RA may result in non-consideration of their bids. In case BHEL decides to go for Reverse Auction, only those bidders who have given their acceptance to participate in RA will be allowed to participate in the Reverse Auction. Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit „online sealed bid“ in the Reverse Auction. Non-submission of „online sealed bid“ by the bidder will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.
- 11.3. For the proposed reverse auction, technically and commercially acceptable bidders only shall be eligible to participate.
- 11.4. Those bidders who have given their acceptance for Reverse Auction (quoted against this tender enquiry) will have to necessarily submit ‘online sealed bid’ in the Reverse Auction. Non-submission of ‘online sealed bid’ by the bidder for any of the eligible items for which techno-commercially qualified, will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue.
- 11.5. BHEL will engage the services of a service provider who will provide all necessary training and assistance before commencement of on line bidding on internet.
- 11.6. In case of reverse auction, BHEL will inform the bidders the details of Service Provider to enable them to contact & get trained.
- 11.7. Business rules like event date, time, bid decrement, extension etc. also will be communicated through service provider for compliance.
- 11.8. Bidders have to fax the Compliance form (annexure IV) before start of Reverse auction. Without this, the bidder will not be eligible to participate in the event.
- 11.9. In line with the NIT terms, BHEL will provide the calculation sheet (e.g., EXCEL sheet) which will help to arrive at “Total Cost to BHEL” like Packing & forwarding charges, Taxes and Duties, Freight charges, Insurance, Service Tax for Services and loading

Notice Inviting Tender (NIT)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

-
- factors (for noncompliance to BHEL standard Commercial terms & conditions) for each of the bidder to enable them to fill-in the price and keep it ready for keying in during the Auction.
- 11.10. Reverse auction will be conducted on scheduled date & time.
- 11.11. At the end of Reverse Auction event, the lowest bidder value will be known on auction portal.
- 11.12. The lowest bidder has to fax/e-mail the duly signed and filled-in prescribed format for price breakup including that of line items, if required, (Annexure VII) as provided on case-to-case basis to Service provider within two working days of Auction without fail.
- 11.13. In case BHEL decides not to go for Reverse Auction procedure for this tender enquiry, the Price bids and price impacts, if any, already submitted and available with BHEL shall be opened as per BHEL's standard practice.
- 11.14. Bidders shall be required to read the "Terms and Conditions" section of the auctions site of Service provider, using the Login IDs and passwords given to them by the service provider before reverse auction event. Bidders should acquaint themselves of the "Business Rules of Reverse Auction", which will be communicated before the Reverse Auction.
- 11.15. If the Bidder or any of his representatives are found to be involved in Price manipulation/ cartel formation of any kind, directly or indirectly by communicating with other bidders, action as per extant BHEL guidelines, shall be initiated by BHEL and the results of the RA scrapped/ aborted.
- 11.16. The Bidder shall not divulge either his Bids or any other exclusive details of BHEL to any other party.
- 11.17. In case BHEL decides to go for reverse auction, the H1 bidder (whose quote is highest in online sealed bid) may not be allowed to participate in further RA process.

12. Interchangeability of Scope:

BHEL reserves right to swap any particular scope of work/any portion of work between Package C and Package D of subject tender as per the requirement of the site during execution of the job.



TECHNICAL CONDITIONS OF CONTRACT (TCC)

BHARAT HEAVY ELECTRICALS LIMITED



TECHNICAL CONDITIONS OF CONTRACT (TCC)
INDEX

Sl No	DESCRIPTION	Chapter	No. OF PAGES
Volume -IA	Part-I: Contract specific details		
1	Project Information	Chapter-I	1
2	Scope of Works and Technical Specifications	Chapter-II	25
3	Facilities in the scope of Contractor/BHEL (Scope Matrix)	Chapter-III	6
4	T&Ps and MMEs to be deployed by Contractor	Chapter-IV	4
5	T&Ps and MMEs to be deployed by BHEL on sharing basis	Chapter-V	1
6	Time Schedule	Chapter-VI	1
7	Terms of Payment	Chapter-VII	1
8	Taxes and other Duties	Chapter-VIII	3
9	Tender Drawings	Chapter-IX	1
10	Appendix	Chapter-X	2

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter - I: PROJECT INFORMATION

PROJECT INFORMATION

SL No	Description	Details
1.1	Location	10 KM from Manuguru Town;
1.2	Nearest Railway Station	Manuguru (20 KM)
1.3	Nearest Airport/Seaport	Vijaywada (220 KM from site)
1.4	Access By Road/Major Cities	38 KM from Bhadrachalam, 345 KM from Hyderabad
1.5	Source of Coal	Singareni Coal Mines/Imported Coal
1.6	Source of Water	Godavari River
1.7	Meteorological Data:	
	Dry Bulb Temperature (Max/Min)	44.8° C/13°C
	Humidity (Max/Min)	82%/31%
	Average Rainfall	1250 mm annually
	Wind Speed	Basic wind speed of 44 m/sec as per IS -875(Part-3)
	Seismic Zone	Basic wind speed of 44 m/sec as per IS -875(Part-3)

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

2.0 SCOPE OF WORK

2.1 Micro Grading: After the completion of structural work the entire area shall be micro graded up to required levels by the contractor to achieve the ground profile at NGL level requirement at no extra cost. Filling/ cutting required to bring the site up to the required finished levels is in the scope of the contractor. The extra material/wastage including contractor's own site office/storage yard etc debris, so generated shall be disposed outside of plant premises at approved location without any extra cost.

2.2.1 List of Building/Structure Covered under this package but not limited to:

2.2.2 Turbine Building cum Control Room: All structural works of TG building including AB Bay; BC Bay; CD Bay (including interconnecting platforms & structures) and any other equipment foundation related structural works.

2.2.3 Mill & Bunker Bay: All structural works of M&N Bay including coal bunkers and silo hopper etc.

2.2.4 Pipe/Cable Rack: All structural works of pipe/cable rack within battery limits of plant area.

2.2.5 Misc Sheds: All structural works of miscellaneous sheds with/without EOT/HOT cranes.

2.2.6 Mono-Rail Beams: All structural works of mono beams in various buildings of plant area.

2.2.7 Cross Overs & Access Platforms/ladders: All structural works of miscellaneous cross overs & access platforms as per drawings/commissioning requirements/customer requirements

2.2.8 Laying of Grating/Handrail: All structural works related with laying of grating and/or handrail in plant area as per drawings/commissioning requirements/customer's requirements.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.2.9 Grouting Works: Grouting of all columns under base plate shall be done by the bidder including supply of material and T&Ps etc complete as per FQP/customer requirements.

2.3 Structural Works Related to Following Services:-

- 1) **Fabrication and Erection of Structural steel including all interfacing works.** The nature of works shall include columns, beams, splicing of steel works as required as per drawings, bracings, purlins, trusses, sheeting work, struts, walkways, galleries, stairs, steps, ladders, handrails, sag rods, Floor gratings, Stub columns, Chequered plate work, equipment supporting beams, pipe supports, silencer supports and all other structures required for successful completion of structural works of the project.
- 2) Pipe/Cable supporting arrangements
- 3) Road Crossings bridges
- 4) Pipe way Bridges
- 5) Pipe way Sleepers
- 6) Hard stand required for erection of heavy structures.
- 7) Any temporary activities required to complete the work.
- 8) Structural platforms, monorail beams, walkways, crossovers, handrails etc for miscellaneous equipment, piping etc.
- 9) Contractor has to submit drawing for approval and construct following infrastructure:-1) PRE-FAB Labour Colony for 500 Person min. with all amenities like drinking water and sanitary system, 2) fabrication yard if required 3) field office and construction of stores has to be developed by the contractor of its own and the Client shall only identify the space on as in where is basis. All the infrastructure facilities required by contractor for carrying out the above work which include roads, approaches, drainage system, pavements etc. shall be developed & provided by the contractor of its own. No extra payment will be entertained under this Nos.
- 10) Bidder to ensure that Pre-Fabricated Labour colony for 500 min. Person with all basic amenities is established at site within 2 month of issue of LOI, if it fails BHEL Reserves the right to carry out this work at risk and cost of Contractor. Number of Workmen mentioned here is minimum only and may increase depending on Project requirement.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.4 The work will involve:

All works required to complete structural works including Fabrication and erection of structural steel work involving rolled section, semi-rolled sections, sections fabricated out of plates, chequered plates, grating, hand rails, shot blasting, primer and final painting for all steel structural works including supply of HSFG Bolts if any, low hydrogen quality electrodes for welding, non-destructive testing etc complete as per Field Quality Plan/Customer requirements. All field quality checks for welds like radiography, NDT, etc are in the scope of work and bidder should quote accordingly. Supply of all consumables required for fabrication and supply of all bolts, nuts, washers, electrodes etc.

2.5 Scope: Structural Works

The scope covers all structural works within the battery limits of this Package.

The important works covered under this package are as below:

2.5.1 Preparation of complete fabrication detailed drawings and erection marking drawings required for all the structures covered under the scope of this contract based on design drawings furnished by BHEL.

2.5.2 Submission of revised fabrication drawings with calculation in case any substitution of designed sections is made. The scope would also include **submission of calculations of joints & calculations.**

2.5.3 Preparation and submission of detailed bill of materials, drawing office despatch lists, bolts lists etc required in connection with the fabrication and erection structural works as directed by the Engineer for his checking and approval.

2.5.4 The fabrication/erection work would include **straightening** of material by mechanical means or localized heating with temperature not exceeding 600° C; cutting by all means; **planning of edges; making holes; assembly at shop or erection site; getting welding sequence** approved; **peening** by suitable tools; **lacing bars;**

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

separators; bearing plates; providing architectural clearances; shop connections and shop painting etc.

2.5.5 All Steel structures shall be cleaned to **near white metal surface conforming to SA 2-1/2** standard before application of shop primer. All arrangements for **shot blasting** such as compressor of required capacities, Diesel/electric generator, GI Sheets, support frames for structural members, Scaffolding pipes for construction of semi closed shed, hose pipe, shed for storage of abrasive materials/paints etc and spray guns/brushes etc shall in the scope of contractor. Any other arrangements that may have to be done to ensure smooth operations of shot blasting shall be in the scope of contractor. The work shall be done as per BHEL specifications/TSGENCO Specifications/applicable standards.

2.5.6 All fabricated steel work shall be **shop painted** complete as per customer specifications.

2.5.7 Transportation of fabricated steel structures from fabrication yard to storage yard/erection site including handling, rigging, assembling, bolting, welding and satisfactory installation of all fabricated steel materials in proper location according to approved erection drawings. If necessary suitable approaches may have to be built for transportation of steel structures. The item rate quoted shall be inclusive of such incidental works.

2.5.8 Checking centre lines, level of all foundation pedestals, position of all bolts/pockets and aligning, plumbing, levelling, bolting, welding and securely fixing the erected steel structures in accordance with drawings. The members erected shall be tied with each other using suitable tie beams/bracing etc or using guys as per directions of engineer in charge.

2.5.9 Removal of bends, kinks and twists etc of parts damaged during transportation/handling etc shall be made good by the contractor at no extra cost.

2.5.10 Cutting, chipping, filling, grinding, reaming of holes, re-fabrication of parts damaged beyond repair during transportation/handling and

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

drilling holes which have either not been drilled or wrongly drilled are all included in the scope of works without any extra cost.

2.5.11 Fabrication/erection tolerances shall be as per approved FQP/TSGENCO specifications.

2.5.12 All welding works shall be done through qualified welders. Such welders shall be duly qualified by BHEL/TSGENCO engineer based on welder test conducted at site as per IS-817. Process Qualification (if required) shall be arranged by contractor through their qualified quality engineer. All samples for the Welder qualification test shall be arranged by contractor. Quoted rates shall be inclusive of all costs towards testing of welders for destructive/non-destructive tests, testing and approval of welders. All welded joints shall be subject to the acceptance of BHEL/TSGENCO engineer. All the welded joints shall be cleaned of slag etc by way of PEENING complete as per BHEL/TSGENCO specifications.

2.5.13 The type of electrode, welding sequence, and pre heat and post heat requirements (if required) shall be approved by BHEL/TSGENCO engineer.

2.5.14 All the welds shall be visually checked for size, length of weldment and external defects. Weld gauges shall be used for checking of welds. **Non Destructive tests** shall be conducted as per approved FQP/TSGENCO Specifications. In case of defects observed during such NDT tests, the joints shall be again back gauged, joints re prepared and re welded. The contractor shall do such repair works at no extra costs.

2.5.15 The fabrication of structural steel members shall be such that the sequence of welding will avoid distortion and minimize shrinkage stresses in the closing welds of rigid assembly. All multiple layers of weld shall be peened with light blows from hammer/round nose tool after the weld has cooled to room temperatures. Care shall be taken to prevent scaling/flaking of weld and base metal from peening.

2.5.16 All fillet welds shall be brought practically closer as far as possible and in no case shall be more than 4 mm. **All butt welds** shall be carefully aligned and mis-alignments greater than 3 mm shall be corrected. All works shall be positioned for flat welding wherever practicable.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

- 2.5.17** The electrodes shall be stored in properly designed racks, separating different types of electrodes in different compartments. They shall be kept in dry and warm condition by way of heating in mother ovens. A separate room shall be constructed and marked as electrode room manned by dedicated engineer. Complete record shall be made in registers each batch wise complete as per directions of engineer.
- 2.5.18** Bolts, nuts & washers and other fastening materials shall be stored on racks above ground and suitably covered with **protective oil**.
- 2.5.19** Suitable marking, bundling, loading/unloading and transport of all fabricated materials to site for further erection works. **The scheme for erection works shall be approved before start of work** by the BHEL Engineer.
- 2.5.20** Taking delivery of Structural steel incl chequered plate and MS rail etc from BHEL stores/storage yard for utilisation in construction work under this package.
- 2.5.21** Supply of all HSFG bolts, Mild steel bolts, erection bolts, nuts, plain/taper and spring washers, all types of electrodes required for fabrication shop and erection welding etc including instruments and personnel for conducting necessary tests at site as specified/as directed by the Engineer.

2.6: General Scope

2.6.1 Furnishing all labour, materials, supervision, construction plans, equipment, supplies, transport, to and from the site, fuel, compressed air, and all other incidental items and temporary works not shown or specified but reasonably implied or necessary for the proper completion, maintenance and handling over the works, except in accordance with the stipulations laid down in the contract documents and additional stipulations as may be provided by the engineer during the course of works.

2.6.2 Furnishing samples of all materials required by the engineers for testing/inspection and approval for use in the works. The

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

samples may be retained by the engineer for final incorporation in the works.

2.6.3 Furnishing test reports for the products used or intended to be used, if called for the specifications or if so desired by the engineer.

2.6.4 Giving all notices, paying all fees, taxes etc., in accordance with the general conditions of contract, that is required for all works including temporary works.

2.6.5 Arranging manufacturer's supervision for items of work done as per manufacturer's specifications when so specified.

2.6.6 The contractor shall establish a suitable yard at an approved location for fabrication of steel material and storage of steel material. The yard shall have facilities like drainage, lighting, suitable access for large cranes, trailers etc. The yard shall be fenced all around with barbed wire and shall have suitable security arrangement with security guards etc. The Contractor shall also make covered store for storage of connection materials, paints, electrodes, shot blast material etc.

2.6.7 The contractor shall cover intermediate floors with planks if so required in case of other works at floors below/ground at no extra cost.

2.6.8 Providing all incidental items not shown or specified but reasonably implied or necessary for the successful completion of the work in accordance with contract.

2.6.9 Arranging for joint checking (with BHEL/TSGENCO/Consultant) of all site construction activities Preparation of joint protocols for each & every activity and maintaining quality records for audit/inspection.

2.6.10 The drawings enclosed with this tender are intended to give the tenderer a general idea of the type and extent of work involved. The drawings are as such only indicative and not to be considered as the exact construction drawings.

Further this is to be noted that the drawings and the documents furnished along with this specification are the sole property of

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

B.H.E.L. It must not be used directly or indirectly in any way detrimental to the interest of the company.

2.6.11 The scope of work will also include such other related works although they may not be specifically mentioned in the above paragraph and all such incidental items not specified but reasonably imply and necessary for completion of the job as a whole all as desired and as directed by the engineer.

2.6.12 The detail scope of work covered above is not a comprehensive list of items of work involved. The detail scope of work may vary considerably depending on the actual construction requirements as per RFC Drawings.

2.7 WORKS BY OTHERS

No work under the specification will be provided by any agency other than the contractor unless specifically mentioned elsewhere in the contract.

2.8 SITE VISIT

Contractor may visit Wanakbori project site, to acquaint himself with the conditions prevailing at site and in and around the plant premises, together with all the statutory, obligatory, mandatory requirements of various authorities before submission of the bid.

2.9 Carrying out of Work by BHEL

BHEL reserves the right to withdraw/restrict/alter the quantum of works as per **clause 2.7 of General Conditions of Contract**. BHEL may carry out work through any other agency/purchase Bought Out items as per GCC. In such cases due notice shall be given for a period of 2 (two) weeks.

NOTE:

Contractor should make him well conversant with the Customer specification. In case of ambiguity between BHEL and customer specification, customer specification shall prevail.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.10 PREAMBLE FOR THE SCHEDULE OF QUANTITIES/BOQ.

2.10.1 Details of the items in this Schedule shall be read in conjunction with the M/s TSGENCO CONSULTANT/TSGENCO specifications, drawings, technical specifications and other documents and shall have precedence over any contrary statement mentioned anywhere in this document.

2.10.2 The work shall be carried out as per construction drawings, specifications, the description of the items in this schedule and/or Engineer's instructions, Drawings enclosed with these documents are only indicative giving some idea of the type of work involved. The layout, sizes and details of the building, structures and foundations shown in tender drawings may vary at a large extent during actual construction. Final drawings will be issued progressively during the execution of the work.

2.10.3 Items of work provided in this schedule but not covered in the specifications shall be executed strictly as per instructions of the Engineer.

2.10.4 Unless specifically mentioned otherwise in the contract, the bidder shall quote his rates for the finished items and shall provide for the complete cost towards fuel, tools, tackle, equipment, constructional plant, temporary works, labour materials, levies, taxes, transport, layout, repairs, rectification, maintenance till handing over, supervision, shops, establishments, services, temporary roads, revenue expenses, contingencies, overhead, profits and all incidental items not specifically mentioned but reasonably implied and necessary to complete the works according to the contract.

2.10.5 The rate quoted shall be inclusive of cleaning the site of any vegetation, dressing and levelling etc., required for commencement of site activities. The rates shall also be inclusive of final micro grading before handing over. No separate payment will be made towards the same these works.

2.10.6 The quantities of the various items mentioned in the schedule are approximate and may vary up to any extent or be deleted altogether. The overall variation in contract value on execution shall be dealt as per GCC. Contractor has to obtain prior approval of BHEL/TSGENCO before procurement of bought out items/ building materials.

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.10.7 Rates shall be quoted both in figures and in words in clear legible writing. No over writing is allowed. All scoring and cancellation should be counter signed by the bidder. In case of illegibility, the interpretation of the engineer shall be final. All entries shall be in English language.

2.10.8 Engineer's decision shall be final and binding on the contractors regarding clarification of items in this schedule with respect to the other section of the contract.

2.10.9 In case of any discrepancy between item description, relevant drawing and/or specification clarification shall be sought at tender stage itself. Otherwise it shall be assumed that the bidder has quoted for the more stringent requirement.

2.10.10 Any reference in the customer specifications regarding mode of measurements/methodology of measurements shall not be applicable.

2.10.11 The scope shall also include setting up a quality laboratory of suitable size in the field, by the bidder to develop **Radiography Test Films** (commonly denoted as **Dark Room**), **Pit Room for source storage, RT Film storage cum film interpretation room** (AC Room of appropriate size), **conducting Welder qualification tests and UT test**. The bidder may tie up with approved/registered inspection agencies for setting up test lab on site as described above.

2.11 HIERARCHY OF DOCUMENTS

In case of any conflict/deviations of **technical specifications** with regard to any work; amongst various documents, the order of precedence shall be as follows:

- 1) Statutory Regulations
- 2) TSGENCO technical specifications/Section C technical specifications
- 3) Items in Schedule of Quantities
- 4) IS standards
- 5) BHEL's standard specification (Section D)

The above hierarchy shall be followed strictly for technical requirements only to carry out works under the scope of this contract.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.12 Laying / Cutting & Re-welding of associated electrical earthing works below the road & drains and surrounding areas shall also be done by civil contractor as per drawings for which 40mm dia. MS rod/GI flats shall be supplied by BHEL free of cost.

2.13 Construction Power: (Free of cost)

2.13.1 Construction power (three phase, 415 V/ 440 V) will be provided free of cost at one point near the site at a distance of approx. 500M. Further distribution shall be arranged by the contractor at his own cost and services. Contractor shall be responsible for fulfillment of all requirements including statutory requirements in this regard. Contractor shall deploy and install required energy meter, cables, fuses, distribution boards, switchboards, bus bars, earthing arrangements, protection devices and any other installation as specified by statutory authority/act. Contractor shall also obtain approvals of appropriate authority and pay necessary fees, levies etc towards the clearance of such installations, prior to use. Sufficient power factor compensation equipment like capacitor shall be provided by contractor for reactive loads like welding machines etc. In case of any fine/penalty on account of low power factor, same shall be shared by contractor proportionately according to power consumption.

2.13.2 Contractor shall make necessary arrangements for onward distribution of construction power taking due care of surrounding construction activities like movement of cranes & vehicles, civil work, fabrication/construction/assembly/ erection etc and safety of personnel. It may become necessary to relocate some of the installations to facilitate work by other agencies or by him.

2.13.3 It shall be the responsibility of the Contractor to provide, maintain the complete installation on the load side of the supply with due regard to the safety requirements at site. All cabling and installations shall comply in all respects with the appropriate statutory requirements. The installation and maintenance of this shall be done by licensed and experienced electrician.

2.13.4 While reasonable efforts will be made to ensure continuous electric power supply, interruptions cannot be ruled out and no claim from the Contractor shall be entertained on this account such as idle

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

labor, extension of time etc. The Contractor shall adjust his working shift accordingly and deploy additional manpower, if necessary, so as to achieve the target.

2.13.5 Contractor shall be well equipped with back-up power supply arrangement like DG set and diesel operated welding machine etc to tackle situations arising due to failure of supplied power, so as to ensure continuity and completion of critical processes that are underway at the time of power failure or important activities planned in immediate future.

2.13.6 BHEL is not responsible for any loss or damage to the Contractor's equipment as a result of variations in voltage or frequency or interruptions in power supply.

2.13.7 **Contractor to note that till construction power is made available by BHEL (approx within 3 months from start of work); contractor shall make his own arrangement like DG set etc. The contractor shall also take the approval/ permission of Gujarat State statutory authorities for his DG set installation.** The Contractor has to make his own arrangement for the same as required to carry out the job under the scope of work within the quoted rate. Nothing extra shall be paid on this account of DG set up and running for construction and office maintenance etc.

2.13.8 Contractor is advised to maintain the calibrated energy measuring instruments and use their system as efficiently as possible to maintain the HT side input energy meter reading and LT side outgoing energy meter reading to sub-contractors as equal.

2.13.9 The bidder will have to Procure & install **General Mobile illumination system during construction as per site requirements.** This system will include temporary pole lighting, portable lighting towers with DG back-up, within the quoted price. The illumination should be such that minimum illumination requirement as specified by Indian standards for general illumination is maintained.

GENERAL:-

If any other voltage level (other than normally available) is required, the same shall be arranged by the contractor from power supply as above.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

Contractor will have to provide at his own cost necessary calibrated energy meters (tamper proof, suitably housed in a weather proof box with lock & key arrangement) at point of power supply along with calibration certificate from authorized / accredited agency for working out the power consumption. In case of recalibration required for any reason the necessary charges including replacement by calibrated meters is to be borne by the contractor. Supply of electricity shall be governed by Indian Electricity Act and Installation Rules and other Rules and Regulation as applicable. The contractor shall ensure usage of electricity in an efficient manner and the same may be audited by BHEL time to time. In case of any major deviation from normally accepted norms is observed, BHEL will reserve the right to impose penalty as deemed fit for such cases.

2.13 Construction water (Free of cost):- Construction water will be provided free of cost at one point near the plant boundary. Bidder has to make arrangement of further distribution of water at his own cost. No extra payment shall be made under this account. The agency should also construct a sump of suitable size for storage of construction water as per their site requirement for use in batching plant and construction purposes.

2.14 Field Quality Assurance:

The contractor shall be responsible for day-to-day quality checks of fabrication, erection and welding works during the progress of work. All quality records and log sheets shall be maintained as per the requirement of BHEL/BHEL'S customer and **as per Field Quality Plan** approved by **BHEL/TSGENCO**. Cutting plans, Fabrication protocols, erection protocols, welding protocols, DP test protocols etc shall be made on regular basis as per approved formats. During erection, alignment of various members shall be checked as per approved erection tolerances with the help of laser alignment tools (**HILTI make or equivalent**) to the extent possible.

2.15 Reconciliation of steel issued by BHEL (free of cost):

2.15.1 General Notes

- a. All steel like **structural steel, MS rods, and MS Rails except MS/GI/SS handrails** as specified in relevant BOQ shall be issued

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

free of cost by BHEL for use in the work covered in this contract from BHEL stores/storage yard. The contractor shall collect these materials from BHEL stores/storage yard at specified places at his own cost and store the same at his stores as per standard norms. Materials issued will be used only for construction of permanent works. Procurement, supply, fabrication, erection and painting of MS/GI/SS handrails as applicable shall be in contractor's scope.

- b.** BHEL reserves the right to recover from the contractor any loss arising out of damage/ theft or any other causes or during verification/stacking or at any time under the custody of the contractor.
- c.** The contractor shall take care of material issued by BHEL and shall protect the same from damage and weathering.
- d.** The contractor shall in no case be entitled for any compensation on account of any delay in supply or non-supply thereof for all or any such materials. However in case of non-availability of any specific section(s) which delays the completion of work, such cases shall be recorded separately in monthly planning format (F 14) and shall be considered for time extension of contract.
- e.** Contractor will have to make his own arrangement at his own cost for procurement of any other materials except as mentioned above/ BOQ, as required for the works and of such quality as acceptable to BHEL.
- f.** The contractor shall maintain proper store account for all the BHEL issued materials and shall give **Three (03) copies of monthly-computerized reconciliation statement** of such account showing total receipt, consumption and balance at site to the BHEL. BHEL Engineer's certification for the reconciliation of steel shall be final. The detailed reconciliation (dia. Wise or as required) shall be done **at least once in three months (03) or before submission of final bill which comes earlier.**
- g.** Contractor shall also carryout in complete association with BHEL, the material management functions and execution like day-to-day update of materials, issued to contractor, accounting for surplus/scrap material returned etc. These functions shall also be

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

carried out through computerized system utilizing suitable software. Contractor shall engage experienced software personnel to associate on dedicated basis for efficient discharge of the same in time.

- h.** The contractor shall solely be responsible for the safety & security of material after it is handed over and issued to contractor by the BHEL.
- i.** BHEL issued materials, shall not be under any circumstances whatsoever, and shall be taken out of the project site unless otherwise permitted by BHEL for outside job.

2.16 HANDLING OF MATERIALS ISSUED BY BHEL:

2.16.1 Materials shall be issued by BHEL based on the weightment basis/linear measurements & sectional weight. However on specific request of the contractor **“as a special case to expedite the job”** the consignment received at BHEL stores can directly be diverted to the work site following issuance procedure of BHEL. Such direct issues shall be as per the Challan/dispatch document/LR received with the consignment. In such cases, contractor shall do unloading of materials from trucks/lorry at their own cost.

2.16.2 All materials issued by BHEL shall be stacked, stored above ground level **by use of concrete or wooden sleepers. No materials shall remain on ground at any time.** All concrete or wooden sleepers required for stacking the materials shall be arranged by contractor at his own cost within the quoted rates. All other equipment like winches, D-Shackles, slings of various sizes, max puller, pulley blocks, jacks, trucks, trailers etc required for such handling of steel from BHEL stores/storage yard etc shall be arranged by contractor within quoted/accepted rates.

2.16.3 Open land for storage purposes shall be provided by BHEL on free of cost/as available basis. Temporary barbed wire fencing of the open storage yard is to be done by the contractor and is included under the scope of his work. Contractor shall also remove grass, bushes, trees etc wherever required off the land provided to him and shall make proper continuous up keeping of the open yard /land by removing grass, bushes trees etc and same is included under the scope of his work & No extra payment shall be made to the contractor in this regard. The bidder shall

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

make complete arrangement of necessary security personnel's to safeguard all such materials in his custody. Materials issued will be used only for construction of permanent works. The contractor shall take care of material issued by BHEL and shall protect the same from theft, damage and weathering. Excessive rusting of steel in custody of agency/contractor must be avoided. **In case, due to any cause attributable to the contractor, such rusting of steel occur rendering the same unusable, then such quantity of steel shall be recovered from the interim payment at the penal rate specified in the tender.**

2.17 ~~ISSUE OF CEMENT (Free of Cost)~~

~~**2.17.1** — Cement as received from the manufacturer/ stockiest will be issued free of cost to the contractor. **The theoretical weight of each bag of cement for issued purposes will be considered as 50 kg.** The contractor shall be accountable for the cement issued to the contractor on this notional weight only. No claim whatsoever will be entertained because of difference between theoretical and actual weight of the bags of cement.~~

~~**2.17.2** — In case, **cement is issued through bulkers being supplied from manufacturer/stockiest; the same shall be emptied in cement silos of batching plant and necessary assistance shall be provided by contractor.**~~

~~**2.17.3** — Contractor to note that batching plant being established at site shall have minimum 2 cement silos of 100 MT capacities each.~~

~~**2.17.4** — The empty cement bags duly accounted for against issue shall be the contractor's property and the same shall be disposed as per statutory regulation prevailing in the project.~~

2.18 **ISSUE OF STEEL.**

2.18.1 The steel shall be issued to the contractor on the following basis:

- i. Structural Steel: Weighment basis (Unit–MT)
- ii. ~~Reinforcement Steel and Earthing~~ **MS Rod**: Weighment basis (Unit-MT)

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

- iii. ~~GI Gratings: Weighment Basis (Unit MT/As Received from manufacturer)~~
- iv. MS Rails: Weighment Basis (Unit-MT)

2.18.2 All the steel (structural, reinforcement, MS Rod, ~~GI Grating, Foundation bolts~~, MS Rails) issued by BHEL shall be properly accounted for. The total quantity of steel required for the work will be calculated from the approved Bar Bending schedule, fabrication drawings, approved laps, chairs and lugs etc. The measurement for payment as well as for accounting shall be based on the sectional weights as indicated in the following IS/BS/EN specifications.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

Sr No	Name of Standard	Name of Section
1	IS: 808-1964	Beams, Channels and Angles
2	IS: 1730-1961	Plates, Sheets and Strips/Flats
3	BS4-1: 1993	UB/UC sections
4	IS: 12778/equivalence with EN-19-57	For NPB sections
5	IS: 12778/equivalence with EN-53-62	For HE/WPB sections
6	IS: 1786 or grade -1 of IS432 (Part-I)	Rounds including deformed high yield strength bars.

In case any such sectional weights are not available in the above documents, the manufacturer recommendation shall be binding.

2.18.3 The steel issued to the contractor shall be mainly in standard length and sections as received from the supplier. However, the contractor shall be bound to accept the steel in length as available in the project stores, no claims for extra payment because of issue of non-standard length will be entertained.

2.18.4 The contractor shall satisfy himself of the quality and quantity of the materials at the time of taking delivery from BHEL stores. No claims whatsoever will be entertained by BHEL because of quality or quantity after the materials are taken by the contractor from BHEL stores.

2.18.5 The contractor shall submit to BHEL, a statement indicating estimated quantity of **cement and steel** required during a quarter. In addition, the contractor shall also furnish the estimated requirement of steel during a month by the third week of the previous month indicating his requirement.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

2.18.6 Following shall be limit for the maximum quantity of BHEL issue materials that would be with the contractor at any point of time when work is in progress (excluding what has already been incorporated in the works).

SL No.	ISSUE OF MATERIALS	MAX QUANTITY IN CONTRACTORS STORE
01	Reinforcement Steel, MS Rod/GI Flat, GI Grating, Foundation Bolts, MS Rails	ONE MONTH
02	Structural Steel	ONE MONTH
03.	Cement	ONE MONTH

2.18.7 Bidders shall ensure that no lamination material is taken over by them from BHEL.

2.18.8 The contractor must note that cement and steel required for the contractor's enabling job like store/ site office/~~batching plant~~/temporary work etc shall be arranged by the contractor at his own cost.

2.19 RETURN OF MATERIALS

2.19.1 Return of Cement: ~~Sealed cement bags remaining unused and in perfectly good condition at the time of completion or termination of the contract shall be returned promptly, (within 15 days from assessment) if BHEL/ engineer is satisfied of the physical condition of the cement. Return of such cement to the project stores / place as identified within the project area by engineer/ BHEL will not be entitled to handling and incidental charges. Only surplus sealed cement bags will be taken back and any other cement with the contractor will have to be consumed.~~

2.19.2 Return of Reinforcement Steel and Structural Steel including Scrap: All surplus steel and all wastage materials will be taken back on weight basis. Surplus, unused and untampered steel shall be sorted section-wise and returned separately at a place directed by BHEL Engineer within the project area. Return of such materials will not be entitled for any handling and incidental charges. All wastage / scrap

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

(including melting scrap, wastage, and unusable scrap) shall be returned to the stores in consultation with BHEL Engineer and a receipt obtained for material accounting purposes. Return of such material will not be entitled to any transportation and incidental charge. Scrap for reinforcement steel and structural steel shall be returned separately.

2.20 Scrap & Serviceable Materials:

2.20.1 All structural steel of length above 2 M except M.S Plate shall be considered as **serviceable materials** provided the materials are free from any physical damage, good condition and un-welded. Structural steel of length less than 2 M shall be treated as scrap.

2.20.2 Plates having both side greater than 1 Meter OR if any side is less than 1 M but greater than 0.5 M and the total area is equal or greater than 2 sq. Meter shall be considered as **serviceable materials**.

2.20.3 All pipe measuring 2 M and above in length shall be treated as serviceable materials provided they are free from any physical damage, good condition and un-welded. Pipe in less than 2 M length shall be treated as Scrap.

~~**2.20.4** All TMT measuring 3 M and above in length shall be treated as serviceable material provided they are free from physical damage, straight, un-welded and in good condition. TMT steel in less than 3 M shall be treated as scrap.~~

2.21 Cement, Steel Consumption and Wastage

2.21.1 Cement Consumption

~~The theoretical consumption of cement shall be based on the following:~~

~~**2.21.1.1** For design mix concrete, as per approved design mix.~~

~~**2.21.1.2** For nominal mix concrete, as per minimum cement as specified or as approved by engineer in charge.~~

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

~~2.21.1.3~~ — For item of works, where volume mix is permitted in writing by the BHEL, for masonry works, plaster other miscellaneous items, the cement consumption shall be governed by the “Statement of cement consumption” attached to the DSR-2013 unless otherwise specified in the specifications or the drawing of contract or mutually agreed by engineer in-charge and the contractor.

~~2.21.1.4~~ — Actual consumption = Issue – Surplus/ unused quantity of cement returned in good condition by the contractor to store. (No sweep cement will be taken back by BHEL).

~~2.21.2~~ — CEMENT WASTAGE

~~2.21.2.1~~ — Allowable wastage: One and half percent (+1.5%) of theoretical consumption of cement.

~~2.21.2.2~~ — For any material issued by BHEL to the contractor free of cost, and which is not accounted for by the contractor to BHEL, then recovery for such material shall be affected at penal rates.

Sl no	Cement consumption	Basis of issue & penal recovery
C-1	Theoretical consumption (without considering any wastage or loss).	Free
C-2	Actual consumption being Limited to one and half percent (+1.5%) of aforesaid theoretical consumption towards allowable wastage.	Free
C-3	Actual consumption beyond one and half percent (+1.5%) of above (C-1).	Penal rate

~~2.21.3~~ **Reinforcement Steel, Earthing MS Rod/GI Flat, GI Gratings, Foundation Bolts and MS Rails Consumption:**

The theoretical consumption of various sections and/or diameter of reinforcement and earthing rod steel shall be based on approved construction drawing and bar bending schedule. Weight shall be calculated considering the sectional weights as per Indian standards. No extra cost shall be payable to the contractor for any deviation in weights for the different procedures adopted for issue and calculation of the theoretical consumption including rolling tolerances.

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.21.3.1 Actual consumption = Issue – Surplus.

2.21.3.2 Surplus = **untempered, unused, uncut quantity of steel including serviceable materials returned by the contractor to BHEL store.**

2.21.3.3 Wastage = Actual consumption – Theoretical consumption.

2.21.4 ~~Reinforcement Steel, Earthing MS Rod/GI Flat, GI Gratings, Foundation Bolts and MS Rails Wastage:~~

2.21.4.1 Allowable Wastage: (+3%) of the theoretical consumption shall be considered as allowable wastage.

Wastage and scrap shall be as per actual weighment basis.		
Sl no	Reinforcement steel & MS earthing rod	Basis of issue & penal recovery
R-1	Theoretical consumption (without considering wastage and scrap or loss)	Free
R-2	Wastage limited to plus THREE percent (+3%) of aforesaid theoretical consumption (R-1) towards allowable wastage.	Free
R-3	Wastage beyond THREE percent (+3%) of the theoretical consumption above (R-1).	Penal rate

2.21.5 Structural Steel (Rolled Sections and Plates etc) Consumption:

The theoretical consumption of various sections shall be based on approved drawings. Weights shall be calculated considering the sectional weights as per Indian standard. No extra shall payable to the contractor for any deviation in weights for the two different procedures adopted for issue and calculation of the theoretical consumption including rolling tolerances.

2.21.5.1 Actual consumption = Issue – Surplus.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

2.21.5.2 Surplus = **untempered, unused, uncut quantity of steel including serviceable materials returned by the contractor to BHEL store.**

2.21.5.3 Wastage = Actual consumption – Theoretical consumption.

2.21.6 Structural Steel Wastage:

2.21.6.1 Allowable wastage: +4% (FOUR percent) of the theoretical consumption shall be considered. Wastage shall be considered as cut pieces and scrap material, measured as per actual weighment basis. Invisible wastage, if any, shall be considered to be included in the specified 4 % allowable wastage.

Sl no	Structural steel including SS plate	Basis of issue & penal recovery
S-1	Theoretical consumption (without considering any wastage, scrap or loss) as per specification & drg.	Free
S-2	Wastage limited to plus four percent (+4%) of the aforesaid theoretical consumption (S-1) towards allowable wastage.	Free
S-3	Wastage beyond four percent (4%) of the aforesaid theoretical consumption (S-1).	Penal rate

2.22 Reconciliation of Materials:

2.22.1 The contractor shall submit a reconciliation statement of cement and steel issued to the contractor with each RA Bill.

2.22.2 At the time of submission of bills, the contractor shall properly account for the material issued to him as specified herein to the satisfaction of BHEL certifying that the balance material are available in the contractor custody at site.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – II: SCOPE OF WORKS AND TECHNICAL SPECIFICATIONS

2.22.3 At the time of submission of bills, if it is noticed by BHEL that the wastage is high and calls recovery at the penal rate, then, BHEL will proceed for recovery for the excess wastage as per penal recovery rates as specified.

2.22.4 The reference drawings for actual material consumption to be used for the purpose of reconciliation shall be drawings prepared by the BHEL and drawings approved by BHEL for fabrication works and such other drawings approved by BHEL. This shall also include the bar bending schedule prepared by the contractor and approved by BHEL.

2.23 Recovery of Materials (Penal Rates):

If wastage exceeds the specified limit, the recovery of excess wastage shall be made from monthly RA Bills as per following penal rates:

Sr No	Item	Penal rate (Rs)
P-1	Cement (OPC/ PPC/ PSC).	6,500 per MT
P-2	Reinforcement steel, MS rod /GI Flat etc.	55,000 per MT
P-3	Chequered Plates, MS plates	60,000 per MT
P-4	MS Flats, beams, channel, angles etc. (Rolled Sections)	60,000 per MT
P-5	Foundation Bolts/GI Gratings if any	90,000 per MT

2.24 Procurement and Testing of Materials by Contractor:

Material required for the entire job (other than issued by BHEL as explained above) like sand, aggregates, windows, doors, ventilators, rolling shutter, sanitary fixtures, painting & finishing material, electrical fittings and wiring material and all other material required for the completion of entire scope, have to be arranged by the contractor, except those specifically indicated as BHEL scope of supply. BHEL reserves the right to reject any material not found satisfactory. Rate quoted shall be inclusive of all such contingencies and no additional payment shall be made on this account. For this purpose, sample shall be collected at site in presence of **BHEL/TSGENCO** representative.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – II: SCOPE OF WORKS AND TECHNICAL
SPECIFICATIONS

Bidders are requested to specifically note the following:

*Bidders are requested to have **pre-bid visit/ inspection of site** to make them fully acquainted with the site situation & nature of job. No claim shall be entertained at later date on account of non-familiarization of site conditions. Bidders may fix up their site visit in consultation with below mentioned contact person:*

Sh Murali Krishna BHEL Site Office: 4x270 MW TPS, Manuguru, Ph No: +917382106908	Sh RP Das PSWR Nagpur Ph no: +918806007760
Sh Balaji M BHEL Site Office: 4x 270 MW TPS, Manuguru Ph No: +918600000268	Sh Anand Kumar PSWR Nagpur Ph no: +917387356299

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of contractor/BHEL (SCOPE MATRIX)

Sl.No	Description	Scope		Remarks
		BHEL	Bidder	
3.1	Establishment			
3.1.1	For Construction Purpose:			
a	Open space for office (as per availability)	Yes		Location will be finalized after joint survey with owner
b	Open space for storage (as per availability)	Yes		Location will be finalized after joint survey with owner
c	Construction of bidder's office, canteen and storage building including supply of materials and other services		Yes	
d	Bidder's all office equipments, office / store / canteen consumables		Yes	
e	Canteen facilities for the bidder's staff, supervisors and engineers etc		Yes	
f	Fire fighting equipments like buckets, extinguishers etc		Yes	
g	Fencing of storage area, office, canteen etc of the bidder		Yes	
3.1.2	For living purpose of the bidder			
a	Open space for labour colony (as per availability)		Yes	Contractor has to make his own arrangements shelter and transportation of labours as per their requirement.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of contractor/BHEL (SCOPE MATRIX)

Sl.No	Description	Scope		Remarks
		BHEL	Bidder	
	PART I			
b	Labour Colony with internal roads, sanitation, complying with statutory requirements		Yes	Construction Plan shall be approved by BHEL
3.2.0	ELECTRICITY			
3.2.1	Electricity for construction purposes 3 Phase 415/440 V			FREE AT ONE SINGLE POINT.
a	Single point source	Yes		Further distribution and Metering is in scope of bidder.
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.2	Electricity for office, stores, canteen etc of the bidder.			
a	Single point source	Yes		Single point as above for construction purpose, no separate point shall be given
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.3	Electricity for living accommodation of the bidder's staff, engineers, supervisors etc			Contractor Has to make his own arrangements
a	Single point source		Yes	
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of contractor/BHEL (SCOPE MATRIX)

Sl.No	Description	Scope		Remarks
		BHEL	Bidder	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.3.0	WATER SUPPLY			
3.3.1	For construction purposes: (to be specified whether chargeable or free)			Free
a	Making the water available at single point	yes		Contractor has to make his own arrangement.
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.2	Water supply for bidder's office, stores, canteen etc.			
a	Making the water available at single point	Yes		Contractor has to make his own arrangements for distribution. Single point as above for construction purpose, no separate point shall be given
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.3	Water supply for Living Purpose			Contractor has to make his own arrangement.
a	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) / 1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) / 1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of contractor/BHEL (SCOPE MATRIX)

Sl.No	Description PART I	Scope		Remarks
		BHEL	Bidder	
3.4.0	LIGHTING			
a	For construction work (supply of all the necessary materials) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	
b	For construction work (execution of the lighting work/ arrangements) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	
c	Providing the necessary consumables like bulbs, switches, etc during the course of project work		Yes	
d	Lighting for the living purposes of the bidder at the colony / quarters		Yes	
3.5.0	Communication facilities for site operations of the bidder			
a	Téléphone, fax, internet, intranet, e-mail etc		Yes	
3.6.0	Compressed air wherever required for the work		Yes	
3.7.0	Demobilization of all the above facilities		YES	
3.8.0	Transportation			
a	For site personnel of the bidder		Yes	
b	For bidder's equipments and consumables (T&P, Consumables etc)		Yes	

Sl.No	Description PART II	Scope / to be taken care by		Remarks
		BHEL	Bidder	
	3.9.0 Erection Facilities			

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of contractor/BHEL (SCOPE MATRIX)

Sl.No	Description PART II 3.9.0 Erection Facilities	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.9.1	Engineering works for construction:			NOT APPLICABLE
a	Providing the erection/constructions drawings for all the equipments covered under this scope	Yes		For Details Pl refer Chapter-IX-
b	Drawings for construction methods	Yes	Yes	In consultation with BHEL
c	As-built drawings – where ever deviations observed and executed and also based on the decisions taken at site		Yes	Changes are to be marked in drawing & handover to BHEL on completion of work.
d	Shipping lists etc for reference and planning the activities			NOT APPLICABLE
e	Preparation of site erection schedules and other input requirements	Yes	Yes	In consultation with BHEL
f	Review of performance and revision of site erection schedules in order to achieve the end dates and other commitments	Yes	Yes	In consultation with BHEL
g	Weekly erection schedules based on Sl No. e		Yes	In consultation with BHEL
h	Daily erection / work plan based on Sl No. g		Yes	In consultation with BHEL

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – III: Facilities in the scope of contractor/BHEL (SCOPE MATRIX)

Sl.No	Description PART II 3.9.0 Erection Facilities	Scope / to be taken care by		Remarks
		BHEL	Bidder	
i	Periodic visit of the senior official of the bidder to site to review the progress so that works are completed as per schedule. It is suggested this review by the senior official of the bidder should be done once in every two months.		Yes	

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps AND MME TO BE DEPLOYED BY
CONTRACTOR

4.1 TOOL & PLANTS

Nos of T&Ps to be deployed at site shall be decided with respect to monthly plan and review formats (F 14) based on site requirement.

4.1.1 The essence of site fabrication works is expeditious and accurate work. It is highly desirable that in the process minimum wastage is generated and BHEL shall be able to provide its customer factory finish structural members. Fabricated members would be such that clean edges are obtained with minimum distortion of the members. Additionally, speedy execution is also the essence of the scope of structural works. **Hence following tools & plants are considered essential to attain above objectives:**

Sl No	Description of T&P	Quantity
1)	Temporary Closed Shed of Required Size suiting site requirement	01 Nos
2)	Gantry Crane (20-25 MT)	02 Nos
3)	In Tandem Submerged Arc Welding machine	01 Nos
4)	High Frequency Plasma Cutting machine	04 Nos
5)	Strand Jack System (as described below)	01 No

Strand Jack System: Strand Jack System includes supply of strand jacks in sets (minimum lifting capacity 50 MT per jack) connected with diesel/electric power packs, set of hydraulic hose and its accessories, set of strands, Hilman roller (if required), spare parts, specialist tools, supervisor/lifting engineer, Rigging Superintendent, Jack operators, labours, up to the specified height as per drawing. Preparation of drawing/scheme for lifting operation, design & detailing of any additional structural modification/fabrication, erection and welding of those structures like track beam for shifting of bunker shell pieces to the designed location, trolley, lifting lugs ,anchor plates, anchor/jack support beams, design checks for safe operation of jacks with respect to the existing/erected structural members and obtaining approval from BHEL-PEM all complete as per specification, drawings and instructions of the Engineer.- In-Charge.(BHEL crane shall be provided for feeding of bunker shell pieces at feeder floor elevation)

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps AND MME TO BE DEPLOYED BY
CONTRACTOR

4.1.2 Further, below given nos are tentative for planning purposes by the bidder.

S1 No	Description of T&P	Quantity
1)	100-120 MT crawler mounted crane	01 No
2)	75 MT crawler mounted Crane	01 No
3)	40/45 MT Tyre mounted crane	01 Nos
4)	18 MT tyre mounted Crane	02 Nos
5)	14 MT tyre mounted crane/Hydra	05 Nos
6)	Radial Drill Machine	03 Nos
7)	Pillar Drill Machine	03 Nos
8)	Portable Drill Machine	05 Nos
9)	Plate Rolling Machine (of required capacity)	01 Nos
10)	Angle/Channel/Beam Bending machine	01 Nos
11)	Submerged arc welding machine	02 Nos
12)	Electrical Winch (of required capacity)	05 Nos
13)	Welding machine	60 Nos.
14)	Welding rectifier	30 Nos
15)	Grinding machine	40 Nos
16)	Pug Cutting machine with circular attachment	10 Nos
17)	Power Driven HSFG bolt tightening machine	02 Nos
18)	Air Compressor/ Air Blowers	As per requirement
19)	Hand Cutting machine	25 Nos
20)	Hydraulic Jacks (of 10 MT to 50 MT)	As per requirement
21)	Self-priming Dewatering pump of various capacity (Diesel/Electric) From 5 HP to 7.5 HP	03 Nos
22)	Stationary/Mother Oven	05 Nos
23)	Portable Oven	80 Nos
24)	Chain Pulley of various capacities	20 Nos
25)	UT Testing m/c	01 No
26)	Trailer (20 MT Cap)	01 No
27)	Radiography Source	01 No
28)	Laser Tools for alignment/verticality (HILTI or equivalent)	06 Nos
29)	Safety belts with fall arrestor	As per Requirement
30)	Safety Nets/Safety Planks	As per

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps AND MME TO BE DEPLOYED BY
CONTRACTOR

		Requirement
31)	All equipment for area lighting like Halogen bulbs and Portable Light Towers etc for General Area Illumination	As per requirement
32)	COMPUTER with printing/photocopying & CD writing facility	15 sets

4.1.2 All tools & plants to be used by the contractor shall have prior approval of BHEL engineer regarding brand, type and specifications. Such tools & plants shall be regularly tested and fitness certificates shall be obtained and submitted to BHEL on regular basis.

4.3 COMPUTER INFRASTRUCTURE

The successful bidder(s) will have to establish computerized project management system along with one no supervisor with sufficient computer knowledge (knowledge of MS office) and the following are the minimum requirements of the system:

4.3.1 The bidder will have to install 2 nos PCs (multimedia PC work station Pentium-Duo, 1 GHZ or above, 320 GB HDD, 2 GB RAM, 100 MBPS LAN card of HCL/ COMPAQ/ ZENITH or equivalent make with window 8 O/S with required accessories like mouse, keyboard, UPS and required software like MS Office 2010 Professional, AutoCAD 2011, ADOBE PDF CREATOR (ver 8.0) with one no laser jet printer compatible for A4 and A3 size printing (ink/ cartridge for which to be supplied as and when required, (the consumption may be assumed as 1 cartridge per month) with power backup at places, as per instruction of BHEL for exclusive use of BHEL.

4.3.2 These computers/ printers along with technical supervisor (two nos) shall remain contractor's property/ownership for all legal/technical purposes; however, contractor shall be allowed to take out/release the same after completion of the site works. **Further, the computer/printer along with two nos technical supervisor shall remain/work at BHEL offices.**

4.3.2 The contractor's technical supervisor shall provide data / information etc in prescribed formats for periodical updating of the progress reports, Billing, daily progress report, updating of schedule pertaining to the contractor's scope of work etc.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – IV: T&Ps AND MME TO BE DEPLOYED BY
CONTRACTOR

4.3.3 This facility has to be provided from 1st month from LOI date till completion of site works or as decided by BHEL. If contractor fails to provide computer/ printer as per requirement, for a continuous period of fifteen days or more, BHEL shall have the right to purchase it at risk and cost of bidder.

4.3.4 In the event of the contract period getting extended beyond the stipulated time for reasons not attributable to the bidder, the bidder will be reimbursed at Rs 8000.00 per month for two computers with printer facility, if the services of computer and printer are being used by BHEL.

4.2 MEASURING AND MONITORING DEVICES (MMD):

Requirement to be jointly decided at site.

NOTE:

The above list is only indicative and neither exhaustive nor limiting. Quantities indicated above are only the minimum required. Contractor shall deploy all necessary T&P to meet the schedules & as prescribed by BHEL engineer and required for completion of work. In the event of non-mobilization of any T&P by the successful bidder and as a result if progress of work gets suffered, BHEL reserves the right to deduct suitable amount from the dues of the bidder, with assigning reasons thereof.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter – V: T&Ps AND MMEs TO BE DEPLOYED BY BHEL ON
SHARING BASIS

5.1 BHEL Will Provide Following Tools & Plants for This Work:

5.1.1 Heavy Lift/High Reach Crane of suitable capacity on sharing basis: Heavy lift crane of required capacity shall be provided for speedy execution of structural works on sharing basis. Diesel shall be provided by the contractor as per site use and regular/Day-to-Day maintenance shall be done by the contractor including supply of ordinary consumables such as grease oil/cleaning cloth etc. Log Sheets shall be duly signed after each use of the crane. The Contractor shall provide assistance in lengthening/shortening of booms by way of cranes/hydra and/or manpower.

5.1.2 Crane returned in defective/damaged condition (defect / damage occurred during use due to negligence of contractor) shall be rectified promptly to the full satisfaction of BHEL engineer failing which suitable recovery along with BHEL overheads will be made from contractor's bills/ dues.

5.1.3 BHEL shall provide crane operator for this crane free of cost. However, the contractor shall bear only overtime charges, if any, for the operator provided by BHEL for services provided beyond normal working hours. Such OT deployment shall be with prior intimation and consent of BHEL and shall not be committal.

5.1.4 In case of exigency leading to crane operator not being available with BHEL, No claim shall be entertained whatsoever against any type of damages. However, the time and progress lost due to such accounts shall be recorded in Monthly Plan and Review Documents (F 14).

5.1.5 In case of non-availability of high capacity Crane (as above) to be provided by BHEL due to break down, major overhauls distribution pattern or any other reason, the contractor shall plan /augment / alter his activities to meet erection /commissioning targets in consultation with BHEL and no compensation will be admissible on the above ground.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: TIME SCHEDULE

6.1 Time Schedule & Mobilization

6.1.1 Initial Mobilization and Time Schedule

After issuance of LOI (through email/fax/courier), Contractor shall report to the construction Manager/Site In charge of BHEL at site within one week and make MOM (Minutes of Meeting) for mobilization of manpower, T&P, Date of start of work and detailed completion program.

The contractor has to subsequently augment his resources in such a manner that the entire works are completed within the contract period of **18 (Eighteen) months** in a manner required by BHEL to match with the project schedule.

Date of start (DOS) of works shall be reckoned **as 01 Month after date of Issue of LOI (Letter of Intent)**. During this period (i.e. after issue of LOI up to 01 month) the contractor shall complete mobilization for start of work.

6.1.2 Contract Period and Schedule of Completion

The entire work under the scope of this contract shall be carried out in such a manner that the following listed major milestones are achieved as per completion schedule given against each activity & **released for further erection (RCC works/Equipment Erection) work by other agency for both Unit #01 and Unit#02.**

Tentative Milestones for Major Structural Works

Sl No	Activity	Date of Release of fronts from DOS	Remarks (if any)
1.	TG Building (AB Bay) incl Roof Truss	6 Months	All structural works of AB Bay excluding Crane Girder Erection.
2.	TG Building (BC Bay)	10 Months	
3.	Bunker Bay Columns, main girders secondary beams incl Feeder Floor etc	7 Months	
4.	Bunker Bay incl Tripper Floor and Roof Floor	17 Months	

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VI: TIME SCHEDULE

5.	Coal Silo and hopper complete	First Coal Silo incl hopper shall be handed over 11 Months	Progressive Completion within 16 Months
6.	Pipe/Cable Racks of Fuel Oil Area	7.5 Months	
7.	Pipe/Cable Racks	12.5 Months	

Notes:

- Miscellaneous works such as runners, purlins, misc platforms, access ways, platforms, stairs and Cage ladders etc shall be fabricated and erected so as to match overall project schedule and RCC works/commissioning requirements.
- **Above milestone period are for Package E (Unit#01 and Unit#02) and Package F (Unit#03 and Unit#04) both.**
- Agency should note that the construction works for all the major systems described in the scope of works shall have to go in parallel to match with the commissioning schedule/completion of the plant. For this it will necessary to deploy “Dedicated Resources” like Manpower, Machineries and Materials Area wise to execute the woks simultaneously. Further, as parallel works for major areas has been envisaged; individual area wise Construction In-charges would be deputed suitably and a project manager shall oversee complete scope of works.
- Bidders are requested to submit Resource deployment plan Area wise with detail program in line with above schedule in the form of Bar Chart /MS project planer along with their offer.
- Contractor shall note that individual milestones as above shall be achieved as per schedule furnished above.

6.2 The underlying philosophy of executing the total scope of works shall be on fast track basis which requires **round the clock work involving extensive use of man and machinery**. As such any T&P that may not have been specifically mentioned in the contract but required and would help in minimising time shall be used as per project requirement.

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter – VII: TERMS OF PAYMENT

7.0 Terms of Payment

7.1 Progressive payment/final payment: The payments for works under the scope of this contract shall be as per clause no 2.6; clause 2.22; clause 2.23 of General Conditions of Contract and Chapter X of Special Conditions of Contract. Few points of consideration are as below:

- The payments shall be made through E-Mode only.
- The measurements sheets of work done in a month shall be submitted in triplicate duly agreed/signed by BHEL Engineer. The contractor shall extend all necessary assistance for verification of measurements of works without any extra cost.
- The RA bill payments are interim payments and shall be submitted in prescribed formats.
- Recoveries on account of electricity, water, statutory deductions etc shall be made as per terms of contract.
- 100% of item rate on pro rata basis shall be made as per progress of work. BHEL decision in this regard shall be final and binding on the contractor.
- Final bill shall be submitted after completion of works and upon material reconciliation along with all prescribed formats.

7.2 Extra/supplementary items of work:-

The works shall be regulated as per clause no 2.15 and clause no 2.16 of General Conditions of Contract.

TECHNICAL CONDITIONS OF CONTRACT (TCC)
Chapter-VIII: Taxes and Other Duties

8.0 TAXES, DUTIES, LEVIES (Consolidated Rev 04 dated 14/05/2015)

8.1. For All types of works excepting works covered under sl no 8.2

8.1.1

The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit.

However, provisions regarding Service Tax and Value Added Tax (VAT) on output services and goods shall be as per following clauses.

8.1.2 Service Tax & Cess on Service Tax

Contractor's price/rates shall be exclusive of Service Tax and Cess on Services. In case, it becomes mandatory for the contractor under provisions of relevant act/law to collect the Service Tax & Cess from BHEL and pay the same to the concerned tax authorities, such applicable amount will be paid by BHEL at the prevailing Service Tax Rate (presently 12.36 %) on the admitted bill value.

Contractor shall submit to BHEL documentary evidence of Service Tax registration certificate specifying name of services covered under this contract. Contractor shall submit serially numbered Service Tax and Cess Invoice, signed by him or a person authorized by him in respect of taxable service provided, and shall contain the following, namely,

- 1. The name, address and the registration number of the contractor,**
- 2. The name and address of the party receiving taxable service,**
- 3. Description, classification and value of taxable service provided and,**
- 4. The service tax payable thereon.**

All the Four conditions shall be fulfilled in the invoice before release of service tax payment.

Wherever, more than one route/option are available for discharge of service tax liability under a particular service, (e.g. "works contract Service"), contractor shall obtain prior written consent from BHEL site before billing the amount towards Service Tax.

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VIII: Taxes and Other Duties

8.1.3 VAT (Sales Tax /WCT)

As regards Value Added Tax (VAT)/CST on transfer of property in goods involved in Works Contract (previously known as Works Contract Tax) applicable as per local laws, the price quoted by the contractor shall be inclusive of the same and in no case input or output VAT/CST will be reimbursed extra.

In any case the Contractor shall register himself with the respective Sales Tax authorities of the state and submit proof of such registration to BHEL along with the first RA bill. Contractor will submit all the details of VAT/CST paid for the contract in the prescribed format of the respective state VAT laws. Also, the contractor will issue the tax Invoices to BHEL as per the Tax laws of respective state on monthly basis. Contractor shall also be required to furnish to BHEL necessary proof of VAT remittance on monthly basis.

Deduction of tax at source shall be made as per the provisions of law and is to be construed as an advance tax paid by the contractor and no reimbursement thereof will be made.

Further, if BHEL, at the instance of customer or otherwise adopts the specific route for discharging output VAT liability itself, benefit of the reduction in liability of the contractor will be passed on to BHEL.

In case, BHEL is forced to pay any VAT liability on behalf of contractor, the same will be recovered from contractor's bill or otherwise as deemed fit

8.2 — 'Enabling Works'

~~The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit. (i.e. rates quoted by bidder shall be inclusive of Service Tax, VAT/WCT and all other taxes and duties)~~

~~However, Since the proposed work is in the nature of 'Works Contract service' as per Service tax law, Hence, For non corporate contractors being Individual, HUF, Proprietary Firm, Partnership Firm or Association of Persons (AOP), BHEL shall recover the applicable Service Tax under~~

BHEL-PSWR (VOL-I-A- TECH Bid)

Tender Specification No: BHE/PW/PUR/MANUT-STR Pkg-E (U-1&2) /1460
BHE/PW/PUR/MANUT-STR Pkg-F (U-3&4) /1461

TECHNICAL CONDITIONS OF CONTRACT (TCC)

Chapter-VIII: Taxes and Other Duties

~~reverse charge mechanism from the contractor and remit the same with the Government as per the provisions of Law. Necessary advice/confirmation of remittance shall be issued to the contractor. The contractor shall not be eligible for any refund/reimbursement of such service tax from BHEL. It shall be the responsibility of the contractor to submit proper invoice giving all the requisite details as per Service Tax Law for the determination of the service tax liability of BHEL under reverse charge mechanism. BHEL reserves the right to determine such liability based on the invoice submitted by the contractor or otherwise independently and remittance of the same with the Government.~~

8.3 New Taxes/Levies

In case the Government imposes any new levy/tax on the output service/goods/work after award of the contract, the same shall be reimbursed by BHEL at actual.

In case any new tax/levy/duty etc. becomes applicable after the date of Bidder's offer, the Bidder/Contractor must convey its impact on his price duly substantiated by documentary evidence in support of the same **before opening of Price Bid**. Claim for any such impact after opening the Price Bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

No reimbursement/recovery on account of increase/reduction in the rate of taxes, levies, duties etc. on input goods/services/work shall be made. Such impact shall be taken care of by the Price Variation/Adjustment Clause (PVC) if any. In case PVC is not applicable for the contract, Bidder has to make his own assessment of the impact of future variation if any, in rates of taxes/duties/ levies etc. in his price bid.

8.4 BOCW Cess

The quoted rates shall be exclusive of the BOCW Cess which shall be paid extra by BHEL against Documentary evidence. However, the applicability of the BOCW Cess shall be got confirmed from BHEL in writing, before remitting such Cess/tax.

8.5 GST: As and when GST becomes applicable to this contract, the net differential (negative or positive) financial liability of the bidder to the Authorities (as compared to such liability prior to applicability of GST), if any, shall be to the account of BHEL. For this purpose, all available options under the GST shall be explored, and the decision of BHEL in this regard shall be final and binding on the bidder.

SPECIAL CONDITIONS OF CONTRACT (SCC)
CHAPTER IX –DRAWINGS

9.1 Following technical specifications and drawings shall form part of this tender:

SL NO	Documents
1.	Section C/Section D: Technical Specifications
2.	Plot Plan

SPECIAL CONDITIONS OF CONTRACT (SCC)

CHAPTER X –APPENDIX

10.1 Tentative Manpower Requirement

1. Project manager – with adequate experience of minimum 15 Years in Industrial Foundation, Building & Structural Works, Power Plant Civil & architectural Works.
2. Construction In-Charge: 02 Heads
3. Experienced Civil/Structural Engineers –6 heads
4. Experienced Foreman / Supervisors – 12 heads
5. Planning & Billing Engineer – 02 heads
6. Stores, Gate Pass – 02 heads
7. Accounts & Administration- 02 head
8. Quality Control Engineer – 1 head
9. Safety Engineer – 2 heads
10. Operator, Licensed Electrician, Mechanic - As per requirement
11. Experienced riggers & helpers – lot for similar nature of work with suitable experience
12. Experienced foreman & fitters – lot for similar nature of work with suitable experience.
13. Experienced Welders for fabrication/erection work – lot for similar nature of work with suitable experience.
14. Experienced gas cutters & grinders – lot for similar nature of work with suitable experience.
15. Security Guards (Round The Clock) – As per requirement

10.2 Deputation of above man-power shall be jointly decided at site in line with construction schedule.

10.3 Engineer/ supervisor for other functions like store & purchase, material management, planning, finance, administration & liaison etc are to be provided as per site requirement and not considered above.

SPECIAL CONDITIONS OF CONTRACT (SCC)

CHAPTER X –APPENDIX

- 10.4** In the event of non-deputation of engineer/ supervisor by the bidder as per above agreed schedule, BHEL shall reserve the right to deduct Rs 50,000.00 per man-month for engineer, Rs 35,000.00 per man-month for the supervisor/ safety officer/chemist and Rs. 30,000 per man-month for safety supervisor from RA bills. Further induction of manpower regarding site supervisor & site engineer will be decided at site as per requirement without any financial implication
- 10.5** BHEL reserves the right to reject or approve the list of personnel proposed by the contractor. The persons whose bio-data have been approved by BHEL will have to be posted at site and deviation in this regard will not be permitted unless specific & reasonable justification is made.
- 10.6** In addition to above, a well experienced qualified engineer to be designated, as 'Project Co-coordinator', shall be deployed by the contractor. Such engineer shall have adequate exposure on the job and shall remain fully involved in all planning activities, guidance etc to contractor's own team during the complete execution period of contract.
- 10.7** The contractor should also submit the fitness/calibration certificate for T&Ps regularly and renew as per applicable IS standards and statutory requirements. The tools & tackles shall not be removed from site without written permission of BHEL.