

TENDER SPECIFICATION

NO: BHE/PW/PUR/DHJOI-BAL CVL PKG2/1401

FOR

**Fire proofing work for Pipe & cable racks, Utility Boilers, HRSG's and other plant
misc. building & structures complete**

AT

2X30MW STG + 4GTG WITH HRSG + 2 UB AT OPAL, DAHEJ- BHARUCH, GUJARAT

VOLUME-II – PRICE BID-1401



BHARAT HEAVY ELECTRICALS LIMITED

(A GOVERNMENT OF INDIA UNDERTAKING)

POWER SECTOR - WESTERN REGION

SHREEMOHINI COMPLEX

345, KINGSWAY - NAGPUR 440 001

BHARAT HEAVY ELECTRICALS LIMITED

(A GOVERNMENT OF INDIA UNDERTAKING)
POWER SECTOR - WESTERN REGION
SHREEMOHINI COMPLEX
345, KINGSWAY - NAGPUR 440 001

TENDER SPECIFICATION

NO: BHE/PW/PUR/DHJOI-BAL CVL PKG2/1401

FOR

**Fire proofing work for Pipe & cable racks, Utility Boilers, HRSG's and other plant misc.
building & structures complete**

AT

**2X30MW STG + 4GTG WITH HRSG + 2 UB AT OPAL,
DAHEJ- BHARUCH, GUJARAT**

EARNEST MONEY DEPOSIT: Please see Notice Inviting Tender.

LAST DATE FOR: Please see Notice Inviting Tender.

TENDER SUBMISSION:

THESE TENDER SPECIFICATION DOCUMENTS CONTAINING **VOLUME-I-Tech Bid**, **VOLUME- II-Price Bid** AND
VOLIME-IBCD Rev-01 ARE ISSUED TO:

M/s.

PLEASE NOTE:

THESE TENDER SPECS DOCUMENTS ARE NOT TRANSFERABLE.

For Bharat Heavy Electricals Limited

AGM (Purchase)

Place: Nagpur

Date:

BHEL-PSWR
T.S NO. BHE/PW/PUR/DHJOI-BAL CVL2/1401
PRICE BID

Job Description:- Fire proofing work for Pipe & cable racks, Utility Boilers, HRSG's and other plant misc. building & structures complete at 2x30MW STG + 4GTG with HRSG + 2 UB at Opal, Dahej-Bharuch, Gujarat.

S.No	DESCRIPTION OF ITEMS	UNIT	QUANTITY	ONE UNIT RATE (IN FIGURE & WORDS)	TOTAL AMOUNT(In Rs) (QTY. X UNIT RATE)
1	Supply and Application of Fire proofing on steel structures at all heights up to 25 mtr with VERMICULITE cementious coating including supply of all Fire proofing compound like Branded product with base as VERMICULITE and mixed with ordinary Portland cement, shall have maximum loose dry density of 400 kg/m ³ :while in moulded condition ,density shall not exceed 800 kg/m ³ .Sulphate content in the branded product shall not exceed 1% when the sulphate content is expressed as sulphur trioxide materials, and fixtures/accesories like reinforcement mesh (3mm thick wire, 50x50 size mesh) , nuts, tie wires, welding, surface preparation, curing, staging, compatible paintings etc. all complete as per customer specification : clause no. 9.3 of Doc. No. 6987-00-16-48-DB01 of Section-C 3.6 & EIL Technical Specification no 6-68-033 Rev 05	CUM	273		
	Grand Total in Rupees (In figure & words)				